

**Don E. Grissette**  
Vice President

**Southern Nuclear  
Operating Company, Inc.**  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
  
Tel 205.992.6474  
Fax 205.992.0341



October 20, 2005

Docket No.: 50-425

NL-05-1791

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant  
Technical Specification Report 2-2005-1  
Number of Steam Generator Tubes Plugged During 2R11

Ladies and Gentlemen:

In accordance with the requirements of Vogtle Electric Generating Plant Technical Specification 5.6.10, Southern Nuclear Operating Company submits this report of the number of steam generator (SG) tubes plugged during the Unit 2 eleventh maintenance/refueling outage (2R11).

As a result of the SG tube inservice inspections completed on October 2, 2005, no tubes were plugged.

This letter contains no NRC commitments. If you have any questions, please advise .

Sincerely,

A handwritten signature in black ink, appearing to read "Don E. Grissette", is written over a horizontal line.

Don E. Grissette

DEG/drg

cc: Southern Nuclear Operating Company  
Mr. J. T. Gasser, Executive Vice President  
Mr. T. E. Tynan, General Manager – Plant Vogtle  
RType: CVC7000

U. S. Nuclear Regulatory Commission  
Dr. W. D. Travers, Regional Administrator  
Mr. C. Gratton, NRR Project Manager – Vogtle  
Mr. G. J. McCoy, Senior Resident Inspector – Vogtle