

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources—Operating

LCO 3.8.4 The Division I, Division II, and Division III DC electrical power subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required battery charger on Division I or II inoperable.	A.1 Restore battery terminal voltage to greater than or equal to the minimum established float voltage.	2 hours
	<u>AND</u>	
	A.2 Verify battery float current ≤ 2 amps.	Once per 12 hours
	<u>AND</u>	
	A.3 Restore battery charger to OPERABLE status.	7 days
B. Division I or II DC electrical power subsystem inoperable for reasons other than Condition A.	B.1 Restore Division I and II DC electrical power subsystems to OPERABLE status.	2 hours
C. Division III DC electrical power subsystem inoperable.	C.1 Declare High Pressure Core Spray System and Standby Service Water System pump 2C inoperable.	Immediately
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3.	12 hours
	<u>AND</u>	
	D.2 Be in MODE 4.	36 hours