

Robert A. Saccone
Vice President - Nuclear Operations

PPL Susquehanna, LLC
769 Salem /Boulevard
Berwick, PA 18603
Tel. 570.542.3959 Fax 570.542.1504
RASaccone@pplweb.com




October 14, 2005

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop O-P1-17
Washington, D.C. 20555-0001

SUSQUEHANNA STEAM ELECTRIC STATION
MONTHLY OPERATING REPORTS
Docket Nos. 50-387/NPF-14 and 50-388/NPF-22
PLA-005975

The September 2005 Monthly Operating Reports for Susquehanna SES Units 1 and 2 are attached.

Very truly yours,




Robert A. Saccone

JJH/cmm

cc: NRC Region 1
NRC Sr. Resident Inspector, Mr. Brice Bickett
NRC Project Manager, Mr. R V. Guzman

IE24

OPERATING DATA REPORT



DOCKET NO.	50-387
UNIT	One
DATE	10/12/2005
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747

OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U1)
2. Reporting Period: September 2005
3. Design Electrical Rating (Net MWe): 1177
4. Maximum Dependable Capacity (Net MWe): 1135

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>720</u>	<u>6551.0</u>	<u>195,624.0</u>
6. Number of Hours Reactor Was Critical	<u>720</u>	<u>6551.0</u>	<u>164,539.0</u>
7. Hours Generator On-Line	<u>720</u>	<u>6551.0</u>	<u>162,151.0</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>811,755</u>	<u>7,415,344</u>	<u>168,055,786</u>

NOTES:

SUSQUEHANNA STEAM ELECTRIC STATION


Docket Number: 50-387
Completed by: J. J. Hennings

Date: 10/12/05
Telephone: (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.

OPERATING DATA REPORT



DOCKET NO.	50-388
UNIT	Two
DATE	10/12/05
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747


OPERATING STATUS

5. Unit Name: Susquehanna Steam Electric Station (U2)
6. Reporting Period: September 2005
7. Design Electrical Rating (Net MWe): 1182
8. Maximum Dependable Capacity (Net MWe): 1140

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>720</u>	<u>6,551</u>	<u>180,864</u>
6. Number of Hours Reactor Was Critical	<u>720</u>	<u>5,782.9</u>	<u>158,462.7</u>
7. Hours Generator On-Line	<u>720</u>	<u>5,691.8</u>	<u>156,384.5</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>808,866</u>	<u>6,326,902</u>	<u>165,142,042</u>

NOTES:

UNIT SHUTDOWNS



DOCKET NO.	50-388
UNIT	Two
DATE	10/12/05
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747

REPORT MONTH September 2005

No.	Date	Type ₁	Duration (Hours)	Reason ₂	Method of Shutting Down Reactor ₃	Cause & Corrective Action to Prevent Recurrence
						No reactor shutdowns this month.

Summary: The only power change greater than 20% this month was on 9/9/05. Power was reduced to 75% for a control rod sequence exchange and condenser waterbox cleaning. 100% power was achieved 9/11/05.

1.

F. Forced
S. Scheduled

2.

Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & Licensee Exam
- F - Administrative
- G - Operational Error (Explain)

3.

Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continuation from previous month
- 5 - Other

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-388
Completed by: J. J. Hennings

Date: 10/12/05
Telephone: (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.