

October 28, 2005

Mr. James A. Spina
Vice President Nine Mile Point
Nine Mile Point Nuclear Station, LLC
P.O. Box 63
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 2 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. MC6561)

Dear Mr. Spina:

By letter dated April 1, 2005, you applied for an amendment to the Nine Mile Point Nuclear Station, Unit No. 2, Facility Operating License No. NPF-69. The proposed amendment would have modified the facility Technical Specifications (TSs) pertaining to Required Action A.1 of TS 3.8.7, "Inverters - Operating," to extend the Completion Time for one emergency uninterruptible power supply inverter inoperable from 24 hours to 7 days. The associated Bases would also be changed to reflect the proposed TS change. Subsequently, by letter dated September 30, 2005, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: Notice of Withdrawal

cc w/encl: See next page

October 28, 2005

Mr. James A. Spina
Vice President Nine Mile Point
Nine Mile Point Nuclear Station, LLC
P.O. Box 63
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 2 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. MC6561)

Dear Mr. Spina:

By letter dated April 1, 2005, you applied for an amendment to the Nine Mile Point Nuclear Station, Unit No. 2, Facility Operating License No. NPF-69. The proposed amendment would have modified the facility Technical Specifications (TSs) pertaining to Required Action A.1 of TS 3.8.7, "Inverters - Operating," to extend the Completion Time for one emergency uninterruptible power supply inverter inoperable from 24 hours to 7 days. The associated Bases would also be changed to reflect the proposed TS change. Subsequently, by letter dated September 30, 2005, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

Non-Public	PDI-1 R/F	RLaufer	TColburn
SLittle	OGC	DLPM DPR	

DOCUMENT NAME: G:\DLPM\PD1-1\NMP2\WDLMC6561.wpd

ACCESSION NUMBER: ML052990133

OFFICE	PDI-1/PM	PDI-1\LA	PDI-1\SC
NAME	TColburn	SLittle	RLaufer
DATE	10/27/05	10/27/05	10/28/05

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION

NINE MILE POINT NUCLEAR STATION, LLC (NMPNS)

LONG ISLAND LIGHTING COMPANY

DOCKET NO. 50-410

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of NMPNS (the licensee) to withdraw its April 1, 2005, application for proposed amendment to Facility Operating License No. NPF-69 for the Nine Mile Point Nuclear Station, Unit No. 2, located in Oswego County, New York.

The proposed amendment would have revised the Technical Specifications (TSs) pertaining to Required Action A.1 of TS 3.8.7, "Inverters - Operating," to extend the Completion Time for one emergency uninterruptible power supply (UPS) inverter inoperable from 24 hours to 7 days. The associated Bases would also be changed to reflect the proposed TS change.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 10, 2005 (70 FR 24653). However, by letter dated September 30, 2005, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated April 1, 2005, and the licensee's letter dated September 30, 2005, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site,

<http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 28th day of October 2005.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Nine Mile Point Nuclear Station, Unit No. 2

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
Nine Mile Point Nuclear Station
P.O. Box 126
Lycoming, NY 13093

Mr. James R. Evans
LIPA
P.O. Box 129
Lycoming, NY 10393

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. Paul D. Eddy
Electric Division
NYS Department of Public Service
Agency Building 3
Empire State Plaza
Albany, NY 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

C. Adrienne Rhodes
Chairman and Executive Director
State Consumer Protection Board
5 Empire State Plaza, Suite 2101
Albany, NY 12223-1556

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Mr. Michael J. Wallace
President
Nine Mile Point Nuclear Station, LLC
c/o Constellation Energy Group
750 East Pratt Street
Baltimore, MD 21202

Mr. Carey W. Fleming, Esquire
Senior Counsel
Constellation Generation Group, LLC
750 East Pratt Street, 17th Floor
Baltimore, MD 21202

Mr. Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Ms. Deb Katz, Executive Director
Nuclear Security Coalition
c/o Citizens Awareness Network
P.O. Box 83
Shelburne Falls, MA 01370