



RECEIVED UNITED STATES
NUCLEAR REGULATORY COMMISSION

JAN 7 1983

Nuclear Licensing

REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JAN 08 1983

NUCLEAR LICENSING
OFFICIAL FILE COPY

RECEIVED

JAN 07 1983

Vice President
Advanced Systems & Technology

Florida Power and Light Company
ATTN: Dr. R. E. Uhrig, Vice President
Advanced Systems and Technology
P. O. Box 14000
Juno Beach, FL 33408

Gentlemen:

SUBJECT: REPORT NO. 50-335/82-33

Thank you for your letter of December 9, 1982, informing us of steps you have taken to correct the violations and deviation concerning activities under NRC License No. DPR-67 brought to your attention in our letter of November 9, 1982. We will examine your corrective actions and plans during subsequent inspections.

With regard to violation "A", it is our understanding based on a telephone conversation between Mr. J. R. Wray of this office and Mr. H. Buchanan of your staff on December 27, 1982, that all potential drain pathways in the Radiation Control Area which are not routed to the liquid radwaste system have been blocked. This includes toilets, urinals, and other drains in the Steam Generator Blowdown Treatment Facility which has recently been incorporated into the Radiation Control Area.

We appreciate your cooperation with us.

Sincerely,

R. C. Lewis
R. C. Lewis, Director
Division of Project and
Resident Programs

cc: C. M. Wethy, Plant Manager
N. Weems, Assistant QA
Construction Manager

A-6

1
JAN 08 1983

Florida Power and Light Company
ATTN: Dr. R. E. Uhrig, Vice President
Advanced Systems and Technology
P. O. Box 14000
Juno Beach, FL 33408

Gentlemen:

SUBJECT: REPORT NO. 50-335/82-33

Thank you for your letter of December 9, 1982, informing us of steps you have taken to correct the violations and deviation concerning activities under NRC license No. DPR-67 brought to your attention in our letter of November 9, 1982. We will examine your corrective actions and plans during subsequent inspections.

With regard to violation "A", it is our understanding based on a telephone conversation between Mr. J. P. Vray of this office and Mr. H. Buchanan of your plant on December 27, 1982, that all potential drain pathways in the Radiation Control Area which are not routed to the liquid radwaste system have been blocked. This includes toilets, urinals, and other drains in the Steam Generator Blowdown Treatment Facility which has recently been incorporated into the Radiation Control Area.

We appreciate your cooperation with us.

Sincerely,

R. C. Lewis, Director
Division of Project and
Resident Programs

cc: C. M. Muthy, Plant Manager
N. Weems, Assistant CA
Construction Manager

cc: Mr. Resident Inspector
Nuclear Management Branch
State of Florida

RCT

J. P. Vray:nd

12/30/82

RCT

K. Barr

12/30/82

RCT

A. H. B. S. H.

12/30/82

RCT

K. J. J.

12/1/82

RCT

G. J. J.

12/3/82

RCT

R. C. Lewis

12/30/82

8301250450

0