

November 7, 2005

Mr. Michael G. Gaffney
Site Vice President
Kewaunee Power Station
Dominion Energy Kewaunee, Inc.
N490 Highway 42
Kewaunee, WI 54216-9511

SUBJECT: KEWAUNEE POWER STATION - RESPONSE FOR BULLETIN 2004-01,
"INSPECTION OF ALLOY 82/182/600 MATERIALS USED IN THE
FABRICATION OF PRESSURIZER PENETRATIONS AND STEAM SPACE
PIPING CONNECTIONS AT PRESSURIZED-WATER REACTORS,"
(TAC NO. MC3486)

Dear Mr. Gaffney:

On May 28, 2004, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2004-01, "Inspection of Alloy 82/182/600 Materials Used in the Fabrication of Pressurizer Penetrations and Steam Space Piping Connections at Pressurized-Water Reactors," to the industry. This Bulletin informed addressees that current methods of inspecting the pressurizer penetrations and steam space piping connections fabricated from Alloy 82/182/600 materials may need to be supplemented with additional measures (e.g., bare-metal visual inspections) to detect pressurizer penetration and steam space piping connection flaws or leakage. The Bulletin requested that these addressees provide the NRC with information related to the materials of construction, the inspections that have been performed, and the inspections which will be performed to verify the integrity of the pressurizer penetrations and steam space piping connections. By letter dated July 26, 2004, you provided your response to Bulletin 2004-01, for the Kewaunee Power Station (Kewaunee).

By this letter, you provided your responses to items 1a, 1b, 1c, and 1d of the Bulletin. These responses described the materials used in the fabrication of pressurizer penetrations and steam space piping connections at Kewaunee. When describing the materials used in the fabrication of the pressurizer penetrations and steam space piping connections, you reported that none of the materials used in the fabrication of the pressurizer penetrations and steam space piping were Alloy 82/182/600 materials. Therefore, there is no specific inspection program for Alloy 82/182/600 materials for the pressurizer other than meeting the requirements of Section XI of the American Society for Mechanical Engineers, *Boiler and Pressure Vessel Code*.

Given your response to items 1a, 1b, 1c, and 1d of the Bulletin, the NRC staff no longer requires a specific response for Kewaunee for item 2 of the Bulletin, which requested that licensees report the results of their next scheduled inspection of Alloy 82/182/600 pressurizer penetrations and steam space piping connections.

M. Gaffney

-2-

The NRC staff has completed its activities associated with the review of your response to Bulletin 2004-01 and finds your response acceptable. Please contact me at (301) 415-1345 if you have any questions on this issue.

Sincerely,

/RA/

John F. Stang, Project Manager
Plant Licensing Branch E
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-305

cc: See next page

M. Gaffney

-2-

The NRC staff has completed its activities associated with the review of your response to Bulletin 2004-01 and finds your response acceptable. Please contact me at (301) 415-1345 if you have any questions on this issue.

Sincerely,

/RA/

John F. Stang, Project Manager
Plant Licensing Branch E
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-305

cc: See next page

DISTRIBUTION:

MMitchell	JStang
PUBLIC	EAndruszkiewicz
LPLE R/F	ACRS
OGC	GGrant, RIII
TColburn	THarris

ADAMS Accession Number: **ML053060208**

OFFICE	NRR/LPLE/PM	NRR/LPLE/LA	NRR/LPLE/BC
NAME	JStang	THarris	LRaghavan
DATE	11/4/05	11/4/05	11/7/05

OFFICIAL RECORD COPY

Kewaunee Power Station

cc:

Resident Inspectors Office
U.S. Nuclear Regulatory Commission
N490 Hwy 42
Kewaunee, WI 54216-9510

Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

David Zellner
Chairman - Town of Carlton
N2164 County B
Kewaunee, WI 54216

Mr. Jeffery Kitsembel
Electric Division
Public Service Commission of Wisconsin
PO Box 7854
Madison, WI 53707-7854

Mr. Michael G. Gaffney
Dominion Energy Kewaunee, Inc.
Kewaunee Power Station
N490 Highway 42
Kewaunee, WI 54216

Mr. Chris L. Funderburk
Director, Nuclear Licensing and
Operations Support
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

Mr. Thomas L. Breene
Dominion Energy Kewaunee, Inc.
Kewaunee Power Station
N490 Highway 42
Kewaunee, WI 54216

Ms. Lillian M. Cuoco, Esq.
Senior Counsel
Dominion Resources Services, Inc.
Millstone Power Station
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Plant Manager
Kewaunee Power Station
N490 Highway 42
Kewaunee, WI 54216-9511