

nee

14-NER K

From: Millard Wohl
To: NLS
Date: Thu, Jun 24, 2004 1:29 PM
Subject: Palo Verde LOOP

Nancy--

Re our earlier brief discussion, these are my chief information needs:

- 1) Root cause (if known) of LOSP
- 2) Number of combustion turbine generators (CTGs) in adjacent yard
- 3) Number of CTGs that started
 - Number of CTGs that were made available to the plant electrical system and by what means (automatic, manual)
- 4) Have the CTGs been added to the plant PRA model and, if so, is common cause failure modeled (including CCF w/EDG(s))?
- 5) Reason(s) for no voltage/ampereage being registered for EDG considered failed
- 6) Any attempts made to cross-connect EDGs before shutting down all three PVNGS units?

Millard (301-415-1181)

L/B
1/4