

16-NRR  
② R

**From:** Thomas Koshy  
**To:** Gody, Tony  
**Date:** Fri, Jun 25, 2004 12:12 PM  
**Subject:** Fwd: RE: Electronic Copy of Palo Verde Switchyard Voltage

APS has agreed to add a second level of protection between 500 KV and 230 KV switchyard.  
Attached is the email from steve

Thomas Koshy,  
email:txk@nrc.gov,  
Tel:(301)415-1176  
Electrical Engineering Section  
Electrical, Instrumentation & Controls Branch  
Mail Stop O-4A15A

**CC:** Calvo, Jose; Jenkins, Ronaldo

CAT 1

4/14