

November 23, 2005

Mr. Christopher M. Crane, President
and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO AMENDMENT REQUEST (TAC NOS. MC7251
AND MC7252)

Reference: Letter from Keith R. Jury (Exelon Generation Company, LLC) to the U.S. Nuclear
Regulatory Commission (NRC), "Request for Amendment to Technical
Specifications Section 5.6.5, "Core Operating Limits Report (COLR)," dated
March 7, 2005

Dear Mr. Crane:

In the referenced letter, Exelon Generation Company, LLC submitted a request for an amendment for LaSalle County Station, Units 1 and 2. This submittal was made to modify the Technical Specification (TS) Sections 5.6.5, "Core Operating Limits Report (COLR)." The proposed changes will add two new NRC approved topical report references to the list of analytical methods in TS 5.6.5, "Core Operating Limits Report (COLR)," that can be used to determine core operating limits. While reviewing your March 7, 2005 submittal, the NRC staff has determined that additional information as discussed in the enclosure to this letter, is needed to complete its review of your application.

The NRC staff developed the enclosed questions and a draft version of these questions were compiled in a request for additional information (RAI) and transmitted to Ms. Alison MacKellar of your staff via e-mail on October 13, 2005. The e-mail, also, provided for an opportunity for a phone call with NRC staff in case any clarifications were sought by Exelon. Subsequently, a phone call was conducted which clarified the final RAI, which is enclosed. It is requested that Exelon provide a response to the enclosed RAI within 30 days from the date of this letter.

C. Crane

-2-

If you have any questions, please do not hesitate to contact me 301-415-3154 or by e-mail: sps1@nrc.gov.

Sincerely,

/RA by G.Dick for/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure: Request for Additional Information

cc w/encl: See next page

C. Crane

-2-

If you have any questions, please do not hesitate to contact me 301-415-3154 or by e-mail: sps1@nrc.gov.

Sincerely,

/RA by G.Dick for/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure: As stated above

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	LLois
LPL III-2 R/F	GMorris
GSuh	SSands
PCoates	TFord
BBurgess, RIII	GHill (4), T5C3

ADAMS Accession Number: ML053260303 Nrr-088

OFFICE	PM:LPLIII-2	LA:LPLIII-2	SC:SBWB	SC:LPLIII-2
NAME	SPSands	PCoates	LLois	GDick for GSuh
DATE	11/22/05	11/22/05	11/22/05	11/23/05

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
AMENDMENT TO TECHNICAL SPECIFICATION 5.6.5
LA SALLE COUNTY STATION, UNITS 1 AND 2
DOCKET NOS. 50-373 AND 50-374

In your letter from Keith R. Jury (Exelon Generation Company, LLC) to the U.S. Nuclear Regulatory Commission (NRC), "Request for Amendment to Technical Specifications Section 5.6.5, "Core Operating Limits Report (COLR)," dated March 7, 2005, one of the changes LaSalle is proposing to TS Section 5.6.5, "Core Operating Limits Report (COLR)" is to add an NRC previously approved Framatome Advanced Nuclear Power, Inc. topical report reference for an updated methodology for evaluation of Loss-of-Coolant Accident (LOCA) conditions (EXEM BWR-2000 ECCS Evaluation Model). In order for the proposed methodology reference to be incorporated into TS Section 5.6.5, (1) the methodology must be approved by the NRC, (2) the applicant must apply the methodology by performing an LOCA analysis, and (3) the applicant must submit the results of the LOCA analysis to the staff.

In performing the new LOCA analysis, the applicant must demonstrate the effects of any change in an acceptable evaluation model or in the application of such a model to determine if the change is significant. A significant change is defined as a peak fuel cladding temperature difference of more than 50E F from the temperature calculated for the limiting transient using the last acceptable model. Based on the above, the staff is requesting additional information to complete its review.

1. Was a new LOCA analysis performed using the proposed EXEM BWR-2000 evaluation model to determine if there is a peak fuel temperature change of more than 50E F from the temperature calculated for the limiting transient using the current acceptable model?
 - (a) If yes,
 - i) please provide the key input parameters used in both the current analysis of record, and for EXEM BWR-2000 and,
 - ii) submit the peak fuel temperature results for the new analysis using EXEM BWR-2000 as well as the peak fuel temperature results for the current analysis of record.
 - (b) If a new LOCA analysis was not performed, please provide justification, or perform a new LOCA analysis using the EXEM BWR-2000 evaluation model and
 - i) please provide the key input parameters used in both the current analysis of record, and for EXEM BWR-2000 and,
 - ii) submit the peak fuel temperature results for the new analysis using EXEM BWR-2000 as well as the peak fuel temperature results for the current analysis of record.

ENCLOSURE

LaSalle County Station Units 1 and 2

cc:

Site Vice President - LaSalle County Station
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

LaSalle County Station Plant Manager
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

Regulatory Assurance Manager - LaSalle
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

U.S. Nuclear Regulatory Commission
LaSalle Resident Inspectors Office
2605 North 21st Road
Marseilles, IL 61341-9756

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, IL 60603

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, IL 60601

Chairman
LaSalle County Board
707 Etna Road
Ottawa, IL 61350

Attorney General
500 S. Second Street
Springfield, IL 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, IL 62706

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, IL 60601

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Boiling Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

LaSalle County Station Units 1 and 2 - 2 -

Director - Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden, Quad Cities
and Clinton
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555