

NOV 15 2005  
LR-N05-0556



United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION – UNIT 1  
DOCKET NOS. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for October 2005 are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "T. P. Joyce", written over a horizontal line.

Thomas P. Joyce  
Site Vice President  
Salem Generating Station

Attachments

JE24

NOV 15 2005

Document Control Desk  
LR-N05-0556

C: Mr. S. Collins, Administrator – Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. S. Bailey, Licensing Project Manager - Salem  
U. S. Nuclear Regulatory Commission  
Mail Stop 08B1  
Washington, DC 20555

USNRC Senior Resident Inspector – Salem (X24)

Mr. K. Tosch, Manager IV  
Bureau of Nuclear Engineering  
PO Box 415  
Trenton, New Jersey 08625

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 11/05/05  
 COMPLETED BY: J.Hiles  
 TELEPHONE: (856) 339-3068

Reporting Period: October

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)  
 No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)  
 Unplanned Transients >20%

Month	Year-to-date	Cumulative
1193		
1159		
260	6772	164414
260	6762	159480
0	0	0
299415	7882737	164336093
0	1	

### UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/COMMENT
2	10/11/05 - 10/31/05	S	485	C	1	Refueling Outage 17 (1R17)

#### (1) Reason

A - Equipment Failure (Explain)  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training/License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other

#### (2) Method

1 - Manual  
 2 - Manual Trip  
 3 - Automatic Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 11/05/05  
COMPLETED BY: J.Wearne  
TELEPHONE: (856) 339-5081

**Summary of Monthly Operating Experience**

- Salem 1 began the month at 100% power and commenced 1R17 on 10/10/05 at 2000 hours, at the end of the month the unit was still in a refueling outage.