

Entergy
Cox, Mark

From: Schwartz, Geoffrey
Sent: Wednesday, September 21, 2005 5:36 PM
To: Dacimo, Fred; Limpas, Oscar; Rubin, Paul; Ventosa, John; Comiotes, Jim; Mayer, Don; Cox, Mark; Hipschman, Thomas
Subject: SFP Wall status

Continued water collection and sampling. Sample results remain essentially unchanged.

I have directed scaffold erection in the pipe pen to allow closer examination of the dry crack in that area.

Draft calculation completed indicating that the wall retains very robust margin.

Ex. 4

Today we held a lengthy team meeting analyzing and collating the radiological and structural data as a whole to begin the processing of report preparation.

Geoff Schwartz
Manager, Spent Fuel Dry Storage

Entergy Nuclear Northeast, Indian Point Energy Center
450 Broadway, Buchanan, NY 10511
Office (914) 734-6684 Fax (914) 271-7191

Page

Cell

Ex. 6

CONFIDENTIALITY NOTICE: This electronic mail transmission is intended only for the use of the individual or entity to which it is addressed and may contain confidential information belonging to the sender which is protected by Entergy or the attorney-client privilege. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you have received this transmission in error, please notify the sender immediately by e-mail and delete the original message.

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 4 & 6
FOIA-2005-0369

C-4