Source Panel	Load	LOCA w/ LOOP Start Time	LOCA w/ LOOP Stop Time	0 sec Voltage	0 sec Current	0.1st Voltage	0.1st Current	0.2nd Voltage	0.2nd Current	0.3rd Voltage	0.3rd Current	0.31st Voltage	0.31st Current	0.32nd Voltage	0.32nd Current	0.33rd Voltage	0.33rd Current	1st Voltage	1st Current	1.1st Voltage	1.1st Current	1.2nd Voltage	1.2nd Current	1.3rd Voltage	1.3rd Current	1.7th Voltage	1.7th Current	1.75th Voltage	1.75th Current	1.8th Voltage	1.8th Current	1.85th Voltage	1.85th Current	1.90th Voltage	1.90th Current	2nd Voltage	2nd Current	2.1st Voltage	2.1st Current	2.2nd Voltage	2.2nd Current	2.3rd Voltage	2.3rd Current	3rd Voltage	3rd Current	3.1st Voltage	3.1st Current	3.2nd Voltage	3.2nd Current	3.3rd Voltage	3.3rd Current	3.4th Voltage	3.4th Current	3.51st Voltage	3.51st Current	3.52nd Voltage	3.52nd Current	3.54th Voltage	3.54th Current
BATTERY 71SB-1				117.69	73.54	113.83	595.02	113.81	585.84	111.36	626.00	113.36	626.00	113.32	629.04	113.36	626.21	112.07	660.82	112.59	660.45	112.60	666.45	112.60	666.45	113.35	626.24	113.13	610.93	113.07	607.20	113.56	608.39	113.48	615.25	113.27	633.84	112.80	675.68	113.17	642.99	112.28	737.56	112.28	737.55	112.84	672.40	113.25	635.48	113.21	639.29	113.25	635.82	113.25	635.80	113.25	635.97	113.24	636.04
71BCB-2A				117.38	73.54	112.03	595.02	112.02	585.84	111.44	626.00	111.44	626.00	111.40	629.04	111.44	626.21	110.95	660.82	110.87	666.45	110.87	666.45	110.87	666.45	111.33	626.24	111.16	610.93	111.71	607.20	111.70	608.39	111.60	615.25	111.23	633.84	110.79	675.68	111.20	642.99	110.02	737.56	110.02	737.55	110.78	672.40	111.31	635.48	111.25	639.29	111.30	635.82	111.30	635.80	111.30	635.97	111.30	636.04
A02	71LPERDC1 Emer Lig Pnl	0.1st sec	7.2nd sec			108.12	16.20	108.11	16.19	109.35	15.23	109.22	85.68	109.22	85.68	109.88	88.91	106.20	85.90	105.47	89.72	102.53	136.73	102.53	136.73	105.69	94.29	106.93	78.13	107.19	74.20	107.09	75.46	106.82	78.41	106.56	78.28	103.15	124.36	105.71	90.09	104.55	89.75	104.55	89.75	105.29	89.97	108.19	51.10	107.89	55.11	108.17	51.46	108.17	51.46	108.15	51.61	108.15	51.69
A03	71LPERUC2 Emer Lig Pnl	0.1st sec	7.2nd sec			107.08	9.07	107.07	9.07	109.35	15.23	109.22	9.02	109.52	9.02	108.48	9.02	108.52	9.02	108.04	8.98	106.04	8.98	105.97	8.98	105.97	8.98	106.52	9.02	106.72	9.04	106.78	9.04	106.78	9.04	106.76	9.04	105.67	9.03	106.41	9.01	105.84	8.96	106.29	9.00	105.16	8.91	105.16	8.91	105.68	8.97	106.39	9.01	106.34	9.01	106.38	9.01	106.38	9.01	106.38	9.01
A04	Panel 71HC-A1			117.22	2.60	111.45	9.49	111.09	15.23	109.22																																																		
A05	71LPEA0C1 Emer Lig Pnl	0.1st sec	7.2nd sec			105.83	17.39	105.82	17.39	109.35	15.23	109.22	17.30	105.28	17.30	105.24	17.29	105.28	17.30	104.61	17.22	104.61	17.22	104.73	17.21	104.73	17.21	105.28	17.30	105.53	17.34	105.53	17.34	105.52	17.34	105.43	17.32	105.17	17.28	104.61	17.19	105.05	17.26	103.94	17.08	103.94	17.08	104.65	17.20	105.15	17.28	105.10	17.27	105.15	17.28	105.15	17.28	105.15	17.28	105.14	17.28
A06	71BMCC-3			117.33	0.34	104.57	57.41	104.56	57.40	104.02	57.11	104.02	57.11	103.98	57.08	104.02	57.40	103.56	56.85	103.56	56.85	103.56	56.85	108.81	15.80	108.81	15.80	109.40	15.72	109.62	15.68	109.66	15.69	109.56	15.70	109.29	15.74	108.68	15.82	109.15	15.75	107.95	15.92	107.95	15.92	108.72	15.81	109.26	15.74	109.21	15.75	109.26	15.74	109.26	15.74	109.26	15.74	109.25	15.74
A07	71LPEsWPDC1 Emer Lig Pnl	0.1st sec	7.2nd sec			110.02	6.84	110.01	6.84	109.35	15.23	109.44	6.80	109.44	6.80	109.40	6.80	109.44	6.80	108.95	6.77	108.95	6.77	108.87	6.77	108.87	6.77	109.44	6.80	109.55	6.81	109.71	6.82	109.70	6.82	109.69	6.82	109.59	6.81	109.33	6.79	108.74	6.76	109.20	6.79	108.04	6.71	108.04	6.71	108.79	6.76	109.31	6.79	109.25	6.79	109.30	6.79	109.30	6.79	109.30	6.79
B02	Panel 71DC-A2			117.31	1.23	110.30	33.99	110.28	33.99	111.91	10.51	110.91	10.51	110.86	10.51	110.90	10.51	110.41	10.47	110.41	10.47	110.33	10.47	110.33	10.47	110.90	10.51	111.16	10.53	111.18	10.53	111.16	10.53	111.06	10.52	110.80	10.50	110.20	10.46	110.67	10.49	109.24	15.29	109.24	15.29	110.25	10.46	110.77	10.50	110.72	10.50	110.77	10.50	110.77	10.50	110.76	10.50
B03	Panel 71DC-A3			116.57	12.90	111.11	14.76	111.10	14.76	111.52	14.73	110.48	14.73	110.42	14.73	110.48	14.72	110.52	14.73	110.03	14.70	110.03	14.70	109.95	14.69	109.95	14.69	110.52	14.73	110.74	14.74	110.79	14.74	110.78	14.74	110.78	14.74	110.62	15.60	108.16	50.78	107.57	50.55	108.03	50.73	106.68	50.28	106.68	50.28	107.62	50.57	108.14	50.77	108.08	50.75	108.13	50.77	108.13	50.77	108.13	50.77
B04	Panel 71DC-A3			117.31	2.30	111.22	29.92	111.34	25.04	111.89	20.52	110.69	20.52	110.65	20.51	110.69	20.52	110.39	20.44	110.39	20.44	110.31	20.43	110.31	20.43	110.89	20.52	111.16	20.56	111.14	20.56	110.95	23.97	109.87	54.06	109.34	51.57	109.60	51.78	107.28	101.28	107.29	101.28	109.75	38.25	110.27	38.42	110.22	38.40	110.27	38.42	110.27	38.42	110.26	38.41	110.26	38.41
B05	71BMCC-1			117.33	0.89	109.63	49.08	109.62	49.07	109.62	48.69	109.06	48.62	109.01	48.60	109.05	48.62	108.56	81.48	108.56	81.48	108.68	81.43	108.68	81.43	107.43	81.85	107.70	82.05	107.70	82.05	107.68	82.04	107.59	81.96	109.56	36.19	108.95	36.39	109.43	36.24	108.08	80.64	108.08	80.62	108.83	80.69	107.36	80.72	107.30	80.72	107.35	80.72	107.35	80.70	107.35	80.72	107.35	80.72
B06	71LPE1 Emer Lig Pnl	0.1st sec	7.2nd sec			109.60	10.76	109.79	10.76	109.23	10.72	109.18	10.72	109.22	10.72	108.74	10.68	108.74	10.68	108.66	10.67	108.66	10.67	109.22	10.72	109.14	10.74	109.49	10.75	109.47	10.75	109.38	10.74	109.12	10.71	108.53	10.66	108.99	10.70	109.41	10.71	108.59	10.66	107.83	10.59	107.58	10.66	109.09	10.71	109.09	10.71	109.09	10.71	109.09	10.71	109.09	10.71
C01	Panel 71DC-A5			114.41	32.84	108.65	35.17	108.64	35.17	108.26	35.28	108.21	35.29	108.25	35.28	108.21	35.29	108.25	35.28	107.75	35.38	107.75	35.38	107.67	35.40	107.67	35.40	108.25	35.28	108.48	35.24	108.53	35.23	108.51	35.23	108.41	35.25	108.14	35.30	107.53	35.42	108.01	35.33	106.81	35.57	106.81	35.57	107.58	35.41	108.12	35.31	108.06	35.32	108.11	35.31	108.11	35.31	108.11	35.31
C03	71UPS-1	0.1st sec	120 min			107.41	129.68	107.40	129.68	106.85	128.39	106.85	128.39	106.81	128.34	106.85	128.39	106.37	127.81	106.37	127.81	106.30	127.72	106.30	127.72	106.85	128.39	107.11	128.70	107.09	128.68	107.00	128.56	106.74	128.25	106.17	127.57	106.62	128.11	105.49	126.78	105.49	126.78	106.21	127.62	106.72	128.23	106.67	128.17	106.72	128.22	106.72	128.22	106.71	128.22	106.71	128.22
D01	31P-7A RPPT Oil Pump Motor	15th sec	120 min																																																									
	31P-7A RPPT Oil Pump Control	15th sec	120 min																																																									
	31P-7A Continuous Control	0.1st sec	15th sec	117.35	0.24	112.00	9.23	111.99	9.23	111.42	9.23	111.37	9.23	111.41	9.23	111.92	9.23	110.84	9.23	110.92	9.23	110.84	9.23	110.84	9.23	111.41	9.23	111.69	9.23	111.69	9.23	111.67	9.23	111.31	9.23	111.17	9.23	110.75	9.23	111.28	9.23	110.00	9.23	110.75	9.23	111.28	9.23	111.28	9.23	111.28	9.23	111.28	9.23	111.27	9.23
D02	94P-13 Seal Oil Pump Motor	0.1st sec	120 min			97.55	145.23	97.54	145.22	97.94	144.47	97.04	144.47	97.00	144.41	97.04	144.47	96.61	143.83	96.61	143.83	96.54	143.72	96.54	143.72	97.04	144.47	97.21	144.75	97.28	144.82	97.28	144.80	97.18	144.67	96.94	144.33	96.42	143.55	96.83	144.16	95.89	142.63	95.89	142.63	96.46	143.61	96.92	144.30	96.88	144.22	96.92	144.29	96.92	144.29	96.92	144.29	96.92	144.28
	94P-13 Seal Oil Pump Control	0.1st sec	120 min			109.26	1.31	109.25	1.31	109.69	1.30	109.65	1.30	109.65	1.30	109.69	1.30	108.20	1.29	108.20	1.29	108.13	1.28	108.13	1.28	108.69	1.30	108.91	1.30	108.94	1.30	108.84	1.30	108.58	1.30	108.00	1.29	108.45	1.30	107.30	1.28	107.30	1.28	108.55	1.30	108.55	1.30	108.55	1.30	108.55	1.30	108.55	1.30	108.55	1.30	108.55	1.30
	94P-13 Continuous Control	0 sec	0.1st sec	117.00	0.18																																																							
N/A	Continuous control	0 sec	120 min	117.38	20.02	112.03	19.10	112.02	19.10	111.44	19.00	111.40	19.00	111.40	19.00	111.44	19.00	110.95	18.92	110.95	18.92	110.87	18.91	110.87	18.91	111.44	19.00	111.69	19.04	111.71	19.05	111.71	19.05	111.70	19.05	111.60	19.03	111.33	18.98	110.73	18.88	111.20	18.96	110.02	18.76	110.02	18.76	110.78	18.89	111.31	18.98	111.25	18.97	111.30	18.98	111.30	18.98	111.30	18.98	111.30	18.98
71DC-A1				117.31	1.23	110.30	33.99	110.28	33.99	111.91	10.51	110.91	10.51	110.86	10.51	110.90	10.51	110.41	10.47	110.41	10.47	110.33	10.47	110.33	10.47	110.90	10.51	111.16	10.53	111.18	10.53	111.16	10.53	111.06	10.52	110.80	10.50	110.20	10.46	110.67	10.49	109.24	15.29	109.24	15.29	110.25	10.46	110.77	10.50	110.72	10.50	110.77	10.50	110.77	10.50	110.76	10.50
02	11UPRN07 Unit 8 NSB Transf BU Prot	0.1 sec	1 min			105.65	9.12	105.84	9.12	106.33	9.17	106.40	9.17	106.40	9.16	106.44	9.17	105.96	9.13	105.96	9.13	105.89	9.12	105.89	9.12	106.44	9.17	106.59	9.19	106.70	9.19	106.68	9.19	106.59	9.18	106.33	9.16	105.76	9.11	106.21	9.15	104.84	9.03	104.84	9.03	105.80	9.11	106.31	9.16	106.28	9.15	106.30	9.16	106.31	9.16	106.30	9.16	106.30	9.16
05	Digital Transient Recorder	0 sec	120 min	116.64	1.07	109.58	1.14	109.57	1.14	109.19	1.13	109.19	1.13	109.15	1.13	109.19	1.13	109.70	1.14	109.70	1.14	109.61	1.14	109.61	1.14	109.19	1.13	109.49	1.13	109.49	1.13	109.45	1.13	109.35	1.13	109.09	1.14	109.48	1.14	109.95	1.14	108.52	1.15	108.52	1.15	109.53	1.14	110.08	1.14	110.00	1.14	110.05	1.14	110.05	1.14	110.05	1.14
06	115kV Line 4 Bus UV Trip Bus A	3rd sec	3.1st sec																																																									
12	71PCB-10912 Blkr Alt. L Failure	0.1 sec	1 min			110.28	0.03	110.27	0.03	111.89	0.03	110.89	0.03	110.85	0.03	110.89	0.03	110.40	0.03	110.40	0.03	110.32	0.03	110.32	0.03	110.89	0.03	111.16	0.03	111.16	0.03	111.14	0.03	111.05	0.03	110.78	0.03	110.19	0.03	110.65	0.03	109.23	0.03	109.23	0.03	110.23	0.03	110.76	0.03	110.70	0.03	110.75	0.03	110.75	0.03	110.75	0.03
14	345kV Blkr 71PCB-10042 Trip	0.1st sec	0.2nd sec			95.89	11.51	95.88	11.51																																																		
19	71PCB-10942 Blkr Alt L Failure	0.1 sec	1 min			110.28	0.03	110.27	0.03	111.89	0.03	110.89	0.03	110.85	0.03	110.89	0.03	110.39	0.03	110.39	0.03	110.31	0.03	110.31	0.03	110.89	0.03	111.16	0.03	111.16	0.03	111.14	0.03	111.04	0.03	110.78	0.03	110.18	0.03	110.65	0.03	109.23	0.03	109.23	0.03	110.23	0.03	110.76	0.03	110.70	0.03	110.75	0.03	110.75	0.03	110.75	0.03
21	345kV Blkr 71PCB-10052 Trip	0.1st sec	0.2nd sec			100.16	12.02	100.15	12.02																																																		
	Contrls 06, 14 & 21 Continuous Cntrl	0 sec	120 min	117.24	0.16	110.[illegible]	0.15	110.21	0.15	110.84	0.15	110.79	0.15	110.83	0.15	110.84	0.15	110.34	0.15	110.34	0.15	110.26	0.15	110.26	0.15	110.83	0.15	111.10	0.15	111.09	0.15	111.09	0.15	110.99	0.15	110.72	0.15	110.19	0.15	109.17	0.15	109.17	0.15	110.17	0.15	110.70	0.15	110.65	0.15	110.70	0.15	110.70	0.15	110.69	0.15
71DC-A2				116.57	12.90	111.11	14.76	111.10	14.76	111.52	14.73	110.48	14.73	110.42	14.73	110.48	14.72	110.52	14.73	110.03	14.70	110.03	14.70	109.95	14.69	109.95	14.69	110.52	14.73	110.74	14.74	110.79	14.74	110.78	14.74	110.78	14.74	110.62	15.60	108.16	50.78	107.57	50.55	108.03	50.73	106.68	50.28	106.68	50.28	107.62	50.57	108.14	50.77	108.08	50.75	108.13	50.77	108.13	50.77	108.13	50.77
03	Core Spray Channel A Logic	0 sec	120 min	116.00	2.97	110.56	2.63	110.55	2.63	110.55	2.63	109.98	2.82	109.94	2.82	109.98	2.82	109.49	2.80	109.49	2.80	109.41	2.80	109.41	2.80	109.98	2.82	110.25	2.82	110.25	2.82	110.23	2.82	110.08	2.82	107.63	2.76	107.05	2.74	107.50	2.75	106.36	2.72	106.36	2.72	107.09	2.74	107.80	2.76	107.80	2.76	107.80	2.76	107.80	2.76	107.80	2.76
04	RHR Channel A Logic	0 sec	120 min			107.59	0.83	107.58	0.83	107.07	0.83	107.02	0.83	106.98	0.83	107.02	0.83	106.54	0.82	106.47	0.82	106.41	0.82	106.47	0.82	107.02	0.83	107.28	0.83	107.28	0.83	107.27	0.83	107.12	0.83	104.73	0.81	104.17	0.80	104.61	0.81	103.50	0.80	103.50	0.80	104.21	0.80	104.71	0.81	104.70	0.81	104.70	0.81	104.70	0.81	104.70	0.81
09	Relay Cab. Ch.A RCIC Pnl	0 sec	120 min	116.07	2.61	110.61	2.60	110.60	2.60	110.60	2.60	110.02	2.60	109.98	2.60	110.02	2.60	109.53	2.60	109.53	2.60	109.45	2.60	109.45	2.60	110.02	2.60	110.29	2.60	110.29	2.60	110.28	2.60	110.12	2.60	107.66	2.60	107.08	2.60	107.53	2.60	106.38	2.61	106.38	2.61	107.12	2.60	107.64	2.60	107.58	2.60	107.63	2.60	107.63	2.60	107.63	2.60
10	Power Supply 13TU-3-13	0 sec	120 min	116.07	1.24	110.61	1.30	110.60	1.30	110.[illegible]	1.31	110.[illegible]	1.31	110.[illegible]	1.31	110.[illegible]	1.31	109.53	1.32	109.53	1.32	109.45	1.32	109.45	1.32	110.02	1.31	110.29	1.31	110.29	1.31	110.28	1.31	110.12	1.31	107.66	1.34	107.08	1.35	107.53	1.34	106.38	1.36	106.38	1.36	107.12	1.35	107.64	1.34	107.58	1.34	107.63	1.34	107.63	1.34	107.63	1.34
19	RCIC & 18K1 Misc Loads	0 sec	120 min	115.96	2.59	110.46	2.75	110.45	2.75	110.45	2.75	109.87	2.75	109.83	2.75	109.87	2.75	109.38	2.75	109.38	2.75	109.30	2.75	109.30	2.75	109.87	2.75	110.14	2.75	110.14	2.75	110.13	2.75	109.97	2.75	107.51	2.76	106.92	2.77	107.38	2.77	106.22	2.77	106.22	2.77	106.97	2.77	107.48	2.77	107.43	2.77	107.48	2.77	107.48	2.77	107.47	2.77
	Inverter 13INV-152	0 sec	120 min	115.96	1.63	110.46	1.71	110.45	1.71	110.45	1.71	109.87	1.72	109.83	1.72	109.87	1.72	109.38	1.72	109.38	1.72	109.30	1.73	109.30	1.73	109.87	1.72	110.14	1.71	110.14	1.71	110.13	1.71	109.97	1.72	107.51	1.75	106.92	1.76	107.38	1.76	106.22	1.78	106.22	1.78	106.97	1.76	107.48	1.75	107.43	1.76	107.48	1.76	107.48	1.76	107.47	1.76
	13SOV-12	0.1st sec	120 min			110.03	0.12	110.02	0.12	109.[illegible]	0.12	109.45	0.12	109.40	0.12	109.44	0.12	108.95	0.12	108.95	0.12	108.87	0.12	108.87	0.12	109.44	0.12	109.71	0.12	109.71	0.12	109.70	0.12	109.55	0.12	107.09	0.12	106.50	0.12	106.99	0.12	105.81	0.12	105.81	0.12	106.55	0.12	107.06	0.12	107.01	0.12	107.06	0.12	107.06	0.12	107.05	0.12
11	02-184P-3A(M) RWR MG Set A Emer	6th sec	120 min																																																								
	02-184P-3A(M) RWR MG Set A Pmp	6th sec	120 min																																																								
	02-184P-3A(M) Continuous Control	0 sec	6th sec	116.52	0.07	111.06	0.07	111.05	0.07	111.[illegible]	0.07	110.47	0.07	110.43	0.07	110.47	0.07	109.98	0.07	109.98	0.07	109.90	0.07	109.90	0.07	110.47	0.07	110.74	0.07	110.74	0.07	110.73	0.07	110.57	0.07	108.11	0.07	107.53	0.07	107.98	0.07	106.83	0.06	106.83	0.06	107.57	0.07	108.09	0.07	108.03	0.07	108.09	0.07	108.09	0.07	108.08	0.07
14	13INV-801A Steam Leak Det Sys	0 sec	120 min	115.66	1.12	110.16	1.17	110.14	1.17	110.[illegible]	1.17	109.[illegible]	1.18	109.52	1.18	109.56	1.18	109.07	1.18	109.07	1.18	108.99	1.19	108.99	1.19	109.56	1.18	109.84	1.18	109.84	1.18	109.82	1.18	109.67	1.18	107.18	1.21	106.59	1.21	107.05	1.21	105.89	1.22	105.89	1.22	106.64	1.21	107.16	1.21	107.10	1.21	107.15	1.21	107.15	1.21	107.15	1.21
16	RCIC Valve Trip Sol 13TTS-1	0.1st sec	120 min			110.90	0.13	110.89	0.13	110.[illegible]	0.13	110.32	0.13	110.28	0.13	110.32	0.13	109.62	0.13	109.62	0.13	109.54	0.13	109.54	0.13	110.[illegible]	0.13	110.59	0.13	110.59	0.13	110.57	0.13	110.42	0.13	107.96	0.12	107.38	0.12	107.83	0.12	106.68	0.12	106.68	0.12	107.42	0.12	107.94	0.12	107.88	0.12	107.93	0.12	107.93	0.12	107.93	0.12
18	Reac Recir MG Set A Trip	17th sec	18th sec																																																								
	600V SWGR 71US			116.63	0.20	111.07	0.19	111.06	0.19	110.[illegible]	0.19	110.49	0.19	110.45	0.19	110.49	0.19	109.98	0.18	109.98	0.18	109.91	0.18	109.91	0.18	110.49	0.19	110.76	0.19	110.76	0.19	110.74	0.19	110.43	1.05	108.50	36.37	101.02	36.17	101.44	36.32	100.36	35.94	100.36	35.94	101.06	36.19	101.54	36.38	101.49	36.34	101.54	36.38	101.54	36.38	101.54	36.38
20	ADS Panel 09-45 Lead	0 sec	120 min	116.40	2.17	110.88	2.87	110.87	2.87	110.[illegible]	2.85	110.30	2.85	110.26	2.85	110.30	2.85	109.80	2.84	109.80	2.84	109.72	2.84	109.72	2.84	110.30	2.85	110.51	2.86	110.57	2.86	110.55	2.86	110.40	2.86	107.94	2.79	107.36	2.78	107.81	2.79	106.66	2.76	106.66	2.76	107.40	2.78	107.92	2.79	107.86	2.79	107.91	2.79	107.91	2.79	107.91	2.79
	ADS Logic	0.1st sec	120 min			110.41	0.80	110.40	0.80	109.[illegible]	0.80	109.83	0.80	109.79	0.80	109.83	0.80	109.34	0.79	109.34	0.79	109.28	0.79	109.28	0.79	109.83	0.80	110.10	0.80	110.10	0.80	110.08	0.80	109.93	0.80	107.48	0.78	106.90	0.78	107.35	0.78	106.21	0.77	106.21	0.77	106.95	0.78	107.46	0.78	107.40	0.78	107.45	0.78	107.45	0.78	107.45	0.78
	ADS SOV (Load Only)	2nd min	60 min																																																								
	92B-7V-1IE1	2nd min	60 min																																																								
	ADS Steam Continuous Control	0 sec	120 min	116.90	2.17	110.86	2.07	110.[illegible]	2.07	110.[illegible]	2.06	110.30	2.06	110.26	2.06	110.30	2.06	109.80	2.05	109.80	2.05	109.72	2.05	109.72	2.05	110.30	2.06	110.57	2.06	110.57	2.06	110.55	2.06	110.40	2.06	107.94	2.01	107.36	2.00	107.81	2.01	106.66	1.99	106.66	1.99	107.40	2.00	107.92	2.01	107.86	2.01	107.91	2.01	107.91	2.01	107.91	2.01
71BMCC-2				117.31	0.34	104.57	57.41	104.56	57.40	104.02	57.11	104.02	57.11	103.98	57.08	104.02	57.40	103.56