



GE Nuclear Energy

175 Curtner Ave., San Jose, CA 95125

NEDO-33075, Revision 5

DRF-0000-0004-3311

Class I

November 2005

NON-PROPRIETARY VERSION

LICENSING TOPICAL REPORT

**GENERAL ELECTRIC BOILING WATER REACTOR
DETECT AND SUPPRESS SOLUTION – CONFIRMATION DENSITY**

Copyright 2005 General Electric Company

INFORMATION NOTICE

This is a non-proprietary version of the document NEDC-33075P, which has the proprietary information removed. Portions of the document that have been removed are indicated by an open and closed bracket as shown here [[]]. GE has received US patent #6,173,026 covering this subject matter.

IMPORTANT NOTICE REGARDING CONTENTS OF THIS REPORT

PLEASE READ CAREFULLY

The information contained in this document is furnished for the purpose of obtaining NRC approval of the licensing requirements for implementation of the stability Detect and Suppress Solution – Confirmation Density (DSS-CD) to provide automatic detection and suppression of stability related power oscillations. The only undertakings of General Electric Company with respect to information in this document are contained in contracts between General Electric Company and participating utilities, and nothing contained in this document shall be construed as changing those contracts. The use of this information by anyone other than that for which it is intended is not authorized; and with respect to any unauthorized use, General Electric Company makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

TABLE OF CONTENTS

	Page
Executive Summary	x
Revisions.....	xi
Acknowledgements.....	xiii
Acronyms and Abbreviations	xiv
1.0 Introduction	1-1
1.1 Background.....	1-1
1.2 Purpose	1-2
1.3 Overview	1-2
2.0 Solution Design Philosophy	2-1
2.1 Design Approach.....	2-1
2.2 Licensing Compliance	2-3
3.0 Solution Description.....	3-1
3.1 System Function	3-1
3.2 System Input and LPRM Assignment	3-2
3.3 Licensing Basis Detection Algorithm	3-3
3.3.1 Confirmation Density Algorithm.....	3-3
3.3.1.1 Introduction	3-5
3.3.1.2 Algorithm Basis.....	3-6
3.3.1.3 Algorithm Description.....	3-8
3.3.1.4 Confirmation Density Setpoint Determination.....	3-11
3.3.1.5 Successive Confirmation Count Threshold Determination.....	3-17
3.3.1.6 Amplitude Discriminator Setpoint Determination	3-18
3.3.1.7 Single Loop Operation	3-20
3.3.1.8 Alarm Setpoint Determination	3-21
3.3.1.9 Generic Setpoints Application.....	3-22
3.4 Defense in Depth Algorithms	3-22
3.4.1 Period Based Detection Algorithm	3-23
3.4.1.1 PBA Application for CDA	3-26
3.4.1.2 PBA Signal Sampling and Resolution for DSS-CD.....	3-28
3.4.2 Amplitude Based Algorithm.....	3-30
3.4.3 Growth Rate Algorithm	3-30
3.5 System Operability	3-31
4.0 Licensing Basis	4-1
4.1 Overview	4-1
4.2 Approach	4-2

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

4.3	Generic Applicability Envelope	4-4
4.4	SLMCPR Protection Confirmation	4-5
4.4.1	Two Loop Operation.....	4-6
4.4.1.1	Event Simulation	4-9
4.4.1.2	MCPR Performance	4-11
4.4.2	Single Loop Operation.....	4-19
4.5	Solution Armed Region.....	4-23
4.6	Application to Non-GE Fuel Design	4-25
5.0	Solution Qualifications and Uncertainties.....	5-1
5.1	TRACG Application.....	5-1
5.1.1	TRACG Qualifications	5-1
5.1.2	Application Approach.....	5-2
5.1.3	Advantages of TRACG Use for Stability Evaluations	5-3
5.1.4	Conformance with CSAU Methodology	5-3
5.2	CSAU Methodology Application.....	5-4
5.3	Detection Algorithm Testing.....	5-12
5.3.1	Successive Period Detection.....	5-13
5.3.2	Confirmation Density Recognition.....	5-13
5.4	Setpoint Methodology Applicability	5-16
5.4.1	CDA Setpoints	5-17
5.4.2	Defense-in-Depth Setpoints	5-17
5.4.3	Armed Region Setpoints	5-17
6.0	Plant Specific Application.....	6-1
6.1	Plant Specific Review Process	6-1
6.2	Lead Use Assembly.....	6-3
7.0	Backup Stability Protection.....	7-1
7.1	Introduction	7-1
7.2	Manual BSP Region Boundaries Generation	7-2
7.2.1	Generic Shape Function.....	7-3
7.2.2	Base Manual BSP Regions Derivation	7-3
7.2.3	Manual BSP Regions Plant Specific Application.....	7-4
7.2.3.1	Region I – Manual BSP Scram Region	7-4
7.2.3.2	Region II – Controlled Entry Region	7-5
7.3	BSP Boundary Generation	7-7
7.3.1	BSP Boundary Plant Specific Application	7-7
7.4	Automated BSP Scram Region Generation.....	7-9
7.4.1	Automated BSP Scram Region Plant Specific Application.....	7-10
7.5	BSP Options Application Summary.....	7-12
7.5.1	BSP Option 1	7-12
7.5.2	BSP Option 2	7-12

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

7.5.3	BSP Reload Application	7-13
8.0	Effect on Technical Specifications.....	8-1
9.0	References	9-1
Appendix A:	Example of Changes to BWR/4 Standard Technical Specifications - Redline/Strikeout Version	A-1
Appendix B:	Example of Changes to BWR/4 Standard Technical Specifications – Revision Bar Version	B-1

LIST OF TABLES

Table	Title	Page
Table 3-1	Confirmation Density Algorithm Setpoints and Basis	3-32
Table 3-2	444 Bundle Core OPRM Channel Operability and CD Setpoint Illustration.....	3-33
Table 3-3	624 Bundle Core OPRM Channel Operability and CD Setpoint Illustration.....	3-34
Table 3-4	Defense in Depth Algorithm Setpoints	3-35
Table 3-5	PBA Parameters	3-36
Table 4-1	TLO DSS-CD Licensing Basis Generic Applicability Envelope.....	4-26
Table 4-2	TLO TRACG Confirmation Analysis Event Matrix.....	4-27
Table 4-3	TLO DSS-CD Evaluation Methodology Summary.....	4-28
Table 4-4	TLO Nominal TRACG Confirmation Analysis MCPR Performance.....	4-29
Table 4-5	TLO DSS-CD Bounding TRACG MCPR Margin.....	4-30
Table 4-6	SLO DSS-CD Licensing Basis Generic Applicability Envelope	4-31
Table 4-7	SLO TRACG Confirmation Analysis Event Matrix	4-31
Table 4-8	SLO DSS-CD Evaluation Methodology Summary.....	4-32
Table 4-9	SLO Nominal TRACG Confirmation Analysis MCPR Performance.....	4-33
Table 4-10	SLO DSS-CD Bounding TRACG MCPR Margin	4-33
Table 4-11	Trip Times for TRACG Confirmation Analysis	4-34
Table 4-12	ODYSY Confirmation of the Armed Region Boundaries.....	4-35
Table 5-1	CSAU Evaluation Methodology	5-19
Table 5-2	Phenomena Governing BWR/3-6 Stability Transients	5-20
Table 5-3	Disposition of High Ranked Stability Model Parameters	5-26
Table 5-4	Key Plant Initial Conditions/Parameters	5-28
Table 5-5	Summary of PBA Testing against Actual Plant Data.....	5-32
Table 5-6	Summary of CDA Testing against Actual Plant Data	5-33
Table 6-1	TLO DSS-CD Plant Specific Applicability Checklist	6-4
Table 6-2	SLO DSS-CD Plant Specific Applicability Checklist.....	6-5
Table 6-3	TLO DSS-CD Applicability Extension Evaluation Procedure	6-6
Table 6-4	SLO DSS-CD Applicability Extension Evaluation Procedure.....	6-7
Table 6-5	Required TRACG Cases for Fuel Design Transition Scenarios	6-8
Table 7-1	Manual BSP Regions Calculation Procedure.....	7-14
Table 7-2	BSP Boundary Calculation Procedure	7-15
Table 7-3	Summary of BSP Boundary Calculation Examples	7-16
Table 8-1	Description and Purpose of TS Changes for DSS-CD Implementation.....	8-3

LIST OF FIGURES

Figure	Title	Page
Figure 3-1	DSS-CD Detection Algorithms Time of Trip Condition Illustration.....	3-37
Figure 3-2	Example RPS Trip Logic	3-38
Figure 3-3	Theoretical Confirmation Density as a Function of Decay Ratio	3-39
Figure 3-4	Practical Confirmation Density as a Function of Decay Ratio	3-40
Figure 3-5	Core Volume Corresponding to CD Upper Bound	3-41
Figure 3-6	PANACEA Contour for a Typical BWR First Order Harmonic.....	3-42
Figure 3-7	OPRM Channel Assignment Map for 444 Bundle Core.....	3-43
Figure 3-8	OPRM Channel Assignment Map for 624 Bundle Core.....	3-44
Figure 3-9	PBA Successive Period Confirmation Process	3-45
Figure 4-1	[[]]	4-36
Figure 4-2	[[]]	4-37
Figure 4-3	[[]]	4-38
Figure 4-4	[[]]	4-39
Figure 4-5	[[]]	4-40
Figure 4-6	[[]]	4-41
Figure 4-7	[[]]	4-42
Figure 4-8	[[]]	4-43
Figure 4-9	[[]]	4-44
Figure 4-10	[[]]	4-45
Figure 4-11	[[]]	4-46
Figure 4-12	[[]]	4-47
Figure 4-13	[[]]	4-48
Figure 4-14	[[]]	4-49
Figure 4-15	[[]]	4-50
Figure 4-16	[[]]	4-51
Figure 4-17	[[]]	4-52
Figure 4-18	[[]]	4-53
Figure 4-19	[[]]	4-54
Figure 4-20	[[]]	4-55
Figure 4-21	[[]]	4-56
Figure 4-22	[[]]	4-57
Figure 4-23	[[]]	4-58
Figure 4-24	[[]]	4-59

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-25 [[]].....	4-60
Figure 4-26 [[]]	4-61
Figure 4-27 [[]]	4-62
Figure 4-28 [[]]4-63	
Figure 4-29 [[]].....	4-64
Figure 4-30 [[]]	4-65
Figure 4-31 [[]]	4-66
Figure 4-32 [[]]	4-67
Figure 4-33 [[]].....	4-68
Figure 4-34 [[]]4-69	
Figure 4-35 [[]]	4-70
Figure 4-36 [[]]	4-71
Figure 4-37 [[]]	4-72
Figure 4-38 [[]]	4-73
Figure 4-39 [[]].....	4-74
Figure 4-40 [[]].....	4-75
Figure 4-41 [[]].....	4-76
Figure 4-42 [[]].....	4-77
Figure 4-43 [[]].....	4-78
Figure 4-44 [[]].....	4-79
Figure 4-45 [[]].....	4-80
Figure 4-46 DSS-CD Armed Region Illustration.....		4-81
Figure 5-1 Example LPRMs Performance for KKL Cycle 7 Instability Test (STAB5).....		5-34
Figure 5-2 CD Performance for KKL Cycle 7 Instability Test (STAB5).....		5-35
Figure 5-3 Columbia LPRM/OPRM Assignment Map Demonstration.....		5-36
Figure 5-4 Example LPRM/OPRM Performance for Columbia Cycle 8 Instability Event.....		5-37
Figure 5-5 LPRM CD Performance for Columbia Cycle 8 Instability Event.....		5-38
Figure 5-6 OPRM CD Performance for Columbia Cycle 8 Instability Event		5-39
Figure 7-1 Base Manual BSP Regions Generation Basis Relative to ICA Regions.....		7-17
Figure 7-2 MELLLA+ Base Manual BSP Regions		7-18
Figure 7-3 Stability Criteria		7-19
Figure 7-4 Example BWR/6 Manual BSP Regions Confirmation.....		7-20
Figure 7-5 Example 1: BWR/6 Manual BSP Region I Confirmation and BSP Boundary		7-21
Figure 7-6 Example 2: BWR/4 Manual BSP Region I Confirmation and BSP Boundary		7-22
Figure 7-7 Example 3: BWR/4 Manual BSP Region I Confirmation and BSP Boundary		7-23
Figure 7-8 Example 4: BWR/4 Manual BSP Region I Confirmation and BSP Boundary		7-24
Figure 7-9 Scram Timing Illustration for BSP Option 2 [[]].....	7-25

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 7-10 Scram Timing Illustration for BSP Option 2 [[]]	7-26
Figure 7-11 Automated BSP Region I Modified APRM Flow Biased Setpoint Construction..		7-27
Figure 7-12 BSP Option 1 Illustration		7-28
Figure 7-13 BSP Option 2 Implementation		7-29

EXECUTIVE SUMMARY

Under certain conditions, boiling water reactors (BWRs) may be susceptible to coupled neutronic/thermal-hydraulic instabilities. These instabilities are characterized by periodic power and flow oscillations. If these oscillations become large enough, and the associated density waves contain a sufficiently high void fraction, the fuel cladding integrity safety limit could be challenged.

Several different stability long-term solution (LTS) options have been developed for BWRs. Certain solutions depend upon automatic reactor instability detection and suppression to show compliance with licensing requirements. The Detect and Suppress Solution – Confirmation Density (DSS-CD) consists of hardware and software for the automatic detection and suppression of stability related power oscillations and represents an evolutionary step from the stability LTS Option III.

DSS-CD introduces an enhanced detection algorithm, the Confirmation Density Algorithm (CDA), which reliably detects the inception of power oscillations and generates an early power suppression trip signal prior to any significant oscillation amplitude growth and Minimum Critical Power Ratio (MCPR) degradation. This report provides a generic licensing basis for GE BWR/3-6 product lines, GE14 and earlier GE fuel designs and operating envelopes up to and including Extended Power Uprate (EPU) and Maximum Extended Load Line Limit Analysis Plus (MELLLA+). A standard procedure is identified for plant specific confirmations of reload designs and other design changes that may affect the DSS-CD generic licensing basis.

REVISIONS

Revision 1:

1. Editorial clarifications and corrections.
2. Updated acknowledgement list.
3. Expanded proprietary marking to include GE proprietary processes.

Revision 2:

1. Minor editorial changes.
2. Correct channel trip designation in Section 3.2 for consistency with Figure 3-1.
3. Clarify in Sections 3.5 and 4.5 the MCPR monitoring threshold application to define the Armed Region boundary.
4. Revise "filter corner frequency" to "filter cutoff frequency" throughout the report for consistency.
5. Lower T_{\min} value to bound expected period range for MELLLA+ operation.
6. Adjust f_c permissible range consistent with the revised T_{\min} value.
7. Identify OPRM cell and channel responsiveness requirements, and clarify relationship to confirmation density setpoint.
8. Change the initial setting for the Period Based Algorithm (PBA) adjustable parameters consistent with plant operating experience.

Revision 3:

1. Minor editorial changes.
2. Clarify terminology use of RPS channel, OPRM channel and OPRM cell.
3. Change DSS-CD system operability requirement in Section 3.5.
4. Change unresponsive OPRM channel to inoperable (INOP) channel status.
5. Clarify that the selection of DSS-CD alarm setpoint is optional.
6. Clarify Manual BSP Region generation cycle exposure requirements, application procedure, and BSP Boundary feature.
7. Define HFCL for MELLLA+ and clarify use for MELLLA+ applications.
8. Identify BSP options
9. Add section of example Technical Specification.
10. Simplify MCPR margin applicability envelope definition.
11. Clarify Armed Region Boundary flow dependence.
12. Clarify that TRACG is not used to establish the SLMCPR.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

13. Specify PBA cutoff frequency and period tolerance values.
14. Eliminate PBA calibration requirement.
15. Revise PBDA confirmation count setpoint value.
16. Specify TRACG fuel transition cases for expanding DSS-CD applicability envelope.

Revision 4:

1. Minor editorial changes.
2. Add to CDA an OPRM cell signal amplitude discriminator.
3. Add explicit TRACG OPRM cell modeling and apply the detection algorithm to OPRM cell signals instead of hot channel signals.
4. Address single loop operation.
5. Add Figure 3-1 to illustrate the DSS-CD detection algorithms time of trip for a growing oscillation.
6. Add basis for the selected OPRM signal averaging cutoff frequency value.
7. Specify a single period tolerance value in Table 3-5.
8. Correct C1AX entry in Table 5-3.
9. Clarify feedwater temperature considerations for Manual BSP Region generation.
10. Add optional exposure dependent BSP regions and boundary.
11. Correct Figures 7-2 and 7-4.
12. Revise the proposed requirement and purpose of TS Required Action I.3 to require NRC acceptance of corrective action plan and schedule.

Revision 5:

1. Minor editorial changes.
2. Clarify on-line implementation.
3. Correct BSP Boundary calculation procedure for xenon concentration and feedwater temperature in Table 7-2.
4. Update Tables 4-4, 4-5, 4-9 and 4-10, Figures 4-1 through 4-27 and 4-32 through 4-45, and the bounding CSAU oscillation component relative uncertainty to account for a void reactivity coefficient correction and the use of a transient CPR model in TRACG.
5. Clarify potential susceptibility to spurious scrams for plants exhibiting high noise level during stable operation.
6. Address partial flow reduction events.
7. Update Table 8-1, Technical Specifications, and associated Bases.

ACKNOWLEDGEMENTS

The following individuals contributed significantly to the development, verification, and review of this report:

J. G.	Andersen	T.	Nakanishi
J. L.	Casillas	D. W.	Newkirk
V.	Chandola	I.	Nir
R. T.	Chiang	J. S.	Post
A. K.	Chung	N.	Sadeghi
M. M.	Cook	J. C.	Shaug
R. M.	Fawcett	B. S.	Shiralkar
M. E.	Harding	J. S.	Stewart
J. F.	Harrison	G. B.	Stramback
L. A.	Klebanov	P. T.	Tran
M. A.	Lalor	D. G.	Vreeland
R. B.	Linford	G. A.	Watford
C. M.	Mowry	P. K.	Wu

ACRONYMS AND ABBREVIATIONS

Term	Definition
ABA	Amplitude Based Algorithm
ABWR	Advanced Boiling Water Reactor
AD _j	Amplitude Discriminator State
AGE	Approved GE
ANGE	Approved Non-GE
AOO	Anticipated Operational Occurrence
APRM	Average Power Range Monitor
ATWS	Anticipated Transient Without Scram
A _n	Averaged OPRM cell signal
BB	Boiling Boundary
BOC	Beginning Of Cycle
BSP	Backup Stability Protection
BT	Boiling Transition
BWR	Boiling Water Reactor
CCFL	Counter Current Flow Limitation
CD	Confirmation Density
CD _j	j th OPRM Channel Confirmation Density
CDA	Confirmation Density Algorithm
CHAN	Fuel Channel
CPR	Critical Power Ratio
CSAU	Code Scaling, Applicability and Uncertainty
C _n	Normalized OPRM cell signal
DIVOM	Delta over Initial MCPR Versus Oscillation Magnitude
DR	Decay Ratio
DSS-CD	Detect and Suppress Solution – Confirmation Density
DVC	Dynamic Void Coefficient
ΔCPR	Delta Critical Power Ratio
ΔT _{FW}	Delta Feedwater Temperature

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Term	Definition
E	Axial loss of PBA efficiency
ECCS	Emergency Core Coolant System
ECP	Engineering Computer Program
EOC	End Of Cycle
ϵ	Period Tolerance
ϵ_{Input}	PBA Period Tolerance Selection
EPU	Extended Power Uprate
f_c	Conditioning Filter Cutoff Frequency
FCL	Flow Control Line
FCV	Flow Control Valve
FM CPR	Final Minimum Critical Power Ratio
FTTC	Fuel Thermal Time Constant
$F_{\text{CD}}^{\text{Max}}$	Maximum response fraction ignoring axial PBA inefficiencies
GDC	General Design Criteria
GESTAR	General Electric Standard Application for Reload Fuel
GEXL	GE Boiling Transition Correlation
GRA	Growth Rate Algorithm
GR ₃	GRA Maximum Allowable Growth Rate
GSF	Generic Shape Function
GT	Guide Tube
HFCL	High Flow Control Line
HT	Heat Transfer
ICA	Interim Corrective Action
ICPR	Initial Critical Power Ratio
IM CPR	Initial Minimum Critical Power Ratio
JP	Jet Pump
KKL	Kernkraftwerk Leibstadt
L	Low Importance
LOCA	Loss Of Coolant Accident
LPCI	Low Pressure Coolant Injection

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Term	Definition
LTR	Licensing Topical Report
LTS	Long-Term Solution
LPRM	Local Power Range Monitor
LUA	Lead Use Assembly
M	Medium Importance
MCPR	Minimum Critical Power Ratio
MELLLA+, M+	Maximum Extended Load Line Limit Analysis Plus
M_{OP}^j	Number of Operable OPRM cells for j^{th} OPRM Channel
M_{RS}^j	Number of Responsive OPRM cells for j^{th} OPRM Channel
M_{AX}^j	Largest Number of OPRM cells Aligned Along a Regional Mode Instability Axis of Symmetry
M_{CD}^j	Number of OPRM cells at or above N_{Th} for j^{th} OPRM channel
M_{DL}^j	Number of Operable OPRM cells with Exclusive Input from D Level LPRMs
MG	Motor Generator
MOC	Middle Of Cycle
NA	Not Applicable
N_{AI}	Successive Confirmation Alarm Setpoint
NCL	Natural Circulation Line
N_i	Successive Confirmation Count of the i^{th} OPRM cell
N_P	PBDA Successive Period Confirmation Setpoint
NMS	Neutron Monitoring System
NRC	Nuclear Regulatory Commission
N_{Th}	Successive Confirmation Count Threshold
ODYSY	GE Best-Estimate Frequency Domain Stability Code
OLMCPR	Operating Limit MCPR
$OLMCPR_{Rated}$	Rated power OLMCPR
$OLMCPR_{SLO}$	Off rated OLMCPR for SLO event simulation
OLTP	Original Licensed Thermal Power
OPRM	Oscillation Power Range Monitor

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Term	Definition
Option II	Stability Detect and Suppress LTS for BWR/2
Option III	Stability OPRM-Based Detect and Suppress LTS, Relying on the PBDA, ABA, and GRA for Detection
PANACEA	GE BWR Core Simulator
PBA	Period Based Algorithm
PBDA	Period Based Detection Algorithm
PFR	Partial Flow Reduction
P_i^j	Last recorded peak of the normalized signal of the i^{th} OPRM cell for the j^{th} OPRM channel
PIRT	Phenomena Identification and Ranking Table
PHE	Peak Hot Excess
PWR	Pressurized Water Reactor
P_1	GRA First Cycle Peak
RPF	Radial Peaking Factor
RPS	Reactor Protection System
RPT	Recirculation Pump Trip
SCC	Successive Confirmation Count
SLMCPR	Safety Limit MCPR
SLO	Single Loop Operation
S_{AD}	Amplitude Discriminator Setpoint
S_{CD}^{Max}	Allowable CD setpoint upper bound
S_{max}	ABA Amplitude Trip Setpoint
S_n	Filtered OPRM cell signal
S_p	PBDA Amplitude Setpoint
S_{Th}^i	OPRM Instability Threshold Flag of i^{th} OPRM cell
S_{CD}^j	j^{th} OPRM Channel CD setpoint
S_1, S_2	ABA and GRA Amplitude Threshold Setpoints
S_3	GRA Trip Setpoint
TLO	Two Loop Operation
TMIN	Minimum Stable Film Boiling Temperature

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Term	Definition
TRACG	Transient Reactor Analysis Code (GE proprietary version)
T _{FW}	Feedwater temperature
T _{max}	PBA Time Period Upper Limit
T _{min}	PBA Time Period Lower Limit
T ₁ , T ₂	ABA and GRA Time Windows
UGE	Unapproved GE
UNGE	Unapproved non-GE
1-D	One Dimensional
1P	Single Phase Pressure Drop
2P	Two Phase Pressure Drop
1RPT	Single Recirculation Pump Trip
2RPT	Two Recirculation Pumps Trip
3-D	Three Dimensional

1.0 INTRODUCTION

1.1 BACKGROUND

Under certain conditions, boiling water reactors (BWRs) may be susceptible to coupled neutronic/thermal-hydraulic instabilities. These instabilities are characterized by periodic power and flow oscillations and are the result of density waves (i.e., regions of highly voided coolant periodically sweeping through the core). If the flow and power oscillations become large enough, and the density waves contain a sufficiently high void fraction, the fuel cladding integrity safety limit could be challenged.

The DSS-CD solution consists of hardware and software that provide for reliable, automatic detection and suppression of stability related power oscillations. It is designed to identify the power oscillation upon inception and initiate control rod insertion to terminate the oscillations prior to any significant amplitude growth. The combination of hardware, software, and system setpoints provides protection against violation of the Safety Limit Minimum Critical Power Ratio (SLMCPR) for anticipated oscillations. Thus, compliance with General Design Criteria (GDC) 10 and 12 of 10CFR50, Appendix A is accomplished via an automatic action.

The DSS-CD is based on the same hardware design as Option III, which is described in References 1 through 3. However, it introduces an enhanced detection algorithm that detects the inception of power oscillations and generates an earlier power suppression trip signal exclusively based on successive period confirmation recognition. The DSS-CD is designed to provide adequate automatic SLMCPR protection for anticipated reactor instability events. The existing Option III algorithms are retained (with generic setpoints) to provide defense-in-depth protection for unanticipated reactor instability events.

This report provides a generic licensing basis for DSS-CD applications to GE BWR/3-6 product lines, GE14 and earlier GE fuel designs and operating envelopes up to and including Extended Power Uprate (EPU) and Maximum Extended Load Line Limit Analysis Plus (MELLLA+).

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Specific hardware/software designs are not addressed in this report and, if necessary, will be submitted separately for Nuclear Regulatory Commission (NRC) approval.

1.2 PURPOSE

This report provides the licensing basis and methodology to demonstrate the adequacy of the DSS-CD solution. Section 2.0 describes the solution design philosophy, including the licensing and defense-in-depth protection approach. Section 3.0 provides a detailed description of the key solution elements, including the licensing and defense-in-depth oscillation detection algorithms. Section 4.0 describes the solution's licensing basis. Section 5.0 describes the analytical and plant data qualifications of the solution detection algorithms. Section 6.0 describes the plant specific confirmation process. Section 7.0 describes the backup stability protection feature to be employed in the unlikely event the DSS-CD licensing basis algorithm cannot be demonstrated to provide its intended SLMCPR protection. Section 8.0 discusses the effect on Technical Specifications and Bases for implementation of DSS-CD.

1.3 OVERVIEW

The licensing basis described in this report demonstrates on a generic basis that the DSS-CD features reliably detect and suppress anticipated stability related power oscillations. This provides a high degree of confidence that the SLMCPR is not violated, thus satisfying the requirements of GDC 10 and 12. The detection algorithm used for this purpose is termed the Confirmation Density Algorithm (CDA). The CDA monitors closely spaced groups of Local Power Range Monitor (LPRM) detectors to detect periodic behavior typical of reactor instability events. The CDA initiates a trip signal upon confirmation that an instability signal signature exists for a specified minimum number of LPRM groups.

The DSS-CD licensing basis consists of two major components:

- a. An efficient oscillation detection algorithm, the CDA, providing an early trip signal following instability inception prior to any significant oscillation amplitude growth and MCPR degradation, and

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

- b. A set of integrated Transient Reactor Analysis Code (TRACG) event simulations for reasonably limiting anticipated events that confirm the limited effect on the MCPR performance within the stated applicability range.

To provide defense in depth, the DSS-CD solution includes additional detection algorithms that are not credited in the licensing basis but provide additional protection against unanticipated oscillations. The DSS-CD defense-in-depth detection algorithms are:

- a. Period Based Detection Algorithm (PBDA),
- b. Amplitude Based Algorithm (ABA), and
- c. Growth Rate Algorithm (GRA).

The PBDA provides the licensing basis protection and the ABA and GRA provide the defense-in-depth protection for LTS Option III (Reference 3). These algorithms are capable of initiating a trip signal to limit the size of an oscillation. Because these detection algorithms are not part of the DSS-CD licensing basis, no Technical Specification actions are required if any of these defense-in-depth algorithms are not operable.

This report also provides a description of Backup Stability Protection (BSP) approaches that may be used when the DSS-CD licensing basis algorithm cannot be demonstrated to provide its intended SLMCPR protection.

2.0 SOLUTION DESIGN PHILOSOPHY

2.1 DESIGN APPROACH

The design philosophy used in the development of the DSS-CD hardware/software and licensing basis is discussed in this section. The hardware design is unchanged from the Option III solution described in Reference 1. The firmware/software is modified relative to Option III to reflect the specific DSS-CD stability detection methods, which may include an upgrade to the Automatic Signal Processor card.

The DSS-CD design provides automatic detection and suppression of reactor instability events. Therefore, reliance on the operator to suppress instability events is minimized. The provision of a reliable automatic system makes the DSS-CD "operator friendly" in that protection does not rely on operator action. However, alarms are provided to alert the operator of an increase in the number of confirmed period counts so actions can be taken to avoid a reactor scram.

As described in Reference 3, a closely spaced group of LPRMs (1 to 8 LPRM detectors) is termed an Oscillation Power Range Monitor (OPRM) cell. Each of four independent OPRM channels consists of many OPRM cells distributed throughout the core so that each channel provides monitoring of the entire core. Thus, the system is fully capable of detecting both core wide and regional modes of oscillation. The system is "robust" in that it provides protection despite LPRM failures, OPRM cell inoperability (e.g., from too few inputs), or OPRM channels being out of service.

The CDA is designed to recognize an instability and initiate control rod insertion before the power oscillations increase much above the noise level. Defense-in-depth is provided by the LTS Option III detection algorithms, which are retained in the DSS-CD. These three algorithms examine aspects of the oscillation (local oscillation period, oscillation amplitude and oscillation growth rate) that may be present for oscillations that are not anticipated and are, therefore, not part of the DSS-CD licensing basis.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

The CDA instability detection method and the MCPR performance confirmation analyses presented in this report provide a high confidence that the SLMCPR is not violated for anticipated oscillations, while minimizing the possibility of non-stability related scrams. The CDA capability of early detection and suppression of instability events is achieved by reliance on the successive confirmation period element of the PBDA. DSS-CD eliminates the reliance on the PBDA amplitude setpoint, which is included in the licensing basis of Option III. It introduces instead a fixed low amplitude OPRM signal discriminator, just above the OPRM signal noise level. As a result, instability suppression occurs prior to any significant growth of oscillation amplitude for anticipated instability events.

The DSS-CD solution introduces a number of changes relative to the Option III solution. In addition, it introduces a number of modifications and restrictions to the successive confirmation period element of the PBDA to improve its ability for early recognition of reactor oscillations. These changes only affect the system software/firmware, and therefore, may be able to be implemented on-line.

To ensure adequate implementation of the DSS-CD solution and to avoid unnecessary spurious reactor scrams, the system may be checked while operable but not armed for the first reactor startup to power operation and controlled shutdown following DSS-CD implementation. During this initial system demonstration, proper alarm setpoint selection should be accomplished. In addition, system performance during normal operational maneuvers may be checked. For example, the system capability to accommodate the residual oscillatory behavior following a recirculation pump upshift/restart without generating an alarm or trip signal should be assessed. During this system check out period, reactor instability protection is provided by the backup stability protection (BSP), described in Section 7.0.

The instability suppression by the DSS-CD for high growth instability events occurs within a few full oscillation periods from the time the instability is sensed by the PBA. Because the solution does not rely on oscillation growth to a specified high amplitude setpoint, suppression occurs within a short time from oscillation inception or close to the low amplitude OPRM signal discriminator and significant margin to the SLMCPR is provided. This inherent MCPR margin

permits other elements of the solution's licensing basis to be demonstrated on a conservative basis, thereby simplifying the required evaluations.

In addition, conservatism is introduced in the design philosophy by selecting the SLMCPR to demonstrate protection of fuel cladding integrity for anticipated stability events. The SLMCPR is a conservative limit for this application because the fuel and clad responses to stability related oscillations are relatively mild even if the critical power ratio falls below the SLMCPR. The DSS-CD initiated control rod insertion assures that the hot bundle only experiences a few oscillations prior to scram. If a fuel rod actually experienced boiling transition, the cyclic nature of the event would result in clad rewet approximately every two seconds. A few oscillations in which the clad rewets would result in a negligible cladding temperature transient. This has been demonstrated in the assessment of Reference 4, showing that, as long as the clad rewets between cycles, the clad temperature increase is typically less than 100°F for oscillations up to 200% of rated power. Therefore, use of the SLMCPR as the acceptance criterion is conservative in protecting the fuel.

2.2 LICENSING COMPLIANCE

The DSS-CD solution and related licensing basis were developed to comply with the requirements of 10CFR50, Appendix A, "General Design Criteria for Nuclear Power Plants". The Appendix A criteria related to stability are Criteria 10 and 12.

Criterion 10 (Reactor Design) requires that:

"The reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences."

Criterion 12 (Suppression of Reactor Power Oscillations) requires that:

"The reactor core and associated coolant, control, and protection systems shall be designed to assure that power oscillations which can result in conditions exceeding

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.”

The DSS-CD hardware and software are designed to reliably and readily detect and suppress both core wide and regional mode oscillations prior to violating the SLMCPR for anticipated oscillations. The ability to trip the reactor is automatically enabled at power and flow conditions at which stability related oscillations are possible.

To detect all expected oscillation modes, the outputs from closely spaced LPRM detectors are combined into OPRM cell signals. Thus, small regions of the core are effectively monitored for instabilities. Multiple cells distributed throughout the core provide input to each of the OPRM channels. This ensures that the system is sensitive to all of the anticipated oscillation modes, and also provides substantial redundancy for the input signals and accommodates out of service or failed LPRMs. A number of LPRM-to-OPRM cell assignments (i.e., number and location of the LPRMs that comprise the OPRM cells) are possible within the constraints of the OPRM definition given in Reference 1, as shown in Reference 3. There are no required changes in OPRM cell assignments from Option III to DSS-CD.

The DSS-CD licensing basis is designed to ensure that the system and setpoints result in suppression of oscillations before the SLMCPR is violated for anticipated instability events. In this context, anticipated oscillations are those which, based on both experience and analytical simulations, might be expected to occur in a reactor.

Anticipated instability events are defined to include core wide and regional mode oscillations with full core participation at reasonably limiting conditions and core designs. These events occur as a result of anticipated transients or normal operational maneuvers. All other instability events are considered unanticipated, including higher instability modes and limited core region participation (e.g., single channel oscillations). Unanticipated instability events occur as a result of unanticipated events or unplanned operator actions.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Protection against violating the SLMCPR for anticipated instability events is achieved solely by use of the CDA. No credit is taken for the other three algorithms that are provided as defense-in-depth protection against unanticipated oscillations.

Anticipated instability events are expected to gradually increase in amplitude and approach a limit cycle. The period of these oscillations becomes relatively constant (i.e., detectable) prior to the oscillation amplitude significantly exceeding the noise level, which allows early detection by the CDA. This is consistent with the observed behavior of actual plant instability events such as LaSalle-2 and Columbia and is consistent with the results of analytical simulations.

The licensing basis described in this report provides a high degree of confidence that power oscillations are terminated at relatively low amplitude by the DSS-CD solution, prior to any significant MCPR degradation, and therefore, obviates SLMCPR violations for anticipated instability events. Thus, the DSS-CD solution complies with GDC 10 and 12. The DSS-CD solution enhances overall plant safety by providing reliable, automatic oscillation detection and suppression function while avoiding unnecessary scrams.

3.0 SOLUTION DESCRIPTION

This section provides a description of the major aspects of the DSS-CD solution. Some elements of the solution common to LTS Option III are contained in References 1 and 2. Where there are common elements, the description provided in this document is applicable to the DSS-CD solution. The arrangement of LPRM detectors into OPRM cells is discussed in Reference 3, and is summarized herein. The CDA and defense-in-depth algorithms are described in this section along with their key setpoints.

3.1 SYSTEM FUNCTION

The DSS-CD solution consists of hardware and software designed to reliably detect and suppress stability related power oscillations. The principal inputs to the system are the signals from a large number of LPRM detectors via the OPRM cell grouping. The signals are filtered, processed, and evaluated for evidence of stability related oscillations. If sufficient evidence exists that the reactor is experiencing unstable operation, a reactor scram is initiated by the Reactor Protection System (RPS).

The key function of the system is to automatically suppress stability related power oscillations to provide a high confidence that the SLMCPR is not violated for anticipated oscillations.

The DSS-CD solution includes four separate algorithms for detecting stability related oscillations:

- Confirmation Density Algorithm (CDA),
- Period Based Detection Algorithm (PBDA),
- Amplitude Based Algorithm (ABA), and
- Growth Rate Algorithm (GRA).

All four algorithms perform calculations on each OPRM cell signal to determine if a trip is required. An illustration of the time of trip condition for each of these oscillation detection algorithms for a growing oscillation OPRM cell signal is depicted in Figure 3-1. The ability to

trip the reactor is automatically enabled at power and flow conditions potentially susceptible to power oscillations. The trip enabled region is termed the Armed Region.

The PBDA, ABA and GRA detection algorithms provide the protection basis for LTS Option III, (Reference 3). They are retained in DSS-CD as defense-in-depth algorithms and are not needed to ensure compliance with the SLMCPR. Therefore, they are not part of the licensing basis for the DSS-CD solution, which is accomplished solely by the CDA. The PBDA, ABA and GRA offer defense-in-depth by providing protection for unanticipated instability events.

3.2 SYSTEM INPUT AND LPRM ASSIGNMENT

The basic input unit of the DSS-CD system is the OPRM cell. Reference 3 specifies that the OPRM cell consists of 1 to 8 closely spaced LPRM detectors. The signals from the individual LPRM detectors in a cell are averaged to produce the OPRM cell signal. For the DSS-CD solution the maximum number of LPRM detectors per OPRM cell is limited to 4. This limitation is introduced consistent with the solution setpoint determination, discussed in Section 3.3.1.4, and existing Option III plant-specific implementation designs.

The cell signal is filtered to remove noise components with frequencies above the range of stability related power oscillations. This is accomplished by a second order Butterworth filter with a cutoff frequency of 1.0 Hz (referred to as the "conditioning" filter), or equivalent. The conditioned signal is filtered again using a second order Butterworth filter with a shorter cutoff frequency of 1/6 Hz, or equivalent, to produce a time-averaged value. The conditioned and time-averaged signals are used by the four algorithms to detect reactor instabilities.

The assignment of LPRM detectors to specific OPRM cells can affect the system's ability to detect an oscillation. For example, a large number of detectors in a cell tends to reduce sensitivity to an oscillation due to the averaging of signals that are slightly out of phase with each other. Conversely, analytical results show that single LPRM cells are the most sensitive. Most plants are expected to use two to four LPRMs per cell to balance OPRM cell responsiveness and spurious trip considerations. Examples of possible LPRM to OPRM cell assignments are shown in Appendix D of Reference 3. The DSS-CD solution does not add new requirements to the

LPRM to OPRM cell assignment other than the maximum limit of 4 LPRMs per OPRM cell constraint and the existing plant-specific cell assignments are acceptable.

Each OPRM cell is permanently assigned to an OPRM channel and a RPS trip channel (e.g., 1A, 2A, 1B, or 2B). If a trip condition is met for an OPRM channel, then the corresponding RPS channel trips. A reactor scram occurs when the necessary combination of channel trips occurs. The DSS-CD solution does not add new requirements to the RPS logic and the existing plant-specific RPS logic is acceptable. For example, Figure 3-2 illustrates "one-out-of-two-taken-twice" RPS logic, where a reactor trip occurs on any of the following channel trips:

1A & 2A,

1A & 2B,

1B & 2A, and

1B & 2B.

3.3 LICENSING BASIS DETECTION ALGORITHM

The CDA provides the licensing basis protection for the DSS-CD solution. The design of the licensing basis algorithm provides automatic action to limit the size of the oscillations of anticipated events, thereby preventing SLMCPR violation.

3.3.1 Confirmation Density Algorithm

The CDA generates a reactor trip signal upon sensing the threshold of coupled neutronic/thermal-hydraulic instability just above the OPRM signal noise level. By suppressing oscillations at the instability threshold, where the reactor response is becoming coherent but not yet resulted in the growth of power oscillations with significant amplitudes, reliance on complex modeling of reactor trip setpoints based on transient MCPR behavior is negated.

The CDA utilizes the Period Based Algorithm (PBA), which is designed to recognize periodic oscillatory behavior in LPRM or OPRM cell signals (referred to herein as OPRM cell signals). The PBA is that portion of the PBDA that is associated with oscillation period recognition. The PBA is described in Section 3.4.1. The PBA application in support of the CDA requires certain

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

modifications and restrictions relative to the Option III application. Those PBA modifications and restrictions are described in Section 3.4.1.1 and associated qualifications are described in Section 5.0. The PBA modifications and restrictions are applied for both the CDA and PBDA by the DSS-CD solution. In addition, the CDA employs a low amplitude OPRM signal discriminator to minimize unnecessary spurious reactor scrams for neutron flux oscillations at or close to the OPRM signal noise level.

The CDA identifies a Confirmation Density (CD), which is the fraction of operable OPRM cells in an OPRM channel that reach a target successive oscillation period confirmation count. When the CD exceeds a preset number of OPRM cells and when any of the confirming OPRM cell signals reaches or exceeds the amplitude discriminator setpoint, an OPRM channel trip signal is generated by the CDA. A reactor trip is generated when multiple channel trips are generated, consistent with the RPS logic design. By monitoring many OPRM cells for multiple successive oscillation period confirmations, the CDA can reliably and efficiently detect the transition to coherent core response, which is characteristic of a reactor at the threshold of instability.

In certain situations, periodic perturbations can be introduced into the thermal-hydraulic behavior of the reactor system (e.g., from control system feedback). These perturbations can potentially drive prolonged neutron flux oscillations within a frequency range expected for reactor instability. The presence of these oscillations is recognized by the CDA as reactor instability, independent of the actual stability of the reactor. Therefore, reactors that exhibit prolonged neutron flux oscillations that lie within the characteristic frequency range, but are not associated with coupled neutronic/thermal-hydraulic instability, are susceptible to spurious scrams from the CDA instability detection method. For reactors that exhibit these prolonged neutron flux oscillations at the OPRM signal noise level, SLMCPR protection can be reliably maintained without increased susceptibility to spurious scrams by inclusion of the CDA signal amplitude discriminator. In cases when the CDA signal amplitude discriminator cannot adequately address these prolonged neutron flux oscillations, the plant may be susceptible to spurious scrams. In these situations, a higher signal amplitude discriminator setpoint may be justified or the CDA may be substituted with a different system for detecting the approach to core instability.

Qualification of any alternatives or substitutes to the CDA is beyond the scope of the generic DSS-CD methodology, and requires application-specific resolution, review and approval.

3.3.1.1 Introduction

The power oscillation Confirmation Density concept is predicated on the thermal-hydraulic behavior of a reactor under three distinctly different stability regimes. These regimes are stable reactor states, reactor instability threshold, and unstable reactor states.

A stable reactor has weak neutronic and thermal-hydraulic coupling, and normally exhibits small, random deviations from the steady-state neutron flux conditions. The response of a stable reactor to global noise perturbations quickly becomes incoherent. Either the response rapidly decays to the background noise level due to the stable core conditions, or subsequent unrelated perturbations disturb the natural decay characteristics. This characteristic behavior of a stable reactor inhibits the generation of many successive oscillation period confirmations, permitting the PBA to discriminate a stable reactor response from an unstable response.

At the threshold of instability, the reactor behavior is characterized by increasing neutronic and thermal-hydraulic coupling. This results in a coherent reactor response to global noise perturbations that is observable throughout the core. This phenomenon of coherent response is independent of the oscillation mode that eventually characterizes each instability event. As the core approaches an unstable state, most OPRM cells detect a periodic oscillatory response. This qualitative change in core behavior at the instability threshold results in a non-linear increase in the successive confirmation count that the PBA identifies in OPRM signals. At the threshold of instability, many OPRM cells simultaneously display oscillatory behavior due to the increased core coupling.

As a result of anticipated instability precursors, the reactor does not instantaneously transition to large amplitude neutron flux oscillations that mark core response beyond the instability inception. The characteristics of a reactor at the threshold of instability exist for a sufficient time to allow the PBA to detect the threshold condition. Specifically, the fraction of operable OPRM cells that exhibit a well-developed oscillatory signature increases from zero, before the instability

threshold is reached, to a theoretical value of unity at the inception of instability. The PBA can therefore detect a significant number of successive period confirmations before the instability results in the growth in flux oscillation amplitude toward large, observable power oscillations that characterize an unstable reactor and threaten the SLMCPR.

These global characteristics of the coupled neutronic and thermal-hydraulic response to changes in core stability form the basis for the CDA methodology. Specifically, the CDA is able to recognize the instability threshold based upon the presence of multiple period confirmations from many OPRM cells. Following recognition of this condition, the CDA provides automatic protection of the fuel SLMCPR by generating a reactor trip signal prior to any significant growth in power oscillation amplitude.

The CDA methodology includes a low OPRM signal amplitude discriminator close to the typical OPRM cell signal noise levels. It avoids, however, the detailed characterization of MCPR performance as a function of growing power oscillations up to a high fixed amplitude setpoint, based on local neutron noise characteristics sensed by a few OPRM cells. As a result, the CDA methodology remains simple. In addition, the neutron noise based CD is expected to remain at zero until the reactor is at the instability threshold, at which time it rapidly approaches unity. This bi-stable behavior of the CDA eliminates the possibility of generating spurious trip signals for stable conditions based on the thermal-hydraulic behavior of the reactor.

3.3.1.2 Algorithm Basis

The CDA detects the presence of oscillatory behavior in the OPRM signal using the PBA. The PBA successive oscillation period confirmation count, for each OPRM cell exhibiting oscillatory behavior, increases in a highly non-linear manner at the instability threshold. In addition, the response of the core to global noise perturbations is observable over larger areas, causing many OPRM cells to exhibit oscillatory behavior.

Therefore, as the reactor decay ratio approaches unity, and the reactor reaches the instability threshold, both the successive confirmation counts of individual OPRM cells and the number of OPRM cells generating multiple successive confirmation counts grow in an accelerated manner.

A direct result of these qualitative changes in core response at the instability threshold is a non-linear increase in the fraction of OPRM cells reaching a target confirmation count, termed Successive Confirmation Count Threshold (N_{Th}). This fraction, which is the fraction of operable OPRM cells in an OPRM channel that exhibits an oscillatory response at or above N_{Th} , is defined to be the Confirmation Density (CD).

The theoretical relationship between CD and reactor Decay Ratio (DR) is illustrated in Figure 3-3. The shape of the relationship assumes that the PBA is perfectly able to discern the oscillatory behavior of all OPRM cells, regardless of the oscillation mode. However, even with a perfect PBA, the relationship between the CD and DR at the instability threshold is not exact. The reactor conditions, growth rate, and the PBA system parameters are examples of elements that may affect the specific shape of this relationship.

The precise shape of the instability threshold band does not affect the qualitative transition in the CD to DR relationship between the stable reactor, instability threshold, and instability inception conditions. Figure 3-3 demonstrates the utility of the CD approach to provide automatic protection of the fuel SLMCPR from reactor instability. During stable reactor operations, decay ratios are typically low ($DR < 0.4$), with occasional increases into the moderate range ($0.4 < DR < 0.7$). For these reactor conditions, individual OPRM cell confirmation counts are not likely to reach the successive confirmation count threshold, and therefore the CD remains practically at zero. However, as soon as the instability threshold is approached ($DR \approx 1.0$), the CD rapidly increases. This bi-stable characteristic of the CD, where the value remains at zero except at the instability threshold, when it rapidly transitions to unity, provides excellent discrimination between stable and unstable operations. As a result, the CDA avoids spurious trips, but can generate a reactor trip signal before oscillations develop significant magnitude.

Some of the operable OPRM cells may exhibit oscillation signatures incompatible with the PBA due to interference from neutron flux originating from areas of the core that are oscillating out-of-phase. This effect is particularly prominent near the axis of symmetry during first order regional mode oscillations. As a result, the maximum CD that is achievable in practice is less than one, as illustrated in Figure 3-4.

A CD setpoint (S_{CD}^j) is established for each OPRM channel, and defined to be the CD value for which a trip signal is generated. The setpoint is selected to ensure that an adequate number of OPRM cells exceed the successive confirmation count threshold, and that a sufficiently representative sample of OPRM cells is available for evaluation by the detection algorithm.

To minimize unnecessary spurious scrams not related to instability events, the CDA includes a low amplitude discriminator setpoint. Its purpose is to prevent a trip signal for situations when an oscillatory signature develops, which may be interpreted by the CDA as an instability event, but is occurring at a low amplitude and does not exhibit any significant amplitude growth. These situations may be associated with low amplitude, undeveloped instability events or reactor perturbation driven oscillations that are not related to coupled neutronic/thermal-hydraulic instability events. An Amplitude Discriminator state (AD_j) is established for each OPRM channel. An OPRM channel trip signal is generated when both the confirmation density and amplitude discriminator trip conditions are met.

3.3.1.3 Algorithm Description

An OPRM cell instability threshold flag, S_{Th}^i , is introduced to indicate the status of the successive confirmation count, N_i , of the i^{th} operable OPRM cell relative to the successive confirmation count threshold (N_{Th}). It is defined as:

$$S_{Th}^i = \begin{cases} 0 & N_i < N_{Th} \\ 1 & N_i \geq N_{Th} \end{cases}$$

Whenever the successive confirmation count, N_i , for the i^{th} OPRM cell is reset to zero, S_{Th}^i is also reset to zero.

The j^{th} OPRM channel confirmation density, CD_j , is the fraction of OPRM cells exhibiting successive confirmation counts that are at or above N_{Th} , and is expressed as:

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

[[]]

where M_{OP}^j is the number of operable OPRM cells in the j^{th} OPRM channel and M_{RS}^j is the number of responsive OPRM cells in the j^{th} OPRM channel.

A certain number of OPRM cells may become inoperable during the course of an operating cycle. The confirmation density is based on operable OPRM cells only. Therefore, inoperable OPRM cells are explicitly addressed by the CD setpoint definition.

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

An amplitude discriminator state, AD_j , is introduced to characterize the amplitude of all OPRM cells with confirmation count at or above N_{Th} (M_{CD}^j), corresponding to the j^{th} OPRM channel, relative to the amplitude discriminator setpoint (S_{AD}). It is defined as:

[[

]]

The reactor instability threshold is identified by each OPRM channel and the j^{th} channel trip signal is generated when both, the j^{th} channel CD setpoint, S_{CD}^j , is reached and the j^{th} channel amplitude discriminator state, AD_j , is enabled:

$$CD_j \geq S_{CD}^j \text{ and } AD_j = 1$$

A reactor trip signal is generated consistent with the plant specific RPS system trip logic, when the required multiple channels trip signals are generated.

An alarm setpoint is included to provide an early indication of reduced stability margin.

Table 3-1 summarizes the CDA process, setpoints and basis.

Implementation of the CDA requires the determination of the following setpoints:

- a. Confirmation Density Setpoint (S_{CD}),
- b. Successive Confirmation Count Threshold (N_{Th}),
- c. Amplitude Discriminator Setpoint (S_{AD}), and
- d. Alarm setpoint,

which are addressed in the subsequent sections.

3.3.1.4 Confirmation Density Setpoint Determination

In principle, the CDA uses the CD Setpoint (S_{CD}^j) to determine when the CD is equal to unity, which indicates the point of instability inception. In practice, however, the CD at the instability inception cannot be precisely predicted. Various factors such as oscillation mode and the relative efficiency of the PBA when applied to OPRM cells near the oscillation axis of symmetry, which is influenced by potential signal cancellation, effectively reduce the value of the CD at the instability inception to a value less than unity. An evaluation of OPRM cells participation during power oscillations is performed to establish the CD upper and lower bounds used to determine the CD setpoint.

Based on the CD model (Figure 3-4), instability threshold conditions exist for a finite time before instability inception occurs. The qualitative differences between stable reactor conditions and conditions at instability threshold are reflected in the strongly bi-stable behavior of the CD as a function of DR, and makes discrimination of the instability threshold straightforward. As a result, the CDA can protect the SLMCPR by appropriate selection of a reactor trip setpoint based on a conservative number of OPRM cells that are indicating instability threshold conditions, rather than attempting to precisely identify the condition of instability inception. Because of the availability of a large number of operable OPRM cells for use by the CDA, a bounding approach is taken to establishing an appropriate upper bound for the CDA trip setpoint.

The allowable CD setpoint upper bound (S_{CD}^{Max}) is given by:

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

$$S_{CD}^{Max} = (1 - E) \times F_{CD}^{Max}$$

E is defined to be the axial loss of PBA efficiency. The maximum response fraction, F_{CD}^{Max} , is defined to be the bounding maximum fraction of OPRM cells, ignoring axial PBA inefficiencies, that reaches N_{Th} at the point of instability inception. The values of E and F_{CD}^{Max} are selected to establish a permissible maximum value for the CD Setpoint. The actual setpoint must be selected at or below this value to ensure proper operation of the CDA.

The neutron mean free path in highly voided core regions is comparable to the spacing between adjacent LPRMs. Therefore, during regional mode oscillations LPRMs in the top of the core can exhibit oscillatory behavior that is caused by the superposition of neutron flux originating from areas of the core on both sides of the oscillation symmetry axis. This composite signal can cause poor performance of the PBA in discriminating successive confirmation counts. As a result, E is generically set to 0.25 for OPRM cells that consist of a single LPRM, corresponding to the conservative assumption that the PBA is completely unresponsive to the D level (highest in the core) LPRMs.

For OPRM cell configurations that have more than a single LPRM per OPRM cell, one or more of the cell's LPRMs is at a level different than D. For these configurations, many of the OPRM cells do not include D level LPRMs. For those that include D level LPRMs, the OPRM cell response is typically dominated by the lower level LPRMs because the D level LPRM relative power is typically low. To maintain consistency with the conservative treatment of the single LPRM OPRM cell, E is generically set to 0.25 for all OPRM cell configurations.

The value of F_{CD}^{Max} is dependent on the mode of the power oscillations present in the core. A regional mode oscillation is conservatively selected as the limiting anticipated core behavior with respect to the CDA performance. LPRMs near the axis of symmetry can detect oscillations that are completely out of phase with the local thermal-hydraulic response. This condition is incompatible with the requirements of the PBA to discern successive confirmation counts. The size of the affected core area is governed by the neutron mean free path. Selection of a corresponding no-response zone width equivalent to 3 mean free paths on each side of the axis of

symmetry provides approximately 95% attenuation of neutron flux from across the axis of symmetry, and bounds those LPRMs that may be affected by neutrons from the opposite oscillation phase. By conservatively using a small reactor design of 444 fuel assemblies, the maximum response fraction, F_{CD}^{Max} , for the assumptions described above is determined for OPRM cells with a single LPRM. Assuming an approximately even LPRM distribution in the core, a conservative estimate is established as:

$$F_{CD}^{Max} = 0.70 \text{ for single LPRM based OPRM cell}$$

For most OPRM cells with more than a single LPRM, the selection of three mean free paths on each side of the axis of symmetry is conservative because the radial distribution of the LPRMs belonging to an OPRM cell provides a wider coverage. To maintain consistency with the conservative treatment of the single LPRM OPRM cell, F_{CD}^{Max} is generically set to 0.70 for all OPRM cells configurations.

The value of S_{CD}^{Max} is now determined based on the conservative estimates of the E and F_{CD}^{Max} values for all OPRM cell configurations:

$$S_{CD}^{Max} = (1 - 0.25) \times 0.70$$

or,

$$S_{CD}^{Max} \approx 0.5$$

The process of establishing the above estimate for the CD setpoint upper bound is illustrated in Figure 3-5. This value places a permissible upper bound on the CD Setpoint, S_{CD}^j , that is consistent with the requirement that the CDA generate a trip signal prior to or at the inception of reactor instability.

The estimate of F_{CD}^{Max} was confirmed using a PANACEA predicted response for an example BWR first order harmonic. The first harmonic contour from the PANACEA case is shown in Figure 3-6. Inside each fuel rectangle is the axial flux distribution for the corresponding bundle.

The bottom of the core is on the left of each rectangle and the top of the core is on the right. The zero flux level is represented by a horizontal line through the center of the rectangle. In this case, first harmonic flux is positive in the lower left half and negative in the upper right half. Except for those fuel channels close to the harmonic axis, running from the northwest to southeast, the majority of the remaining fuel channels participate in the regional oscillations. The F_{CD}^{Max} value estimate based on the first harmonic contour is 0.8, which confirms the above estimate for all OPRM cell configurations.

A permissible minimum confirmation density setpoint, S_{CD}^{Min} , can also be established for S_{CD}^j . The minimum permissible value is not dictated by safety considerations. Instead, as S_{CD}^j decreases, the required number of OPRM cells reaching N_{Th} needed to generate a reactor trip signal becomes smaller. As a result, the CDA may become more sensitive to the characteristics of the instability threshold specific to a particular event and could potentially lead to a premature generation of reactor trip signals. To conservatively preclude this type of spurious actuation, a minimum number of OPRM cells are required to reach N_{Th} before the CDA generates RPS channel and reactor trip signals.

BWR experience to date has demonstrated that it is unlikely that the N_{Th} setpoint be exceeded for any OPRM cell during stable reactor operation in the Armed Region, where the system is armed. Moreover, for these conditions, it is not credible that multiple OPRM cells exceed the N_{Th} setpoint simultaneously. For certain OPRM cell configurations selected LPRMs may be grouped to 4 different OPRM cells. Therefore, a postulated dominating spurious LPRM oscillatory signature may affect the behavior of 4 different OPRM cells. To reduce the potential for spurious trip signals during stable reactor operation in the Armed Region, [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]]

For plants requiring at least two LPRMs to maintain OPRM operability, the possible reduction in the number of responsive OPRM cells by M_{DL}^j can be eliminated by implementing LPRM to

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

OPRM cell assignments that include no more than one D level LPRM in each OPRM cell. For these configurations, OPRM cells with exclusive input from D level LPRMs include only a single operable LPRM, and are therefore declared inoperable. Example LPRM to OPRM cell assignments are shown in Appendix D of Reference 3.

[[

]]

3.3.1.5 Successive Confirmation Count Threshold Determination

The CDA utilizes the successive confirmation count threshold (N_{Th}) to discriminate the stability characteristics of individual OPRM cell successive confirmation counts generated by the PBA. The choice of N_{Th} is based on two considerations.

[[

]] Because the reactor is not anticipated to instantaneously transition to unstable, growing power oscillations, this CDA response time provides adequate protection of fuel SLMCPR for anticipated instability events.

3.3.1.6 Amplitude Discriminator Setpoint Determination

The CDA utilizes the amplitude discriminator setpoint (S_{AD}) to prevent CDA-generated trip signals at the naturally occurring OPRM signal noise level. The choice of S_{AD} is based on two considerations.

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

3.3.1.7 Single Loop Operation

Application of the TLO CDA setpoints to SLO may result, under certain operating conditions, in excessive unnecessary spurious scrams. [[

3.3.1.8 Alarm Setpoint Determination

The CDA provides automatic indication of reductions in stability margin to alert the operator of possible approach to the instability threshold when operating inside the Armed Region. With an appropriately selected alarm setpoint, sufficient time for manual operator action may exist for transients that cause a gradual erosion of reactor stability margin from stable reactor operating conditions. This CDA alarm capability is provided in addition to the alarm being actuated upon entry into the Armed Region, which is designed to alert the operator that an entry into a region potentially susceptible to reactor instability had occurred.

The CDA alarm setpoint, N_{AI} , is selected on a plant-specific basis to ensure that no spurious alarms occur during stable plant operation. The alarm setpoint may be applied to the leading OPRM cell. The alarm occurs when the successive period confirmation count for any single OPRM cell (in any OPRM channel) reaches the CDA alarm setpoint. Alternatively, the alarm setpoint may be applied to the second confirming OPRM cell (i.e., provided a single OPRM cell exceeds N_{AI} , the alarm is generated when any additional OPRM cell in the same OPRM channel exceeds the selected alarm setpoint). The CDA alarm may be implemented with another means of stability monitoring (e.g., on-line stability predictor or monitor) to improve the capability to predict gradual changes in stability margin.

The selection of a specific alarm setpoint value and definition of the associated operator actions are operational considerations and depend on the plant-specific neutron flux noise characteristics and operational preferences and are not addressed in this report. Because the CDA alarm function has no effect on the system automatic protection capability, the choice of the plant specific alarm setpoint is optional and is not subject to any generic or plant specific requirements. Therefore, from a licensing perspective, any alarm option selection is acceptable.

The alarm function is not required during rated power operation outside the Armed Region, where the system is operable but not armed. If the alarm function is not continuously armed

during operations at core flow above the Armed Region, the alarm function is automatically armed upon entry into the Armed Region.

3.3.1.9 Generic Setpoints Application

[[

]]

3.4 DEFENSE IN DEPTH ALGORITHMS

The PBDA, ABA and GRA offer defense-in-depth by providing protection for unanticipated instability events. These algorithms are not required to provide licensing basis protection for the SLMCPR within the DSS-CD solution.

The design objective for the defense-in-depth algorithms is to provide automatic action to limit the size of the oscillations of unanticipated events, thereby preventing fuel cladding damage. As demonstrated in Reference 4, power oscillations up to 200% of rated power produce a temperature transient such that no cladding failure would be expected. The defense-in-depth detection algorithms offer a high degree of assurance that fuel failure does not occur as a consequence of unanticipated stability related oscillations.

Table 3-4 lists the DSS-CD defense-in-depth algorithm recommended setpoints. The choice of setpoints for the ABA and GRA is consistent with References 1 through 3. For the PBDA, nominal setpoint values are recommended on a generic basis. These setpoints would reasonably limit the size of unanticipated stability related power oscillations. They are selected to provide early protection without significantly increasing the likelihood of a spurious scram not related to instability events. The defense-in-depth trips with the specified setpoints provide backup protection greater than that provided by the Average Power Range Monitor (APRM) high flux scram, in particular for the regional mode of oscillations. No further analysis is required to justify these setpoints.

3.4.1 Period Based Detection Algorithm

The Period Based Detection Algorithm (PBDA) is described in References 1 and 2. The PBDA utilizes the observation that LPRM noise becomes progressively more coherent during the approach to the inception of an instability event, before the amplitude becomes large. The PBDA uses a combination of period confirmation count and amplitude setpoint to determine if a trip is required. The period confirmation count portion of the PBDA is referred to as the Period Based Algorithm (PBA). It constitutes the entire algorithm with the exception of the amplitude aspect.

According to Reference 1, the PBA focuses on the periodicity of the oscillation in the approximate range from 0.3 to 0.7 Hz, or the equivalent time period limits (T_{\min} and T_{\max}). T_{\min} and T_{\max} are conservatively selected to bound the anticipated instability frequency range. The algorithm interrogates the OPRM cell signal based on a short sample time (t_i). When the time difference between successive peaks (or successive minima) in an OPRM cell signal is consistent with the time period limits, this time difference is defined as the base period, T_0 . The next period (T_1) calculated between successive peaks (or minima) must be within a small time window, period tolerance ($\pm \epsilon$), of T_0 to produce a "confirmation" that oscillatory behavior exists. A new base period is defined as the average of all consecutively confirmed periods in that cell. Based on evaluation of plant data, as the decay ratio increases toward 1.0, the oscillation period becomes constant, resulting in many consecutive confirmations. If a successive period is not confirmed to be within the period tolerance of the base period, the period count is reset to zero

and the search for a new base period is initiated. The PBA period confirmation process is illustrated in Figure 3-9.

The PBDA is programmed to identify an instability based on the occurrence of a fixed number of consecutive period confirmations, which is considered evidence of a stability related power oscillation. A trip is generated for an OPRM cell (and hence for that RPS channel) if:

1. The number of successive period confirmations exceeds its setpoint value (N_p), and
2. The relative signal exceeds a specified amplitude setpoint, S_p .

The value of S_p is set sufficiently above the noise level to minimize the likelihood of an inadvertent scram. Consequently, the PBDA generates a trip when oscillatory behavior consistent with an instability exists and the peak-to-average cell signal has increased to the trip amplitude setpoint. This balances the probability that the system trips when needed to suppress an instability event and does not trip when it is not required.

For DSS-CD, the PBDA successive period confirmations setpoint, N_p , is selected above the CDA setpoint (i.e., 15). This setpoint is representative of the higher end of the range provided in Reference 3, Appendix E. This selection is made to further reduce the likelihood of a spurious scram by the PBDA, which is appropriate since the PBDA is a DSS-CD defense in depth algorithm that is not required to demonstrate SLMCPR protection. The PBDA amplitude setpoint, S_p , is selected at 1.1 consistent with the other defense-in-depth algorithms, to provide protection at the ABA and GRA amplitude detection threshold (S_1).

References 1 and 2 define two adjustable parameters that affect period confirmations, and are used to achieve proper plant-specific system calibration, the period tolerance (ϵ) and the conditioning filter cutoff frequency (f_c). Based on existing experience and to ensure adequate instability detection by the PBA, these parameters' values are fixed for DSS-CD applications, and are not subject to adjustment. The assigned values for these parameters have been demonstrated to provide continuous confirmations upon transition from stable reactor operation to a growing reactor instability. Specifying the parameters' values provides assurance that the PBDA provides sufficient confirmations for a growing reactor instability.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Based on testing of the algorithm against available plant data and DSS-CD specific considerations (see below), the acceptable parameter values are specified in Table 3-5. The conditioning filter cutoff frequency value is selected at 1 Hz to ensure efficient filtering of high frequency noise components, which is critical for proper PBA functioning during the development of reactor instability events. The conditioning filter cutoff frequency has been shown to have little effect on the PBA successive confirmation count during stable operation. The period tolerance value is selected at 100 msec to ensure adequate period confirmation during the development of reactor instability events, which is supported by existing instability event experience. This value, however, may result in increased PBA successive confirmation count during stable operation, which need to be considered in the selection of the CDA alarm setpoint.

The normalized OPRM signal processed by the PBA is constructed as the ratio of the filtered input signal to the OPRM signal average. Reference 2 specifies that a typical range for the time constant associated with the signal averaging process is 5 to 7 seconds. This range provides an appropriate signal average value for steady state or quasi steady state operation. However, the averaged signal may significantly lag the input signal during a fast transient, such as a significant flow reduction event from rated power operation. Because MELLLA+ operation may result in off-rated conditions that are inherently unstable following a flow reduction event, instability may develop during the time the averaged signal is lagging and the normalized signal is inappropriately low.

To address this concern, an averaging filter cutoff frequency of 1/6 Hz (or an equivalent time constant of 0.95 seconds) is used for DSS-CD, which substantially reduces the averaged signal lag (the transition band is reduced from close to 30 seconds to approximately 5 seconds). This cutoff frequency value provides less effective averaging process during steady state operations, resulting in low amplitude residual oscillations. However, because the cutoff frequency value is sufficiently low, the average signal exhibits only insignificant amplitude variations for the signal amplitude range up to the DSS-CD PBDA amplitude setpoint. A parametric study of the normalized signal performance with the 1/6 Hz filter cutoff frequency for the detection algorithm oscillation period range (from 0.8 second to 4.0 seconds) has demonstrated that the normalized signal values are always conservative (i.e., higher) during steady state operations. Therefore, the

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

use of the 1/6 Hz averaging cutoff frequency eliminates the concern of significant normalized signal lag following a fast flow reduction event, and ensures a conservative normalized signal value during oscillations relative to the DSS-CD PBDA amplitude setpoint.

3.4.1.1 PBA Application for CDA

A number of modifications and restrictions for the Option III PBA version (Reference 3) are required for the proper application of the PBA in the CDA. [[

]] These PBA modifications

and restrictions are also used for the PBDA, [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]]

Significant flow reduction events from power operation may result in operating conditions that are unstable. This is more likely for 2RPT events that initiate from the rated power and minimum flow conditions. Because the reactor state condition is rapidly changing during the 2RPT event, the ensuing oscillations are not developed instantaneously. The transition to a coherent oscillation mode involves the alignment of the entire core, which not only requires some limited duration but also may exhibit transitional effects. In particular, the oscillation frequency, and therefore, the detected period for individual channels may exhibit modulated behavior.

[[

]]

The time period limits specified in Table 3-4 conservatively envelop the range of characteristic periods anticipated for all DSS-CD applications addressed by this report. [[

]]

[[

]]

3.4.1.2 PBA Signal Sampling and Resolution for DSS-CD

The PBA evaluates a discrete representation of the OPRM cell input signal that depends on the signal sample rate. The signal sample rate is selected to ensure that signal periods, which fall within the specified algorithm frequency range, contain a large number of samples. Discretization of the input signal creates the possibility of shifts in the number of time step intervals associated with a single period. For an input signal with a constant period, variations of plus or minus one time step relative to the average number of time steps per period may occur. If the selected period tolerance value is equal to the sampling time step, occasional reset of the

Successive Confirmation Count (SCC) for a fully periodic signal may occur due to shifts in the time step count per period.

The base period is equal to a whole multiple of the sampling time step for each SCC. A single occurrence of a period with one less time step than the base period count reduces the base period by one time step. If the subsequent period contains one more time step than the original base period, the difference between the current period and the base period is more than one time step. As a result, the period tolerance criterion is violated when it is equal to the sampling time step and results in an erroneous SCC reset. A SCC reset also occurs with the reverse scenario, when the higher time step count per period is encountered prior to the lower count.

To ensure that a continuous SCC is generated for a periodic OPRM cell signal within the PBA range, the theoretical minimum period tolerance is related to the discretization of the OPRM cell signal by the following relationship:

$$\varepsilon = \text{Max} (\varepsilon_{\text{Input}}, 2 \times \text{Signal sampling time step})$$

where $\varepsilon_{\text{Input}}$ is the PBA period tolerance selection available and ε is the resultant period tolerance.

The DSS-CD solution design requires a criterion specifying the minimum acceptable resolution of the OPRM cell signal amplitude. Appropriate selection of this criterion ensures that under all anticipated reactor conditions approaching reactor instabilities the system is capable of performing its design functions, including the identification of successive signal minima and maxima and characterization of signal period.

Reactor two recirculation loop operations in regions of the operating domain susceptible to reactor instabilities are typically associated with a nominal peak-to-average OPRM noise amplitude of 1 to 2%. This amplitude is dependent on the specific reactor conditions and may vary from plant to plant. However, the peak-to-average range is characteristic of stable reactor operation. During the approach to reactor instabilities, peak-to-average amplitudes increase from those associated with stable reactor operation amplitudes.

To ensure the system is designed with an acceptable signal amplitude resolution, the criterion specifying the minimum acceptable resolution of the OPRM cell signal peak-to-average amplitude difference is set at 1% of scale. This value represents the lower bound of typically

observed peak-to-average amplitudes during stable reactor operation, and is conservative for conditions approaching reactor instabilities. Application of this criterion ensures that the system is capable of successfully identifying successive minima and maxima for periodic signals, with peak-to-average amplitude difference of 1% of scale or higher, for the full frequency range expected for reactor instabilities.

3.4.2 Amplitude Based Algorithm

The ABA is described in References 1 and 2. The value of the OPRM cell relative signal is compared at each detection time step to a threshold setpoint, S_1 (greater than 1.0). If the relative signal exceeds S_1 , then the algorithm checks to determine if the relative signal decreases to a second setpoint, S_2 (less than 1.0), within a time period typical of an instability oscillation. If the signal goes below S_2 in the expected time window (T_1), then the algorithm looks for the next peak in the relative signal. Then, if the relative signal exceeds the trip setpoint, S_{max} , in the expected time window (T_2), a trip is generated for that OPRM cell (and hence for that RPS channel). Recommended values for S_1 , S_2 , S_{max} , T_1 , and T_2 are given in Table 3-4.

3.4.3 Growth Rate Algorithm

The GRA is described in References 1 and 2. It examines OPRM cell signals for rapidly growing oscillations. As for the ABA, the value of the OPRM cell relative signal is compared at each detection time step to a threshold setpoint, S_1 (greater than 1.0). If the relative signal exceeds S_1 , then the algorithm checks to determine if the relative signal decreases to a second setpoint, S_2 (less than 1.0), within a time period typical of an instability oscillation. If the signal goes below S_2 in the expected time window (T_1), then the algorithm looks for the next peak in the relative signal. A trip signal is generated by the GRA if the setpoint S_3 is exceeded in the expected time window. S_3 is calculated from the peak of the previous cycle (P_1) and the desired maximum allowable growth rate (GR_3):

$$S_3 = GR_3 \times (P_1 - 1.0) + 1.0$$

If the signal goes above S_1 , then below S_2 in the expected time window, and then exceeds S_3 within the expected time window, a trip is generated for that OPRM cell (and hence for that RPS

channel). The GRA uses the same values for S_1 , S_2 , T_1 , and T_2 as the Amplitude Based Algorithm. Recommended values for S_1 , S_2 , GR_3 , T_1 and T_2 are given in Table 3-4.

3.5 SYSTEM OPERABILITY

To provide its specified stability protection function, the DSS-CD system is required to be operable in Mode 1 at all times and is automatically armed inside the solution Armed Region, as described in Section 4.5. Alternatively, the DSS-CD may be required to be operable above a power level set at 5% of rated power below the lower boundary of the Armed Region defined by the MCPR monitoring threshold power level. This alternative method is acceptable since system operability is assured prior to entry into the Armed Region.

For operation outside the Armed Region, the system is disarmed to reduce the probability of spurious scrams and alarms, but maintained operable at all times. If the system licensing basis protection is not assured, a supplemental backup, as specified in the plant Technical Specifications, is required. Example backup stability protection (BSP) approaches are described in Section 7.0. Other backup approaches that are justified to provide protection similar to the BSP may also be used. Backup protection is required when the DSS-CD is bypassed.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 3-1 Confirmation Density Algorithm Setpoints and Basis

Process Step	Algorithm	Definition and Setpoint	Basis and Notes
Determination of OPRM cell Instability Threshold Flag (S_{Th}^i) state	$S_{Th}^i = \begin{cases} 0 & N_i < N_{Th} \\ 1 & N_i \geq N_{Th} \end{cases}$	N_i = Successive confirmation count of the i^{th} OPRM cell N_{Th} = Successive Confirmation Count Threshold [[]]	- OPRM cells or single LPRMs may be used - S_{Th}^i is set to 1 at signal extremum only if the confirmation count is equal or above N_{Th} - S_{Th}^i is reset on count reset for the i^{th} OPRM cell - [[]]
Determination of j^{th} OPRM channel Confirmation Density (CD_j)	[[]]	M_{RS}^j = Number of responsive OPRM cells for j^{th} OPRM channel M_{OP}^j = Number of operable OPRM cells for j^{th} OPRM channel $M_{RS}^j = M_{OP}^j - M_{AX}^j - M_{DL}^j$	- Operable OPRM cells require at least 1 or 2 operable LPRMs [[]]
Determination of j^{th} OPRM channel amplitude discriminator state (AD_j)	[[]]	P_i^j = Last recorded peak of i^{th} OPRM cell normalized signal for j^{th} OPRM channel M_{CD}^j = Number of OPRM cells at or above N_{Th} for j^{th} OPRM channel S_{AD} = Amplitude discriminator setpoint [[]]	- [[]] -]]
Trip signal for j^{th} RPS channel by comparison with CD setpoint (S_{CD}^j) and AD state (AD_j)	$CD_j \geq S_{CD}^j$ AND $AD_j = 1$	S_{CD}^j = j^{th} channel CD setpoint [[]]	[[]]
NMS trip signal	System architecture	E.g., one-out-of-two, twice	- Adheres to NMS requirements of divisional separation and redundancy
NMS alarm signal	$N_i \geq N_{AI}$	N_{AI} = Successive confirmation alarm setpoint	- Early indication of reduced stability margin - Applied to leading or second OPRM cell - Determined based on plant specific performance

Table 3-2 444 Bundle Core OPRM Channel Operability and CD Setpoint Illustration

(OPRM Map assignment per Figure 3-7 and OPRM cell operability requirement of at least one operable LPRM)

[[

]]

Table 3-3 624 Bundle Core OPRM Channel Operability and CD Setpoint Illustration

(OPRM Map assignment per Figure 3-8 and OPRM cell operability requirement of at least two operable LPRMs)

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 3-4 Defense in Depth Algorithm Setpoints

Algorithm	Setpoint	Value
PBDA	N_p	15
PBDA	S_p	1.1
PBDA	T_{min}, T_{max}	[[]]
ABA, GRA	S_1	1.10
ABA, GRA	S_2	0.92
ABA	S_{max}	1.30
GRA	GR_3	1.30
ABA, GRA	T_1 (time window)	0.3 to 2.5 seconds
ABA, GRA	T_2 (time window)	0.3 to 2.5 seconds

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 3-5 PBA Parameters

Parameter	Value
ϵ - Period Tolerance (milliseconds)	100
f_c - Conditioning Filter Cutoff Frequency (Hz)	1.0

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 3-1 DSS-CD Detection Algorithms Time of Trip Condition Illustration

[[

]]

Figure 3-2 Example RPS Trip Logic




Figure 3-3 Theoretical Confirmation Density as a Function of Decay Ratio




Figure 3-4 Practical Confirmation Density as a Function of Decay Ratio





Figure 3-5 Core Volume Corresponding to CD Upper Bound



NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 3-6 PANACEA Contour for a Typical BWR First Order Harmonic




Figure 3-7 OPRM Channel Assignment Map for 444 Bundle Core




Figure 3-8 OPRM Channel Assignment Map for 624 Bundle Core





Figure 3-9 PBA Successive Period Confirmation Process



4.0 LICENSING BASIS

4.1 OVERVIEW

This section demonstrates on a generic basis that the DSS-CD system and its associated setpoints result in timely suppression of oscillations without violating the SLMCPR for anticipated instability events. A plant-specific confirmation assessment is performed whenever design changes beyond a specified generic applicability envelope are introduced that may affect stability performance and for each cycle to ensure that the generic DSS-CD basis remains valid for plant reload applications.

The presence of reactor instability can challenge the fuel SLMCPR. This occurs when fuel cladding heat flux and channel coolant flow rates deviate from steady state conditions during power oscillations significantly above the normal neutron noise level. To comply with GDC 12, protection of the SLMCPR can be accomplished by either detecting and suppressing instability induced power oscillations, or preventing them altogether.

The existing "detect and suppress" algorithms of LTS Option III (Reference 3) are based on a common approach. An OPRM cell signal oscillation, consistent with that characteristic of the reactor thermal-hydraulic oscillation frequencies, is identified. The presence of these characteristic power oscillations is then confirmed by various methods. The PBDA monitors successive oscillation periods and provides an oscillation amplitude trigger to generate a reactor trip signal. The GRA consists of an oscillation growth rate limit, which if exceeded, generates a reactor trip. Finally, the ABA consists of an oscillation amplitude limit, which if exceeded, generates a reactor trip.

The Option III licensing basis (Reference 3) relies on the PBDA, with setpoints based on a combination of power oscillation period confirmation counts and oscillation amplitude. These setpoints are designed to ensure that the SLMCPR is not violated by the presence of growing power oscillations resulting from anticipated instability events. Option III methodology reliance on a fixed amplitude setpoint, which is associated with the SLMCPR, requires quantification of

the MCPR performance as a function of power oscillation scenarios for the full spectrum of core designs and operating conditions.

The DSS-CD methodology is also based on identification and confirmation of power oscillation periods, characteristic of reactor instability. However, the confirmation process in this approach takes place at the threshold of reactor instability. By providing suppression at these conditions, the development of power oscillations that could challenge the SLMCPR is avoided. This early recognition function is performed by the Confirmation Density Algorithm (CDA), which identifies the unique features of instability threshold and generates a reactor trip before significant power oscillations and MCPR margin degradation develop.

4.2 APPROACH

The CDA and its associated setpoints are described in Section 3.3.1. The Confirmation Density (CD) and Amplitude Discriminator (AD) setpoints are used by the CDA to protect the SLMCPR from anticipated instability events. These anticipated events exhibit gradual reactor transition from a stable to an unstable configuration. The physical parameters in a reactor that are critical to the coupled thermal-hydraulic and neutronic stability characteristics require a finite time to realign following an anticipated transient that results in power oscillations.

At the instability threshold, although the decay ratio may constantly increase, the power oscillations do not experience a significant amplitude growth because the decay ratio is less than 1.0. Only when the decay ratio exceeds 1.0, following the instability inception, can the oscillation amplitude start to appreciably increase.

The CDA is designed to provide effective early protection of the fuel SLMCPR. No significant MCPR degradation is expected during the short duration between the initial oscillation recognition for the specified CD [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] As a result, power oscillations are not permitted to grow significantly above the background neutron noise level.

Significant margin to the SLMCPR is assured at the instability inception, which may be reached as a result of:

- a. Normal operational maneuvers, which maintain significant MCPR margin at off-rated conditions,
- b. Anticipated events from off-rated conditions, which are expected to be mild and retain substantial MCPR margin, or
- c. Anticipated flow reduction events from rated conditions, which are expected to result in a MCPR margin increase from the required margin at the initial rated conditions (i.e., Operating Limit Minimum Critical Power Ratio (OLMCPR)).

As stated above, the transition to fully developed instability is gradual. Therefore, the CDA protection precludes any significant MCPR margin degradation as a result of anticipated instability events. The SLMCPR is protected by generating a reactor scram before the core thermal-hydraulic conditions deviate significantly from steady state conditions. Based on BWR operational experience, the anticipated increase in background neutron noise level at the instability inception is no more than approximately a factor of 3 prior to reactor trip, and therefore has an insignificant effect on MCPR margin.

To confirm the MCPR performance of anticipated instability events, reasonably limiting, best-estimate event simulations are performed using the GE TRACG code for a specified range of operating conditions, selected GE BWR product lines, and anticipated oscillation modes. It must be emphasized that these TRACG event simulations are not used to determine the CDA setpoints, nor are they used to establish the SLMCPR. Their sole purpose is to confirm the inherent MCPR margin afforded by the CDA design. Method qualifications and uncertainty treatment are addressed in Section 5.0.

4.3 GENERIC APPLICABILITY ENVELOPE

The confirmation process of MCPR performance afforded by the DSS-CD for anticipated instability events is established on a generic basis. To this end, a set of key parameters is identified and a range established to define a generic applicability envelope. Future plant-specific designs, which are bounded by the generic applicability envelope, are confirmed based on the generic basis documented in this report. If any of the key parameters is outside of the generic applicability envelope for plant-specific application, additional justification may be required, as described in Section 6.0. This section addresses TLO considerations. SLO is addressed in Section 4.4.2.

[[

]]

The specified range established for each of these parameters is summarized in Table 4-1. The plant specific review process, confirming the continued applicability of the DSS-CD generic applicability envelope, is documented in Section 6.0. The analyses documented in this report,

demonstrating the MCPR performance on a generic basis for anticipated core wide and regional mode oscillations, address the specified range of the generic applicability envelope key parameters.

[[

]]

4.4 SLMCPR PROTECTION CONFIRMATION

The SLMCPR protection confirmation is based on anticipated instability events, which are defined to include core wide and regional modes oscillations with full core participation at reasonably limiting conditions and core designs. These events are initiated as a result of anticipated transients or normal operational maneuvers. All other instability events are considered unanticipated events. They do not require SLMCPR protection and are addressed by

the defense-in-depth solution features of DSS-CD. Consistent with the DSS-CD generic confirmation envelope, reasonably limiting events are selected and simulated by TRACG to quantify their effect on the margin to SLMCPR. A generic DSS-CD procedure specifying bounding CPR uncertainty is established and used to confirm that the margin to the SLMCPR for the reasonably limiting best-estimate events is adequate. Section 4.4.1 addresses TLO considerations and Section 4.4.2 addresses SLO.

The purpose of the confirmation analysis event matrix is to evaluate the licensing basis generic applicability envelope (Table 4-1) and any future changes outside this envelope. The events to be considered are identified in the matrices associated with TLO (Table 4-2) and SLO (Table 4-7).

4.4.1 Two Loop Operation

The TLO limiting events, selected to confirm that the SLMCPR is protected by the DSS-CD design, are established based on a review of all potential anticipated instability event initiators. Anticipated instability events may be initiated as a result of:

- a. Normal operational maneuvers,
- b. Anticipated events from off-rated operating conditions, or
- c. Anticipated flow reduction events from rated conditions.

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]]

4.4.1.1 Event Simulation

[[

]]

The simulation results in the following section are used to assess the MCPR response and margin to the SLMCPR. The transient responses of key simulation parameters, including core power and flow, core inlet subcooling, hot channel power, hot channel flow, leading OPRM cell normalized signal and CPR, are presented in [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] The event suppression occurs prior to any significant amplitude growth and CPR degradation, as discussed in the next section.

4.4.1.2 MCPR Performance

The margin to the SLMCPR for each of the TRACG simulated events is calculated by applying the DSS-CD evaluation methodology to the event MCPR results. The evaluation methodology and the event specific MCPR margin results are discussed in the following subsections.

Evaluation Methodology

The DSS-CD evaluation methodology establishes the time sequence from the oscillation detection through suppression, and determines the SLMCPR margin from the TRACG generated MCPR results. The TRACG simulations represent best-estimate calculations for reasonably limiting instability scenarios. A CSAU assessment is provided in Section 5.0.

The DSS-CD evaluation methodology represents a significant simplification from the Option III licensing methodology. [[

]]

The elimination of these elements is possible because of the:

- a. Early detection and suppression of oscillations afforded by the CDA,
- b. Elimination of determining the amplitude setpoint directly based on SLMCPR protection (i.e., the final MCPR is equal or just above the SLMCPR) in the licensing basis detection algorithm, and
- c. Use of TRACG to simulate the full instability scenario, from the steady state initial condition to the instability suppression.

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]]

Best Estimate MCPR Margin

The DSS-CD evaluation methodology has been applied to the cases specified in the confirmation analysis event matrix (Table 4-2). Table 4-4 summarizes the nominal MCPR performance and margins to the SLMCPR for these cases. [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

2
1
2

|

]]

For all cases in Table 4-4, adequate margin to the SLMCPR is maintained. [[

]] and therefore
confirms on a generic basis the CDA early detection capability and the CDA setpoints selection.

MCPR Uncertainty Assessment

The Code Scaling Applicability and Uncertainty (CSAU) bounding approach described in
Section 5.2 was applied to the [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] the CSAU bounding approach resulted, as expected, in a significant decrease in
CPR margin.

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

|

]] For each of these cases the final MCPR, including the DSS-CD procedure component uncertainties, and the resulting SLMCPR margin are summarized in Table 4-5. For all cases, adequate margin exists, confirming the DSS-CD protection approach and setpoint selection. [[

]]

4.4.2 Single Loop Operation

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] The event suppression occurs prior to any significant amplitude growth and CPR degradation.

The margin to the SLMCPR for the TRACG SLO simulated event is calculated by applying the DSS-CD evaluation methodology to the event MCPR results similar to the TLO process. [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] and therefore confirms on a generic basis the CDA early detection capability and the CDA setpoints selection for SLO.

[[

]] The final MCPR, including the DSS-CD procedure component uncertainties, and the resulting SLMCPR margin are summarized in Table 4-10, demonstrating adequate margin and confirming the DSS-CD protection approach and setpoint selection for SLO.

[[

]]

4.5 SOLUTION ARMED REGION

The DSS-CD solution is designed to reliably and readily detect and suppress both core wide and regional mode oscillations prior to violating the SLMCPR for anticipated oscillations. The ability to trip the reactor and generate system alarm is automatically enabled at power and flow conditions potentially susceptible to power oscillation. The trip-enabled region is termed the Armed Region. For DSS-CD, the Armed Region boundaries are specified on a generic basis to envelop power and flow conditions potentially susceptible to power oscillation.

The trip and alarm functions are automatically enabled below a specified flow level and above a specified core power level. The DSS-CD Armed Region is illustrated in Figure 4-46. The specified flow level is designed to disarm the trip and alarm functions during rated power operations. Because power oscillations are not expected at rated power operations and the

reactor is operated at these conditions most of the time, disarming the trip and alarm functions reduces the probability of unnecessary spurious scrams. In addition, the specified flow level is designed to arm the trip and alarm functions at a flow level that bounds the core conditions potentially susceptible to power oscillation.

To accomplish these goals, the flow level is set just below the minimum flow associated with rated power operation. The flow boundary of the Armed Region is generically specified as 75% of rated recirculation drive flow for plants licensed for MELLLA+ operations and 70% of rated recirculation drive flow for plants not licensed for MELLLA+ operations. The flow signal used to implement the Armed Region is the relative recirculation drive flow. The relative recirculation drive flow at the 100% core power and 100% core flow statepoint is defined as the rated recirculation drive flow. Because the relationship between the core flow and recirculation drive flow has a weak dependence on core power, small variation in the Armed Region flow boundary in terms of core flow may be observed during operation as a function of the core power level (or load line). However, this is acceptable because the resulting effect of slight variation in the Armed Region boundary in terms of core flow has a negligible effect on stability margin based on the low decay ratios around the Armed Region boundary as demonstrated in Table 4-12.

The specified power level is designed to arm the trip and alarm functions at a power level that bounds the core conditions potentially susceptible to anticipated power oscillations. This power level is selected generically at the MCPR monitoring threshold of 25% Original Licensed Thermal Power (OLTP). For a power-uprated plant, the MCPR monitoring threshold may have been scaled to a lower percent value. This scaled value defines the Armed Region boundary in this situation. Instabilities are not expected to occur below 30% OLTP. In the unlikely event of significant stability margin degradation at this power level, the loss of margin is gradual, allowing for early detection by the system. In addition, below the MCPR monitoring threshold, an instability event would not be expected to grow large enough to threaten the SLMCPR. This expectation is due, in part, to the large MCPR margin that exists at low power operation.

To demonstrate that the generic Armed Region boundaries are associated with stable core conditions, ODYSY (Reference 6) calculations were performed for reasonably limiting

conditions on the boundaries of example BWR/4 and BWR/6 plants for both MELLLA+ and pre-MELLLA+ operating domains. Table 4-12 summarizes the state point conditions and calculated decay ratio results. [[

]] As expected, both channel and core decay ratios are low, indicating weak susceptibility to both core wide and regional oscillations at or near the Armed Region boundaries.

4.6 APPLICATION TO NON-GE FUEL DESIGN

The fuel design range of applicability of this report is specified in Tables 4-1 and 4-6. Fuel designs not covered in this report, including non-GE fuel, are addressed as outlined in Section 6.0. This report methodology, or equivalent NRC approved methodology, will be used to confirm adequate MCPR performance of the new fuel design. Application of this report MCPR confirmation methodology to existing non-GE fuel design is expected to result in confirmation of adequate MCPR margins because of the fuel design thermal-hydraulic compatibility and the robustness of the DSS-CD solution.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-1 TLO DSS-CD Licensing Basis Generic Applicability Envelope

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-2 TLO TRACG Confirmation Analysis Event Matrix

[[

|

]]

[[

11

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-4 TLO Nominal TRACG Confirmation Analysis MCPR Performance

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-5 TLO DSS-CD Bounding TRACG MCPR Margin

[[

]]

[[

11

Table 4-7 SLO TRACG Confirmation Analysis Event Matrix

[[

11

1. 1. The first part of the report is a general introduction to the project.
2. 2. The second part of the report is a detailed description of the methodology used.
3. 3. The third part of the report is a discussion of the results of the study.
4. 4. The fourth part of the report is a conclusion and recommendations.
5. 5. The fifth part of the report is a list of references.

Table 4-8 SLO DSS-CD Evaluation Methodology Summary

[[

]]

Table 4-9 SLO Nominal TRACG Confirmation Analysis MCPR Performance

[[

]]

Table 4-10 SLO DSS-CD Bounding TRACG MCPR Margin

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-11 Trip Times for TRACG Confirmation Analysis

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 4-12 ODYSY Confirmation of the Armed Region Boundaries

[[

11

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-1 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-2 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-3 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-4 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-5 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-6 [[

1. The purpose of this document is to provide a clear and concise description of the system architecture and its components. This document is intended for use by system administrators and developers who are responsible for the maintenance and operation of the system.

2. The system architecture is designed to be modular and scalable, allowing for the addition of new components and the removal of existing ones without affecting the overall system functionality. The architecture is based on a client-server model, where clients request services from the server and the server responds with the requested data or service.

3. The system architecture is designed to be secure and reliable, ensuring that data is protected and the system is available at all times. The architecture includes a number of security features, such as authentication, authorization, and encryption, to protect the system from unauthorized access and data loss.

4. The system architecture is designed to be easy to use and maintain, allowing system administrators to manage the system with minimal effort. The architecture includes a number of management tools and interfaces that make it easy to configure, monitor, and troubleshoot the system.

5. The system architecture is designed to be flexible and adaptable, allowing it to be used in a variety of environments and for a variety of applications. The architecture is designed to be able to handle a wide range of data and to support a variety of different types of users and applications.

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-7 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-8 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-9 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-10 [[

11

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-11 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-12 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-13 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-14 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-15 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-16 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-17 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-18 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-19 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-20 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-21 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-22 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-23 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-24 [[

THE FOLLOWING INFORMATION IS FOR INFORMATIONAL PURPOSES ONLY.
IT IS NOT TO BE USED AS A BASIS FOR DESIGN OR CONSTRUCTION.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.
THE INFORMATION IS NOT TO BE USED FOR ANY OTHER PURPOSE.

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-25 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-26 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-27 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-28 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-29 [[

]]


NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-30 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-31 [[



]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-32 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-33 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-34 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-35 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-36 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-37 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-38 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-39 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-40 [[

]]


NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-41 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-42 [[



]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-43 [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-44 [[

]]


NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 4-45 [[

Figure 4-45 is a schematic diagram of the NEDO-33075 system. It shows the interconnections between the various components of the system, including the power supply, the control unit, and the output devices. The diagram is a block diagram, with each component represented by a block and the connections between them shown as lines. The components are labeled with their respective part numbers and names. The diagram is a schematic representation of the system's architecture.

]]

Figure 4-46 DSS-CD Armed Region Illustration
(100% EPU = 120% OLTP)



Note: The Armed Region flow boundary is defined and implemented by the recirculation drive flow and is shown as an approximate vertical line as a function of core flow for illustration purposes only.

5.0 SOLUTION QUALIFICATIONS AND UNCERTAINTIES

5.1 TRACG APPLICATION

The TRACG code is used to simulate [[]] events to confirm the DSS-CD solution early oscillation detection and suppression capability. The TRACG event simulations are not used to establish the DSS-CD CDA design or setpoints. The purpose of the TRACG qualification review is to provide background for the code limited use in support of the DSS-CD application.

5.1.1 TRACG Qualifications

TRACG is a GE proprietary version of the Transient Reactor Analysis Code (TRAC). TRACG uses advanced best-estimate one-dimensional and three-dimensional methods to model the phenomena that are important in evaluating the operation of BWRs. Best-estimate analyses performed with TRACG have been approved by the NRC to support licensing applications in different areas, including specific thermal-hydraulic instability performance and Anticipated Operational Occurrence (AOO) transients.

TRAC was originally developed for pressurized water reactor (PWR) analysis by Los Alamos National Laboratory, the first PWR version of TRAC being TRAC-P1A. The development of the BWR version of TRAC started in 1979 in close cooperation between GE and Idaho National Engineering Laboratory. The objective of this cooperation was the development of a version of TRAC capable of simulating BWR LOCAs. The main tasks consisted of improving the basic models in TRAC for BWR applications and in developing models for specific BWR phenomena and components.

GE continued to develop TRACG to upgrade the capabilities of the code to include stability, transient, and anticipated transients without scram (ATWS) applications. During this phase, major developments included the implementation of the three-dimensional kinetics model and an implicit integration scheme. Modeling of the BWR fuel bundle was also improved.

TRACG includes a multi-dimensional, two-fluid model for the reactor thermal-hydraulics and a three-dimensional reactor kinetics model. The models can be used to simulate a large variety of

test and reactor configurations. These features allow for detailed, best-estimate simulation of a wide range of BWR phenomena, and are described in detail in the TRACG Model Description Licensing Topical Report (Reference 8).

TRACG has been extensively qualified against separate effects tests, component performance data, integral system effects tests and full-scale BWR plant data. The details are presented in the TRACG Qualification Licensing Topical Report (Reference 9).

5.1.2 Application Approach

This section demonstrates the acceptable use of TRACG analysis results for licensing BWR/3-6 power plants to support the DSS-CD licensing basis. GE has provided information to support the use of TRACG as an extension to the previously approved method of analyzing BWR stability and demonstrating compliance with licensing limits (References 1 and 2). Stability events are analyzed to establish the reactor system response, including the calculation of the CPR. This report addresses TRACG capabilities to confirm that acceptable fuel design limits are not exceeded during specified stability event.

The originally approved TRACG stability application for Option III (Reference 3) evaluated the CPR response versus the hot channel oscillation magnitude based on conservative pre-oscillation initial conditions. The event was assumed to initiate at off-rated equilibrium feedwater temperature, resulting in a fast oscillatory growth. The TRACG application for DSS-CD

[[
]]

This section describes the quantification of key parameter uncertainties, as applied to the TRACG instability event simulations. The analysis of these instability events accounts for the uncertainties and biases in the models and plant parameters, using a bounding approach. The uncertainties and biases considered include:

- Model uncertainties,
- Experimental uncertainties and uncertainties related to test scaleup, and
- Plant parameter uncertainties.

The overall analysis approach is consistent with the Code Scaling, Applicability and Uncertainty (CSAU) analysis methodology (Reference 10) and Regulatory Guide 1.157 (Reference 11), and addresses all the elements of the NRC-developed CSAU evaluation methodology. In the CSAU process, the model uncertainty is derived from the propagation of individual model uncertainties through code calculations, and experimental comparisons are used as a check on the derived uncertainty. The detailed demonstration of the CSAU analysis methodology for DSS-CD is addressed in Section 5.2.

5.1.3 Advantages of TRACG Use for Stability Evaluations

TRACG use for stability analyses includes the following advantages:

- [[
]] TRACG is not only capable of simulating core response, but also determining the response of individual (including limiting) channels, including transient critical power response.
- With its 3-D kinetics model, TRACG is capable of simulating the complex thermal-hydraulic and neutronic interactions of the core. The nuclear model is consistent with the PANACEA 3-D steady-state simulator (Reference 12), which is constantly being benchmarked against steady-state nuclear data.
- TRACG calculates the CPR directly.

5.1.4 Conformance with CSAU Methodology

The CSAU demonstration application to TRACG BWR stability analysis addresses all the elements of the NRC-developed CSAU evaluation methodology. The CSAU approach is a rigorous process for evaluating the total model and plant parameter uncertainty for nuclear power plant calculations. The process for applying best-estimate codes and quantifying the overall model and plant parameter uncertainties represents the best available practice. While the CSAU methodology was developed for application to LOCA scenarios, there are no technical reasons that prevent CSAU methodology from being applied to other event scenarios, such as stability.

The CSAU methodology consists of 14 steps, as outlined in Table 5-1, which summarizes how these steps are addressed for the DSS-CD demonstration.

5.2 CSAU METHODOLOGY APPLICATION

This section presents the CSAU methodology demonstration for DSS-CD. [[

]] and documented in Section 4.4.3. The demonstration of the CSAU methodology documented in this section is limited to the DSS-CD solution.

Each of the 14 steps of the CSAU methodology application to the DSS-CD demonstration is discussed below.

1. Stability Scenario Specification

The stability scenarios are those associated with anticipated stability events in BWR/3-6 type plants. [[

]]

2. Nuclear Power Plant Selection

The DSS-CD is applicable to BWR/3-6 plant product lines.

3. Phenomena Identification and Ranking

The critical safety parameter for stability events is the MCPR. The MCPR value is determined by the governing physical phenomena. The phenomena identification and ranking table (PIRT) is used to delineate the important physical phenomena. PIRTs are ranked with respect to their impact on the critical safety parameters. For example, the MCPR is determined by the reactor short-term response to stability events. The coupled core neutronic and thermal-hydraulic characteristics govern the neutron flux, reactor pressure, and core flow in a stability transient.

All processes and phenomena that occur during a transient do not equally influence plant behavior. Disposition analysis is used to reduce all candidate phenomena to a manageable set by identifying and ranking the phenomena with respect to their influence on the critical safety parameters. The phases of the events and the important components are investigated. The processes and phenomena associated with each component are examined. Cause and effect are differentiated. After the processes and phenomena have been identified, they are ranked with respect to their effect on the critical safety parameters for the event.

PIRTs are developed with only the importance of the phenomena in mind and are independent of whether or not the model is capable of handling the phenomena and whether or not the model shows a strong sensitivity to the phenomena. For example, two phenomena may be of high importance yet may tend to cancel each other so that there is little sensitivity to either phenomenon. Both phenomena are of high importance because the balance between these competing phenomena is important.

Table 5-2 was developed to identify the phenomena that govern BWR/3-6 stability responses, and represents a consensus of GE expert opinions. The stability transient events have been categorized into three distinct groups:

- Channel thermal-hydraulic instability,
- Core-wide instability, and
- Regional instability.

For each event type, the phenomena are listed and ranked for each major component in the reactor system. The ranking of the phenomena is done on a scale of high importance to low importance or not applicable, as defined by the following categories:

- **High importance (H):** These phenomena have a significant impact on the primary safety parameters and should be included in the overall uncertainty evaluation.
- **Medium importance (M):** These phenomena have insignificant impact on the primary safety parameters and may be excluded in the overall uncertainty evaluation.
- **Low importance (L) or not applicable (NA):** These phenomena have no impact on the primary safety parameters and need not be considered in the overall uncertainty evaluation.

The PIRT serves a number of purposes. First, the phenomena are identified and compared to the modeling capability of the code to assess whether the code has the necessary models to simulate the phenomena. Second, the identified phenomena are cross-referenced to the qualification basis to determine what qualification data are available to assess and qualify the code models and to determine whether additional qualification is needed. As part of this assessment, the range of the PIRT phenomena covered in the tests is compared with the corresponding range for the intended application to establish that the code has been qualified for the highly ranked phenomena over the appropriate range.

Table 5-2 also tabulates a number of derived parameters (e.g. ratio of core power to core flow) important to reactor instability.

Using the PIRT table ranking results, the uncertainties for the highly ranked PIRT phenomena are established and evaluated based on a bounding analysis to arrive at the total model uncertainty.

4. Frozen Code Version Selection

A frozen code version (TRACG02A) has been used in this evaluation.

5. Code Documentation

The TRACG program is a controlled Engineering Computer Program (ECP), and therefore, the documentation provided to the users is also maintained in a controlled manner. References 7 and 8 document both the TRACG licensing basis and application methodology.

6. Determination of Code Applicability

This section demonstrates the applicability of TRACG for the analysis of anticipated instability events in BWRs. The capability of the TRACG models to treat the highly ranked phenomena and the qualification assessment of the TRACG code for stability applications is examined.

The capability to simulate an event for a nuclear power plant depends on four elements:

- Conservation equations, which provide the code capability to address global processes,
- Correlations and models, which provide the code capability to model and scale particular processes,
- Numerics, which provide the code capability to perform efficient and reliable calculations, and
- Structure and nodalization, which address the code capability to model plant geometry and perform efficient and accurate calculations.

Consequently, these four elements must be considered when evaluating the applicability of the code to the event of interest for the nuclear power plant calculation. The key phenomena for each event are identified in generating the PIRTs for the intended application. The capability of the code to simulate the key phenomena for stability applications is addressed, documented, and supported by the code qualification in Reference 7. The difference between the (H) ranked PIRTs of Table 5-2 and those of Reference 7 are the inclusion of:

[[

]]

[[

]] The derived core stability parameters are combinations of parameters considered elsewhere in the bounding treatment. Therefore the difference between the PIRT ranking of Reference 7 and Table 5-2 is not significant and the assessment and qualification matrices of Reference 7 are applicable for this CSAU evaluation.

7. Establishment of Assessment Matrix

The qualification assessment of the TRACG models is summarized in Reference 7. The models have been identified so that they may be easily correlated to the model description and qualification reports. For each model, the relevant elements from the Model Description LTR (Reference 8) and the Qualification LTR (Reference 9) are identified.

For the governing BWR phenomena, TRACG qualifications have been performed against a wide range of data, including instability data. The list of phenomena is cross-referenced to the model capabilities in Table 4-1 of Reference 7. Similarly, as shown in Table 4-2 of Reference 7, the complete list of phenomena is cross-referenced to the qualification assessment basis. Data from separate effects tests, component tests, integral system tests and plant tests, as well as plant data have been used to qualify the capability of TRACG to model the phenomena.

8. Nuclear Power Plant Nodalization Definition

The nodalization strategy for the various reactor components was developed from the qualification of TRACG against test data for these components. The same consistent nodalization strategy was then applied for full-scale plant calculations. The adequacy of the nodalization has been demonstrated and supported by sensitivity studies. Standard nodalization

for modeling of BWR reactor vessels and other components have been presented in the TRACG Qualification LTR (Reference 9).

Specific nodalization and additional details for the nodalization for some components may be critical for specific applications. [[

]] This is based on a nodalization study that examines the minimum number of fuel channels required to adequately model the CPR response for a regional mode oscillation.

9. Definition of Code and Experimental Accuracy

The code definition and experimental accuracy has been addressed in Reference 9. The TRACG code has been qualified against the LaSalle-2 instability event (March 1988), the Leibstadt Cycle 1 regional instability tests, the Forsmark-1 stability tests (January 1989), and the Cofrentes Cycle 6 instability event (January 1991). The overall TRACG prediction agrees well with the experimental data.

10. Determination of Effect of Scale

Effects of scale have been addressed as part of the model development as well as the qualification. In the TRACG model description report (Reference 8), the applicability of the basic models and correlations are stated and shown to cover the scale and operating range of BWRs. The qualification of TRACG (Reference 9) covers separate effects tests, scaled as well as full-scale component performance tests, scaled integral system effects tests, and full-scale BWR plant tests. The qualification shows that data from scaled test facilities and full-scale plants are both well predicted. There is no apparent effect of scale in TRACG. In addition, demonstrations of the application methodology for TRACG have shown that full-scale plant data are bounded, when the effect of the model uncertainties are accounted for. Because these model uncertainties have primarily been determined from scaled experiments, this again demonstrates that there is no significant impact of scale on TRACG.

11. Determination of the Effect of Reactor Input Parameters and State

Overall model biases and uncertainties for the stability application are assessed for each high ranked phenomena by using a combination of comparisons of calculated results to: (1) separate effects test facility data, (2) integral test facility test data, (3) component qualification test data and (4) BWR plant data. Where data is not available, cross-code comparisons or engineering judgment are used to obtain approximations for the biases and uncertainties. For some phenomena that have little impact on the calculated results, it is appropriate to simply use a nominal value or to conservatively estimate the bias and uncertainty.

The phenomena for BWR stability have already been identified and ranked, as indicated in Step 3 above.

Code inputs can be divided into four broad categories: (1) geometry inputs, (2) model selection inputs, (3) initial condition inputs, and (4) plant parameters. For each type of input, it is necessary to specify the value for the input. If the calculated result is sensitive to the input value, then it is also necessary to quantify the uncertainty in the input.

The geometry inputs specify lengths, areas and volumes. Uncertainties in these quantities are due to measurement uncertainties and manufacturing tolerances. These uncertainties usually have a much smaller impact on the results than do uncertainties associated with the modeling simplifications.

Individual geometric inputs are the building blocks for the spatial nodalization. The spatial nodalization includes modeling simplifications such as the lumping together of individual elements into a single model component. For example, several similar fuel channels may be lumped together and simulated as one fuel channel group. An assessment of these kinds of simplifications, along with the sensitivities to spatial nodalization, is included in the TRACG Qualification LTR (Reference 9).

Inputs are used to select the features of the model that apply for the intended application. Once established, these inputs are fully specified in the procedure for the application and do not change.

A plant parameter is defined as a plant-specific quantity such as a protection system scram characteristic, etc. Plant parameters influence the characteristics of the transient response and have essentially no impact on steady-state operation.

Initial conditions are those conditions that define a steady-state operating condition. Initial conditions may vary due to the allowable operating range or due to uncertainty in the measurement at a give operating condition. The plant Technical Specifications and Operating Procedures provide the means by which controls are instituted and the allowable initial conditions are defined. At a given operating condition, the plant's measurement system has inaccuracies that also must be accounted for as an uncertainty.

Table 5-3 identifies items that have been recognized as having an impact on the critical safety parameter for stability application. These items are represented in the table by ID, description, ranking (H for High), and bias and deviation information. Table 5-4 lists the key plant initial conditions/parameters that are high ranked for the stability application. For the high ranked phenomena, the bases used to establish the nominal value, bias and uncertainty for that parameter are documented.

12. Performance of Nuclear Power Plant Sensitivity Calculations

Two plant types (BWR/3-5 and BWR/6) with different limiting operating conditions are evaluated for the stability application. [[

]]

13. Determination of Combined Bias and Uncertainty

[[

]]

14. Determination of Total Uncertainty

A commonly used approach in traditional conservative analyses is combining the uncertainties linearly, by applying bounding models for the phenomena and by setting plant parameters to values expected to produce the most limiting plant response. [[

]] Separate calculations were performed to characterize the effect of each response parameter important for stability in order to define the appropriate uncertainty range. The total uncertainty treatment is based on reasonably limiting initial conditions and model uncertainties identified in the previous CSAU steps.

The advantage of this approach is that it requires no more than one computer run for each output parameter of interest. The most significant disadvantage of this method is that it is very conservative. In extreme cases, it can give unrealistic results, and no statistical quantification of the margins to design limits is possible.

As discussed earlier in this section, the CSAU [[

]] is documented in Section 4.4.3.

5.3 DETECTION ALGORITHM TESTING

The DSS-CD licensing basis detection algorithm, the CDA, relies on the recognition of successive periods in OPRM cells signals that consists of two related pattern recognition elements:

- a. Successive period detection, and
- b. Confirmation density recognition.

Actual plant data and TRACG event simulations that are used to test these CDA elements are documented in this section.

5.3.1 Successive Period Detection

The PBA application in DSS-CD for the purpose of recognizing successive oscillation periods is similar to Option III. The key PBA testing from References 1 and 2 is summarized in Table 5-5. Testing of the PBA application to OPRM cells was performed in support of Option III algorithm qualifications and is also summarized in Table 5-5.

Because certain changes are introduced to the PBA for application to the CDA, selected retesting is appropriate. The PBA modifications and restrictions specified in Section 3.4.1.1 are expected to have insignificant effect on the testing and qualifications documented in References 1 and 2.

[[

]] Table 5-5

lists the retested plant data, which includes Pilgrim stable startup data and KKL instability event data. These retests have demonstrated that the PBA changes have insignificant effect on the detection results, as expected.

The PBA was applied to selected TRACG power traces to test the algorithm capability to recognize the inception of instability [[]. The PBA, consistent with the modifications and restrictions specified in Section 3.4.1.1, provided timely identification of the inception of instability oscillations and continuous recognition of successive period counts. [[

]]

5.3.2 Confirmation Density Recognition

The CDA requires simultaneous successive counts of multiple OPRM cells for generating an OPRM channel trip signal. The testing of the instability events listed in Table 5-5 were

previously performed for multiple LPRMs. However, the relative timing of the successive period counts is not included in Reference 2. To demonstrate the CD approach and effectiveness, multiple LPRM signals from the KKL Cycle 7 regional instability test event and Columbia Cycle 8 core wide instability event were examined by the PBA, integrated to calculate the CD as function of time, and compared to the algorithm CD setpoint.

A segment of the KKL Cycle 7 regional instability test, STAB5, was selected to demonstrate the CDA performance. This test segment is at the instability threshold and exhibits very gradual loss of stability margin. The PBA was applied to the available 25 LPRM signals that were recorded during the test. Figure 5-1 illustrates the stability performance of two LPRMs, including signal amplitude and PBA successive confirmation count. The LPRMs were selected to represent examples of responsive and unresponsive signals. Figure 5-2 depicts the CD based on the single LPRM PBA confirmation results. The figure illustrates the CDA responsiveness and ability to identify the instability inception and generate a trip signal when the CD setpoint [[

]] is reached. The number and distribution of the LPRMs was not conducive for OPRM cell demonstration. OPRM cell demonstration is performed for the Columbia instability event below.

The KKL Cycle 7 regional instability test represents a significant challenge for the CDA demonstration. The oscillations were established under controlled test conditions and resulted in a very gradual instability inception. The test was also occasionally interrupted by manual operator actions (e.g., control rod movements). In addition, the test appears to exhibit precession characteristics during its instability inception. For instabilities resulting from anticipated events [[]] with no manual operator manipulations, full core coupling and distinct characteristic oscillatory behavior is expected to form early in the event.

The second CDA demonstration example consists of the Columbia Cycle 8 unplanned instability event. The PBA was applied to the available 80 LPRM signals that were recorded during the event. These LPRMs consist of LPRM levels A and C (i.e., bottom and third from bottom axial positions). They were divided into 2 representative RPS channels of 39 LPRMs (Channel 1) and 41 LPRMs (Channel 2), as illustrated in Figure 5-3. The figure also illustrates an OPRM cell assignment, which simulates 2 OPRM channels of 35 OPRM cells each. This OPRM cell

assignment is similar to the Columbia's assignment, including adjustments to accommodate the available recorded LPRM signals. Most of the OPRM cells consist of 4 LPRMs and only a few with a lesser count.

Figure 5-4 illustrates the stability performance of a typical LPRM signal, including signal amplitude and PBA successive confirmation count. [[

]] which is initiated prior to any significant signal amplitude growth. The figure also includes a simulated OPRM cell signal, associated with the selected LPRM. It compares the performance of a 4-LPRM OPRM cell to one of its LPRM signals. [[

]]

Figure 5-5 depicts the CD based on a single LPRM per OPRM cell PBA confirmation results. The figure illustrates the CDA ability to identify the instability inception and generate an early trip signal when the CD setpoint [[is reached. Even though the event is developing slowly with a low growth rate, the increase in the number of confirming LPRMs is apparent. The figure demonstrates that the CD is not increasing prior to the development of oscillatory behavior, is associated with the instability threshold, and is rapidly increasing as the instability event develops.

The Columbia Cycle 8 instability event was also used to test the CDA detection capability with OPRM cells consisting of multiple LPRMs, as illustrated in Figure 5-3. Figure 5-6 depicts the OPRM CD performance, including the LPRM based CD for comparison. [[

]]

as indicated in the figure. [[

]].

Figure 5-6 illustrates the effectiveness of the OPRM approach. The simulated OPRM channels exhibit a total number of confirming cells that is continuously increasing as the event evolves, reaching a CD close to unity when the oscillation amplitude has not shown any significant growth (around 50 seconds). This test demonstrates the CDA capability to provide early detection and suppression signal. In addition, it successfully demonstrates the use of OPRM cells as the source of signal to the CDA.

In addition, the CDA was applied to selected TRACG power traces in Section 4, which demonstrated the algorithm capability to recognize the instability inception [[

]]

5.4 SETPOINT METHODOLOGY APPLICABILITY

The DSS-CD relies on several setpoints for its oscillation detection algorithms. These setpoints are classified into three distinct groups:

- a. CDA setpoints,
- b. Defense-in-depth algorithms setpoints, and
- c. Armed region setpoints.

[[

]]

5.4.1 CDA Setpoints

The CDA includes trip and alarm setpoints, which are assigned discrete values. They include the successive confirmation count threshold (N_{Th}), CDA alarm setpoint (N_{Al}), and confirmation density setpoint (S_{CD}^i).

N_{Th} is a generic, predetermined discrete setpoint [[]]. Its purpose is to provide early recognition of OPRM cell oscillatory behavior. For a well-developed oscillatory behavior at the instability threshold and inception, the successive period count is an unambiguous process. In addition, based on actual experience and simulation of instability events, N_{Th} is selected well below the count range associated with SLMCPR violation.

The alarm setpoint, N_{Al} , is selected on a plant and cycle-specific basis and is based on plant-specific operational objectives and preferences.

S_{CD}^i is used to generate a trip signal based on a limited number of OPRM cells exhibiting oscillatory behavior. For a well-developed oscillatory behavior at the instability threshold and inception, the count of confirming OPRM cells, recognized by the CDA, is a discrete and unambiguous process. In addition, based on actual experience and simulation of instability events, S_{CD}^i is selected well below the count range associated with SLMCPR violation.

5.4.2 Defense-in-Depth Setpoints

The defense-in-depth algorithms are based on a generic set of nominal setpoint values, summarized in Table 3-2. The defense-in-depth algorithms are not designed to provide SLMCPR protection.

5.4.3 Armed Region Setpoints

The DSS-CD Armed Region is defined to conservatively bound the operating domain region potentially susceptible to core oscillations. The bounding size of the region is designed to accommodate, on a generic basis, all plant-specific applications within the solution licensing basis generic applicability envelope defined in Tables 4-1 and 4-6. Confirmatory analysis of the

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

decay ratios at the Armed Region boundaries demonstrated large stability margin. Significant instability events are expected only at low core flow and high core power conditions. Operations at lower core power or higher core flow, well within the Armed Region (i.e., approximately 60% core flow, 30% OLTP), may result in a gradual loss of stability margin. For these conditions, early indication of degraded stability margin is available through the alarm feature of the solution. [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 5-1 CSAU Evaluation Methodology

CSAU Step	Step Description	DSS-CD
1	Scenario Specification	[[]]
2	Nuclear Power Plant Selection	BWR/3-6
3	Phenomena Identification and Ranking	Addressed in Table 5-2
4	Frozen Code Version Selection	TRACG02A
5	Code Documentation	NEDE-32176P (Reference 8), NEDE-32177P (Reference 9)
6	Determination of Code Applicability	AOO LTR (Reference 7); Additional parameters disposition
7	Establishment of Assessment Matrix	AOO LTR (Reference 7)
8	Nuclear Power Plant Nodalization Definition	Nodalization defined. Plant nodalization study performed
9	Definition of Code and Experimental Accuracy	NEDE-32177P (Reference 9)
10	Determination of Effect of Scale	Full scale data available, addressed in Section 5.2, Item 10
11	Determination of the Effect of Reactor Input Parameters and State	Addressed in Tables 5-2 and 5-4
12	Performance of Nuclear Power Plant Sensitivity Calculations	Addressed in Tables 5-3 and 5-4
13	Determination of Combined Bias and Uncertainty	[[]]
14	Determination of Total Uncertainty	DSS-CD bounding calculations demonstrate that FMCP > SLMCP

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

[[**Table 5-2 Phenomena Governing BWR/3-6 Stability Transients**

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

11

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 5-3 Disposition of High Ranked Stability Model Parameters

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 5-4 Key Plant Initial Conditions/Parameters

[[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 5-5 Summary of PBA Testing against Actual Plant Data

Testing Purpose	Data Source	Reference	Retest
Single/Multiple LPRM count response for operational event	LaSalle pump upshift event	2	No
Single/Multiple LPRM count response for stable steady state conditions	Pilgrim stable startup data	2	Yes
Single/Multiple LPRM count response for operational events	Limerick test data (1RPT, 2RPT, turbine stop valve, pressure regulator, feedwater flow step change, recirculation flow step)	2	No
Single/Multiple LPRM count response for regional instability event	KKL Cycle 1 instability events	2	No
Single/Multiple LPRM count response for regional instability event	KKL Cycle 7 instability events	2	Yes
Single/Multiple LPRM count response for regional instability event	Coarso instability data (regional)	2	No
OPRM count response for regional instability event	KKL Cycle 7 instability events	2	Yes
OPRM count response for core wide instability event	Limerick Cycle 1	2	No

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 5-6 Summary of CDA Testing against Actual Plant Data

Testing Purpose	Data Source
Multiple LPRM count response and timing for regional instability test event	KKL Cycle 7 instability event (STAB5)
Multiple LPRM and OPRM count response and timing for core wide instability event	Columbia Cycle 8 instability event

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 5-1 Example LPRMs Performance for KKL Cycle 7 Instability Test (STAB5)

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 5-2 CD Performance for KKL Cycle 7 Instability Test (STAB5)


[[



]]


NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 5-3 Columbia LPRM/OPRM Assignment Map Demonstration



*Data not available

764 Bundle Core, OPRM Channel 1



*Data not available

764 Bundle Core, OPRM Channel 2

Figure 5-4 Example LPRM/OPRM Performance for Columbia Cycle 8 Instability Event

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION


Figure 5-5 LPRM CD Performance for Columbia Cycle 8 Instability Event

[[

]]

Figure 5-6 OPRM CD Performance for Columbia Cycle 8 Instability Event

[[



]]

6.0 PLANT SPECIFIC APPLICATION

A plant specific review procedure is established to confirm that the generic DSS-CD licensing basis is applicable to plant-specific designs, including reload designs, and therefore, demonstrating SLMCPR protection by the DSS-CD for anticipated stability related oscillations. If the generic DSS-CD licensing basis is not applicable to a plant specific design, additional analyses will be necessary to demonstrate applicability.

6.1 PLANT SPECIFIC REVIEW PROCESS

The generic DSS-CD licensing basis allows solution implementation for GE BWR/3-6 product lines and existing GE fuel designs. The solution provides for early instability detection and suppression with minimal degradation in CPR performance during anticipated instability events. The resulting inherent CPR margin to the SLMCPR is expected to accommodate future evolution in fuel cycle designs and operating flexibility features that may affect stability performance.

The standard plant specific review process, which also applies to the reload process, consists of an applicability checklist, confirming that the generic applicability envelope, as defined in Section 4.0, is not exceeded. The plant specific applicability checklist is provided in Table 6-1 for TLO and in Table 6-2 for SLO.

If any checklist criterion is not met as a result of a plant specific design change that may affect reactor stability performance, the DSS-CD plant specific procedure will be performed to demonstrate adequate SLMCPR protection. If the design change is either within the DSS-CD plant specific applicability checklist envelope or does not affect the reactor stability performance, no additional DSS-CD applicability demonstration analysis is required.

Any extension of the DSS-CD applicability envelope requires confirmation analysis based on the methodology outlined in Section 4.0. In Section 4.0, the [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] The DSS-CD

procedure uncertainty (or equivalent), documented in Section 4.0, is then applied to confirm the margin to the SLMCPR. The DSS-CD applicability extension procedure is summarized in Table 6-3 for TLO and in Table 6-4 for SLO.

Design changes beyond the DSS-CD plant specific applicability checklist envelope that affect stability performance will require confirmation analysis according to the DSS-CD applicability extension procedures of Tables 6-3 and 6-4. [[

]]

If the DSS-CD applicability extension involves a new GE fuel design beyond GE14 or non-GE fuel designs, then Table 6-5 is applied. The table lists the possible fuel design transitions among approved and unapproved GE and non-GE fuel designs for DSS-CD applications. The table specifies the required [[

]]

6.2 LEAD USE ASSEMBLY

For a typical reload core, single channel oscillations are not probable because unstable channel condition is approached by a large number of channels, leading to significant core participation in the ensuing instability. However, the introduction of lead use assemblies (LUA) in a reload core creates the possibility of a unique thermal-hydraulic behavior, potentially leading to single channel oscillations. The DSS-CD solution provides early detection for such situations through its alarm function and eventual trip signal in the event of significant oscillation magnitude through its defense-in-depth protection features. When a limited number of LUAs is introduced to a reload core, the LUA thermal-hydraulic performance and stability characteristics will be assessed to determine potential susceptibility to single channel oscillations.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 6-1 TLO DSS-CD Plant Specific Applicability Checklist

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 6-2 SLO DSS-CD Plant Specific Applicability Checklist

[[

]]


NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 6-3 TLO DSS-CD Applicability Extension Evaluation Procedure

[[

|

]]



NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 6-4 SLO DSS-CD Applicability Extension Evaluation Procedure

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 6-5 Required TRACG Cases for Fuel Design Transition Scenarios

[[

|

]]

7.0 BACKUP STABILITY PROTECTION

7.1 INTRODUCTION

This section provides a description of Backup Stability Protection (BSP) approaches that may be used when the OPRM system is inoperable, applicable up to and including operation in the MELLLA+ domain. The elements of the BSP are confirmed on a plant and cycle specific basis to provide consistency with the LTS general requirement of long-term applicability. Other NRC approved backup approaches that are justified to provide appropriate protection may also be implemented.

Two BSP options are presented in this section and summarized in Section 7.5. Both options provide adequate protection for continued operation in the unlikely event the DSS-CD licensing basis algorithm cannot be demonstrated to provide its intended SLMCPR protection. The sections below discuss the three constituents of the two options, which are:

- | | |
|-----------------------------------|--|
| Manual BSP Regions | Comprises plant-specific regions (Scram and Controlled Entry) in the licensed power-flow operating domain and specified manual operator actions. The basis for the Manual BSP Regions is presented in Section 7.2, Manual BSP Region Boundaries Generation |
| BSP Boundary | Defines the operation domain where potential instability events can be effectively addressed by specified operator actions. Its basis is presented in Section 7.3, BSP Boundary Generation |
| Automated BSP Scram Region | Comprises an automatic reactor scram region implemented by the APRM flow-biased scram setpoint. Its basis is presented in Section 7.4, Automated BSP Scram Region Generation |

7.2 MANUAL BSP REGION BOUNDARIES GENERATION

The DSS-CD Manual BSP Regions use the GE/BWROG Interim Corrective Actions (ICAs) regions presented in Reference 5 as a starting point. The following elements are included in the Manual BSP Region generation process:

- The size of the base (minimal) Manual BSP Regions is equivalent to the current ICA regions,
- The three ICA regions (Scram, Exit, Controlled Entry) are replaced by two Manual BSP Regions (Scram and Controlled Entry),
- Common decay ratio criteria are established for plant and cycle-specific confirmation, and as necessary, the base Manual BSP Regions are increased to satisfy these criteria,
- The Manual BSP Regions are established based on two intercept state points, one on the High Flow Control Line (HFCL) and the other on the Natural Circulation Line (NCL), which are connected by the Generic Shape Function (GSF). When confirming the Manual BSP Regions for MELLLA+ operation, the HFCL is defined as the MELLLA+ upper boundary above 55% core flow and its extension to the NCL. The NCL is defined as the plant specific natural circulation line,
- The manual BSP regions is developed considering the appropriate feedwater temperature, including reduced feedwater temperature operation,
- Operator actions in the two Manual BSP Regions are similar to the operator actions currently defined for the ICA Scram and Controlled Entry regions,
- Operator awareness is required when operating within 10% of rated core flow or power from the Manual BSP Controlled Entry region.

Figure 7-1 illustrates the base Manual BSP Regions relative to the ICA regions. For uprated plants, the ICA region boundaries are scaled to maintain the pre-uprate region boundaries absolute power and flow values, which is then used to generate the base Manual BSP Regions, following the process illustrated in Figure 7-1.

7.2.1 Generic Shape Function

The Generic Shape Function (GSF) is a fit to power/flow state points representing a constant decay ratio. The GSF procedure is applied to two state points that meet specified region boundary generation stability criteria, one on the HFCL and the other on the NCL. The region boundary is defined with the GSF as:

$$P = P_B \left(\frac{P_A}{P_B} \right)^{\frac{1}{2} \left[\frac{W - W_B}{W_A - W_B} + \left(\frac{W - W_B}{W_A - W_B} \right)^2 \right]}, \quad W \geq W_B$$

where:

Point A: Intersection of the HFCL and specified core flow,

Point B: Intersection of the NCL and specified load line,

P: Core power in % rated

W: Core flow in % rated.

If core flow rates below W_B are assessed, the generic shape function slope may become negative when the quadratic exponential term dominates. Typically, this situation is not expected to occur because the flow range below W_B is limited. In the unlikely situation where negative slope below W_B is encountered, a modified form of this function is used. To ensure both a positive slope and continuity below W_B , the quadratic exponential term is eliminated and the following function is used:

$$P = P_B \left(\frac{P_A}{P_B} \right)^{\frac{1}{2} \left[\frac{W - W_B}{W_A - W_B} \right]}, \quad W < W_B$$

7.2.2 Base Manual BSP Regions Derivation

The base Manual BSP Regions are generated based on the minimal requirements of the original ICA regions using the GSF as illustrated in Figure 7-1. The base Manual BSP Regions are established on a plant specific basis based on the generic process outlined below.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

The base Manual Scram Region (Region I) boundary is generated by applying the GSF to Points A and B:

Point A: Intersection of the MELLLA upper boundary and 40% rated core flow,

Point B: Intersection of the NCL and 100% OLTP load line,

The base Manual BSP Region I boundary is extrapolated up to the extension of the MELLLA+ HFCL through the application of the GSF for core flows above 40%.

The base Manual BSP Controlled Entry Region (Region II) boundary is generated by applying the GSF to Points A' and B':

Point A': Intersection of the MELLLA upper boundary and 50% rated core flow,

Point B': Intersection of the NCL and 70% OLTP load line,

The base Manual BSP Region II boundary is defined only up to the MELLLA upper boundary.

The base manual BSP regions for MELLLA+ operation are illustrated in Figure 7-2.

The base manual BSP region boundaries define the minimum region size required.

7.2.3 Manual BSP Regions Plant Specific Application

The process defining the plant and cycle-specific manual regions is described in this section.

7.2.3.1 Region I – Manual BSP Scram Region

Region Definition

The Manual BSP Region I boundary is established by applying the GSF to Points A (along the HFCL) and Point B (along the NCL). Each point is selected based on the more limiting of the following options:

1. The base minimal region.
2. A best-estimate stability calculation using the ODYSY frequency domain code (Reference 6) with the calculation procedure outlined in Table 7-1 for Manual BSP Region I and the

stability criterion associated with 0.8 core and channel decay ratios, as illustrated in Figure 7-3.

If the best-estimate calculation results at both points are bounded by the base minimal region, the base minimal region is confirmed. If the best-estimate calculation results exceed the base minimal region at any point, the base minimal region is extended at that point.

For MELLLA+, the Manual BSP Region I boundary is extended outside the operating domain upper boundary (i.e., MELLLA) up to the extension of the HFCL, to ensure proper operator action upon unplanned entry into the region. Figure 7-4 illustrates the process for establishing manual BSP boundaries for an example BWR/6. For this example the continued applicability of the base Manual BSP Region I is confirmed.

Actions

An immediate manual scram is required upon determination that the region has been entered. If entry is unavoidable, early scram initiation is appropriate.

7.2.3.2 Region II – Controlled Entry Region

Region Definition

The Manual BSP Region II boundary is established by applying the GSF to Points A' (along the HFCL) and Point B' (along the NCL). Each point is selected based on the more limiting of the following options:

1. The base minimal region.
2. A best-estimate stability calculation using the ODYSY frequency domain code (Reference 6) with the calculation procedure outlined in Table 7-1 for Manual BSP Region II and the stability criterion associated with 0.8 core and channel decay ratios (illustrated in Figure 7-3) applied to point B' and the stability criterion associated with 0.6 core and channel decay ratios (also illustrated in Figure 7-3) applied to point A'. The 0.6 criterion is used for point A' rather than 0.8 to provide additional stability margin for operation at off-rated conditions.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

If the best-estimate calculation results at both points are bounded by the base manual BSP minimal region, the base manual BSP region is confirmed. If the best-estimate calculation results exceed the base manual BSP minimal region at any point, the base manual BSP region is extended at that point.

The Manual BSP Region II boundary is defined by the GSF inside the licensed operating domain. Unlike the Manual BSP Region I boundary, extension of Manual BSP Region II boundary outside the MELLLA upper boundary for the core flow range below the MELLLA+ operating domain extension is not necessary. This is because immediate corrective operator action is required for unplanned operations at reactor power levels exceeding the licensed values. Figure 7-4 illustrates the process for establishing BSP boundaries for an example BWR/6. For this example the continued applicability of the base Region II is confirmed.

Actions

- If the entry is inadvertent or forced, immediate exit from the region is required. The region can be exited by control rod insertion or core flow increase by pump speed increase for Motor Generator (MG) set plants or flow control valve (FCV) opening for FCV plants. Increasing the core flow by either restarting or upshifting (for FCV plants) a recirculation pump is not an acceptable method of exiting the region.
- Deliberate entry into the Manual BSP Controlled Entry Region requires compliance with at least one of the stability controls outlined below:
 - Maintain core average Boiling Boundary (BB) ≥ 4.0 feet,
 - Maintain core decay ratio (DR) < 0.6 as calculated by an on-line core stability monitor,
 - Determine appropriate limits for core DR (< 0.60) as calculated by a core stability monitor or by pre-analysis of a reactor state trajectory through the Manual BSP Controlled Entry Region, or
 - Continuous dedicated monitoring of real time control room neutron monitoring instrumentation with manual scram required upon indication of a reactor instability induced power oscillation.

- The guidance and actions recommended by the BSP emphasize instability prevention to minimize the burden placed on the operator when monitoring for the onset of power oscillations. Therefore, caution is required whenever operating near the Manual BSP Region II boundary (i.e., within approximately 10% of core power or core flow), and it is recommended that the amount of time spent operating near this region be minimized.

7.3 BSP BOUNDARY GENERATION

The BSP Boundary delineates that portion of the core power and flow operating domain that is not expected to be susceptible to instability events associated with a high initial growth rate. These instability events if developed can be recognized by the operator sufficiently early to allow timely manual power suppression prior to significant MCPR degradation. [[

]] Therefore, operation above the BSP Boundary is not permitted.

7.3.1 BSP Boundary Plant Specific Application

Boundary Definition

The BSP Boundary is defined by connecting Point A" (at power condition) and Point B" (along the NCL) as illustrated in Figure 7-5. [[

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

]] This is illustrated in the example BSP Boundaries provided below.

Figure 7-5 illustrates a BSP Boundary for an example BWR/6. [[

]] any flow reduction event from off-rated conditions that is terminated inside the Manual BSP Region I, including all events terminating above the OLTP 100% load line, requires immediate operator action to manually scram the reactor.

Only those portions of the BSP Boundary that traverse the core power and flow licensed operating domain outside the Manual BSP Scram Region are explicitly identified on the operating map. The Manual BSP Controlled Entry Region boundary is extended to the appropriate licensed operating domain upper boundary. If any portion of the BSP Boundary traverses the Manual BSP Scram Region, this portion is not explicitly identified because operation inside the Manual BSP Scram Region requires an immediate action to scram the reactor, which is controlling.

Figures 7-6 through 7-8 illustrate BSP Boundaries for additional examples, comprising of different BWR/4 plants. Table 7-3 provides a summary of the four BSP Boundary examples.

[[

]]

Actions

Operation above the BSP Boundary requires immediate initiation of actions to lower the reactor power to below the BSP Boundary by control rod insertion.

7.4 AUTOMATED BSP SCRAM REGION GENERATION

The Manual BSP Scram Region, which requires an immediate manual scram upon determination that the region has been entered, may be automated by extending the APRM flow-biased scram setpoint to encompass the region. Because the Manual BSP Scram Region boundary intersection with the plant specific NCL is not higher than the intersection of the original 100% load line with the plant NCL, flow reduction events from the MELLLA+ region to the NCL would result in an entry into the Automated BSP Scram Region, and therefore an automatic reactor scram.

Automating the Manual BSP Scram Region provides an adequate instability prevention protection for operation in the entire MELLLA+ domain for interim situation when the CDA protection is temporarily unavailable. However, such a protection requires plant specific system modifications that may include hardware and/or software changes. This feature may be implemented based on plant specific considerations of the added benefits of continued operation in the MELLLA+ domain versus the added cost associated with the necessary system modifications.

Figures 7-9 and 7-10 illustrate the [[

]]

7.4.1 Automated BSP Scram Region Plant Specific Application

Region Definition

The APRM flow-biased scram setpoint is extended to encompass the Manual BSP Region I boundary, defined in Section 7.2. [[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

The Automated BSP Scram Region is [[

]] any

flow reduction event initiating from off-rated conditions and terminating inside the Automated BSP Scram Region, including all events terminating above the OLTP 100% load line, results in immediate automatic reactor scram.

Figure 7-11 illustrates the construction of the modified APRM flow-biased scram setpoints, including the Automated BSP Scram Region. The figure also illustrates the APRM flow-biased rod block setpoints, which are constructed to provide the standard scram avoidance protection.

[[

]]

Because a plant cycle specific assessment is required to confirm the applicability or update the Manual BSP Region I boundary, the Automated BSP Scram Region is also required to be confirmed or updated.

Actions

There are no required operator actions associated with the Automated BSP Scram Region since an automatic reactor scram is initiated upon entry.

7.5 BSP OPTIONS APPLICATION SUMMARY

Two BSP options are described in this section, which may be used in the unlikely event the OPRM system is inoperable. They both provide effective SLMCPR protection.

7.5.1 BSP Option 1

This option comprises manually implemented region boundaries (Scram and Controlled Entry Regions) and specified manual operator actions, as described in Section 7.2, Manual BSP Region Boundaries Generation, and restrictions in the allowable operating domain as described in Section 7.3, BSP Boundary Generation. Figure 7-12 illustrates this option for the BWR/4 example of Figure 7-6.

In Figure 7-12, the Manual BSP Region I is the same as the base Manual BSP Region I since the base region is confirmed, as illustrated in Figure 7-6. The Manual BSP Region II in Figure 7-12 is larger relative to the base Manual BSP Region II shown in Figure 7-6 as a result of the conservative stability criteria applied at its high end, thus illustrating the added measure to ensure higher stability margin for off-rated operation below the BSP Boundary.

7.5.2 BSP Option 2

This option comprises the Automated BSP Scram Region implemented by the APRM flow-biased scram setpoint, as described in Section 7.4, Automated BSP Scram Region Generation, and the Manual BSP Controlled Entry Region and associated manual operator actions, as described in Section 7.2.3.2, Region II – Controlled Entry Region. The Manual BSP Region II boundary and actions are the same for both BSP Options 1 and 2 and the Manual BSP Region I is not required for BSP Option 2. Figure 7-13 illustrates this option for the BWR/4 example of Figure 7-6. For this option, the APRM flow-biased setpoints may intersect the Manual BSP Region II. In this case, the required operator actions for the Manual BSP Region II is further restricted by the APRM flow-biased setpoints.

7.5.3 BSP Reload Application

A plant cycle specific assessment is required to confirm the applicability or update the BSP option for reload-specific fuel, core design, and operating strategy. [[

]]

A conservative representation of the Manual BSP Regions, BSP Boundary or Automated BSP Scram Region may be established to minimize the need for cycle-specific updates.

Implementation of a BSP option will require plant specific Technical Specifications (TS) changes and associated justifications. Section 8.0 discusses the recommended TS and Bases changes. Approved setpoint calculation methodology will be applied to the APRM flow-biased setpoints in order to define the allowable values as a function of the reactor recirculation drive flow. The Manual BSP Regions, BSP Boundary, and APRM flow-biased setpoints associated with the Automated BSP Scram Region will be defined in the COLR.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 7-1 Manual BSP Regions Calculation Procedure

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 7-2 BSP Boundary Calculation Procedure

[[

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 7-3 Summary of BSP Boundary Calculation Examples

Example No.	Figure No.	Description
1	7-5	BWR/6, Nominal feedwater temperature
2	7-6	BWR/4, Nominal rated feedwater temperature
3	7-7	BWR/4, Reduced rated feedwater temperature (- 23°F)
4	7-8	BWR/4, Reduced rated feedwater temperature (- 55°F)

Note: Examples 2 through 4 comprise of different BWR/4 plants.

Figure 7-1 Base Manual BSP Regions Generation Basis Relative to ICA Regions
(100% EPU = 120% OLTP)





Figure 7-2 MELLLA+ Base Manual BSP Regions
(100% EPU = 120% OLTP)



NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 7-3 Stability Criteria




Figure 7-4 Example BWR/6 Manual BSP Regions Confirmation
(100% EPU = 120% OLTP)




Figure 7-5 Example 1: BWR/6 Manual BSP Region I Confirmation and BSP Boundary
(100% EPU = 120% OLTP, Nominal Feedwater Temperature)




Figure 7-6 Example 2: BWR/4 Manual BSP Region I Confirmation and BSP Boundary
(100% EPU = 120% OLTP, Nominal Feedwater Temperature)




Figure 7-7 Example 3: BWR/4 Manual BSP Region I Confirmation and BSP Boundary

(100% EPU = 120% OLTP, 23°F Feedwater Temperature Reduction)





Figure 7-8 Example 4: BWR/4 Manual BSP Region I Confirmation and BSP Boundary

(100% EPU = 120% OLTP, 55°F Feedwater Temperature Reduction)



NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 7-9 Scram Timing Illustration for BSP Option 2 [[

]]

[[

Scram Timing Illustration for BSP Option 2

]]

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 7-10 Scram Timing Illustration for BSP Option 2

[[

]]

]]

Figure 7-11 Automated BSP Region I Modified APRM Flow Biased Setpoint Construction






Figure 7-12 BSP Option 1 Illustration



NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Figure 7-13 BSP Option 2 Implementation



8.0 EFFECT ON TECHNICAL SPECIFICATIONS

Changes to the Technical Specifications (TS) and Bases are required to address the implementation of DSS-CD. This section provides examples of changes to TS and Bases as generic guidance in developing the plant-specific license amendment to address DSS-CD implementation. Differences in plant-specific changes to the TS and Bases from those examples provided herein may be justifiable based on the plant-specific licensing basis and the inclusion of other licensing basis changes in the plant's license amendment request.

The example TS and Bases changes are provided in Appendices A and B. The appendices assume implementation of the TS and Bases proposed in Reference 13 for BWR/4 Standard Technical Specifications, Rev. 1, 4/7/95. Both Appendixes A and B show the same changes to the TS and Bases. The changes in Appendix A are indicated with revision bars in the left margin with deletions shown by a strikeout fonts and additions shown by an underlined font. Appendix B provides an easier to read set of proposed TS and Bases with the incorporated changes indicated by revision bars only. In general, only pages with changes are shown, but in a few cases other pages are included to better show the context.

A summary of the changes in the TS and Bases is as follows:

1. The proposed changes reflect the implementation of the Backup Stability Protection (BSP) in the event that the DSS-CD is inoperable,
2. Changes in the applicability requirements for DSS-CD,
3. Initial operation of the DSS-CD,
4. Elimination of an unnecessary Surveillance Requirement,
5. Additional core operating limits to the Core Operating Limits Report, and
6. Update the applicable references.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 8-1 provides a description of the changes in the TS. This description assumes that the changes proposed for the BWR/4 Standard Technical Specifications in Reference 13 are the existing Technical Specifications. The proposed requirements reflect generic guidance to implement DSS-CD. The purpose of each change is presented to provide an understanding of the generic guidance. The individual plant-specific license amendment request will justify and evaluate the adequacy of necessary TS changes based on the plant's unique licensing basis and any other license basis changes.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Table 8-1 Description and Purpose of TS Changes for DSS-CD Implementation

Specification	Existing Requirement	Proposed Requirement	Purpose
TS 3.3.1.1, Reactor Protection System (RPS) Instrumentation			
Required Action I.1	Initiate alternate method to detect and suppress thermal hydraulic instability oscillations.	Initiate action to implement the Manual BSP Regions defined in the COLR.	The Manual BSP Region and required actions are described in Section 7.2. The change reflects a portion of the requirements for Backup Stability Protection if OPRM Upscale trip capability is not maintained.
Completion Time I.1	12 hours	Immediately	The purpose of the reduced Completion Time is to reflect the importance of limiting the period of time during which no automatic or alternate capability is in place.
Required Action I.2.1	None	Implement the Automated BSP Scram Region using the modified APRM flow-biased scram setpoints defined in the COLR.	Actions I.2.1 and I.2.2 are required actions both of which are required to be taken in conjunction with Action I.1 when OPRM Upscale trip capability is not maintained. The Automated BSP Scram Region and required actions are described in Section 7.4.
Completion Time I.2.1	None	12 hours	The Completion Time of 12 hours provides the plant operating staff sufficient time for implementation in an orderly manner.
Required Action I.2.2	None	Initiate action in accordance with Specification 5.6.9	Backup Stability Protection is a temporary means for protection against thermal-hydraulic instability events. While an extended period of inoperability does not warrant the shutdown of the plant with an automatic trip capability provided by the Automated BSP Scram Region, a written plan and schedule, with NRC oversight, to restore the required channels to operability provides appropriate management attention.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Specification	Existing Requirement	Proposed Requirement	Purpose
Completion Time I.2.2	None	90 days	The Completion Time of 90 days is adequate to allow time to evaluate the cause of the inoperability and to determine the appropriate corrective actions and schedule to restore the required channels to OPERABLE status.
Required Action J.1	None	Initiate action to implement the Manual BSP Regions defined in the COLR.	See Required Action I.1.
Completion Time J.1	None	Immediately	See Required Action I.1.
Required Action J.2	None	Reduce operation to below the BSP Boundary defined in the COLR.	Both Actions J.2 and J.3 are required in conjunction with Action J.1. If an automatic trip function for instability events is not maintained, operational conditions during which manual operator actions are sufficient must be established. The BSP Boundary and required actions are described in Section 7.3.
Completion Time J.2	None	12 hours	The Completion Time of 12 hours provides the plant operating staff sufficient time for implementation in an orderly manner.
Required Action J.3	I.2 Restore required channels to OPERABLE.	J.3 Restore required channels to OPERABLE. (Same other than re-numbering of the Action)	Purpose unchanged.
Required Action K.1	Reduce THERMAL POWER to < [25]% RTP.	Reduce THERMAL POWER to less than [20]% RTP or be in Mode 2.	The intent is to place the plant in a condition to which the LCO does not apply. A choice of different applicability requirements is provided, one of which would be proposed in the plant specific application. Either of the two choices represents regions of power-flow operation with minimal susceptibility to thermal-hydraulic oscillations. The [20]% RTP is a plant-specific value that is 5% below the lower boundary of the DSS-CD Armed Region.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Specification	Existing Requirement	Proposed Requirement	Purpose
Completion Time K.1	[4] hours	[4 or 6] hours	The Completion Time of [4 or 6] hours provides the plant operating staff sufficient time for implementation in an orderly manner. A choice of different Completion Times is provided, one of which would be addressed in the plant-specific application. The longer of the two choices of Completions Times addresses the action to a reduce operations to Mode 2.
SR 3.3.1.1.18	Verify OPRM is not bypassed when APRM Simulated Thermal Power is $\geq [30]\%$ and recirculation drive flow is $\leq [60]\%$ of rated recirculation drive flow.	Delete	The DSS-CD automatically arms and the SR is unnecessary.
Table 3.3.1.1-1, Function 2.b, Allowable Value, footnote (d)	None	With OPRM Upscale (Function 2.f) inoperable, the modified APRM flow-biased setpoints defined in the COLR may be required to implement the Automated BSP Scram Region in accordance with Action I of this Specification.	The footnote is intended to reflect a possible change in the APRM allowable value due to implementation of the Automated BSP Scram Region described in Section 7.4.
Table 3.3.1.1-1, Function 2.f, Applicable Modes or Other Specified Conditions	$\geq [25]\%$ RTP	$\geq [20]\%$ RTP or Mode 1	A choice of different applicability requirements is provided, one of which would be addressed in the plant-specific application. Either one of which represents regions of power-flow operation where anticipated events could lead to thermal-hydraulic oscillations and related neutron flux oscillations. The $[20]\%$ RTP is a plant-specific value that is 5% below the lower boundary of the DSS-CD Armed Region.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

Specification	Existing Requirement	Proposed Requirement	Purpose
Table 3.3.1.1-1, Function 2.f, Footnote e	See COLR for OPRM period-based detection algorithm (PBDA) setpoint limits.	Following DSS-CD implementation, DSS-CD is not required to be armed while in the DSS-CD Armed Region from the first reactor startup and until the first controlled shutdown that passes completely through the DSS-CD Armed Region. However, DSS-CD shall be OPERABLE and capable of automatically arming consistent with Bases Reference [17] for operation at recirculation drive flow rates above the DSS-CD Armed Region. The DSS-CD Armed Region is defined in Bases Reference [17].	The existing requirement is no longer applicable since the PBDA is no longer credited in the safety analysis. The proposed requirement addresses the limited operability requirements during the initial testing phase following DSS-CD implementation.
Changes in sections other than Specification 3.3.1.1			
5.6.5, Core Operating Limits Report (COLR)	The period-based detection algorithm (PBDA) setpoint for Function 2.f, Oscillation Power Range Monitor (OPRM) Upscale, for Specification 3.3.1.1	The Manual Backup Stability Protection (BSP) Scram Region (Region I), the Manual BSP Controlled Entry Region (Region II), [the modified APRM flow-biased setpoints used in the Automated BSP Scram Region, or the BSP Boundary] for Specification 3.3.1.1.	The existing PBDA is no longer credited in the safety analysis. Specification 3.3.1.1 includes additional core operating limits that must be addressed in the COLR. The choice of the Automated BSP Scram Region or the BSP Boundary, reflects the plant-specific option to implement BSP consistent with Section 7.5.
5.6.9, Reporting Requirements	None	When a report is required by Condition I of LCO 3.3.1.1, "RPS Instrumentation," a report shall be submitted within 90 days of entering the LCO. The report shall outline the preplanned means to provide backup stability protection, the cause of the inoperability, and the plans and schedule for restoring the required instrumentation channels to OPERABLE status.	See Required Action I.2.2.

9.0 REFERENCES

1. NEDO-31960-A, BWR Owners' Group Long-Term Stability Solutions Licensing Methodology, November 1995.
2. NEDO-31960-A, Supplement 1, BWR Owners' Group Long-Term Stability Solutions Licensing Methodology, November 1995.
3. NEDO-32465-A, BWR Owners' Group Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications, August 1996.
4. NEDO-32047-A, ATWS Rule Issues Related to BWR Core Thermal-Hydraulic Stability, June 1995.
5. BWROG-94078, BWR Owners' Group Guidelines for Stability Interim Corrective Action, June 1994.
6. NEDC-32992P-A, ODYSY Application for Stability Licensing Calculations, July 2001.
7. NEDE-32906P-A, Rev. 1, TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses, April 2003.
8. NEDE-32176P, Rev. 2, TRACG Model Description, December 1999.
9. NEDE-32177P, Rev. 2, TRACG Qualification, January 2000.
10. NUREG/CR-5249, Quantifying Reactor Safety Margins: Application of Code Scaling, Applicability, and Uncertainty Evaluation Methodology to a Large-Break, Loss-of-Coolant Accident, December 1989.
11. Regulatory Guide 1.157, Best-Estimate Calculations of Emergency Core Cooling System Performance, May 1989.
12. NEDO-30130-A, Steady State Nuclear Methods, April 1985.
13. NEDC-32410P-A, Supplement 1, NUMAC-PRNM Retrofit Plus Option III Stability Trip Function, November 1997.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

**APPENDIX A: EXAMPLE OF CHANGES TO BWR/4 STANDARD
TECHNICAL SPECIFICATIONS -
REDLINE/STRIKEOUT VERSION**

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.1-1.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	OR A.2 -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- Place associated trip system in trip.	12 hours
B. -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	OR B.2 Place one trip system in trip.	6 hours
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < [30]% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately
I. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	I.1 Initiate action to implement the Manual BSP Regions defined in the COLR alternate method to detect and suppress thermal hydraulic instability oscillations.	12- hours <u>Immediately</u>
	<u>AND</u> I.2.1 <u>Implement the Automated BSP Scram Region using the modified APRM flow-biased scram setpoints defined in the COLR.</u>	<u>12 hours</u>
	<u>AND</u> I.2.2 <u>Initiate action in accordance with</u>	<u>90 days</u>

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

CONDITION	REQUIRED ACTION	COMPLETION TIME
	<u>Specification 5.6.9.</u>	
<u>J. Required Action and associated Completion Time of Condition I not met.</u>	<u>J.1 Initiate action to implement the Manual BSP Regions defined in the COLR.</u> <u>AND</u> <u>J.2 Reduce operation to below the BSP Boundary defined in the COLR.</u> <u>AND</u> <u>J.3 Restore required channel to OPERABLE</u>	<u>Immediately</u> <u>12 hours</u> <u>120 days</u>
<u>JK. Required Action and associated Completion Time of Condition I-J not met.</u>	<u>JK.1 [Reduce THERMAL POWER to <less than [2520]% RTP or Be in Mode 2].</u>	<u>[4 or 6] hours</u>

BWR/4 STS

3.3-2

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.1.2	<p>-----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP.</p> <p>Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power is \leq 2% RTP [plus any gain adjustment required by LCO 3.2.4, "Average Power Range Monitor (APRM) Setpoints"] while operating at \geq 25% RTP.</p>	7 days
SR 3.3.1.1.3	(Not used.)	
SR 3.3.1.1.4	<p>-----NOTE----- Not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	7 days

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.5	Perform CHANNEL FUNCTIONAL TEST.	7 days
SR 3.3.1.1.6	Verify the source range monitor (SRM) and intermediate range monitor (IRM) channels overlap.	Prior to withdrawing SRMs from the fully inserted position
SR 3.3.1.1.7	-----NOTE----- Only required to be met during entry into MODE 2 from MODE 1. ----- Verify the IRM and APRM channels overlap.	7 days
SR 3.3.1.1.8	Calibrate the local power range monitors.	[1000] MWD/T average core exposure
SR 3.3.1.1.9	Perform CHANNEL FUNCTIONAL TEST.	[92] days
+-- SR 3.3.1.1.10 +--	Calibrate the trip units.	[92] days --+ --+

(continued)

NOTE: The addition of "[]" around the 1000 MWD/T in SR 3.3.1.1.8 above is to recognize that some plants have justified 2000 MWD/T. It is not related to the OPRM addition and does not affect the actual APRM change required by a plant.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.11	<p>-----NOTE-----</p> <p>For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	184 days
SR 3.3.1.1.12	Perform CHANNEL FUNCTIONAL TEST.	[18] months
SR 3.3.1.1.13	<p>-----NOTES-----</p> <p>1. Neutron detectors are excluded.</p> <p>2. For Function 1, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	[18] months
SR 3.3.1.1.14	(Not used.)	
SR 3.3.1.1.15	Perform LOGIC SYSTEM FUNCTIONAL TEST.	[18] months

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.16 Verify Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are not bypassed when THERMAL POWER is \geq [30]% RTP.	[18] months
SR 3.3.1.1.17 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 5 "n" equals 4 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. ----- Verify the RPS RESPONSE TIME is within limits.	[18] months on a STAGGERED TEST BASIS
SR 3.3.1.1.18 Verify OPRM is not bypassed when APRM Simulated Thermal Power is \geq[30]% and recirculation drive flow is $<$[60]% of rated recirculation drive flow.	[18] months

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux—High	2	[3]	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [120/125] divisions of full scale
	5 (a)	[3]	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [120/125] divisions of full scale
b. Inop	2	[3]	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 (a)	[3]	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux—High, (Setdown)	2	3 ^(c)	G	SR 3.3.1.1.1 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [20]% RTP
b. Simulated Thermal Power—High	1	3 ^(c)	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [0.58 W + 62]% RTP and ≤ [115.5]% RTP (b) (d)

(continued)

- (a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) [0.58 W + 62% - 0.58 ΔW] RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."
- (c) Each APRM channel provides inputs to both trip systems.
- (d) With OPRM Upscale (function 2.f) inoperable, the modified APRM flow-biased setpoints defined by the COLR may be required to implement the Automated BSP Scram Region in accordance with Action I of this Specification.

BWR/4 STS

3.3-7

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
c. Neutron Flux—High	1	3 ^(c)	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [120] % RTP
d. Inop	1,2	3 ^(c)	G	SR 3.3.1.1.11	NA
e. 2-Out-Of-4 Voter	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.11 SR 3.3.1.1.15 SR 3.3.1.1.17	NA
f. OPRM Upscale	≥ [2520] % RTP or 1) ^(e)	3 ^(c)	I	SR 3.3.1.1.1 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13 SR 3.3.1.1.18	NA ^(e)
3. Reactor Vessel Steam Dome Pressure—High	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ [1054] psig
4. Reactor Vessel Water Level—Low, Level 3	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≥ [10] inches
5. Main Steam Isolation Valve—Closure	1	[8]	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ [10] % closed
6. Drywell Pressure—High	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [1.92] psig

(continued)

(c) Each APRM channel provides inputs to both trip systems.

(e) Following DSS-CD implementation, DSS-CD is not required to be armed while in the DSS-CD Armed Region during the first reactor startup and during the first controlled shutdown that passes completely through the DSS-CD Armed Region. However, DSS-CD shall be OPERABLE and capable of automatically arming consistent with Reference [17] for operation at recirculation drive flow rates above the DSS-CD Armed Region. The DSS-CD Armed Region is defined in Reference [17].

(e) See COLR for OPRM period-based detection algorithm (PBDA) setpoint limits.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level—High					
a. Resistance Temperature Detector	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
	5 (a)	[2]	H	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
b. Float Switch	1,2	[2]	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
	5 (a)	[2]	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
8. Turbine Stop Valve— Closure	≥ [30]% RTP	[4]	E	SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ [10]% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure—Low	≥ [30]% RTP	[2]	E	SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ [600] psig
10. Reactor Mode Switch— Shutdown Position	1,2	[2]	G	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
	5 (a)	[2]	H	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	[2]	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 (a)	[2]	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

5.6 Reporting Requirements (continued)

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

The individual specifications that address core operating limits must be referenced here.

[For DSS-CD, the following is required in addition to the normal list of limits:]

- ~~1. The period based algorithm (PBDA) setpoint for Function 2.f, Oscillation Power Range Monitor (OPRM) Upscale, for Specification 3.3.1.1~~
1. The Manual Backup Stability Protection (BSP) Scram Region (Region I), the Manual BSP Controlled Entry Region (Region II), [the modified APRM flow-biased setpoints used in the Automated BSP Scram Region, or the BSP Boundary] for Specification 3.3.1.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
- Identify the Topical Report(s) by number and title or identify the Staff Safety Evaluation Report for a plant specific methodology by NRC letter and date. The COLR will contain the complete identification for each of the TS referenced topical reports used to prepare the COLR (i.e., report number, title, revision, date, and any supplements).
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

(continued)

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

5.6 Reporting Requirements (continued)

5.6.9 OPRM Report

When a report is required by Condition I of LCO 3.3.1.1, "RPS Instrumentation," a report shall be submitted within 90 days of entering the LCO. The report shall outline the preplanned means to provide backup stability protection, the cause of the inoperability, and the plans and schedule for restoring the required instrumentation channels to OPERABLE status.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE
SAFETY ANALYSES,
LCO, and
APPLICABILITY.

BWR/6 STS Note: The wording of the BASES descriptions of APRM Functions is somewhat different from the corresponding Functions for the BWR/4 ISTS to reflect slight differences in the architecture. However, the replacement text will be very similar to that shown in this example mark-up.

Average Power Range Monitor (APRM)

The APRM channels provide the primary indication of neutron flux within the core and respond almost instantaneously to neutron flux increases. The APRM channels receive input signals from the local power range monitors (LPRMs) within the reactor core to provide an indication of the power distribution and local power changes. The APRM channels average these LPRM signals to provide a continuous indication of average reactor power from a few percent to greater than RTP. Each APRM also includes an Oscillation Power Range Monitor (OPRM) Upscale Function which monitors small groups of LPRM signals to detect thermal-hydraulic instabilities.

The APRM System is divided into four APRM channels and four 2-out-of-4 voter channels. Each APRM channel provides inputs to each of the four voter channels. The four voter channels are divided into two groups of two each, with each group of two providing inputs to one RPS trip system. The system is designed to allow one APRM channel, but no voter channels, to be bypassed. A trip from any one unbypassed APRM will result in a "half-trip" in all four of the voter channels, but no trip inputs to either RPS trip system. APRM trip Functions 2.a, 2.b, 2.c, and 2.d are voted independently from OPRM Upscale Function 2.f. Therefore, any Function 2.a, 2.b, 2.c, or 2.d trip from any two unbypassed APRM channels will result in a full trip in each of the four voter channels, which in turn results in two trip inputs into each RPS trip system logic channel (A1, A2, B1, and B2). Similarly, a Function 2.f trip from any two unbypassed APRM channels will result in a full trip from each of the four voter channels. Three of the four APRM channels and all four of the voter channels are required to be OPERABLE to ensure that no single failure will preclude a scram on a valid signal. In addition, to provide adequate coverage of the entire core, consistent with the design bases for the APRM Functions 2.a, 2.b, and 2.c, at least [20] LPRM inputs, with at least [three] LPRM inputs from each of the four axial levels at which the LPRMs are located, must be operable for each APRM channel. For the OPRM Upscale, Function 2.f, LPRMs are assigned to "cells" of [4] detectors. A minimum of [later] cells, each with a minimum of [2] LPRMs, must be OPERABLE for the OPRM Upscale Function 2.f to be OPERABLE.

BWR/4 STS

NO CHANGE TO THIS PAGE
B 3.3-7

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE SAFETY ANALYSES, LCO, and APPLICABILITY	<u>2.d. Average Power Range Monitor--Inop</u> Three of the four APRM channels are required to be OPERABLE for each of the APRM Functions. This Function (Inop) provides assurance that the minimum number of APRM channels are OPERABLE.
---	---

For any APRM channel, any time its mode switch is in any position other than "Operate," an APRM module is unplugged, or the automatic self-test system detects a critical fault with the APRM channel, an Inop trip is sent to all four voter channels. Inop trips from two or more unbypassed APRM channels result in a trip output from all four voter channels to their associated trip system.

This Function was not specifically credited in the accident analysis, but it is retained for the overall redundancy and diversity of the RPS as required by the NRC approved licensing basis.

There is no Allowable Value for this Function.

This Function is required to be OPERABLE in the MODES where the APRM Functions are required.

2.e. 2-Out-Of-4 Voter

The 2-Out-Of-4 Voter Function provides the interface between the APRM Functions, including the OPRM Upscale Function, and the final RPS trip system logic. As such, it is required to be OPERABLE in the MODES where the APRM Functions are required and is necessary to support the safety analysis applicable to each of those Functions. Therefore, the 2-Out-Of-4 Voter Function needs to be OPERABLE in MODES 1 and 2.

All four voter channels are required to be OPERABLE. Each voter channel includes self-diagnostic functions. If any voter channel detects a critical fault in its own processing, a trip is issued from that voter channel to the associated trip system.

The 2-Out-Of-4 Voter Function votes APRM Functions 2.a, 2.b, 2.c, and 2.d independently of Function 2.f. The voter also includes separate outputs to RPS for the two independently voted sets of Functions, each of which is redundant (four total outputs). The voter Function 2.e must be declared inoperable if any of its functionality is inoperable. However, due to the independent voting of APRM trips, and the redundancy of outputs, there may be conditions where the voter Function 2.e is inoperable, but trip capability for one or more of the other APRM Functions through that voter is still maintained. This may be considered when determining the condition of other APRM Functions resulting from partial inoperability of the Voter Function 2.e.

There is no Allowable Value for this Function.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE

SAFETY ANALYSES, 2.f. Oscillation Power Range Monitor (OPRM) Upscale
LCO, and

APPLICABILITY

The OPRM Upscale Function provides compliance with GDC 10 and GDC 12, thereby providing protection from exceeding the fuel MCPR safety limit (SL) due to anticipated thermal-hydraulic power oscillations.

Reference [17] describes the Detect and Suppress - Confirmation Density (DSS-CD) long-term stability solution and the licensing basis Confirmation Density Algorithm (CDA). and Reference [17] also describes the DSS-CD Armed Region and the References [12], [13] and [14] describe three additional algorithms for detecting thermal-hydraulic instability related neutron flux oscillations: the period based detection algorithm (PBDA), the amplitude based algorithm (ABA), and the growth rate algorithm (GRA). All three algorithms are implemented in the OPRM Upscale Function, but the safety analysis takes credit only for the period-based detection algorithm CDA. The remaining three algorithms provide defense in depth and additional protection against unanticipated oscillations. OPRM Upscale Function OPERABILITY for Technical Specification purposes is based only on the period-based detection algorithm CDA.

The OPRM Upscale Function receives input signals from the local power range monitors (LPRMs) within the reactor core, which are combined into "cells" for evaluation by the OPRM algorithms.

DSS-CD operability requires at least 8 responsive OPRM cells per channel.

The OPRM Upscale Function is required to be OPERABLE when the plant is [at \geq greater than or equal to {25}% RTP below the lower boundary of the Armed Region, which is 20% RTP or in Mode 1], encompassing the region of power-flow operation where anticipated events could lead to thermal-hydraulic instability and related neutron flux oscillations. Within this region, the automatic trip is enabled when THERMAL POWER, as indicated by the APRM Simulated Thermal Power, is greater than or equal to the \geq {30}% RTP corresponding to the plant-specific MCPR monitoring threshold and reactor core flow, as indicated by recirculation drive flow, is \leq less than {6075 for MELLLA+ or 70 for MELLLA}% of rated flow, the operating region where actual thermal-hydraulic oscillations may occur. The lower bound, {25}% RTP, is chosen to provide margin in the unlikely event of loss of feedwater heating while the plant is operating below the {30}% automatic OPRM Upscale trip enable point. Loss of feedwater heating is the only identified event that could cause reactor power to increase into the region of concern without operator action. Note e allows for entry into the DSS-CD Armed Region without automatic arming of DSS-CD prior to completely passing through the DSS-CD Armed Region during both a single startup and a single shutdown following DSS-CD implementation. Note e reflects the need for plant data collection in order to test the DSS-CD equipment. Testing the DSS-CD equipment ensures its proper operation and prevents spurious reactor trips. Entry into the DSS-CD Armed Region without automatic arming of DSS-CD during this initial testing phase also allows for changes in plant operations to address

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

maintenance or other operational needs. However, during this initial testing period, DSS-CD operability and capability to automatically arm shall be maintained at recirculation drive flow rates above the DSS-CD Armed Region.

An OPRM Upscale trip is issued from an APRM-OPRM channel when the period based detection confirmation density algorithm in that channel detects oscillatory changes in the neutron flux, indicated by period confirmations and amplitude exceeding specified setpoints for a specified number of OPRM cells in the channel. the combined signals of the LPRM detectors in a cell, with period confirmations and relative cell amplitude exceeding specified setpoints. One or more cells in a channel exceeding the trip conditions will result in a channel trip. An OPRM Upscale trip is also issued from the channel if either any of the defense-in-depth algorithms (PBDA, ABA, GRA) the growth rate or amplitude based algorithms detect growing oscillatory changes in the neutron flux exceed the trip condition for one or more cells in that channel.

Three of the four channels are required to be operable. Each channel is capable of detecting thermal-hydraulic instabilities, by detecting the related neutron flux oscillations, and issuing a trip signal before the MCPR SL is exceeded. There is no allowable value for this function.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

A.1 and A.2A.1

Because of the diversity of sensors available to provide trip signals and the redundancy of the RPS design, an allowable out of service time of 12 hours has been shown to be acceptable (Ref. 9 and [11]) to permit restoration of any inoperable channel to OPERABLE status. However, this out of service time is only acceptable provided the associated Function's inoperable channel is in one trip system and the Function still maintains RPS trip capability (refer to Required Actions B.1, B.2, and C.1 Bases). If the inoperable channel cannot be restored to OPERABLE status within the allowable out of service time, the channel or the associated trip system must be placed in the tripped condition per Required Actions A.1 and A.2. Placing the inoperable channel in trip (or the associated trip system in trip) would conservatively compensate for the inoperability, restore capability to accommodate a single failure, and allow operation to continue. Alternatively, if it is not desired to place the channel (or trip system) in trip (e.g., as in the case where placing the inoperable channel in trip would result in a full scram), Condition D must be entered and its Required Action taken.

As noted, Action A.2 is not applicable for APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f. Inoperability of one required APRM channel affects both trip systems. For that condition, Required Action A.1 must be satisfied, and is the only action (other than restoring OPERABILITY) that will restore capability to accommodate a single failure. Inoperability of more than one required APRM channel of the same trip function results in loss of trip capability and entry into Condition C, as well as entry into Condition A for each channel.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

B.1 and B.2

Condition B exists when, for any one or more Functions, at least one required channel is inoperable in each trip system. In this condition, provided at least one channel per trip system is OPERABLE, the RPS still maintains trip capability for that Function, but cannot accommodate a single failure in either trip system.

Required Actions B.1 and B.2 limit the time the RPS scram logic, for any Function, would not accommodate single failure in both trip systems (e.g., one-out-of-one and one-out-of-one arrangement for a typical four channel Function). The reduced reliability of this logic arrangement was not evaluated in References 9 or [11] for the 12 hour Completion Time. Within the 6 hour allowance, the associated Function will have all required channels OPERABLE or in trip (or any combination) in one trip system.

Completing one of these Required Actions restores RPS to a reliability level equivalent to that evaluated in References 9 or [11], which justified a 12 hour allowable out of service time as presented in Condition A. The trip system in the more degraded state should be placed in trip or, alternatively, all the inoperable channels in that trip system should be placed in trip (e.g., a trip system with two inoperable channels could be in a more degraded state than a trip system with four inoperable channels if the two inoperable channels are in the same Function while the four inoperable channels are all in different Functions). The decision of which trip system is in the more degraded state should be based on prudent judgment and take into account current plant conditions (i.e., what MODE the plant is in). If this action would result in a scram or RPT, it is permissible to place the other trip system or its inoperable channels in trip.

The 6 hour Completion Time is judged acceptable based on the remaining capability to trip, the diversity of the sensors available to provide the trip signals, the low probability of extensive numbers of inoperabilities affecting all diverse Functions, and the low probability of an event requiring the initiation of a scram.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS B.1 and B.2 (continued)

Alternately, if it is not desired to place the inoperable channels (or one trip system) in trip (e.g., as in the case where placing the inoperable channel or associated trip system in trip would result in a scram [or RPT]), Condition D must be entered and its Required Action taken.

As noted, Condition B is not applicable for APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f. Inoperability of an APRM channel affects both trip systems and is not associated with a specific trip system as are the APRM 2-out-of-4 voter and other non-APRM channels for which Condition B applies. For an inoperable APRM channel, Required Action A.1 must be satisfied, and is the only action (other than restoring OPERABILITY) that will restore capability to accommodate a single failure. Inoperability of a Function in more than one required APRM channel results in loss of trip capability for that Function and entry into Condition C, as well as entry into Condition A for each channel. Because Conditions A and C provide Required Actions that are appropriate for the inoperability of APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f, and these functions are not associated with specific trip systems as are the APRM 2-out-of-4 voter and other non-APRM channels, Condition B does not apply.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

C.1

Required Action C.1 is intended to ensure that appropriate actions are taken if multiple, inoperable, untripped channels within the same trip system for the same Function result in the Function not maintaining RPS trip capability. A Function is considered to be maintaining RPS trip capability when sufficient channels are OPERABLE or in trip (or the associated trip system is in trip), such that both trip systems will generate a trip signal from the given Function on a valid signal. For the typical Function with one-out-of-two taken twice logic and the IRM and APRM Functions, this would require both trip systems to have one channel OPERABLE or in trip (or the associated trip system in trip). For Function 5 (Main Steam Isolation Valve--Closure), this would require both trip systems to have each channel associated with the MSIVs in three main steam lines (not necessarily the same main steam lines for both trip systems) OPERABLE or in trip (or the associated trip system in trip).

For Function 8 (Turbine Stop Valve--Closure), this would require both trip systems to have three channels, each OPERABLE or in trip (or the associated trip system in trip).

The Completion Time is intended to allow the operator time to evaluate and repair any discovered inoperabilities. The 1 hour Completion Time is acceptable because it minimizes risk while allowing time for restoration or tripping of channels.

E.1, F.1, G.1, and J.1

If the channel(s) is not restored to OPERABLE status or placed in trip (or the associated trip system placed in trip) within the allowed Completion Time, the plant must be placed in a MODE or other specified condition in which the LCO does not apply. The allowed Completion Times are reasonable, based on operating experience, to reach the specified condition from full power conditions in an orderly manner and without challenging plant systems. In addition, the Completion Time of Required Actions E.1 and J.1 are consistent with the Completion Time provided in LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)."

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

ACTIONS

I.1

If OPRM Upscale trip capability is not maintained, Condition I exists and Backup Stability Protection (BSP) is required. Reference [11] justified use of alternate methods to detect and suppress oscillations for a limited period of time. The Manual BSP Regions are described in Reference [17]. The alternate Manual BSP Regions methods are are procedurally established consistent with the guidelines identified in Reference [1617] and requiring specified manual operator actions to scram the plant if certain predefined events operational conditions occur.

The Completion Time of immediate is based on the importance of The 12 hour allowed action time is based on engineering judgment to allow orderly transition to the alternate methods while limiting the period of time during which no automatic or alternate detect and suppress trip capability is formally in place. Based on the small probability of an instability event occurring at all, the 12 hours is judged to be reasonable.

I.2.1 and I.2.2

Actions I.2.1 and I.2.2 are both required to be taken in conjunction with Action I.1 if OPRM Upscale trip capability is not maintained. As described in Section 7.4 of Reference [17], the Automated BSP Scram Region is designed to avoid reactor instability by automatically preventing entry into the region of the power and flow-operating map that is susceptible to reactor instability. The reactor trip would be initiated by the modified APRM flow-biased scram setpoints for flow reduction events that would have terminated in the Manual BSP Region I. The Automated BSP Scram Region ensures an early scram and SLMCPR protection.

The Completion Time of 12 hours to complete the specified actions is reasonable, based on operational experience, and based on the importance of restoring an automatic reactor trip for thermal hydraulic instability events.

Backup Stability Protection is intended as a temporary means to protection against thermal-hydraulic instability events. The reporting requirements of Specification 5.6.9 document the corrective actions and schedule to restore the required channels to an OPERABLE status. The Completion Time of 90 days is adequate to allow time to evaluate the cause of the inoperability and to determine the appropriate corrective actions and schedule to restore the required channels to OPERABLE status.

J.1

If the Required Actions I are not completed within the associated Completion Times, then Action J is required. The Bases for the Manual BSP Regions and associated Completion Time is addressed in the Bases for I.1. The Manual BSP Regions are required in conjunction with the BSP Boundary.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

J.2

The BSP Boundary, as described in Section 7.3 of Reference [17], defines an operating domain where potential instability events can be effectively addressed by the specified BSP manual operator actions. The BSP Boundary is constructed such that the immediate final statepoint for a flow reduction event initiated from this boundary and terminated at the core natural circulation line (NCL) would not exceed the Manual BSP Region I stability criterion. Potential instabilities would develop slowly as a result of the feedwater temperature transient (Reference [17]).

The Completion Time of 12 hours to complete the specified actions is reasonable, based on operational experience, to reach the specific condition from full power conditions in an orderly manner and without challenging plant system.

J.3

Backup Stability Protection (BSP) is a temporary means for protection against thermal-hydraulic instability events. An extended period of inoperability without automatic trip capability is not justified. Consequently, the required channels are required to be restored to OPERABLE status within 120 days.

~~The alternate method to detect and suppress oscillations implemented in accordance with I.1 was evaluated (Reference [11]) based on use up to 120 days only. The evaluation, based on engineering judgment, concluded that the likelihood of an instability event that could not be adequately handled by the alternate methods use of the BSP Regions (See Action J.1) and the BSP Boundary (See J.2) during this a 120-day period was is negligibly small. The 120-day period is intended to be an outside limit to allow for the case where limited design changes or extensive analysis might be required to understand or correct some unanticipated characteristic of the instability detection algorithms or equipment. This action is not intended and was not evaluated as a routine alternative to returning failed or inoperable equipment to OPERABLE status. Correction of routine equipment failure or inoperability is expected to normally be accomplished within the completion times allowed for Actions for Conditions A and B.~~

K.1

If the required channels are not restored to OPERABLE status and the Required Actions of J are not met within the associated Completion Times, then the plant must be placed in an operating condition in which the LCO does not apply. To achieve this status, the plant must be brought to at least [20% RTP or Mode 2] within [4 or 6] hours. The allowed Completion Time is reasonable, based on operating experience, to reach the specified operating power level from full power conditions in an orderly manner and without challenging plant systems.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.1

Performance of the CHANNEL CHECK once every 12 hours ensures that a gross failure of instrumentation has not occurred. A CHANNEL CHECK is normally a comparison of the parameter indicated on one channel to a similar parameter on other channels. It is based on the assumption that instrument channels monitoring the same parameter should read approximately the same value. Significant deviations between instrument channels could be an indication of excessive instrument drift in one of the channels or something even more serious. A CHANNEL CHECK will detect gross channel failure; thus, it is key to verifying the instrumentation continues to operate properly between each CHANNEL CALIBRATION.

Agreement criteria are determined by the plant staff based on a combination of the channel instrument uncertainties, including indication and readability. If a channel is outside the criteria, it may be an indication that the instrument has drifted outside its limit.

The Frequency is based upon operating experience that demonstrates channel failure is rare. The CHANNEL CHECK supplements less formal, but more frequent, checks of channels during normal operational use of the displays associated with the channels required by the LCO.

SR 3.3.1.1.2

To ensure that the APRMs are accurately indicating the true core average power, the APRMs are calibrated to the reactor power calculated from a heat balance. LCO 3.2.4, "Average Power Range Monitor (APRM) Gain and Setpoints," allows the APRMs to be reading greater than actual THERMAL POWER to compensate for localized power peaking. When this adjustment is made, the requirement for the APRMs to indicate within 2% RTP of calculated power is modified to require the APRMs to indicate within 2% RTP of calculated MFLPD. The Frequency of once per 7 days is based on minor changes in LPRM sensitivity, which could affect the APRM reading between performances of SR 3.3.1.1.8.

A restriction to satisfying this SR when < 25% RTP is provided that requires the SR to be met only at $\geq 25\%$ RTP because it is difficult to accurately maintain APRM indication of core THERMAL POWER consistent with a heat balance when < 25% RTP. At low power levels, a high degree of accuracy is unnecessary because of the large, inherent margin to thermal limits (MCPR

NO CHANGE TO THIS PAGE

BWR/4 STS

B 3.3-25

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.6 and SR 3.3.1.1.7 (Continued)

A Frequency of 7 days is reasonable based on engineering judgment and the reliability of the IRMs and APRMs.

SR 3.3.1.1.8

LPRM gain settings are determined from the local flux profiles measured by the Traversing Incore Probe (TIP) System. This establishes the relative local flux profile for appropriate representative input to the APRM System. The [1000] MWD/T Frequency is based on operating experience with LPRM sensitivity changes.

SR 3.3.1.1.9 and SR 3.3.1.1.12

A CHANNEL FUNCTIONAL TEST is performed on each required channel to ensure that the entire channel will perform the intended function. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology. The 92 day Frequency of SR 3.3.1.1.9 is based on the reliability analysis of Reference 9.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.

SR 3.3.1.1.10

Calibration of trip units provides a check of the actual trip setpoints. The channel must be declared inoperable if the trip setting is discovered to be less conservative than the Allowable Value specified in Table 3.3.1.1-1. If the trip setting is discovered to be less conservative than accounted for in the appropriate setpoint methodology, but is not beyond the Allowable Value, the channel performance is still within the requirements of the plant safety analysis. Under these conditions, the setpoint must be

readjusted to be equal to or more conservative than accounted for in the appropriate setpoint methodology.

The Frequency of 92 days is based on the reliability analysis of Reference 9.

NOTE: The addition of "[J]" around the 1000 MWD/T in SR 3.3.1.1.8 above is to recognize that some plants have justified 2000 MWD/T. It is not related to the OPRM addition and does not affect the actual APRM change required by a plant.

NO CHANGE TO THIS PAGE

BWR/4 STS

B 3.3-28

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.11

A CHANNEL FUNCTIONAL TEST is performed on each required channel to ensure that the entire channel will perform the intended function. For the APRM Functions, this test supplements the automatic self-test functions that operate continuously in the APRM and voter channels. The APRM CHANNEL FUNCTIONAL TEST covers the APRM channels (including recirculation flow processing -- applicable to Function 2.b only), the 2-out-of-4 voter channels, and the interface connections into the RPS trip systems from the voter channels. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology. The 184 day Frequency of SR 3.3.1.1.11 is based on the reliability analysis of Reference [11]. (NOTE: The actual voting logic of the 2-Out-Of-4 Voter Function is tested as part of SR 3.3.1.1.15.)

A Note is provided for Function 2.a that requires this SR to be performed within 12 hours of entering MODE 2 from MODE 1. Testing of the MODE 2 APRM Function cannot be performed in MODE 1 without utilizing jumpers or lifted leads. This Note allows entry into MODE 2 from MODE 1 if the associated Frequency is not met per SR 3.0.2.

NOTE: *The addition of "for Function 2.a" in the above paragraph repeats what the note actually says for clarity. It is not related to the OPRM addition, and is optional for APRM changes in that it does not change the actual meaning.*

SR 3.3.1.1.13

A CHANNEL CALIBRATION is a complete check of the instrument loop and the sensor. This test verifies that the channel responds to the measured parameter within the necessary range and accuracy. CHANNEL CALIBRATION leaves the channel adjusted to account for instrument drifts between successive calibrations consistent with the plant specific setpoint methodology. For the APRM Simulated Thermal Power - High Function, this SR also includes calibrating the associated recirculation loop flow channel.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.13 (continued)

Note 1 states that neutron detectors are excluded from CHANNEL CALIBRATION because they are passive devices, with minimal drift, and because of the difficulty of simulating a meaningful signal. Changes in neutron detector sensitivity are compensated for by performing the 7 day calorimetric calibration (SR 3.3.1.1.2) and the [1000] MWD/T LPRM calibration against the TIPS (SR 3.3.1.1.8). A second Note is provided that requires the IRM SRs to be performed within 12 hours of entering MODE 2 from MODE 1. Testing of the MODE 2 IRM Functions cannot be performed in MODE 1 without utilizing jumpers, lifted leads, or movable links. This Note allows entry into MODE 2 from MODE 1 if the associated Frequency is not met per SR 3.0.2. Twelve hours is based on operating experience and in consideration of providing a reasonable time in which to complete the SR.

The Frequency of SR 3.3.1.1.13 is based upon the assumption of an 18 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis.

SR 3.3.1.1.14

(Not used.)

SR 3.3.1.1.15

The LOGIC SYSTEM FUNCTIONAL TEST demonstrates the OPERABILITY of the required trip logic for a specific channel. The functional testing of control rods (LCO 3.1.3), and SDV vent and drain valves (LCO 3.1.8), overlaps this Surveillance to provide complete testing of the assumed safety function.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.

The LOGIC SYSTEM FUNCTIONAL TEST for APRM Function 2.e simulates APRM and OPRM trip conditions at the 2-out-of-4 voter channel inputs to check all combinations of two tripped inputs to the 2-out-of-4 logic in the voter channels and APRM related redundant RPS relays.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.16

This SR ensures that scrams initiated from the Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions will not be inadvertently bypassed when THERMAL POWER is $\geq 30\%$ RTP. This involves calibration of the bypass channels. Adequate margins for the instrument setpoint methodologies are incorporated into the actual setpoint. Because main turbine bypass flow can affect this setpoint nonconservatively (THERMAL POWER is derived from turbine first stage pressure), the main turbine bypass valves must remain closed at THERMAL POWER $\geq 30\%$ RTP to ensure that the calibration remains valid.

If any bypass channel's setpoint is nonconservative (i.e., the Functions are bypassed at $\geq 30\%$ RTP, either due to open main turbine bypass valve(s) or other reasons), then the affected Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are considered inoperable. Alternatively, the bypass channel can be placed in the conservative condition (nonbypass). If placed in the nonbypass condition, this SR is met and the channel is considered OPERABLE.

The Frequency of 18 months is based on engineering judgment and reliability of the components.

SR 3.3.1.1.17

This SR ensures that the individual channel response times are less than or equal to the maximum values assumed in the accident analysis. This test may be performed in one measurement or in overlapping segments, with verification that all components are tested. The RPS RESPONSE TIME acceptance criteria are included in Reference [].

RPS RESPONSE TIME for the APRM 2-Out-Of-4 Voter Function (2.e) includes the output relays of the voter and the associated RPS relays and contactors. (The digital portion of the APRM and 2-out-of-4 voter channels are excluded from RPS RESPONSE TIME testing because self-testing and calibration checks the time base of the digital electronics. Confirmation of the time base is adequate to assure required response times are met. Neutron detectors are excluded from RPS RESPONSE TIME testing because the principles of detector operation virtually ensure an instantaneous response time.)

NOTE: Replacement of Reference "10" with "[]" is to avoid confusion. The NUREG includes a "10", but no actual Reference by that number. The reference should be to the utility's document containing response time testing requirements — not identified in this sample mark-up.

NO CHANGE TO THIS PAGE

BWR/4 STS

B 3.3-31

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS
(continued)

SR 3.3.1.1.17 (continued)

RPS RESPONSE TIME tests are conducted on an 18 month STAGGERED TEST BASIS. Note 2 requires STAGGERED TEST BASIS Frequency to be determined based on 4 channels per trip system, in lieu of the 8 channels specified in Table 3.3.1.1-1 for the MSIV Closure Function. This Frequency is based on the logic interrelationships of the various channels required to produce an RPS scram signal. The 18 month Frequency is consistent with the typical industry refueling cycle and is based upon plant operating experience, which shows that random failures of instrumentation components causing serious response time degradation, but not channel failure, are infrequent occurrences.

SR 3.3.1.1.18

~~This SR ensures that scrams initiated from OPRM Upscale Function (Function 2.f) will not be inadvertently bypassed when THERMAL POWER, as indicated by the APRM Simulated Thermal Power, is $\geq [30]\%$ RTP and core flow, as indicated by recirculation drive flow, is $\leq [60]\%$ rated core flow. This normally involves confirming the bypass setpoints. Adequate margins for the instrument setpoint methodologies are incorporated into the actual setpoint. The actual surveillance ensures that the OPRM Upscale Function is enabled (not bypassed) for the correct values of APRM Simulated Thermal Power and recirculation drive flow. Other surveillances ensure that the APRM Simulated Thermal Power and recirculation flow properly correlate with THERMAL POWER and core flow, respectively.~~

~~If any bypass setpoint is nonconservative (i.e., the OPRM Upscale Function is bypassed when APRM Simulated Thermal Power $\geq [30]\%$ and recirculation drive flow $\leq [60]\%$ rated), then the affected channel is considered inoperable for the OPRM Upscale Function. Alternatively, the bypass setpoint may be adjusted to place the channel in a conservative condition (nonbypass). If placed in the nonbypass condition, this SR is met and the channel is considered OPERABLE.~~

~~The Frequency of [18] months is based on engineering judgment and reliability of the components.~~

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

REFERENCES

1. FSAR, Figure [].
2. FSAR, Section [15.1.2].
3. NEDO-23842, "Continuous Control Rod Withdrawal in the Startup Range," April 18, 1978.
4. FSAR, Section [5.2.2].
5. FSAR, Section [15.1.38].
6. FSAR, Section [6.3.3].
7. FSAR, Chapter [15].
8. P. Check (NRC) letter to G. Lainas (NRC), "BWR Scram Discharge System Safety Evaluation," December 1, 1980.
9. NEDO-30851-P-A, "Technical Specification Improvement Analyses for BWR Reactor Protection System," March 1988.
10. FSAR, Table [7.2-2].
11. NEDC-32410P-A, "Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC PRNM) Retrofit Plus Option III Stability Trip Function", October 1995. ~~[March 1995].~~
12. ~~NEDO 31960 A, "BWR Owners' Group Long Term Stability Solutions Licensing Methodology," November 1995~~ Not used.
13. ~~NEDO 31960 A, Supplement 1, "BWR Owners' Group Long Term Stability Solutions Licensing Methodology," November 1995~~ Not used.
14. ~~NEDO 32465 A, "BWR Owners' Group Long Term Stability Detect and Suppress Solutions Licensing Basis Methodology And Reload Applications," [March 1996]~~ Not used.
15. NEDC-32410P-A, Supplement 1, "Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC PRNM) Retrofit Plus Option III Stability Trip Function", [August 1996].
16. ~~Letter, LA England (BWROG) to MJ Virgilio, "BWR Owners' Group Guidelines for Stability Interim Corrective Action", June 6, 1994~~ Not used.
17. NEDC-33075P, Revision 5, "General Electric Boiling Water Reactor Detect and Suppress Solution - Confirmation Density," November 2005.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

**APPENDIX B: EXAMPLE OF CHANGES TO BWR/4 STANDARD
TECHNICAL SPECIFICATIONS –
REVISION BAR VERSION**

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.1-1.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	OR A.2 -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- Place associated trip system in trip.	12 hours
B. -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	OR B.2 Place one trip system in trip.	6 hours
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < [30]% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies..	Immediately
I. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	I.1 Initiate action to implement the Manual BSP Regions defined in the COLR.	Immediately
	<u>AND</u> I.2.1 Implement the Automated BSP Scram Region using the modified APRM flow-biased scram setpoints defined in the COLR.	12 hours
	<u>AND</u> I.2.2 Initiate action in accordance with Specification 5.6.9.	90 days

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

CONDITION	REQUIRED ACTION	COMPLETION TIME
J. Required Action and associated Completion Time of Condition I not met.	<p>J.1 Initiate action to implement the Manual BSP Regions defined in the COLR.</p> <p>AND</p> <p>J.2 Reduce operation to below the BSP Boundary defined in the COLR.</p> <p>AND</p> <p>J.3 Restore required channel to OPERABLE</p>	<p>Immediately</p> <p>12 hours</p> <p>120 days</p>
K. Required Action and associated Completion Time of Condition J not met.	K.1 [Reduce THERMAL POWER to less than [20]% RTP or Be in Mode 2].	[4 or 6] hours

BWR/4 STS

3.3-2

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.1.2	<p>-----NOTE----- Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP.</p> <p>Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power is \leq 2% RTP [plus any gain adjustment required by LCO 3.2.4, "Average Power Range Monitor (APRM) Setpoints"] while operating at \geq 25% RTP.</p>	7 days
SR 3.3.1.1.3	(Not used.)	
SR 3.3.1.1.4	<p>-----NOTE----- Not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	7 days

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)		
SURVEILLANCE		FREQUENCY
SR 3.3.1.1.5	Perform CHANNEL FUNCTIONAL TEST.	7 days
SR 3.3.1.1.6	Verify the source range monitor (SRM) and intermediate range monitor (IRM) channels overlap.	Prior to withdrawing SRMs from the fully inserted position
SR 3.3.1.1.7	-----NOTE----- Only required to be met during entry into MODE 2 from MODE 1. ----- Verify the IRM and APRM channels overlap.	7 days
SR 3.3.1.1.8	Calibrate the local power range monitors.	[1000] MWD/T average core exposure
SR 3.3.1.1.9	Perform CHANNEL FUNCTIONAL TEST.	[92] days
+-- SR 3.3.1.1.10 +--	Calibrate the trip units.	[92] days ---+ ---+

(continued)

NOTE: The addition of "[]" around the 1000 MWD/T in SR 3.3.1.1.8 above is to recognize that some plants have justified 2000 MWD/T. It is not related to the OPRM addition and does not affect the actual APRM change required by a plant.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.11	<p>-----NOTE----- For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.</p>	184 days
SR 3.3.1.1.12	Perform CHANNEL FUNCTIONAL TEST.	[18] months
SR 3.3.1.1.13	<p>-----NOTES----- 1. Neutron detectors are excluded. 2. For Function 1, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. ----- Perform CHANNEL CALIBRATION.</p>	[18] months
SR 3.3.1.1.14	(Not used.)	
SR 3.3.1.1.15	Perform LOGIC SYSTEM FUNCTIONAL TEST.	[18] months

(continued)

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.16 Verify Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are not bypassed when THERMAL POWER is \geq [30]% RTP.	[18] months
SR 3.3.1.1.17 -----NOTES----- 1. Neutron detectors are excluded. 2. For Function 5 "n" equals 4 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. ----- Verify the RPS RESPONSE TIME is within limits.	[18] months on a STAGGERED TEST BASIS

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux—High	2	[3]	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [120/125] divisions of full scale
	5 (a)	[3]	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [120/125] divisions of full scale
b. Inop	2	[3]	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 (a)	[3]	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux—High, (Setdown)	2	3 ^(c)	G	SR 3.3.1.1.1 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [20] % RTP
b. Simulated Thermal Power—High	1	3 ^(c)	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [0.58 W + 62] % RTP and ≤ [115.5] % This advance down .01 code was inserted to comply with editor's request for added space to keep the "(b)" from running into the line above --bk 8/17/92RTP (b) (d)

(continued)

- (a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) [0.58 W + 62% - 0.58 ΔW] RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating."
- (c) Each APRM channel provides inputs to both trip systems.
- (d) With OPRM Upscale (function 2.f) inoperable, the modified APRM flow-biased setpoints defined by the COLR may be required to implement the Automated BSP Scram Region in accordance with Action I of this Specification.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
c. Neutron Flux—High	1	3 ^(c)	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	≤ [120] % RTP
d. Inop	1,2	3 ^(c)	G	SR 3.3.1.1.11	NA
e. 2-Out-Of-4 Voter	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.11 SR 3.3.1.1.15 SR 3.3.1.1.17	NA
f. OPRM Upscale	≥ [20] % RTP or 1 ^(e)	3 ^(c)	I	SR 3.3.1.1.1 SR 3.3.1.1.8 SR 3.3.1.1.11 SR 3.3.1.1.13	NA
3. Reactor Vessel Steam Dome Pressure—High	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ [1054] psig
4. Reactor Vessel Water Level—Low, Level 3	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≥ [10] inches
5. Main Steam Isolation Valve—Closure	1	[8]	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ [10] % closed
6. Drywell Pressure—High	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 [SR 3.3.1.1.10] SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [1.92] psig

(continued)

(c) Each APRM channel provides inputs to both trip systems.

(e) Following DSS-CD implementation, DSS-CD is not required to be armed while in the DSS-CD Armed Region during the first reactor startup and during the first controlled shutdown that passes completely through the DSS-CD Armed Region. However, DSS-CD shall be OPERABLE and capable of automatically arming consistent with Reference [17] for operation at recirculation drive flow rates above the DSS-CD Armed Region. The DSS-CD Armed Region is defined in Reference [17].

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
3.3.1.1

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level—High					
a. Resistance Temperature Detector	1,2	[2]	G	SR 3.3.1.1.1 SR 3.3.1.1.9 {SR 3.3.1.1.10} SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
	5 (a)	[2]	H	SR 3.3.1.1.1 SR 3.3.1.1.9 {SR 3.3.1.1.10} SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
b. Float Switch	1,2	[2]	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
	5 (a)	[2]	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ [57.15] gallons
8. Turbine Stop Valve— Closure	≥ [30] % RTP	[4]	E	SR 3.3.1.1.9 {SR 3.3.1.1.10} SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ [10] % closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure—Low	≥ [30] % RTP	[2]	E	SR 3.3.1.1.9 {SR 3.3.1.1.10} SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ [600] psig
10. Reactor Mode Switch— Shutdown Position	1,2	[2]	G	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
	5 (a)	[2]	H	SR 3.3.1.1.12 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	[2]	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 (a)	[2]	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

5.6 Reporting Requirements (continued)

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

The individual specifications that address core operating limits must be referenced here.

[For DSS-CD, the following is required in addition to the normal list of limits:]

1. The Manual Backup Stability Protection (BSP) Scram Region (Region I), the Manual BSP Controlled Entry Region (Region II), [the modified APRM flow-biased setpoints used in the Automated BSP Scram Region, or the BSP Boundary] for Specification 3.3.1.1.

- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

Identify the Topical Report(s) by number and title or identify the Staff Safety Evaluation Report for a plant specific methodology by NRC letter and date. The COLR will contain the complete identification for each of the TS referenced topical reports used to prepare the COLR (i.e., report number, title, revision, date, and any supplements.

- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

(continued)

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

5.6 Reporting Requirements (continued)

5.6.9 OPRM Report

When a report is required by Condition I of LCO 3.3.1.1, "RPS Instrumentation," a report shall be submitted within 90 days of entering the LCO. The report shall outline the preplanned means to provide backup stability protection, the cause of the inoperability, and the plans and schedule for restoring the required instrumentation channels to OPERABLE status.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE
SAFETY ANALYSES,
LCO, and
APPLICABILITY

BWR/6 STS Note: The wording of the BASES descriptions of APRM Functions is somewhat different from the corresponding Functions for the BWR/4 ISTS to reflect slight differences in the architecture. However, the replacement text will be very similar to that shown in this example mark-up.

Average Power Range Monitor (APRM)

The APRM channels provide the primary indication of neutron flux within the core and respond almost instantaneously to neutron flux increases. The APRM channels receive input signals from the local power range monitors (LPRMs) within the reactor core to provide an indication of the power distribution and local power changes. The APRM channels average these LPRM signals to provide a continuous indication of average reactor power from a few percent to greater than RTP. Each APRM also includes an Oscillation Power Range Monitor (OPRM) Upscale Function which monitors small groups of LPRM signals to detect thermal-hydraulic instabilities.

The APRM System is divided into four APRM channels and four 2-out-of-4 voter channels. Each APRM channel provides inputs to each of the four voter channels. The four voter channels are divided into two groups of two each, with each group of two providing inputs to one RPS trip system. The system is designed to allow one APRM channel, but no voter channels, to be bypassed. A trip from any one unbypassed APRM will result in a "half-trip" in all four of the voter channels, but no trip inputs to either RPS trip system. APRM trip Functions 2.a, 2.b, 2.c, and 2.d are voted independently from OPRM Upscale Function 2.f. Therefore, any Function 2.a, 2.b, 2.c, or 2.d trip from any two unbypassed APRM channels will result in a full trip in each of the four voter channels, which in turn results in two trip inputs into each RPS trip system logic channel (A1, A2, B1, and B2). Similarly, a Function 2.f trip from any two unbypassed APRM channels will result in a full trip from each of the four voter channels. Three of the four APRM channels and all four of the voter channels are required to be OPERABLE to ensure that no single failure will preclude a scram on a valid signal. In addition, to provide adequate coverage of the entire core, consistent with the design bases for the APRM Functions 2.a, 2.b, and 2.c, at least [20] LPRM inputs, with at least [three] LPRM inputs from each of the four axial levels at which the LPRMs are located, must be operable for each APRM channel. For the OPRM Upscale, Function 2.f, LPRMs are assigned to "cells" of [4] detectors. A minimum of [later] cells, each with a minimum of [2] LPRMs, must be OPERABLE for the OPRM Upscale Function 2.f to be OPERABLE.

BWR/4 STS

NO CHANGE TO THIS PAGE
B 3.3-7

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE SAFETY ANALYSES, LCO, and APPLICABILITY	<u>2.d. Average Power Range Monitor—Inop</u> Three of the four APRM channels are required to be OPERABLE for each of the APRM Functions. This Function (Inop) provides assurance that the minimum number of APRM channels are OPERABLE.
---	--

For any APRM channel, any time its mode switch is in any position other than "Operate," an APRM module is unplugged, or the automatic self-test system detects a critical fault with the APRM channel, an Inop trip is sent to all four voter channels. Inop trips from two or more unbypassed APRM channels result in a trip output from all four voter channels to their associated trip system.

This Function was not specifically credited in the accident analysis, but it is retained for the overall redundancy and diversity of the RPS as required by the NRC approved licensing basis.

There is no Allowable Value for this Function.

This Function is required to be OPERABLE in the MODES where the APRM Functions are required.

2.e. 2-Out-Of-4 Voter

The 2-Out-Of-4 Voter Function provides the interface between the APRM Functions, including the OPRM Upscale Function, and the final RPS trip system logic. As such, it is required to be OPERABLE in the MODES where the APRM Functions are required and is necessary to support the safety analysis applicable to each of those Functions. Therefore, the 2-Out-Of-4 Voter Function needs to be OPERABLE in MODES 1 and 2.

All four voter channels are required to be OPERABLE. Each voter channel includes self-diagnostic functions. If any voter channel detects a critical fault in its own processing, a trip is issued from that voter channel to the associated trip system.

The 2-Out-Of-4 Voter Function votes APRM Functions 2.a, 2.b, 2.c, and 2.d independently of Function 2.f. The voter also includes separate outputs to RPS for the two independently voted sets of Functions, each of which is redundant (four total outputs). The voter Function 2.e must be declared inoperable if any of its functionality is inoperable. However, due to the independent voting of APRM trips, and the redundancy of outputs, there may be conditions where the voter Function 2.e is inoperable, but trip capability for one or more of the other APRM Functions through that voter is still maintained. This may be considered when determining the condition of other APRM Functions resulting from partial inoperability of the Voter Function 2.e.

There is no Allowable Value for this Function.

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

APPLICABLE

SAFETY ANALYSES, 2.f. Oscillation Power Range Monitor (OPRM) Upscale
LCO, and

APPLICABILITY

The OPRM Upscale Function provides compliance with GDC 10 and GDC 12, thereby providing protection from exceeding the fuel MCPR safety limit (SL) due to anticipated thermal-hydraulic power oscillations.

Reference [17] describes the Detect and Suppress - Confirmation Density (DSS-CD) long-term stability solution and the licensing basis Confirmation Density Algorithm (CDA). Reference [17] also describes the DSS-CD Armed Region and the three additional algorithms for detecting thermal-hydraulic instability related neutron flux oscillations: the period based detection algorithm (PBDA), the amplitude based algorithm (ABA), and the growth rate algorithm (GRA). All four algorithms are implemented in the OPRM Upscale Function, but the safety analysis takes credit only for the CDA. The remaining three algorithms provide defense in depth and additional protection against unanticipated oscillations. OPRM Upscale Function OPERABILITY is based only on the CDA.

The OPRM Upscale Function receives input signals from the local power range monitors (LPRMs) within the reactor core, which are combined into "cells" for evaluation by the OPRM algorithms.

DSS-CD operability requires at least 8 responsive OPRM cells per channel.

The OPRM Upscale Function is required to be OPERABLE when the plant is [at greater than or equal to 5% RTP below the lower boundary of the Armed Region, which is 20% RTP or in Mode 1], encompassing the region of power-flow operation where anticipated events could lead to thermal-hydraulic instability and related neutron flux oscillations. The automatic trip is enabled when THERMAL POWER, as indicated by the APRM Simulated Thermal Power, is greater than or equal to the RTP corresponding to the plant-specific MCPR monitoring threshold and reactor recirculation drive flow, is less than [75 for MELLLA+ or 70 for MELLLA]% of rated flow. Note e allows for entry into the DSS-CD Armed Region without automatic arming of DSS-CD prior to completely passing through the DSS-CD Armed Region during both a single startup and a single shutdown following DSS-CD implementation. Note e reflects the need for plant data collection in order to test the DSS-CD equipment. Testing the DSS-CD equipment ensures its proper operation and prevents spurious reactor trips. Entry into the DSS-CD Armed Region without automatic arming of DSS-CD during this initial testing phase also allows for changes in plant operations to address maintenance or other operational needs. However, during this initial testing period, DSS-CD operability and capability to automatically arm shall be maintained at recirculation drive flow rates above the DSS-CD Armed Region.

An OPRM Upscale trip is issued from an OPRM channel when the confirmation density algorithm in that channel detects oscillatory changes in the neutron flux, indicated by period confirmations and amplitude exceeding specified setpoints for a specified number of OPRM cells in the channel. An OPRM Upscale trip is also issued from the channel if any of the defense-in-

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

depth algorithms (PBDA, ABA, GRA) exceed its trip condition for |
one or more cells in that channel.

Three of the four channels are required to be operable. Each channel is capable of detecting thermal-hydraulic instabilities, by detecting the related neutron flux oscillations, and issuing a trip signal before the MCPR SL is exceeded. There is no allowable value for this function.

BWR/4 STS

B 3.3-13a

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

A.1 and A.2A.1

Because of the diversity of sensors available to provide trip signals and the redundancy of the RPS design, an allowable out of service time of 12 hours has been shown to be acceptable (Ref. 9 and [11]) to permit restoration of any inoperable channel to OPERABLE status. However, this out of service time is only acceptable provided the associated Function's inoperable channel is in one trip system and the Function still maintains RPS trip capability (refer to Required Actions B.1, B.2, and C.1 Bases). If the inoperable channel cannot be restored to OPERABLE status within the allowable out of service time, the channel or the associated trip system must be placed in the tripped condition per Required Actions A.1 and A.2. Placing the inoperable channel in trip (or the associated trip system in trip) would conservatively compensate for the inoperability, restore capability to accommodate a single failure, and allow operation to continue. Alternatively, if it is not desired to place the channel (or trip system) in trip (e.g., as in the case where placing the inoperable channel in trip would result in a full scram), Condition D must be entered and its Required Action taken.

As noted, Action A.2 is not applicable for APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f. Inoperability of one required APRM channel affects both trip systems. For that condition, Required Action A.1 must be satisfied, and is the only action (other than restoring OPERABILITY) that will restore capability to accommodate a single failure. Inoperability of more than one required APRM channel of the same trip function results in loss of trip capability and entry into Condition C, as well as entry into Condition A for each channel.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

B.1 and B.2

Condition B exists when, for any one or more Functions, at least one required channel is inoperable in each trip system. In this condition, provided at least one channel per trip system is OPERABLE, the RPS still maintains trip capability for that Function, but cannot accommodate a single failure in either trip system.

Required Actions B.1 and B.2 limit the time the RPS scram logic, for any Function, would not accommodate single failure in both trip systems (e.g., one-out-of-one and one-out-of-one arrangement for a typical four channel Function). The reduced reliability of this logic arrangement was not evaluated in References 9 or [11] for the 12 hour Completion Time. Within the 6 hour allowance, the associated Function will have all required channels OPERABLE or in trip (or any combination) in one trip system.

Completing one of these Required Actions restores RPS to a reliability level equivalent to that evaluated in References 9 or [11], which justified a 12 hour allowable out of service time as presented in Condition A. The trip system in the more degraded state should be placed in trip or, alternatively, all the inoperable channels in that trip system should be placed in trip (e.g., a trip system with two inoperable channels could be in a more degraded state than a trip system with four inoperable channels if the two inoperable channels are in the same Function while the four inoperable channels are all in different Functions). The decision of which trip system is in the more degraded state should be based on prudent judgment and take into account current plant conditions (i.e., what MODE the plant is in). If this action would result in a scram or RPT, it is permissible to place the other trip system or its inoperable channels in trip.

The 6 hour Completion Time is judged acceptable based on the remaining capability to trip, the diversity of the sensors available to provide the trip signals, the low probability of extensive numbers of inoperabilities affecting all diverse Functions, and the low probability of an event requiring the initiation of a scram.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS B.1 and B.2 (continued)

Alternately, if it is not desired to place the inoperable channels (or one trip system) in trip (e.g., as in the case where placing the inoperable channel or associated trip system in trip would result in a scram [or RPT]), Condition D must be entered and its Required Action taken.

As noted, Condition B is not applicable for APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f. Inoperability of an APRM channel affects both trip systems and is not associated with a specific trip system as are the APRM 2-out-of-4 voter and other non-APRM channels for which Condition B applies. For an inoperable APRM channel, Required Action A.1 must be satisfied, and is the only action (other than restoring OPERABILITY) that will restore capability to accommodate a single failure. Inoperability of a Function in more than one required APRM channel results in loss of trip capability for that Function and entry into Condition C, as well as entry into Condition A for each channel. Because Conditions A and C provide Required Actions that are appropriate for the inoperability of APRM Functions 2.a, 2.b, 2.c, 2.d, or 2.f, and these functions are not associated with specific trip systems as are the APRM 2-out-of-4 voter and other non-APRM channels, Condition B does not apply.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

ACTIONS

C.1

Required Action C.1 is intended to ensure that appropriate actions are taken if multiple, inoperable, untripped channels within the same trip system for the same Function result in the Function not maintaining RPS trip capability. A Function is considered to be maintaining RPS trip capability when sufficient channels are OPERABLE or in trip (or the associated trip system is in trip), such that both trip systems will generate a trip signal from the given Function on a valid signal. For the typical Function with one-out-of-two taken twice logic and the IRM and APRM Functions, this would require both trip systems to have one channel OPERABLE or in trip (or the associated trip system in trip). For Function 5 (Main Steam Isolation Valve--Closure), this would require both trip systems to have each channel associated with the MSIVs in three main steam lines (not necessarily the same main steam lines for both trip systems) OPERABLE or in trip (or the associated trip system in trip).

For Function 8 (Turbine Stop Valve--Closure), this would require both trip systems to have three channels, each OPERABLE or in trip (or the associated trip system in trip).

The Completion Time is intended to allow the operator time to evaluate and repair any discovered inoperabilities. The 1 hour Completion Time is acceptable because it minimizes risk while allowing time for restoration or tripping of channels.

E.1, F.1, G.1, and J.1

If the channel(s) is not restored to OPERABLE status or placed in trip (or the associated trip system placed in trip) within the allowed Completion Time, the plant must be placed in a MODE or other specified condition in which the LCO does not apply. The allowed Completion Times are reasonable, based on operating experience, to reach the specified condition from full power conditions in an orderly manner and without challenging plant systems. In addition, the Completion Time of Required Actions E.1 and J.1 are consistent with the Completion Time provided in LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)."

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

ACTIONS

I.1

If OPRM Upscale trip capability is not maintained, Condition I exists and Backup Stability Protection (BSP) is required. The Manual BSP Regions are described in Reference [17]. The Manual BSP Regions are procedurally established consistent with the guidelines identified in Reference [17] and require specified manual operator actions if certain predefined operational conditions occur.

The Completion Time of immediate is based on the importance of limiting the period of time during which no automatic or alternate detect and suppress trip capability is in place.

I.2.1 and I.2.2

Actions I.2.1 and I.2.2 are both required to be taken in conjunction with Action I.1 if OPRM Upscale trip capability is not maintained. As described in Section 7.4 of Reference [17], the Automated BSP Scram Region is designed to avoid reactor instability by automatically preventing entry into the region of the power and flow-operating map that is susceptible to reactor instability. The reactor trip would be initiated by the modified APRM flow-biased scram setpoints for flow reduction events that would have terminated in the Manual BSP Region I. The Automated BSP Scram Region ensures an early scram and SLMCPR protection.

The Completion Time of 12 hours to complete the specified actions is reasonable, based on operational experience, and based on the importance of restoring an automatic reactor trip for thermal hydraulic instability events.

Backup Stability Protection is intended as a temporary means to protection against thermal-hydraulic instability events. The reporting requirements of Specification 5.6.9 document the corrective actions and schedule to restore the required channels to an OPERABLE status. The Completion Time of 90 days is adequate to allow time to evaluate the cause of the inoperability and to determine the appropriate corrective actions and schedule to restore the required channels to OPERABLE status.

J.1

If the Required Actions I are not completed within the associated Completion Times, then Action J is required. The Bases for the Manual BSP Regions and associated Completion Time is addressed in the Bases for I.1. The Manual BSP Regions are required in conjunction with the BSP Boundary.

J.2

The BSP Boundary, as described in Section 7.3 of Reference [17], defines an operating domain where potential instability events can be effectively addressed by the specified BSP manual operator actions. The BSP Boundary is constructed such that the immediate final statepoint for a flow reduction event initiated from this boundary and terminated at the core natural circulation line (NCL) would not exceed the Manual BSP Region I stability criterion. Potential instabilities would

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

develop slowly as a result of the feedwater temperature transient (Reference [17]).

The Completion Time of 12 hours to complete the specified actions is reasonable, based on operational experience, to reach the specific condition from full power conditions in an orderly manner and without challenging plant system.

J.3

Backup Stability Protection (BSP) is a temporary means for protection against thermal-hydraulic instability events. An extended period of inoperability without automatic trip capability is not justified. Consequently, the required channels are required to be restored to OPERABLE status within 120 days.

Based on engineering judgment, the likelihood of an instability event that could not be adequately handled by the use of the BSP Regions (See Action J.1) and the BSP Boundary (See J.2) during a 120-day period is negligibly small. The 120-day period is intended to allow for the case where limited design changes or extensive analysis might be required to understand or correct some unanticipated characteristic of the instability detection algorithms or equipment. This action is not intended and was not evaluated as a routine alternative to returning failed or inoperable equipment to OPERABLE status. Correction of routine equipment failure or inoperability is expected to normally be accomplished within the completion times allowed for Actions for Conditions A and B.

K.1

If the required channels are not restored to OPERABLE status and the Required Actions of J are not met within the associated Completion Times, then the plant must be placed in an operating condition in which the LCO does not apply. To achieve this status, the plant must be brought to at least [20% RTP or Mode 2] within [4 or 6] hours. The allowed Completion Time is reasonable, based on operating experience, to reach the specified operating power level from full power conditions in an orderly manner and without challenging plant systems.

BWR/4 STS

B 3.3-24a

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.1

Performance of the CHANNEL CHECK once every 12 hours ensures that a gross failure of instrumentation has not occurred. A CHANNEL CHECK is normally a comparison of the parameter indicated on one channel to a similar parameter on other channels. It is based on the assumption that instrument channels monitoring the same parameter should read approximately the same value. Significant deviations between instrument channels could be an indication of excessive instrument drift in one of the channels or something even more serious. A CHANNEL CHECK will detect gross channel failure; thus, it is key to verifying the instrumentation continues to operate properly between each CHANNEL CALIBRATION.

Agreement criteria are determined by the plant staff based on a combination of the channel instrument uncertainties, including indication and readability. If a channel is outside the criteria, it may be an indication that the instrument has drifted outside its limit.

The Frequency is based upon operating experience that demonstrates channel failure is rare. The CHANNEL CHECK supplements less formal, but more frequent, checks of channels during normal operational use of the displays associated with the channels required by the LCO.

SR 3.3.1.1.2

To ensure that the APRMs are accurately indicating the true core average power, the APRMs are calibrated to the reactor power calculated from a heat balance. LCO 3.2.4, "Average Power Range Monitor (APRM) Gain and Setpoints," allows the APRMs to be reading greater than actual THERMAL POWER to compensate for localized power peaking. When this adjustment is made, the requirement for the APRMs to indicate within 2% RTP of calculated power is modified to require the APRMs to indicate within 2% RTP of calculated MFLPD. The Frequency of once per 7 days is based on minor changes in LPRM sensitivity, which could affect the APRM reading between performances of SR 3.3.1.1.8.

A restriction to satisfying this SR when < 25% RTP is provided that requires the SR to be met only at $\geq 25\%$ RTP because it is difficult to accurately maintain APRM indication of core THERMAL POWER consistent with a heat balance when < 25% RTP. At low power levels, a high degree of accuracy is unnecessary because of the large, inherent margin to thermal limits (MCPR

NO CHANGE TO THIS PAGE

BWR/4 STS

B 3.3-25

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.6 and SR 3.3.1.1.7 (Continued)

A Frequency of 7 days is reasonable based on engineering judgment and the reliability of the IRMs and APRMs.

SR 3.3.1.1.8

LPRM gain settings are determined from the local flux profiles measured by the Traversing Incore Probe (TIP) System. This establishes the relative local flux profile for appropriate representative input to the APRM System. The [1000] MWD/T Frequency is based on operating experience with LPRM sensitivity changes.

SR 3.3.1.1.9 and SR 3.3.1.1.12

A CHANNEL FUNCTIONAL TEST is performed on each required channel to ensure that the entire channel will perform the intended function. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology. The 92 day Frequency of SR 3.3.1.1.9 is based on the reliability analysis of Reference 9.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.

SR 3.3.1.1.10

Calibration of trip units provides a check of the actual trip setpoints. The channel must be declared inoperable if the trip setting is discovered to be less conservative than the Allowable Value specified in Table 3.3.1.1-1. If the trip setting is discovered to be less conservative than accounted for in the appropriate setpoint methodology, but is not beyond the Allowable Value, the channel performance is still within the requirements of the plant safety analysis. Under these conditions, the setpoint must be

readjusted to be equal to or more conservative than accounted for in the appropriate setpoint methodology.

The Frequency of 92 days is based on the reliability analysis of Reference 9.

NOTE: The addition of "[J]" around the 1000 MWD/T in SR 3.3.1.1.8 above is to recognize that some plants have justified 2000 MWD/T. It is not related to the OPRM addition and does not affect the actual APRM change required by a plant.

BWR/4 STS

NO CHANGE TO THIS PAGE
B 3.3-28

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.11

A CHANNEL FUNCTIONAL TEST is performed on each required channel to ensure that the entire channel will perform the intended function. For the APRM Functions, this test supplements the automatic self-test functions that operate continuously in the APRM and voter channels. The APRM CHANNEL FUNCTIONAL TEST covers the APRM channels (including recirculation flow processing -- applicable to Function 2.b only), the 2-out-of-4 voter channels, and the interface connections into the RPS trip systems from the voter channels. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology. The 184 day Frequency of SR 3.3.1.1.11 is based on the reliability analysis of Reference [11]. (NOTE: The actual voting logic of the 2-Out-Of-4 Voter Function is tested as part of SR 3.3.1.1.15.)

A Note is provided for Function 2.a that requires this SR to be performed within 12 hours of entering MODE 2 from MODE 1. Testing of the MODE 2 APRM Function cannot be performed in MODE 1 without utilizing jumpers or lifted leads. This Note allows entry into MODE 2 from MODE 1 if the associated Frequency is not met per SR 3.0.2.

NOTE: *The addition of "for Function 2.a" in the above paragraph repeats what the note actually says for clarity. It is not related to the OPRM addition, and is optional for APRM changes in that it does not change the actual meaning.*

SR 3.3.1.1.13

A CHANNEL CALIBRATION is a complete check of the instrument loop and the sensor. This test verifies that the channel responds to the measured parameter within the necessary range and accuracy. CHANNEL CALIBRATION leaves the channel adjusted to account for instrument drifts between successive calibrations consistent with the plant specific setpoint methodology. For the APRM Simulated Thermal Power - High Function, this SR also includes calibrating the associated recirculation loop flow channel.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.13 (continued)

Note 1 states that neutron detectors are excluded from CHANNEL CALIBRATION because they are passive devices, with minimal drift, and because of the difficulty of simulating a meaningful signal. Changes in neutron detector sensitivity are compensated for by performing the 7 day calorimetric calibration (SR 3.3.1.1.2) and the [1000] MWD/T LPRM calibration against the TIPS (SR 3.3.1.1.8). A second Note is provided that requires the IRM SRs to be performed within 12 hours of entering MODE 2 from MODE 1. Testing of the MODE 2 IRM Functions cannot be performed in MODE 1 without utilizing jumpers, lifted leads, or movable links. This Note allows entry into MODE 2 from MODE 1 if the associated Frequency is not met per SR 3.0.2. Twelve hours is based on operating experience and in consideration of providing a reasonable time in which to complete the SR.

The Frequency of SR 3.3.1.1.13 is based upon the assumption of an 18 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis.

SR 3.3.1.1.14

(Not used.)

SR 3.3.1.1.15

The LOGIC SYSTEM FUNCTIONAL TEST demonstrates the OPERABILITY of the required trip logic for a specific channel. The functional testing of control rods (LCO 3.1.3), and SDV vent and drain valves (LCO 3.1.8), overlaps this Surveillance to provide complete testing of the assumed safety function.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.

The LOGIC SYSTEM FUNCTIONAL TEST for APRM Function 2.e simulates APRM and OPRM trip conditions at the 2-out-of-4 voter channel inputs to check all combinations of two tripped inputs to the 2-out-of-4 logic in the voter channels and APRM related redundant RPS relays.

NO CHANGE TO THIS PAGE

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.3.1.1.16

This SR ensures that scrams initiated from the Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions will not be inadvertently bypassed when THERMAL POWER is $\geq 30\%$ RTP. This involves calibration of the bypass channels. Adequate margins for the instrument setpoint methodologies are incorporated into the actual setpoint. Because main turbine bypass flow can affect this setpoint nonconservatively (THERMAL POWER is derived from turbine first stage pressure), the main turbine bypass valves must remain closed at THERMAL POWER $\geq 30\%$ RTP to ensure that the calibration remains valid.

If any bypass channel's setpoint is nonconservative (i.e., the Functions are bypassed at $\geq 30\%$ RTP, either due to open main turbine bypass valve(s) or other reasons), then the affected Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are considered inoperable. Alternatively, the bypass channel can be placed in the conservative condition (nonbypass). If placed in the nonbypass condition, this SR is met and the channel is considered OPERABLE.

The Frequency of 18 months is based on engineering judgment and reliability of the components.

SR 3.3.1.1.17

This SR ensures that the individual channel response times are less than or equal to the maximum values assumed in the accident analysis. This test may be performed in one measurement or in overlapping segments, with verification that all components are tested. The RPS RESPONSE TIME acceptance criteria are included in Reference [].

RPS RESPONSE TIME for the APRM 2-Out-Of-4 Voter Function (2.e) includes the output relays of the voter and the associated RPS relays and contactors. (The digital portion of the APRM and 2-out-of-4 voter channels are excluded from RPS RESPONSE TIME testing because self-testing and calibration checks the time base of the digital electronics. Confirmation of the time base is adequate to assure required response times are met. Neutron detectors are excluded from RPS RESPONSE TIME testing because the principles of detector operation virtually ensure an instantaneous response time.)

NOTE: Replacement of Reference "10" with "[]" is to avoid confusion. The NUREG includes a "10", but no actual Reference by that number. The reference should be to the utility's document containing response time testing requirements — not identified in this sample mark-up.

NO CHANGE TO THIS PAGE

BWR/4 STS

B 3.3-31

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

SURVEILLANCE
REQUIREMENTS
(continued)

SR 3.3.1.1.17 (continued)

RPS RESPONSE TIME tests are conducted on an 18 month STAGGERED TEST BASIS. Note 2 requires STAGGERED TEST BASIS Frequency to be determined based on 4 channels per trip system, in lieu of the 8 channels specified in Table 3.3.1.1-1 for the MSIV Closure Function. This Frequency is based on the logic interrelationships of the various channels required to produce an RPS scram signal. The 18 month Frequency is consistent with the typical industry refueling cycle and is based upon plant operating experience, which shows that random failures of instrumentation components causing serious response time degradation, but not channel failure, are infrequent occurrences.

BWR/4 STS

B 3.3-31a

Rev 1, 04/07/95

NEDO-33075, REVISION 5
NON-PROPRIETARY VERSION

RPS Instrumentation
B 3.3.1.1

BASES

REFERENCES

1. FSAR, Figure [].
2. FSAR, Section [15.1.2].
3. NEDO-23842, "Continuous Control Rod Withdrawal in the Startup Range," April 18, 1978.
4. FSAR, Section [5.2.2].
5. FSAR, Section [15.1.38].
6. FSAR, Section [6.3.3].
7. FSAR, Chapter [15].
8. P. Check (NRC) letter to G. Lainas (NRC), "BWR Scram Discharge System Safety Evaluation," December 1, 1980.
9. NEDO-30851-P-A, "Technical Specification Improvement Analyses for BWR Reactor Protection System," March 1988.
10. FSAR, Table [7.2-2].
11. NEDC-32410P-A, "Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC PRNM) Retrofit Plus Option III Stability Trip Function", October 1995.
12. Not used.
13. Not used.
14. Not used.
15. NEDC-32410P-A, Supplement 1, "Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC PRNM) Retrofit Plus Option III Stability Trip Function", [August 1996].
16. Not used.
17. NEDC-33075P, Revision 5, "General Electric Boiling Water Reactor Detect and Suppress Solution - Confirmation Density," November 2005.

BWR/4 STS

B 3.3-32

Rev 1, 04/07/9

ENCLOSURE 1

MFN 05-145

DSS-CD LTR Rev 5

IMPORTANT NOTICE

GE Proprietary Information

PROPRIETARY INFORMATION NOTICE

This enclosure contains proprietary information of the General Electric Company (GE) and is furnished in confidence solely for the purpose(s) stated in the transmittal letter. No other use, direct or indirect, of the document or the information it contains is authorized. Furnishing this enclosure does not convey any license, express or implied, to use any patented invention or, except as specified above, any proprietary information of GE disclosed herein or any right to publish or make copies of the enclosure without prior written permission of GE. The header of each page in this enclosure carries the notation "GE Proprietary Information."

GE proprietary information is identified by a double underline inside double square brackets. In each case, the superscript notation⁽³⁾ refers to Paragraph (3) of the affidavit provided in Enclosure 3, which documents the basis for the proprietary determination. [[This sentence is an example.⁽³⁾]] Specific information that is not so marked is not GE proprietary.