

December 19, 2005

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-05-013A

This preliminary notification constitutes EARLY notice of events of possible safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by Region II staff (Atlanta, Georgia) on this date.

Facility

Southern Nuclear Operating Company, Inc.
Vogtle Electric Generating Plant, Unit 2
Waynesboro, Georgia
Dockets/License: 50-425/NPF-81

Licensee Emergency Classification

Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
X Not Applicable

Subject: UPDATE-VOGTLE UNIT 2 SHUTDOWN TO REPAIR RESIDUAL HEAT REMOVAL PIPE LEAK

On December 16, 2005, the residual heat removal bypass line was satisfactorily repaired per ASME code repair requirements. The licensee determined the failure was due to a defect in the root pass of the weld. The licensee examined 11 other welds on the residual heat removal bypass lines and determined they were acceptable.

The unit was restarted on December 18, 2005, and is currently at 25 percent rated thermal power.

Region II received this information verbally from the Licensee. This information presented herein is current as of 10:00 a.m., EST, December 19, 2005.

CONTACT: Malcolm Widmann
404-562-4550

Gerald McCoy
706-554-9901