

February 7, 2006

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO EXTENSION DATE FOR CORRECTIVE ACTIONS REGARDING GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY RECIRCULATION DURING DESIGN BASIS ACCIDENTS AT PRESSURIZED-WATER REACTORS" (TAC NO. MC9564)

Dear Mr. Ridenoure:

By letter dated November 18, 2005, Omaha Public Power District (OPPD/the licensee) submitted a response to Generic Letter (GL) 2004-02 for the Fort Calhoun Station, Unit 1 (FCS). The licensee requested an extension for the GL closure date of December 31, 2007, to the end of the refueling outage scheduled to start in March 2008. The NRC has reviewed OPPD's letter dated November 18, 2005, in which it also provided information regarding the FCS considerations of Information Notice 2005-26. In OPPD's November 18, 2005, letter OPPD listed five corrective measures to be completed in the FCS 2006 refueling outage (including removal of significant quantities of calcium silicate insulation material from containment). This letter also described existing procedural guidance: (1) to shutdown, under certain conditions, redundant high pressure safety injection (HPSI) and core spray pumps to minimize the strainer approach velocity; (2) to reduce the total sump flow when pump cavitation is detected; and (3) to refill the safety injection refueling water tank (SIRWT) with HPSI re-alignment to draw a suction on the SIRWT and inject into the reactor coolant system, if HPSI suction via the containment sump strainers in the recirculation mode is lost.

In addition, OPPD indicated that its strategy for compliance with GL 2004-02, "Potential Impact of Debris Blockage on Emergency Recirculation During Design Basis Accidents at Pressurized-Water Reactors," was provided in the FCS August 31, 2005, followup response to GL 2004-02. This strategy has been to "procure sump strainers with sufficient margin to accommodate any chemical effects that were identified by industry testing." OPPD concluded that: "... OPPD has [now] determined that the chemical effects and potential downstream effects from the combination of trisodium phosphate (TSP) and calcium silicate insulation identified in Information Notice 2005-26 cannot be accommodated by this [current strainer sizing] strategy and will require additional testing (industry and plant-specific) and evaluation." OPPD described the envisioned testing and stated that such testing could not be completed in time to support design and installation of replacement sump strainers during the scheduled fall 2006 refueling outage. Therefore, OPPD stated that the implementation of the complete GSI-191 modifications by December 31, 2007, as required by GL 2004-02, could not be accomplished.

The Nuclear Regulatory Commission (NRC) staff has reviewed OPPD's submittal and had a teleconference on January 13, 2006, with OPPD to discuss this submittal. OPPD has stated

that it has developed an option (item 3 above) to only inject as an interim corrective measure, which would allow them to comply with Section 50.46 of Title 10 of the *Code of Federal Regulations* until a permanent solution is implemented. The NRC staff has determined that additional information is needed to complete our review. A request for additional information is enclosed. This request was discussed with Thomas Matthews of your staff on January 13, 2006, and it was agreed that a response would be provided within 30 days of receipt of this letter.

If you have any questions, please contact me at (301) 415-1445.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: Request for Additional Information

cc w/encl: See next page

which would allow them to comply with Section 50.46 of Title 10 of the *Code of Federal Regulations* until a permanent solution is implemented. The NRC staff has determined that additional information is needed to complete our review. A request for additional information is enclosed. This request was discussed with Thomas Matthews of your staff on January 13, 2006, and it was agreed that a response would be provided within 30 days of receipt of this letter.

If you have any questions, please contact me at (301) 415-1445.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

RidsNrrDorlLplg (DTerao)

RidsNrrLALFeizollahi

LPLIV R/F

RidsNrrPMAWang

RidsNrrDorlDpr

RidsRgn4MailCenter (DGraves)

RidsAcrsAcnwMailCenter

RidsOgcRp

ADAMS ACCESSION NO.: ML060180221

OFFICE	LPL4/PM	LPL4/LA	LPL4/BC
NAME	AWang	LFeizollahi	DTerao
DATE	02/06/06	02/06/06	02/07/06

Official Record Copy

REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 2004-02 EXTENSION REQUEST
OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION
DOCKET NO. 50-285

By letter dated November 18, 2005, Omaha Public Power District (OPPD/the licensee) submitted a response to Generic Letter (GL) 2004-02 for the Fort Calhoun Station, Unit 1 (FCS). The licensee requested an extension for the GL closure date of December 31, 2007, to the end of the refueling outage scheduled to start in March 2008. The Nuclear Regulatory Commission (NRC) staff has reviewed OPPD's submittal and had a teleconference on January 13, 2006, with OPPD to discuss this submittal.

OPPD indicated that its strategy for compliance with Generic Letter 2004-02, "Potential Impact of Debris Blockage on Emergency Recirculation during Design Basis Accidents at Pressurized-Water Reactors," was provided in the FCS August 31, 2005, followup response to Generic Letter 2004-02. Its strategy has been to "procure sump strainers with sufficient margin to accommodate any chemical effects that were identified by industry testing." OPPD has stated that it has developed an option to only inject as an interim corrective measure that would allow them to comply with Section 50.46 of Title 10 of the *Code of Federal Regulations* until a permanent solution is implemented. The NRC has reviewed OPPD's letter dated November 18, 2005, with respect to filling the containment to the top of the hot leg using high pressure safety injection (HPSI) suction on the safety injection refueling water tank (SIRWT). Please address the following issues related to this approach:

1. What are the physical stresses on the containment building as a result of the higher containment water levels using this approach?
2. OPPD stated that it would "enhance procedures to identify equipment and instrumentation that could be affected by flooding the containment above the flood level assumed for equipment qualification," but did not list this equipment and instrumentation and any measures to preserve their functionality or deal with their malfunction,
3. OPPD should describe its systems or methods for measuring water level "above the maximum water level at the start of recirculation,"
4. List the hierarchy of water sources for SIRWT refill, or discuss the flow paths and flow rates which could be achieved in accomplishing refill, and
5. Discuss the actual refill flow rates versus the required refill flow rates, and resultant SIRWT water levels at the various times during which this direct injection lineup would be used in lieu of the recirculation mode (e.g., does OPPD show that the SIRWT does not go empty while HPSI pump suction is required?).

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

January 2006