

February 14, 2006

Mr. Christopher M. Crane, President
and Chief Executive Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, Illinois 60555

SUBJECT: BRAIDWOOD STATION, UNITS 1 AND 2; BYRON STATION, UNITS 1 AND 2;
CLINTON POWER STATION, UNIT 1; DRESDEN NUCLEAR STATION, UNITS 1,
2, AND 3; LASALLE COUNTY STATION, UNITS 1 AND 2; AND QUAD CITIES
NUCLEAR POWER STATION, UNITS 1 AND 2 RE: APPROVAL OF CHANGES
TO THE EXELON NUCLEAR STANDARDIZED RADIOLOGICAL EMERGENCY
PLAN, AND BYRON AND QUAD CITIES STATIONS EMERGENCY PLAN
ANNEXES (TAC NOS. MC7492 THROUGH MC7502)

Dear Mr. Crane:

By letter dated June 21, 2005 (Agencywide Documents Access and Management System
Accession No. ML051790238), Exelon Generation Company, LLC and AmerGen Energy
Company, requested changes to the Byron Station Emergency Plan Annex (EP-AA-1002), the
Quad Cities Station Emergency Plan Annex (EP-AA-1006), and the Exelon Nuclear
Standardized Radiological Emergency Plan (EP-AA-1000).

The proposed changes would consolidate the two Joint Information Centers within the State of
Illinois into a single facility. This consolidation would result in an additional change that
eliminates three Emergency Response Organization positions.

The U.S. Nuclear Regulatory Commission (NRC) staff has completed its review of your
submittal and the supporting documentation. Based on its review, the staff concludes that the
proposed changes meet the requirements of Title 10 of the *Code of Federal Regulations*
(10 CFR), Section 50.47(b), and Appendix E to 10 CFR Part 50. Therefore, the staff finds that
the changes are acceptable. The basis for our conclusion is contained in the enclosed safety
evaluation. If you have comments regarding this matter, please contact Kahtan Jabbour at
301-415-1496.

Sincerely,

/RA/

Kahtan N. Jabbour, Senior Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Numbers: STN 50-456 and STN 50-457; STN 50-454 and STN 50-455; 50-461; 50-10,
50-237, 50-249 and 72-37; 50-373 and 50-374; and 50-254 and 50-265.

Enclosure: As stated

cc w/encl: See next page

Mr. Christopher M. Crane, President
and Chief Executive Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, Illinois 60555

February 14, 2006

SUBJECT: BRAIDWOOD STATION, UNITS 1 AND 2; BYRON STATION, UNITS 1 AND 2;
CLINTON POWER STATION, UNIT 1; DRESDEN NUCLEAR STATION, UNITS 1,
2, AND 3; LASALLE COUNTY STATION, UNITS 1 AND 2; AND QUAD CITIES
NUCLEAR POWER STATION, UNITS 1 AND 2 RE: APPROVAL OF CHANGES
TO THE EXELON NUCLEAR STANDARDIZED RADIOLOGICAL EMERGENCY
PLAN, AND BYRON AND QUAD CITIES STATIONS EMERGENCY PLAN
ANNEXES (TAC NOS. MC7492 THROUGH MC7502)

Dear Mr. Crane:

By letter dated June 21, 2005 (Agencywide Documents Access and Management System
Accession No. ML051790238), Exelon Generation Company, LLC and AmerGen Energy
Company, requested changes to the Byron Station Emergency Plan Annex (EP-AA-1002), the
Quad Cities Station Emergency Plan Annex (EP-AA-1006), and the Exelon Nuclear
Standardized Radiological Emergency Plan (EP-AA-1000).

The proposed changes would consolidate the two Joint Information Centers within the State of
Illinois into a single facility. This consolidation would result in an additional change that
eliminates three Emergency Response Organization positions.

The U.S. Nuclear Regulatory Commission (NRC) staff has completed its review of your
submittal and the supporting documentation. Based on its review, the staff concludes that the
proposed changes meet the requirements of Title 10 of the *Code of Federal Regulations*
(10 CFR), Section 50.47(b), and Appendix E to 10 CFR Part 50. Therefore, the staff finds that
the changes are acceptable. The basis for our conclusion is contained in the enclosed safety
evaluation. If you have comments regarding this matter, please contact Kahtan Jabbour at
301-415-1496.

Sincerely,

/RA/

Kahtan N. Jabbour, Senior Project Manager
Plant Licensing Branch III-2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Numbers: STN 50-456 and STN 50-457; STN 50-454 and STN 50-455; 50-461; 50-10,
50-237, 50-249 and 72-37; and 50-254 and 50-265.

Enclosure: As stated
cc w/encl: See next page

DISTRIBUTION:

PUBLIC

JHoncharick

JHickman

RidsNrrPMKJa
bbour

RidsOgcRp
LPLIII-2 R/F
RidsAcrsAcnwMailCenter

SSands
MBanerjee
RKuntz

EWeiss (EWW)
DJohnson (DAJ3)
CCraig

RidsNrrLADClarke
RidsRgn3MailCenter
DORL DPR (BKS1)

ADAMS ACCESSION NO: **ML060450538**

OFFICE	LPLIII-2/PM	LPLIII-2/LA	NSIR/DPR/EPD	OGC	LPLIII-2/BC(A)
NAME	KJabbour	DClarke (DJohnson for)	EWeiss	DFochter nlo w/comments	MLandau
DATE	2/14/06	2/14/06	2/8/06	2/1/06	2/14/06

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO PROPOSED EMERGENCY PLAN CHANGES
FOR
BRAIDWOOD STATION, UNITS 1 AND 2; BYRON STATION, UNITS 1 AND 2;
CLINTON POWER STATION, UNIT 1; DRESDEN NUCLEAR STATION, UNITS 1, 2, AND 3;
LASALLE COUNTY STATION, UNITS 1 AND 2; AND QUAD CITIES NUCLEAR POWER
STATION, UNITS 1 AND 2;
DOCKET NUMBERS: STN 50-456 AND STN 50-457; STN 50-454 AND
STN 50-455; 50-461; 50-10, 50-237, 50-249 AND 72-37;
50-373 AND 50-374; AND 50-254 AND 50-265

1.0 INTRODUCTION

By letter dated June 21, 2005 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML051790238), Exelon Generation Company and AmerGen Energy Company (the licensees), requested changes to the Exelon Nuclear Standardized Radiological Emergency Plan (EP) and the associated Byron Station and Quad Cities Station EP Annexes. The licensees are proposing changes to the EP that consolidate two Joint Information Centers (JICs) within the State of Illinois into a single facility. This consolidation results in additional changes that would eliminate three Emergency Response Organization (ERO) positions.

The licensees currently use the Morrison JIC for Byron and Quad Cities Stations. The proposed changes centralize the Morrison JIC with the JIC located in Warrenville, Illinois. The Warrenville JIC currently services Braidwood, Clinton, Dresden, and La Salle Stations, as well as being co-located with the licensee's Midwest Emergency Operations Facility (EOF).

Due to the proposed centralization of all Morrison JIC activities in the same facility as the EOF, some of the existing ERO positions associated with performance of EOF and remote JIC functions are no longer necessary and could be eliminated (e.g., JIC Public Information Liaison, and EOF Emergency News Center Technical and Radiological Advisors).

The physical relocation of the JIC only affects the Byron and Quad Cities Stations, while the elimination of ERO positions affects Braidwood, Byron, Clinton, Dresden, La Salle, and Quad Cities.

2.0 REGULATORY EVALUATION

The applicable regulations and guidance that the licensees must meet for the EPs are as follows:

2.1 Regulations

The underlying purpose of the standards in Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.47(b), is to ensure nuclear power reactor licensees have emergency response plans that provide reasonable assurance that adequate protective measures will be taken in the event of an emergency at a nuclear power reactor.

The following regulatory requirements are applicable:

10 CFR 50.47(b)(2): "On-shift facility licensee responsibilities for emergency response are unambiguously defined, adequate staffing to provide initial facility accident response in key functional areas is maintained at all times, timely augmentation of response capabilities is available and the interfaces among various onsite response activities and offsite support and response activities are specified."

10 CFR 50.47(b)(7): "Information is made available to the public on a periodic basis on how they will be notified and what their initial actions should be in an emergency (e.g., listening to a local broadcast station and remaining indoors), the principal points of contact with the news media for dissemination of information during an emergency (including the physical location or locations) are established in advance, and procedures for coordinated dissemination of information to the public are established."

10 CFR 50.47 (b)(8): "Adequate emergency facilities and equipment to support the emergency response are provided and maintained."

2.2 Guidance

NRC Regulatory Issue Summary 2005-02, "Clarifying the Process for Making Emergency Plan Changes," dated February 14, 2005, provides guidance to licensees making changes to their EPs.

Sections II.B.6, II.B.7d, II.G.3a, II.G.3b, II.G.4.a, II.G.4.b, II.G.4.c, and II.H.4 of NUREG-0654/FEMA [Federal Emergency Management Agency]-REP-1, Revision 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants," are applicable to this evaluation.

3.0 TECHNICAL EVALUATION

The proposed revision to the applicable EPs was evaluated by the licensees to be a potential decrease in effectiveness (DIE). Consequently, the proposed changes had to be submitted to the NRC for approval prior to implementation, as required by 10 CFR 50.54(q).

The evaluation below is based on the NRC staff's review of the licensees' technical and regulatory analysis in support of the proposed EP changes as provided in the submittal dated June 21, 2005.

The licensees stated that the relocation of the Byron and Quad Cities Station JIC to Warrenville offers several enhancements, including closer proximity to Chicago and the major news media outlets, closer proximity to the NRC Region III office, better utilization of existing cellular and wireless communication systems surrounding the Warrenville area, and consolidation of all the licensees' midwest nuclear stations' JIC functions into a centralized location. The licensees provided a letter from the State of Iowa and an e-mail from the State of Illinois (ADAMS Accession No. ML060400343) that document their concurrence with the relocation of the JIC. The NRC staff has determined that this relocation, as stated in the proposal, is acceptable.

The elimination of the following ERO positions was evaluated for impact on the Exelon Nuclear Standardized Radiological EP.

JIC Public Information Liaison

The licensees stated that due to the relocation, the need for an extra ERO position to coordinate information flow between the EOF and JIC was removed (note that this responsibility was also redundant to that of the Public Information Director). The responsibility for ensuring that approved news releases and chronological event description logs are made available will be transferred to the JIC Coordinator. The NRC staff verified that this change does not unduly impact the ability of the JIC Coordinator to perform their assigned responsibilities. This change is considered acceptable.

EOF Emergency News Center Technical Advisor

The licensees stated that the responsibilities of this position will be transferred to the Technical Spokesperson in the common JIC. The responsibilities of the Technical Spokesperson were evaluated by the NRC staff to ensure that this position was not adversely affected by this proposed change and it was determined that the additional responsibilities of the EOF Emergency News Center Technical Advisor would not adversely impact the performance of the Technical Spokesperson. This change is considered acceptable.

EOF Emergency News Center Radiological Advisor

The licensees stated that the responsibilities of this position will be transferred to the Radiation Protection Spokesperson in the common JIC. The responsibilities of the Radiation Protection Spokesperson were evaluated by the NRC staff to ensure that this position was not adversely affected by this proposed change and it was determined that the additional responsibilities of the EOF Emergency News Center Radiological Advisor would not adversely impact the performance of the Radiological Protection Spokesperson. This change is considered acceptable.

4.0 CONCLUSION

The staff performed a review of the proposed changes to the Exelon Nuclear Standardized Radiological EP and the associated Byron Station and Quad Cities Station EP Annexes. As such, the proposed EP changes meet the requirements of 10 CFR 50.47(b). The staff has determined, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the approval of the proposed EP changes will not be inimical to the common defense and security or to the health and safety of the public.

The proposed changes to the Exelon Nuclear Standardized Radiological EP and the associated Byron Station and Quad Cities Station EP Annexes, as reflected in the submitted documentation, are acceptable.

Principal Contributor: D. Johnson, NSIR

Date: February 14, 2006

Clinton Power Station, Unit 1

cc:

Senior Vice President - Nuclear Services
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Boiling Water Reactors
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and
Regulatory Affairs
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden, Quad Cities,
and Clinton
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regulatory Assurance Manager - Clinton
AmerGen Energy Company, LLC
Clinton Power Station
RR3, Box 228
Clinton, IL 61727-9351

Director - Licensing and Regulatory Affairs
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Document Control Desk-Licensing
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Clinton Power Station
AmerGen Energy Company, LLC
Clinton Power Station
RR 3, Box 228
Clinton, IL 61727-9351

Clinton Power Station Plant Manager
AmerGen Energy Company, LLC
Clinton Power Station
RR 3, Box 228
Clinton, IL 61727-9351

Resident Inspector
U.S. Nuclear Regulatory Commission
RR #3, Box 229A
Clinton, IL 61727

Chief Operating Officer
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Associate General Counsel
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

R. T. Hill
Licensing Services Manager
General Electric Company
175 Curtner Avenue, M/C 481
San Jose, CA 95125

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, IL 61727

Clinton Power Station, Unit 1

- 2 -

cc:

J. W. Blattner
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, IL 60603

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Byron/Braidwood Stations

cc:

Dwain W. Alexander, Project Manager
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355
Pittsburgh, PA 15230-0355

Joseph Gallo
Gallo & Ross
1025 Connecticut Ave., NW, Suite 1014
Washington, DC 20036

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
35 East Wacker Dr., Suite 1300
Chicago, IL 60601-2110

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 N. German Church Road
Byron, IL 61010-9750

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Ms. Lorraine Creek
RR 1, Box 182
Manteno, IL 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, IL 61061

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, IL 61107

George L. Edgar
Morgan, Lewis and Bockius
1800 M Street, NW
Washington, DC 20036-5869

Attorney General
500 S. Second Street
Springfield, IL 62701

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Byron Station Plant Manager
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Site Vice President - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

U.S. Nuclear Regulatory Commission
Braidwood Resident Inspectors Office
35100 S. Rt. 53, Suite 79
Braceville, IL 60407

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, IL 60434

Braidwood Station Plant Manager
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Ms. Bridget Little Rorem
Appleseed Coordinator
117 N. Linden Street
Essex, IL 60935

cc:

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Braidwood, Byron
and LaSalle
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Braidwood
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Pressurized Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regulatory Assurance Manager - Braidwood
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Regulatory Assurance Manager - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and
Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Peach Bottom Atomic Power Station, Unit Nos. 2 and 3

cc:

Site Vice President
Peach Bottom Atomic Power Station
Exelon Generation Company, LLC
1848 Lay Road
Delta, PA 17314

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Plant Manager
Peach Bottom Atomic Power Station
Exelon Generation Company, LLC
1848 Lay Road
Delta, PA 17314

Regulatory Assurance Manager
Peach Bottom Atomic Power Station
Exelon Generation Company, LLC
1848 Lay Road
Delta, PA 17314

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, PA 17314

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Roland Fletcher
Department of Environment
Radiological Health Program
2400 Broening Highway
Baltimore, MD 21224

Correspondence Control Desk
Exelon Generation Company, LLC
P. O. Box 160
Kennett Square, PA 19348

Rich Janati, Chief
Division of Nuclear Safety
Bureau of Radiation Protection
Department of Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Board of Supervisors
Peach Bottom Township
545 Broad Street Ext.
Delta, PA 17314-9203

Mr. Richard McLean
Power Plant and Environmental
Review Division
Department of Natural Resources
B-3, Tawes State Office Building
Annapolis, MD 21401

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Manager-Financial Control & Co-Owner
Affairs
Public Service Electric and Gas Company
P.O. Box 236
Hancocks Bridge, NJ 08038-0236

Manager Licensing-Peach Bottom
Atomic Power Station
Exelon Generation Company, LLC
200 Exelon Way, KSA -3E
Kennett Square, PA 19348

Peach Bottom Atomic Power Station,
Unit Nos. 2 and 3

-2-

cc:

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President-Operations Mid-Atlantic
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Senior Vice President, Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director-Licensing and Regulatory Affairs
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-E
Kennett Square, PA 19348

Dresden and Quad Cities Nuclear Power Stations

cc:

Site Vice President - Dresden Nuclear Power Station
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Dresden Nuclear Power Station Plant Manager
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Regulatory Assurance Manager - Dresden
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

U.S. Nuclear Regulatory Commission
Dresden Resident Inspectors Office
6500 N. Dresden Road
Morris, IL 60450-9766

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, IL 60450

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Boiling Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden,
Quad Cities and Clinton
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Quad Cities Nuclear
Power Station
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Nuclear Power Station
Plant Manager
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Dresden and Quad Cities Nuclear Power Stations

- 2 -

cc:

Regulatory Assurance Manager - Quad
Cities

Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Resident Inspectors Office
U.S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, IL 61242

David C. Tubbs
MidAmerican Energy Company
One River Center Place
106 E. Second, P.O. Box 4350
Davenport, IA 52808-4350

Vice President - Law and Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, IA 52808

Chairman
Rock Island County Board of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, IL 61201

Oyster Creek Nuclear Generating Station

cc:

Chief Operating Officer
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Oyster Creek
Generating Station
AmerGen Energy Company, LLC
P.O. Box 388
Forked River, NJ 08731

Vice President - Mid-Atlantic
Operations
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

John E. Matthews, Esquire
Morgan, Lewis, & Bockius LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Kent Tosch, Chief
New Jersey Department of
Environmental Protection
Bureau of Nuclear Engineering
CN 415
Trenton, NJ 08625

Vice President - Licensing and
Regulatory Affairs
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Operations Support
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mayor of Lacey Township
818 West Lacey Road
Forked River, NJ 08731

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 445
Forked River, NJ 08731

Director - Licensing and Regulatory Affairs
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-E
Kennett Square, PA 19348

Manager Licensing - Oyster Creek
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-E
Kennett Square, PA 19348

Oyster Creek Generating Station Plant
Manager
AmerGen Energy Company, LLC
P.O. Box 388
Forked River, NJ 08731

Regulatory Assurance Manager
Oyster Creek
AmerGen Energy Company, LLC
P.O. Box 388
Forked River, NJ 08731

Oyster Creek Nuclear Generating Station -2-

cc:

Vice President, General Counsel and
Secretary
AmerGen Energy Company, LLC
2301 Market Street, S23-1
Philadelphia, PA 19101

Pete Eselgroth, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Correspondence Control Desk
AmerGen Energy Company, LLC
P.O. Box 160
Kennett Square, PA 19348

LaSalle County Station Units 1 and 2

cc:

Site Vice President - LaSalle County Station
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

LaSalle County Station Plant Manager
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

Regulatory Assurance Manager - LaSalle
Exelon Generation Company, LLC
2601 North 21st Road
Marseilles, IL 61341-9757

U.S. Nuclear Regulatory Commission
LaSalle Resident Inspectors Office
2605 North 21st Road
Marseilles, IL 61341-9756

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, IL 60603

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, IL 60601

Chairman
LaSalle County Board
707 Etna Road
Ottawa, IL 61350

Attorney General
500 S. Second Street
Springfield, IL 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, IL 62706

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, IL 60601

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Boiling Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden, Quad Cities
and Clinton
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Limerick Generating Station, Unit Nos. 1 and 2

cc:

Site Vice President
Limerick Generating Station
Exelon Generation Company, LLC
P.O. Box 2300
Sanatoga, PA 19464

Plant Manager
Limerick Generating Station
Exelon Generation Company, LLC
P.O. Box 2300
Sanatoga, PA 19464

Regulatory Assurance Manager - Limerick
Exelon Generation Company, LLC
P.O. Box 2300
Sanatoga, PA 19464

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Operations, Mid-Atlantic
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Vice President
Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director
Licensing and Regulatory Affairs
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-E
Kennett Square, PA 19348

Manager Licensing
Limerick Generating Station
Exelon Generation Company, LLC
200 Exelon Way, KSA 3-E
Kennett Square, PA 19348

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Correspondence Control Desk
Exelon Generation Company, LLC
P.O. Box 160
Kennett Square, PA 19348

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Limerick Generating Station
P.O. Box 596
Pottstown, PA 19464

Library
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Chief-Division of Nuclear Safety
PA Dept. of Environmental Resources
P.O. Box 8469
Harrisburg, PA 17105-8469

Chairman
Board of Supervisors of Limerick Township
646 West Ridge Pike
Linfield, PA 19468

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Three Mile Island Nuclear Station, Unit 1

cc:

Site Vice President - Three Mile Island Nuclear
Station, Unit 1
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

Senior Vice President Nuclear Services
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Mid-Atlantic Operations Support
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Senior Vice President -
Mid Atlantic Regional Operating Group
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Vice President -
Licensing and Regulatory Affairs
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Director - Licensing - Mid-Atlantic Regional
Operating Group
AmerGen Energy Company, LLC
Nuclear Group Headquarters
Correspondence Control
P.O. Box 160
Kennett Square, PA 19348

Rich Janati, Chief
Division of Nuclear Safety
Bureau of Radiation Protection
Department of Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Three Mile Island Nuclear Station, Unit 1
Plant Manager
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

Regulatory Assurance Manager - Three Mile
Island Nuclear Station, Unit 1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

John F. Rogge, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Michael A. Schoppman
Framatome ANP
Suite 705
1911 North Ft. Myer Drive
Rosslyn, VA 22209

Three Mile Island Nuclear Station, Unit 1

cc:

Vice President, General Counsel and Secretary
AmerGen Energy Company, LLC
2301 Market Street, S23-1
Philadelphia, PA 19101

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Eric Epstein
TMI Alert
4100 Hillsdale Road
Harrisburg, PA 17112

Correspondence Control Desk
AmerGen Energy Company, LLC
200 Exelon Way, KSA 1-N
Kennett Square, PA 19348

Manager Licensing - Oyster Creek and Three Mile Island
AmerGen Energy Company, LLC
Nuclear Group Headquarters
Correspondence Control
P.O. Box 160
Kennett Square, PA 19348

Mr. John L. Skolds, Chairman
and Chief Executive Officer
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555