 SYSTEM INTENDED
FUNCTION BOUNDAR




COMPONENTS SUBJECT TO AMR



**CONDENSATE STORAGE
SYSTEM AMPM-27**

NOTES:

1. THE MAKE-UP AND REJECT LINE IS ALSO USED FOR REFUELING RETURN FLOW FROM THE REACTOR WELL WA CONDENSATE DEMINERALIZER.
2. RADIATION ELEMENT RE 1741 IS ABANDONED IN PLACE AND IS NON FUNCTIONAL.
3. THE 1/2" - 3/4" COOLING WATER LINE TO AIR BLOWERS WAS ORIGINALLY SUPPLIED FROM THE DOMESTIC WATER SYSTEM 34. F01-11-21 CONNECTED TO DEMINERALIZED WATER SYSTEM. ORIGINAL DESIGN SYSTEM AND PIPE CLASS SHOULD BE MAINTAINED. THIS LINE MAY BE SUPPLIED FROM EITHER THE DOMESTIC WATER OR DEMINERALIZED WATER SYSTEM.
4. INTERNALS OF CHECK VALVES 26-OK-73 AND 26-OK-74 WERE REMOVED PER PDC 95-27.

		E55 1/00 REVISED FOR FRN 99-01-69 PER DCN 06470		CTS	-	AUB AEJ SCALE NONE	DESIGNED	BECHTEL	DRAWING R. BRIDGED	E
		E54 1/00 REVISED FOR DCN 98-04-388		TEB	-	AEJ DLJ	 BOSTON EDISON MFG. CO. BOSTON EDISON COMPANY			
		E53 1/00 REVISED FOR ER 03120859 PER DCN 15782		TEB	-	DLJ NED				
		E54 1/00 REVISED FOR DCN 03-15346		TEB	-	AEJ NED				
		E55 1/00 REVISED FOR PDC 02-68 PER DCN 13824		TEB	-	AEJ NED				
		E62 1/00 REVISED FOR FRN 99-01-70 PER DCN 13636		TEB	-	AEJ NED	P&D CONDENSATE & DEMINERALIZED WATER STORAGE & TRANSFER SYSTEMS			
		E61 3/02 REVISED PER DCN 02-12826		CTS	-	AEJ DLJ				
		E60 1/00 REVISED FOR PDC 98-29 PER DCN 12287		CTS	-	AEJ DLJ				
		E50 1/00 REVISED FOR PDC 00-99 PER DCN 11653		CTS	-	AEJ DLJ				
		E58 3/01 REVISED PER DCN 01-10196		OLT	-	NAP DLJ				
		E57 1/00 REVISED FOR PR 005818 PER DCN 08047		CTS	-	AUB DLJ	Q  DRAWING NO.			REV
		E55 1/00 REVISED FOR PR 004900 PER DCN 07847		CTS	-	AUB DLJ	Non Q 			E65
TITLE OF REFERENCE DRAWING		DWG NUMBER		REVISIONS		BY		CHK APP		

0	11-14-05					
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-209-0						
CAD FILE LRA-M-209_E65.DGN						
MASTER FILE M209-CALS_E65.CAL						