




26A6642AD
Revision 1
January 2006



ESBWR Design Control Document

Tier 2

Chapter 1

***Introduction and
General Description of
Plant***

Sections 1.1 - 1.11



Contents

1. Introduction and General Description of Plant	1.1-1
1.1 Introduction.....	1.1-1
1.1.1 Format and Content.....	1.1-1
1.1.2 General Description	1.1-1
1.1.2.1 ESBWR Standard Plant Scope.....	1.1-1
1.1.2.2 Type of License Request.....	1.1-2
1.1.2.3 Number of Plant Units	1.1-2
1.1.2.4 Description of Location	1.1-2
1.1.2.5 Type of Nuclear Steam Supply	1.1-2
1.1.2.6 Type of Containment	1.1-2
1.1.2.7 Rated Core Thermal Power.....	1.1-2
1.1.3 COL Information	1.1-2
1.1.4 References.....	1.1-2
1.2 General Plant Description.....	1.2-1
1.2.1 Principal Design Criteria.....	1.2-1
1.2.1.1 General Power Generation (Nonsafety) Design Criteria	1.2-1
1.2.1.2 General Safety Design Criteria	1.2-2
1.2.1.3 Nuclear System Criteria.....	1.2-4
1.2.1.4 Electrical Power Systems Criteria	1.2-5
1.2.1.5 Auxiliary Systems Criteria.....	1.2-5
1.2.1.6 Shielding and Access Control Criteria.....	1.2-5
1.2.1.7 Power Conversion Systems Criteria	1.2-5
1.2.1.8 Nuclear System Process Control Criteria	1.2-5
1.2.1.9 Electrical Power System Process Control Criteria.....	1.2-6
1.2.2 Plant Description.....	1.2-6
1.2.2.1 Nuclear Steam Supply.....	1.2-6
1.2.2.1.1 Reactor Pressure Vessel and Internals	1.2-6
1.2.2.1.2 Nuclear Boiler System	1.2-10
1.2.2.1.3 RPV Natural Circulation Process.....	1.2-15
1.2.2.2 Controls and Instrumentation.....	1.2-15
1.2.2.2.1 Rod Control and Information System	1.2-15
1.2.2.2.2 Control Rod Drive System.....	1.2-17
1.2.2.2.3 Feedwater Control System.....	1.2-19
1.2.2.2.4 Standby Liquid Control System.....	1.2-21
1.2.2.2.5 Neutron Monitoring System	1.2-21
1.2.2.2.6 Remote Shutdown System	1.2-22
1.2.2.2.7 Reactor Protection System.....	1.2-23
1.2.2.2.8 Plant Automation System	1.2-24
1.2.2.2.9 Steam Bypass and Pressure Control System.....	1.2-25
1.2.2.2.10 Distributed Control and Information System.....	1.2-25
1.2.2.2.11 Leak Detection and Isolation System	1.2-26
1.2.2.2.12 Safety System Logic and Control System	1.2-27
1.2.2.2.13 Diverse Instrumentation and Controls	1.2-28

1.2.2.3 Radiation Monitoring Systems	1.2-29
1.2.2.3.1 Process Radiation Monitoring System.....	1.2-29
1.2.2.3.2 Area Radiation Monitoring System	1.2-32
1.2.2.4 Core Cooling Systems Used For Abnormal Events.....	1.2-33
1.2.2.4.1 Isolation Condenser System.....	1.2-33
1.2.2.4.2 Emergency Core Cooling System — Gravity-Driven Cooling System...	1.2-34
1.2.2.5 Reactor Servicing Equipment	1.2-36
1.2.2.5.1 Fuel Service Equipment.....	1.2-36
1.2.2.5.2 Miscellaneous Service Equipment.....	1.2-36
1.2.2.5.3 Reactor Pressure Vessel Servicing Equipment.....	1.2-37
1.2.2.5.4 RPV Internals Servicing Equipment.....	1.2-37
1.2.2.5.5 Refueling Equipment	1.2-37
1.2.2.5.6 Fuel Storage Facility	1.2-38
1.2.2.5.7 Under-Vessel Servicing Equipment.....	1.2-38
1.2.2.5.8 FMCRD Maintenance Area	1.2-39
1.2.2.5.9 Fuel Cask Cleaning.....	1.2-39
1.2.2.5.10 Fuel Transfer System	1.2-40
1.2.2.5.11 Loose Parts Monitoring System.....	1.2-41
1.2.2.6 Reactor Auxiliary Systems	1.2-41
1.2.2.6.1 Reactor Water Cleanup/Shutdown Cooling System.....	1.2-41
1.2.2.6.2 Fuel and Auxiliary Pools Cooling System.....	1.2-42
1.2.2.7 Control Panels.....	1.2-44
1.2.2.7.1 Main Control Room Panels.....	1.2-44
1.2.2.7.2 Radwaste Control Room Panels.....	1.2-44
1.2.2.7.3 Local Control Panels and Racks	1.2-44
1.2.2.8 Nuclear Fuel.....	1.2-45
1.2.2.8.1 Fuel Rods and Bundles	1.2-45
1.2.2.8.2 Fuel Channel	1.2-45
1.2.2.9 Control Rods	1.2-45
1.2.2.10 Radioactive Waste Management System.....	1.2-46
1.2.2.10.1 Liquid Waste Management System	1.2-46
1.2.2.10.2 Solid Waste Management System	1.2-46
1.2.2.10.3 Gaseous Waste Management System	1.2-47
1.2.2.11 Power Cycle.....	1.2-48
1.2.2.11.1 Turbine Main Steam System.....	1.2-48
1.2.2.11.2 Condensate and Feedwater System.....	1.2-49
1.2.2.11.3 Condensate Purification System	1.2-49
1.2.2.11.4 Main Turbine	1.2-50
1.2.2.11.5 Turbine Gland Seal System	1.2-50
1.2.2.11.6 Turbine Bypass System.....	1.2-51
1.2.2.11.7 Main Condenser	1.2-52
1.2.2.11.8 Circulating Water System.....	1.2-53
1.2.2.12 Station Auxiliaries	1.2-53
1.2.2.12.1 Makeup Water System.....	1.2-53
1.2.2.12.2 Condensate Storage and Transfer System.....	1.2-54
1.2.2.12.3 Reactor Component Cooling Water System.....	1.2-54

1.2.2.12.4 Turbine Component Cooling Water System.....	1.2-54
1.2.2.12.5 Chilled Water System	1.2-54
1.2.2.12.6 Oxygen Injection System.....	1.2-55
1.2.2.12.7 Plant Service Water System.....	1.2-55
1.2.2.12.8 Service Air System	1.2-55
1.2.2.12.9 Instrument Air System	1.2-56
1.2.2.12.10 High Pressure Nitrogen Supply System.....	1.2-56
1.2.2.12.11 Auxiliary Boiler System	1.2-56
1.2.2.12.12 Hot Water System.....	1.2-57
1.2.2.12.13 Hydrogen Water Chemistry System	1.2-57
1.2.2.12.14 Process Sampling System	1.2-57
1.2.2.12.15 Zinc Injection System	1.2-58
1.2.2.12.16 Freeze Protection	1.2-58
1.2.2.13 Station Electrical System	1.2-58
1.2.2.13.1 Electrical Power Distribution System.....	1.2-58
1.2.2.13.2 Electrical Penetrations	1.2-58
1.2.2.13.3 Direct Current Power Supply.....	1.2-59
1.2.2.13.4 Standby On-Site AC Power Supply.....	1.2-59
1.2.2.13.5 Uninterruptible AC Power Supply.....	1.2-60
1.2.2.13.6 Instrument and Control Power Supply.....	1.2-60
1.2.2.13.7 Communications System	1.2-60
1.2.2.13.8 Lighting Power Supply	1.2-60
1.2.2.14 Power Transmission.....	1.2-61
1.2.2.15 Containment and Environmental Control Systems.....	1.2-61
1.2.2.15.1 Containment System	1.2-61
1.2.2.15.2 Containment Vessel	1.2-63
1.2.2.15.3 Containment Internal Structures	1.2-64
1.2.2.15.4 Passive Containment Cooling System	1.2-64
1.2.2.15.5 Containment Inerting System	1.2-65
1.2.2.15.6 Drywell Cooling System.....	1.2-66
1.2.2.15.7 Containment Monitoring System.....	1.2-67
1.2.2.16 Structures and Servicing Systems.....	1.2-69
1.2.2.16.1 Cranes, Hoists and Elevators	1.2-69
1.2.2.16.2 Heating Ventilating and Air Conditioning.....	1.2-69
1.2.2.16.3 Fire Protection System.....	1.2-70
1.2.2.16.4 Equipment and Floor Drainage System	1.2-71
1.2.2.16.5 Reactor Building.....	1.2-71
1.2.2.16.6 Control Building	1.2-71
1.2.2.16.7 Fuel Building	1.2-72
1.2.2.16.8 Turbine Building.....	1.2-72
1.2.2.16.9 Radwaste Building.....	1.2-72
1.2.2.16.10 Other Building Structures	1.2-72
1.2.2.17 Intake Structure and Servicing Equipment	1.2-72
1.2.2.17.1 Intake and Discharge Structures	1.2-72
1.2.2.18 Yard Structures and Equipment.....	1.2-73
1.2.2.18.1 Oil Storage and Transfer System	1.2-73

1.2.2.18.2 Site Security	1.2-73
1.2.3 COL Information	1.2-73
1.2.4 References	1.2-73
1.3 Comparison Tables	1.3-1
1.4 Identification of Agents and Contractors	1.4-1
1.5 Requirements for Further Technical Information	1.5-1
1.5.1 Evolutionary Design	1.5-1
1.5.2 Analysis and Design Tools	1.5-1
1.5.2.1 TRACG	1.5-2
1.5.2.2 Scope of Application of TRACG to ESBWR	1.5-3
1.5.3 Testing	1.5-4
1.5.3.1 Major ESBWR Unique Test Programs	1.5-6
1.5.4 References	1.5-8
1.6 Material Incorporated by Reference	1.6-1
1.7 Drawings and Other Detailed Information	1.7-1
1.7.1 Electrical, Instrumentation and Control Drawings	1.7-1
1.7.2 Piping and Instrumentation Diagrams	1.7-1
1.7.3 Other Detailed Information	1.7-1
1.8 Interfaces for Standard Designs	1.8-1
1.8.1 Identification of NSSS Safety-Related Interfaces	1.8-1
1.8.2 Identification of BOP Interfaces	1.8-1
1.8.2.1 Circulating Water System (CIRC)	1.8-1
1.8.2.2 Plant Service Water System (PSWS)	1.8-1
1.8.2.3 Off-site Electrical Power	1.8-1
1.8.2.4 Makeup Water System (MWS)	1.8-1
1.8.2.5 Potable and Sanitary Water	1.8-2
1.8.2.6 Communications Systems	1.8-2
1.9 Conformance with Standard Review Plan and Applicability of Codes and Standards ..	1.9-1
1.9.1 Conformance with Standard Review Plan	1.9-1
1.9.2 Applicability to Regulatory Criteria	1.9-1
1.9.3 Applicability of Experience Information	1.9-1
1.9.4 COL information	1.9-1
1.9.4.1 SRP Deviations	1.9-1
1.9.4.2 Experience Information	1.9-1
1.9.5 References	1.9-1
1.10 Summary of COL Items	1.10-1
1.11 Technical Resolutions of Task Action Plan Items, New Generic Issues, New Generic Safety Issues and Chernobyl Issues	1.11-1
1.11.1 Approach	1.11-1

List of Tables

Global Abbreviations And Acronyms List

Table 1.3-1 Comparison of Reactor System Design Characteristics

Table 1.3-2. Comparison of Emergency Core Cooling Systems and Safety-Related Containment Cooling Systems

Table 1.3-3 Comparison of Containment Design Characteristics

Table 1.3-4 Comparison of Structural Design Characteristics

Table 1.4-1 Commercial Nuclear Reactors Completed and Under Construction By General Electric

Table 1.5-1 Evolution of the General Electric BWR

Table 1.5-2 ESBWR Features and Related Experience

Table 1.6-1 Referenced Reports

Table 1.7-1 Piping Designations and Specifications for DCD Drawings

Table 1.8-1 Matrix of NSSS Interfaces

Table 1.8-2 Matrix of BOP Interfaces

Table 1.9-1 Summary of Differences from SRP Section 1

Table 1.9-2 Summary of Differences from SRP Section 2

Table 1.9-3 Summary of Differences from SRP Section 3

Table 1.9-4 Summary of Differences from SRP Section 4

Table 1.9-5 Summary of Differences from SRP Section 5

Table 1.9-6 Summary of Differences from SRP Section 6

Table 1.9-7 Summary of Differences from SRP Section 7

Table 1.9-8 Summary of Differences from SRP Section 8

Table 1.9-9 Summary of Differences from SRP Section 9

Table 1.9-10 Summary of Differences from SRP Section 10

Table 1.9-11 Summary of Differences from SRP Section 11

Table 1.9-12 Summary of Differences from SRP Section 12

Table 1.9-13 Summary of Differences from SRP Section 13

Table 1.9-14 Summary of Differences from SRP Section 14

Table 1.9-15 Summary of Differences from SRP Section 15

Table 1.9-16 Summary of Differences from SRP Section 16

Table 1.9-17 Summary of Differences from SRP Section 17

Table 1.9-18 Summary of Differences from SRP Section 18

Table 1.9-19 Summary of Differences from SRP Section 19

Table 1.9-20 NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

Table 1.9-21 NRC Regulatory Guides Applicability to ESBWR

Table 1.9-21a EPRI Intent and Optimization Topics

Table 1.9-21b ESBWR Compliance with Quality Related Regulatory Guides

Table 1.9-22 Industrial Codes and Standards* Applicable to ESBWR

Table 1.9-23 Experience Information Applicable to ESBWR

Table 1.10-1 Summary of COL Items

Table 1.11-1 Resolutions To NUREG-0933 Table II Task Action Plan Items, New Generic Issues, Human Factors Issues and Chernobyl Issues

List of Illustrations

Figure 1.1-1. ESBWR Standard Plant General Site Plan
Figure 1.1-2. Safety System Configuration (not to scale)
Figure 1.1-3a. Reactor System Heat Balance at 100% Power (SI Units)
Figure 1.1-3b. Reactor System Heat Balance at 100% Power (English Units)
Figure 1.2-1. Nuclear Island Plan at Elevation –11500
Figure 1.2-2. Nuclear Island Plan at Elevation –6400
Figure 1.2-3. Nuclear Island Plan at Elevation –1000
Figure 1.2-3. Nuclear Island Plan at Elevation –1000
Figure 1.2-4. Nuclear Island Plan at Elevation 4650
Figure 1.2-4. Nuclear Island Plan at Elevation 4650
Figure 1.2-5. Nuclear Island Plan at Elevation 9060
Figure 1.2-6. Nuclear Island Plan at Elevation 13570
Figure 1.2-7. Nuclear Island Plan at Elevation 17500
Figure 1.2-8. Nuclear Island Plan at Elevation 27000
Figure 1.2-9. Nuclear Island Plan at Elevation 34000
Figure 1.2-10. Nuclear Island Elevation Section A-A
Figure 1.2-11. Nuclear Island Elevation Section B-B
Figure 1.2-12. Turbine Building Plan at Elevation –1400
Figure 1.2-13. Turbine Building Plan at Elevation 4650
Figure 1.2-14. Turbine Building Plan at Elevation 12000
Figure 1.2-15. Turbine Building Plan at Elevation 20000
Figure 1.2-16. Turbine Building Plan at Elevation 28000
Figure 1.2-17. Turbine Building Plan at Elevation 33000 and 38000
Figure 1.2-18. Turbine Building Plan at Elevation Various
Figure 1.2-19. Turbine Building Elevation Section A-A
Figure 1.2-20. Turbine Building Elevation Section B-B
Figure 1.2-21. Radwaste Building Plan at Elevation -9350
Figure 1.2-22. Radwaste Building Plan at Elevation -2350
Figure 1.2-23. Radwaste Building Plan at Elevation 4650
Figure 1.2-24. Radwaste Building Plan at Elevation 10650
Figure 1.2-25. Radwaste Building Elevation Section A-A
Figure 1.2-26. Electrical Building Plan at Elevation 4650
Figure 1.2-27. Electrical Building Plan at Elevation 9800
Figure 1.2-28. Electrical Building Plan at Elevation 13000
Figure 1.2-29. Electrical Building Plan at Elevation 18000
Figure 1.2-30. Electrical Building Plan at Elevation 22000
Figure 1.2-31. Electrical Building Plan at Elevation 27000
Figure 1.2-32. Electrical Building Plan at Elevation Various
Figure 1.2-33. Electrical Building Elevation Section A-A
Figure 1.5-1. Evolution of the GE BWR
Figure 1.5-2. Evolution of the BWR Reactor Design
Figure 1.5-3. Comparison of BWR Containments

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
10 CFR	Title 10, Code of Federal Regulations
A/D	Analog-to-Digital
AASHTO	American Association of Highway and Transportation Officials
AB	Auxiliary Boiler
ABMA	Anti-Friction Bearing Manufacturers Association
ABS	Auxiliary Boiler System
ABWR	Advanced Boiling Water Reactor
ac / AC	Alternating Current
AC	Air Conditioning
ACF	Automatic Control Function
ACI	American Concrete Institute
ACS	Atmospheric Control System
AD	Administration Building
ADS	Automatic Depressurization System
AEC	Atomic Energy Commission
AFIP	Automated Fixed In-Core Probe
AGMA	American Gear Manufacturer's Association
AHS	Auxiliary Heat Sink
AHU	Air Handling Units
AISC	American Institute of Steel Construction
AISI	American Iron and Steel Institute
AL	Analytical Limit
ALARA	As Low As Reasonably Achievable
ALWR	Advanced Light Water Reactor
AMCA	Air Movement and Control Association
ANI	American Nuclear Insurers
ANS	American Nuclear Society
ANSI	American National Standards Institute
AOO	Anticipated Operational Occurrence
AOV	Air Operated Valve
API	American Petroleum Institute
APRM	Average Power Range Monitor
APR	Automatic Power Regulator
APRS	Automatic Power Regulator System
ARI	Alternate Rod Insertion
ARI	Air-Conditioning and Refrigeration Institute
ARMS	Area Radiation Monitoring System
ASA	American Standards Association

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
ASA	Acoustical Society of America
ASCE	American Society of Civil Engineers
ASD	Adjustable Speed Drive
ASHRAE	American Society of Heating, Refrigerating, and Air Conditioning Engineers
ASME	American Society of Mechanical Engineers
ASQ	American Society for Quality
AST	Alternate Source Term
ASTM	American Society of Testing Methods
ASTM	American Society for Testing and Materials
AT	Unit Auxiliary Transformer
ATLM	Automated Thermal Limit Monitor
ATWS	Anticipated Transients Without Scram
AV	Allowable Value
AWS	American Welding Society
AWWA	American Water Works Association
B&PV	Boiler and Pressure Vessel
BAF	Bottom of Active Fuel
BHP	Brake Horse Power
BiMAC	Basemat-Internal Melt Arrest Coolability
BOC	Beginning of Cycle
BOP	Balance of Plant
BOPCWS	Balance of Plant Chilled Water Subsystem
BPU	Bypass Unit
BPV	Bypass Valve
BPWS	Banked Position Withdrawal Sequence
BRE	Battery Room Exhaust
BRL	Background Radiation Level
BTP	NRC Branch Technical Position
BTU	British Thermal Unit
BWR	Boiling Water Reactor
BWROG	Boiling Water Reactor Owners Group
CAV	Cumulative Absolute Velocity
C&FS	Condensate and Feedwater System
C&I	Control and Instrumentation
C/C	Cooling and Cleanup
CB	Control Building
CBGAHVS	Control Building General Area
CBHVAC	Control Building HVAC
CBHVS	Control Building Heating, Ventilation and Air Conditioning System

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
CCI	Core-Concrete Interaction
CDF	Core Damage Frequency
CDU	Condensing Unit
CEA	Consumer Electronics Association
CFR	Code of Federal Regulations
CH	Chugging
CIRC	Circulating Water System
CIS	Containment Inerting System
CIV	Combined Intermediate Valve
CLAVS	Clean Area Ventilation Subsystem of Reactor Building HVAC
CM	Cold Machine Shop
CMAA	Crane Manufacturers Association of America
CMS	Containment Monitoring System
CMU	Control Room Multiplexing Unit
CO	Condensate Oscillation
COL	Combined Operating License
COLR	Core Operating Limits Report
CONAVS	Controlled Area Ventilation Subsystem of Reactor Building HVAC
CPR	Critical Power Ratio
CPS	Condensate Purification System
CPU	Central Processing Unit
CR	Control Rod
CRD	Control Rod Drive
CRDA	Control Rod Drop Accident
CRDH	Control Rod Drive Housing
CRDHS	Control Rod Drive Hydraulic System
CRDS	Control Rod Drive System
CRGT	Control Rod Guide Tube
CRHA	Control Room Habitability Area
CRHAHVS	Control Room Habitability Area HVAC Sub-system
CRT	Cathode Ray Tube
CS&TS	Condensate Storage and Transfer System
CSAU	Code Scaling, Applicability, and Uncertainty
CSDM	Cold Shutdown Margin
CS / CST	Condensate Storage Tank
CT	Main Cooling Tower
CTI	Cooling Technology Institute
CTSS	Communications Continuous Tone-Controlled Squelch System
CTVCF	Constant Voltage Constant Frequency

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
CUF	Cumulative usage factor
CWS	Chilled Water System
D-RAP	Design Reliability Assurance Program
DAC	Design Acceptance Criteria
DAW	Dry Active Waste
DBA	Design Basis Accident
DBE	Design Basis Event
DB%	Dry-Basis-Percent
dc / DC	Direct Current
DCD	Design Control Document
DCPSS	Direct Current Power Supply System
DCS	Drywell Cooling System
DCIS	Distributed Control and Information System
DEPSS	Drywell Equipment and Pipe Support Structure
DF	Decontamination Factor
D/F	Diaphragm Floor
DG	Diesel-Generator
DHR	Decay Heat Removal
DPS	Diverse Protection System
DM&C	Digital Measurement and Control
DOF	Degree of Freedom
DOI	Dedicated Operators Interface
DORT	Discrete Ordinates Techniques
DOT	Department of Transportation
dPT	Differential Pressure Transmitter
DPS	Diverse Protection System
DPV	Depressurization Valve
DR&T	Design Review and Testing
DTM	Digital Trip Module
DW	Drywell
EAB	Exclusion Area Boundary
EB	Electrical Building
EBAS	Emergency Breathing Air System
EBHV	Electrical Building HVAC
ECA	Electronic Components Assemblies Materials Association
ECCS	Emergency Core Cooling System
E-DCIS	Essential DCIS (Distributed Control and Information System)
EDO	Environmental Qualification Document
EFDS	Equipment and Floor Drainage System

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
EFPY	Effective Full Power Years
EFU	Emergency Filter Unit
EHC	Electro-Hydraulic Control (Pressure Regulator)
EIA	Electronic Industries Alliance
ENS	Emergency Notification System
EOC	Emergency Operations Center
EOC	End of Cycle
EOF	Emergency Operations Facility
EOP	Emergency Operating Procedures
EPDS	Electric Power Distribution System
EPG	Emergency Procedure Guidelines
EPRI	Electric Power Research Institute
EQ	Environmental Qualification
EQD	Environmental Qualification Document
ERICP	Emergency Rod Insertion Control Panel
ERIP	Emergency Rod Insertion Panel
ESF	Engineered Safety Feature
ESP	Early Site Permit
ETS	Emergency Trip System
FAA	Federal Aviation Administration
FAC	Flow-Accelerated Corrosion
FAPCS	Fuel and Auxiliary Pools Cooling System
FATT	Fracture Appearance Transition Temperature
FB	Fuel Building
FBGAHV	Fuel Building General Area HVAC
FBHV	Fuel Building HVAC
FCI	Fuel-Coolant Interaction
FCI	Fluid Controls Institute Inc.
FCISL	Fuel Cladding Integrity Safety Limit
FCM	File Control Module
FCS	Flammability Control System
FCU	Fan Cooling Unit
FDA	Final Design Approval
FDDI	Fiber Distributed Data Interface
FEBAVS	Fuel Building Ventilation System
FFT	Fast Fourier Transform
FFWTR	Final Feedwater Temperature Reduction
FHA	Fire Hazards Analysis
FHA	Fuel Handling Accident

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
FIV	Flow-Induced Vibration
FM	Factory Mutual
FMCRD	Fine Motion Control Rod Drive
FMEA	Failure Modes and Effects Analysis
FPS	Fire Protection System
FO	Diesel Fuel Oil Storage Tank
FOAKE	First-of-a-Kind Engineering
FPC	Fuel Pool Cleanup
FPE	Fire Pump Enclosure
FS	Partial Full Scale
FSI	Fluid Structure Interaction
FTDC	Fault-Tolerant Digital Controller
FW	Feedwater
FWCS	Feedwater Control System
FWL	Feedwater Line
FWLB	Feedwater Line Break
FWS	Fire Water Storage Tank
GCS	Generator Cooling System
GDC	General Design Criteria
GDOS	Gravity-Driven Cooling System
GE	General Electric Company
GENE	GE Nuclear Energy
GEN	Main Generator System
GETAB	General Electric Thermal Analysis Basis
GL	Generic Letter
GM	Geiger-Mueller Counter
GM-B	Beta-Sensitive GM (Geiger-Mueller Counter) Detector
GENE	General Electric Nuclear Energy
GNF	Global Nuclear Fuel
GSI	Generic Safety Issue
GSIC	Gamma-Sensitive Ion Chamber
GSOS	Generator Sealing Oil System
GWSR	Ganged Withdrawal Sequence Restriction
HAZ	Heat-Affected Zone
HCU	Hydraulic Control Unit
HCW	High Conductivity Waste
HDVS	Heater Drain and Vent System
HEI	Heat Exchange Institute
HELB	High Energy Line Break

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
HELSA	High Energy Line Separation Analysis
HEP	Human Error Probability
HEPA	High Efficiency Particulate Air/Absolute
HFE	Human Factors Engineering
HFF	Hollow Fiber Filter
HGCS	Hydrogen Gas Cooling System
HI	Hydraulic Institute
HIC	High Integrity Container
HID	High Intensity Discharge
HIS	Hydraulic Institute Standards
HM	Hot Machine Shop & Storage
HP	High Pressure
HPNSS	High Pressure Nitrogen Supply System
HPT	High-Pressure Turbine
HRA	Human Reliability Assessment
HSI	Human-System Interface
HSSS	Hardware/Software System Specification
HVAC	Heating, Ventilation and Air Conditioning
HVS	High Velocity Separator
HVT	Horizontal Vent Test
HWC	Hydrogen Water Chemistry
HWCS	Hydrogen Water Chemistry System
HWS	Hot Water System
HX	Heat Exchanger
I&C	Instrumentation and Control
I/O	Input/Output
IAS	Instrument Air System
IASCC	Irradiation Assisted Stress Corrosion Cracking
IBA	Intermediate Break Accident
IBC	International Building Code
IC	Ion Chamber
IC	Isolation Condenser
ICC	International Code Council
ICD	Interface Control Diagram
ICGT	In-core Guide Tubes
ICP	Instrument and Control Power
ICPR	Initial Critical Power Ratio
ICS	Isolation Condenser System
IE	Inspection and Enforcement

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
IEB	Inspection and Enforcement Bulletin
IEC	International Electrotechnical Commission
IED	Instrument and Electrical Diagram
IEEE	Institute of Electrical and Electronic Engineers
IESNA	Illuminating Engineering Society of North America
IFTS	Inclined Fuel Transfer System
IGSCC	Intergranular Stress Corrosion Cracking
IIS	Iron Injection System
ILRT	Integrated Leak Rate Test
IOP	Integrated Operating Procedure
IMC	Induction Motor Controller
IMCC	Induction Motor Controller Cabinet
IRM	Intermediate Range Monitor
ISA	Instrument Society of America
ISI	In-Service Inspection
ISLT	In-Service Leak Test
ISM	Independent Support Motion
ISMA	Independent Support Motion Response Spectrum Analysis
ISO	International Standards Organization
ITA	Inspections, Tests or Analyses
ITAAC	Inspections, Tests, Analyses and Acceptance Criteria
ITA	Initial Test Program
LANL	Los Alamos National Laboratory
LAPP	Loss of Alternate Preferred Power
LBB	Leak Before Break
LCO	Limiting Conditions for Operation
LCS	Leakage Control System
LCW	Low Conductivity Waste
LD	Logic Diagram
LDA	Lay down Area
LDW	Lower Drywell
LD&IS	Leak Detection and Isolation System
LED	Light Emitting Diode
LERF	Large Early Release Frequency
LFCV	Low Flow Control Valve
LHGR	Linear Heat Generation Rate
LLRT	Local Leak Rate Test
LMU	Local Multiplexer Unit
LO	Dirty/Clean Lube Oil Storage Tank

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
LOCA	Loss-of-Coolant-Accident
LOFW	Loss-of-feedwater
LOOP	Loss of Offsite Power
LOPP	Loss of Preferred Power
LP	Low Pressure
LPCI	Low Pressure Coolant Injection
LPCRD	Locking Piston Control Rod Drive
LPFL	Low Pressure Flooder
LPMS	Loose Parts Monitoring System
LPRM	Local Power Range Monitor
LPSP	Low Power Setpoint
LUA	Lead Use Assembly
LWMS	Liquid Waste Management System
MAAP	Modular Accident Analysis Program
MAPLHGR	Maximum Average Planar Linear Head Generation Rate
MAPRAT	Maximum Average Planar Ratio
MBB	Motor Built-In Brake
MCC	Motor Control Center
MCES	Main Condenser Evacuation System
MCOP	Manual containment overpressure protection (function)
MCPR	Minimum Critical Power Ratio
MCR	Main Control Room
MCRP	Main Control Room Panel
MELB	Moderate Energy Line Break
MIT	Massachusetts Institute of Technology
MLHGR	Maximum Linear Heat Generation Rate
MMI	Man-Machine Interface
MMIS	Man-Machine Interface Systems
MOV	Motor-Operated
MOV	Motor-Operated Valve
MPC	Maximum Permissible Concentration
MPL	Master Parts List
MRBM	Multi-Channel Rod Block Monitor
MS	Main Steam
MSIV	Main Steam Isolation Valve
MSL	Main Steam Line
MSLB	Main Steamline Break
MSLBA	Main Steamline Break Accident
MSR	Moisture Separator Reheater

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
MSS	Manufacturers Standardization Society
MSV	Mean Square Voltage
MT	Main Transformer
MTTR	Mean Time To Repair
MCP	Mechanical Vacuum Pump
MWS	Makeup Water System
NBR	Nuclear Boiler Rated
NBS	Nuclear Boiler System
NCIG	Nuclear Construction Issues Group
NDE	Nondestructive Examination
NE-DCIS	Non-Essential Distributed Control and Information System
NDRC	National Defense Research Committee
NDT	Nil Ductility Temperature
NEMA	National Electrical Manufacturers Association
NFPA	National Fire Protection Association
NIST	National Institute of Standard Technology
NICWS	Nuclear Island Chilled Water Subsystem
NMS	Neutron Monitoring System
NOV	Nitrogen Operated Valve
NPHS	Normal Power Heat Sink
NPSH	Net Positive Suction Head
NRC	Nuclear Regulatory Commission
NRHX	Non-Regenerative Heat Exchanger
NS	Non-seismic
NSSFC	National Severe Storms Forecast Center
NSSS	Nuclear Steam Supply System
NT	Nitrogen Storage Tank
NTSP	Nominal Trip Setpoint
O&M	Operation and Maintenance
O-RAP	Operational Reliability Assurance Program
OBCV	Overboard Control Valve
OBE	Operating Basis Earthquake
OGS	Offgas System
OHLH	Overhead Heavy Load Handling
OIS	Oxygen Injection System
OLMCPR	Operating Limit Minimum Critical Power Ratio
OLU	Output Logic Unit
OOS	Out-of-Service
OPRM	Oscillation Power Range Monitor

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
ORNL	Oak Ridge National Laboratory
OSC	Operational Support Center
OSHA	Occupational Safety and Health Administration
OSI	Open Systems Interconnect
P&ID	Piping and Instrumentation Diagram
PA/PL	Page/Party-Line
PABX	Private Automatic Branch (Telephone) Exchange
PAM	Post Accident Monitoring
PAR	Passive Autocatalytic Recombiner
PAS	Plant Automation System
PASS	Post Accident Sampling Subsystem of Containment Monitoring System
PCC	Passive Containment Cooling
PCCS	Passive Containment Cooling System
PCT	Peak Cladding Temperature
PCV	Primary Containment Vessel
PDA	Piping Design Analysis
PFD	Process Flow Diagram
PGA	Peak Ground Acceleration
PGCS	Power Generation and Control Subsystem of Plant Automation System
PH	Pump House
PIRT	Phenomena Identification and Ranking Table
PL	Parking Lot
PM	Preventive Maintenance
PMCS	Performance Monitoring and Control Subsystem of NE-DCIS
PMF	Probable Maximum Flood
PMP	Probable Maximum Precipitation
PQCL	Product Quality Check List
PRA	Probabilistic Risk Assessment
PRMS	Process Radiation Monitoring System
PRNM	Power Range Neutron Monitoring
PS	Plant Stack or Pool Swell
PSD	Power Spectral Density
PSS	Process Sampling System
PSTF	Pressure Suppression Test Facility
PSWS	Plant Service Water System
PT	Pressure Transmitter
PWR	Pressurized Water Reactor
QA	Quality Assurance
RACS	Rod Action Control Subsystem

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
RAM	Reliability, Availability and Maintainability
RAPI	Rod Action and Position Information
RAT	Reserve Auxiliary Transformer
RB	Reactor Building
RBC	Rod Brake Controller
RBCC	Rod Brake Controller Cabinet
RBCWS	Reactor Building Chilled Water Subsystem
RBHV	Reactor Building HVAC (Heating, Ventilation and Air Conditioning)
RBS	Rod Block Setpoint
RBV	Reactor Building Vibration
RC&IS	Rod Control and Information System
RCC	Remote Communication Cabinet
RCCV	Reinforced Concrete Containment Vessel
RCCWS	Reactor Component Cooling Water System
RCPB	Reactor Coolant Pressure Boundary
RCS	Reactor Coolant System
RDA	Rod Drop Accident
RDC	Resolver-to-Digital Converter
REPAVS	Refueling and Pool Area Ventilation Subsystem of Fuel Building HVAC (Heating, Ventilation and Air Conditioning)
RFP	Reactor Feed Pump
RG	Regulatory Guide
RHR	Residual Heat Removal (function)
RHX	Regenerative Heat Exchanger
RMS	Root Mean Square
RMS	Radiation Monitoring Subsystem
RLP	Reference Loading Pattern
RMU	Remote Multiplexer Unit
RO	Reverse Osmosis
ROM	Read-only Memory
RPS	Reactor Protection System
RPV	Reactor Pressure Vessel
RRPS	Reference Rod Pull Sequence
RSM	Rod Server Module
RSPC	Rod Server Processing Channel
RSS	Remote Shutdown System
RSSM	Reed Switch Sensor Module
RSW	Reactor Shield Wall
RTD	Resistance Temperature Detector

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
RTIF	Reactor Trip and Isolation Function(s)
RT _{NDT}	Reference Temperature of Nil-Ductility Transition
RTP	Reactor Thermal Power
RW	Radwaste Building
RWBCR	Radwaste Building Control Room
RWBGA	Radwaste Building General Area
RWBHVAC	Radwaste Building HVAC (Heating, Ventilation and Air Conditioning)
RWCU/SDC	Reactor Water Cleanup/Shutdown Cooling
RWE	Rod Withdrawal Error
RWM	Rod Worth Minimizer
SA	Severe Accident
SAG	Sever Accident Guidelines
SAM	Severe Accident Management
SAR	Safety Analysis Report
SB	Service Building
SBA	Small Break Accident
S/C	Digital Gamma-Sensitive GM (Geiger-Mueller Counter) Detector
SC	Suppression Chamber
S/D	Scintillation Detector
S/DRSRO	Single/Dual Rod Sequence Restriction Override
S/N	Signal-to-Noise
S/P	Suppression Pool
SAS	Service Air System
SB&PC	Steam Bypass and Pressure Control
SBO	Station Blackout
SBWR	Simplified Boiling Water Reactor
SCEW	System Component Evaluation Work
SCRRI	Selected Control Rod Run-in
SDC	Shutdown Cooling
SDM	Shutdown Margin
SDS	System Design Specification
SEOA	Sealed Emergency Operating Area
SER	Safety Evaluation Report
SF	Service Water Building
SFA	Spent Fuel Assembly
SFP	Spent fuel pool
SIL	Service Information Letter
SIT	Structural Integrity Test
SIU	Signal Interface Unit

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
SJAE	Steam Jet Air Ejector
SLC	Standby Liquid Control
SLCS	Standby Liquid Control System
SLMCPR	Safety Limit Minimum Critical Power Ratio
SMACNA	Sheet Metal and Air Conditioning Contractors' National Association
SMU	SSLC (Safety System Logic and Control) Multiplexing Unit
SOV	Solenoid Operated Valve
SP	Setpoint
SPC	Suppression Pool Cooling
SPDS	Safety Parameter Display System
SPTMS	Suppression Pool Temperature Monitoring Subsystem of Containment Monitoring System
SR	Surveillance Requirement
SRM	Source Range Monitor
SRNM	Startup Range Neutron Monitor
SRO	Senior Reactor Operator
SRP	Standard Review Plan
SRS	Software Requirements Specification
SRSRO	Single Rod Sequence Restriction Override
SRSS	Square Root Sum of Squares
SRV	Safety Relief Valve
SRVDL	Safety Relief Valve Discharge Line
SSAR	Standard Safety Analysis Report
SS	Sub-scale
SST	Sub-scale Test
SSC(s)	Structure, System and Component(s)
SSE	Safe Shutdown Earthquake
SSI	Soil Structure Interaction
SSLC	Safety System Logic and Control
SSPC	Steel Structures Painting Council
ST	Spare Transformer
STI	Startup Test Instruction
STP	Sewage Treatment Plant
STRAP	Scram Time Recording and Analysis Panel
STRP	Scram Time Recording Panel
SV	Safety Valve
SWH	Static Water Head
SWMS	Solid Waste Management System
SY	Switch Yard
TAF	Top of Active Fuel

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
TASS	Turbine Auxiliary Steam System
TB	Turbine Building
TBCE	Turbine Building Compartment Exhaust
TBAS	Turbine Building Air Supply
TBE	Turbine Building Exhaust
TBLOE	Turbine Building Lube Oil Area Exhaust
TBS	Turbine Bypass System
TBHV	Turbine Building HVAC (Heating, Ventilation and Air Conditioning)
TBV	Turbine Bypass Valve
TC	Training Center
TCCWS	Turbine Component Cooling Water System
TCS	Turbine Control System
TCV	Turbine Control Valve
TDH	Total Developed Head
TEDE	Total Effective Dose Equivalent
TEMA	Tubular Exchanger Manufacturers' Association
TFSP	Turbine First Stage Pressure
TG	Turbine Generator
TGSS	Turbine Gland Seal System
THA	Time-History Accelerograph
TIA	Telecommunications Industry Association
TIP	Traversing In-core Probe
TLOS	Turbine Lubricating Oil System
TLU	Trip Logic Unit
TMI	Three Mile Island
TMSS	Turbine Main Steam System
TRAC	Transient Reactor Analysis Code
TRM	Technical Requirements Manual
TS	Technical Specification(s)
TSC	Technical Support Center
TSI	Turbine Supervisory Instrument
TSV	Turbine Stop Valve
TTWFATBV	Turbine trip with failure of all bypass valves
UBC	Uniform Building Code
UCB	University of California at Berkeley
UHS	Ultimate Heat Sink
UL	Underwriter's Laboratories Inc.
UPS	Uninterruptible Power Supply
URD	Utilities Requirements Document

Global Abbreviations And Acronyms List

<u>Term</u>	<u>Definition</u>
USE	Upper Shelf Energy
USI	Unresolved Safety Issue
USM	Uniform Support Motion
USMA	Uniform Support Motion Response Spectrum Analysis
USNRC	United States Nuclear Regulatory Commission
USS	United States Standard
UV	Ultraviolet
V&V	Verification and Validation
Vac / VAC	Volts Alternating Current
Vdc / VDC	Volts Direct Current
VDU	Video Display Unit
VW	Vent Wall
VWO	Valves Wide Open
WD	Wash Down Bays
WH	Warehouse
WS	Water Storage
WT	Water Treatment
WW	Wetwell
XMFR	Transformer
ZPA	Zero Period Acceleration

1. INTRODUCTION AND GENERAL DESCRIPTION OF PLANT

1.1 INTRODUCTION

1.1.1 Format and Content

This design control document (DCD) Tier 2 is written based on the general contents of the ABWR DCD Tier 2 with additional material added to be consistent with the NUREG-0800 Standard Review Plan versions as summarized in Table 1.9-20. In addition, a number of other relevant topics are addressed, e.g., Appendix 1A describes the treatment of TMI-related matters; Appendix 1B discusses plant shielding to provide access to vital areas and protective safety equipment for post-accident operation; Appendix 1C discusses industry operating experience; and Appendix 1D discusses regulatory treatment of non-safety systems.

Chapter 19 provides the response to the severe accident policy statement.

1.1.2 General Description

1.1.2.1 ESBWR Standard Plant Scope

The ESBWR Standard Plant includes buildings dedicated exclusively or primarily to housing systems and equipment related to the nuclear system or controlled access to these systems and equipment. Six such main buildings (see Figure 1.1-1) are within the scope for the ESBWR. These are:

- Reactor Building – houses safety-related structures, systems and components (SSC), except for the main control room, safety-related Distributed Control and Information System equipment rooms in the Control Building and spent fuel storage pool and associated auxiliary equipment in the Fuel Building. The Reactor Building includes the reactor, containment, refueling area and auxiliary equipment.
- Control Building – houses the main control room and safety-related controls outside the reactor building.
- Fuel Building – houses the spent fuel storage pool and its associated auxiliary equipment.
- Turbine Building – houses equipment associated with the main turbine and generator, and their auxiliary systems and equipment, including the condensate purification system and the process offgas treatment system.
- Radwaste Building – houses equipment associated with the collection and processing of solid and liquid radioactive waste generated by the plant.
- Electrical Building – houses the two nonsafety-related standby diesel generators and their associated auxiliary equipment.

Buildings and structures not in the ESBWR Standard Plant scope include the main transformer; switchyard; heat sinks for the main condenser, decay heat, and system waste heat; sewage and water treatment building; and storage tanks for fuel oil, nitrogen and demineralized water.

1.1.2.2 Type of License Request

Per 10 CFR 52, this DCD Tier 2 is submitted in support of the application for final design approval (FDA) and standard design certification (DC) for the ESBWR Standard Plant.

1.1.2.3 Number of Plant Units

For the purpose of this document, only a single standard unit is considered. If a multi-unit is desired, the changes and additional information needed to license a multi-unit plant would be supplied by the Combined Operating License (COL) applicant.

1.1.2.4 Description of Location

This plant can be constructed at any location that meets the parameters identified in Chapter 2.

1.1.2.5 Type of Nuclear Steam Supply

This plant has a boiling water reactor nuclear steam supply system designed and supplied by GE and designated as ESBWR.

1.1.2.6 Type of Containment

The ESBWR has a low-leakage containment vessel, which comprises the drywell and wetwell. The containment vessel is a cylindrical steel-lined reinforced concrete structure integrated with the reactor building. The containment boundary is illustrated as a dashed red line on Figure 1.1-2, which also shows key features of the safety system configuration.

1.1.2.7 Rated Core Thermal Power

The information presented herein pertains to one reactor unit with a rated thermal power level of up to 4500 MWt. The plant uses a direct-cycle, natural circulation boiling water reactor. The reactor system heat balance at rated power is shown in Figures 1.1-3a and 1.1-3b. The overall plant heat balance is provided within Section 10.1. Based on the reference design the plant operates at an estimated gross electrical power output at rated power of approximately 1600 MWe and net estimated electrical power output of approximately 1535 MWe. These electrical output numbers can vary as much as ± 50 MWe depending on the Turbine Island design and site-specific conditions. (To be confirmed in COL phase)

1.1.3 COL Information

If the COL applicant desires multiple units on one site, the changes and additional information needed to license a multi-unit plant will be supplied by the COL applicant. The COL applicant and its equipment suppliers will establish the rated electrical power output based on the Turbine Island design selected and site-specific conditions, and may base the COL application on a lower rated thermal power output in order to satisfy site-specific environmental parameters.

1.1.4 References

None.




Figure 1.1-1. ESBWR Standard Plant General Site Plan






Figure 1.1-2. Safety System Configuration (not to scale)



Core Thermal Power	4500.0
Cleanup Losses	-6.3
Other System Losses	-1.4
Turbine Cycle Use	4492.3 MWt

Figure 1.1-3a. Reactor System Heat Balance at 100% Power (SI Units)



*Conditions at upstream side of TSV

Core Thermal Power	4500.0
Cleanup Losses	-6.3
<u>Other System Losses</u>	<u>-1.4</u>
Turbine Cycle Use	4492.3 MWt

Figure 1.1-3b. Reactor System Heat Balance at 100% Power (English Units)

1.2 GENERAL PLANT DESCRIPTION

1.2.1 Principal Design Criteria

The principal design criteria governing the ESBWR Standard Plant are presented in two ways. First, the criteria are classified as applicable to either a power generation function or a safety-related function. Second, they are grouped according to system. Although the distinctions between power generation and safety-related functions are not always clear-cut and are sometimes overlapping, the functional classification facilitates safety analysis reviews, while the grouping by system facilitates understanding both the system function and design.

The principal plant structures are listed below:

- **Reactor Building** — houses all safety-related structures, systems and components (SSCs), except for the main control room, safety-related distributed control and information system equipment rooms and spent fuel storage pool. This includes the reactor, containment, equipment rooms/compartments outside containment, the refueling area with the fuel buffer pool, and auxiliary equipment area.
- **Control Building** — houses the main control room and all safety-related controls outside the reactor building.
- **Fuel Building** — houses the spent fuel storage pool, its auxiliary equipment and the lower end of the fuel transfer machine.
- **Turbine Building** — houses equipment associated with the main turbine and generator and their auxiliary systems and equipment including the condensate purification system and the process offgas treatment system.
- **Radwaste Building** — houses equipment associated with the collection and processing of solid and liquid radioactive waste generated by the plant.
- **Electrical Building** — houses the two nonsafety-related standby diesel generators and their associated auxiliary equipment.

1.2.1.1 General Power Generation (Nonsafety) Design Criteria

- The plant is designed to produce electricity from a turbine generator unit using steam generated in the reactor.
- Heat removal systems are provided with sufficient capacity and operational adequacy to remove heat generated in the reactor core for the full range of normal operational conditions and anticipated operational occurrences.
- Backup heat removal systems are provided to remove decay heat generated in the core under circumstances wherein the normal operational heat removal systems become inoperative. The capacity of such systems is adequate to prevent fuel cladding damage.
- The fuel cladding, in conjunction with other plant systems, is designed to retain integrity so that the consequences of any failures are within acceptable limits throughout the range of normal operational conditions and anticipated operational occurrences for the design life of the fuel.

- Control equipment is provided to allow the reactor to respond automatically to load changes and anticipated operational occurrences.
- Reactor power level is manually controllable.
- Control of the reactor is possible from a single location.
- Reactor controls, including status displays and alarms, are arranged to allow the operator to rapidly assess the condition of the reactor system and locate system malfunctions.
- Interlocks or other automatic equipment are provided as backup to procedural control to avoid conditions requiring the functioning of safety-related systems or engineered safety features.
- The station is designed for routine continuous operation whereby activation products, fission products, activated corrosion products and coolant dissociation products are processed to remain within acceptable limits.

1.2.1.2 General Safety Design Criteria

- The station design conforms to applicable codes and standards as described within Section 1.9.
- The station is designed, fabricated, erected and operated in such a way that the release of radioactive material to the environment does not exceed the limits and guideline values of applicable government regulations pertaining to the release of radioactive materials for normal operations, for anticipated operational occurrences and for accidents.
- The reactor core is designed so its nuclear characteristics do not contribute to a divergent power transient.
- The reactor is designed so there is no tendency for divergent oscillation of any operating characteristic considering the interaction of the reactor with other appropriate plant systems.
- The design provides means by which plant operators are alerted when limits on the release of radioactive material are approached.
- Sufficient indications are provided to allow determination that the reactor is operating within the envelope of conditions considered safe by plant analysis.
- Those portions of the nuclear system that form part of the reactor coolant pressure boundary (RCPB) are designed to retain integrity as a radioactive material containment barrier following anticipated operational occurrences and to ensure cooling of the reactor core following accidents.
- Safety-related systems and engineered safety features are designed to ensure that no damage to the RCPB results from internal pressures caused by anticipated operational occurrences, accidents and special events.
- Where positive, precise action is immediately required in response to anticipated operational occurrences and accidents, such action is automatic and requires no decision or manipulation of controls by plant operations personnel.

- Safety-related functions are performed by equipment of sufficient redundancy and independence so that no single failure of active components, or of passive components in certain cases in the long term, prevents performance of the safety-related functions. For systems or components to which IEEE 279 applies, single failures of either active or passive electrical components are considered in recognition of the higher anticipated failure rates of passive electrical components relative to passive mechanical components.
- Provisions are made for control of active components of safety-related systems from the control room.
- Safety-related systems are designed to permit demonstration of their functional performance requirements.
- The design of safety-related structures, systems and components includes allowances for natural environmental disturbances such as earthquakes, floods, and storms at the station site.
- Standby electrical DC power sources have sufficient capacity to power those safety-related systems requiring electrical power concurrently.
- Standby electrical power sources are provided to allow prompt reactor shutdown and removal of decay heat even if normal auxiliary power is not available.
- A containment is provided, the boundary of which completely encloses the reactor systems, drywell and wetwell (or suppression chamber). The containment employs the pressure suppression concept.
- The containment design provides for the testing of containment integrity and leak tightness at periodic intervals.
- A Reactor Building is provided that encloses the containment. The areas above the containment top slab and drywell head are flooded in a pool of water during operation. The Reactor Building forms an additional barrier helping to control any potential post-accident containment leakage. The water pools above the containment top slab and drywell head are effective in scrubbing any potential containment leakage through that path.
- The containment and Reactor Building in conjunction with other safety-related features limit radiological effects of design basis accidents to less than the prescribed acceptable limits.
- Provisions are made for removing energy from the containment as necessary to maintain the integrity of the containment system following accidents that release energy to the containment.
- Piping that penetrates the containment and could serve as a path for the uncontrolled release of radioactive material to the environs is automatically isolated when necessary to limit the radiological effects from an uncontrolled release to less than acceptable limits.
- Emergency core cooling systems are provided to limit fuel cladding temperature to less than the limit of 10 CFR 50.46 in the event of a design basis loss-of-coolant accident (LOCA).

- The emergency core cooling systems provide for continuity of core cooling over the complete range of postulated break sizes in the reactor coolant pressure boundary piping.
- Emergency core cooling is initiated automatically when required regardless of the availability of off-site power supplies and the normal generating system of the station.
- The control room is shielded against radiation so that continued occupancy under design basis accident conditions is possible.
- In the event that the control room becomes not habitable, it is possible to bring the reactor from power range operation to cold shutdown conditions by utilizing alternative controls and equipment that are available outside the control room.
- Fuel handling and storage facilities are designed to prevent inadvertent criticality and to maintain shielding and cooling of spent fuel as necessary to meet operating and off-site dose constraints.
- Systems that have redundant or backup safety-related functions are physically separated, and arranged so that credible events causing damage to one division/system of safety-related equipment have minimum prospects for compromising the functional capability of the redundant divisions/systems.

1.2.1.3 Nuclear System Criteria

- The fuel cladding is a fission product barrier designed to retain integrity so that any fuel failures occurring during normal operation do not result in dose consequences that exceed acceptable limits.
- The fuel cladding in conjunction with other plant systems is designed to retain integrity so that dose consequences as a result of any fuel failures occurring during any anticipated operational occurrence are within acceptable limits.
- Those portions of the nuclear system that form part of the reactor coolant pressure boundary are designed to retain integrity as a fission product barrier during normal operation and following anticipated operational occurrences, and to retain sufficient integrity to ensure core cooling following accidents.
- The capacity of the heat removal systems provided to remove heat generated in the reactor core for the full range of normal operational transients as well as for anticipated operational occurrences is adequate to prevent fuel cladding damage that results in dose consequences exceeding acceptable limits.
- The reactor is capable of being shut down automatically in sufficient time to prevent fuel cladding damage during anticipated operational occurrences.
- The reactor core and reactivity control system are designed such that control rod action is capable of making the core subcritical and maintaining subcriticality even with two control rods (associated with the same hydraulic control unit) of highest reactivity worth fully withdrawn and unavailable for insertion.
- Backup reactor shutdown capability is provided independent of normal reactivity control provisions. This backup system has the capability to shut down the reactor from any operating condition and subsequently to maintain the shutdown condition.

- The nuclear system is designed so there is no tendency for divergent oscillation of any operating characteristic, considering the interaction of the nuclear system with other appropriate plant systems.

1.2.1.4 Electrical Power Systems Criteria

Sufficient normal, auxiliary and standby sources of electrical power are provided to attain prompt shutdown and continued maintenance of the station in a safe condition under all credible circumstances. The DC power sources are adequate to accomplish required safety-related functions under all postulated accident conditions.

1.2.1.5 Auxiliary Systems Criteria

- The ESBWR requires no safety-related auxiliary system, except for the Standby Liquid Control (SLC) system.
- Other auxiliary systems, such as service water, cooling water, fire protection, heating and ventilating, communications and lighting, are designed to function as needed during normal conditions. They can also operate during accident conditions but are not required to do so.
- Auxiliary systems that are not required to achieve safe shutdown of the reactor or maintain it in a safe condition are designed so that a failure of these systems shall not prevent the safety-related systems from performing their design functions.

1.2.1.6 Shielding and Access Control Criteria

Radiation shielding is provided and access control patterns are established to allow a properly trained operating staff to control radiation doses within the limits of applicable regulations in any normal mode of plant operation.

1.2.1.7 Power Conversion Systems Criteria

Components of the power conversion systems are designed to attain the following basic objectives:

- The components of the power conversion systems are designed to produce electrical power from the steam coming from the reactor, condense the steam into water, and return the water to the reactor as heated feedwater with a major portion of its noncondensable gases and particulate impurities removed.
- The components of the power conversion systems are designed so that any fission products or radioactivity associated with the steam and condensate during normal operation are safely contained inside the system or are released under controlled conditions in accordance with waste disposal procedures.

1.2.1.8 Nuclear System Process Control Criteria

- Control equipment is provided to allow the reactor to respond automatically to load changes within design limits.
- Manual control of the reactor power level is provided.

- Nuclear system process displays, controls and alarms are arranged to allow the operator to rapidly assess the condition of the nuclear system and to locate process system malfunctions.

1.2.1.9 Electrical Power System Process Control Criteria

- The Class 1E DC power systems are designed with four divisions. During anticipated operational occurrences, operation of any three divisions is adequate to safely place the unit in the safe shutdown condition and meet all other design requirements associated with these events. For loss-of-coolant accident events, operation of any three divisions is adequate to safely place the unit in a safe shutdown condition.
- Protective relaying is used, in the event of equipment failure, to detect and isolate faulted equipment from the system with a minimum of disturbance to uninvolved systems or equipment.
- Two nonsafety-related standby diesel generators (DGs) are started and connected to both safety-related and nonsafety-related loads if other AC power sources are lost. If these non-Class 1E DGs are also inoperable, all safety-related loads are powered by the Class 1E divisional batteries.
- The function of key safety-related electrical systems and components are monitored in the control room.

1.2.2 Plant Description

1.2.2.1 Nuclear Steam Supply

1.2.2.1.1 Reactor Pressure Vessel and Internals

The Reactor Pressure Vessel (RPV) assembly consists of the pressure vessel and its appurtenances, supports and insulation, and the reactor internals enclosed by the vessel (excluding the core, in-core nuclear instrumentation, neutron sources, control rods, and control rod drives).

The reactor coolant pressure boundary (RCPB) of the RPV retains integrity as a radioactive material barrier during normal operation and following anticipated operational occurrences and retains integrity to contain coolant during design basis accidents (DBAs).

Certain RPV internals support the core and support instrumentation used during a DBA. Other RPV internals direct coolant flow, separate steam from the steam/water mixture leaving the core, hold material surveillance specimens, and support instrumentation used for normal operation.

The RPV, together with its internals, provides guidance and support for the fine-motion control rod drives (FMCRDs). Reactor internals associated with the SLC system are used to distribute sodium pentaborate solution when necessary to achieve core subcriticality via means other than inserting of control rods.

The RPV restrains the FMCRDs to prevent ejection of a control rod connected with a drive in the event of a postulated failure of a drive housing.

RPV

The RPV consists of a vertical, cylindrical pressure vessel of welded construction, with a removable top head, and head flanges, seals and bolting. The vessel also includes penetrations, nozzles, shroud support, and venturi shaped flow restrictors in the steam outlet nozzles. The shroud support carries the weight of peripheral fuel assemblies, neutron sources, core plate, top guide, shroud, chimney and chimney head with steam separators, and it laterally supports the fuel assemblies. Sliding block type supports near the bottom of the vessel support and anchor the vessel on the RPV support structure in the containment.

The RPV dimensions are shown in Table 5.3-3, and its key features are shown in Figure 5.3-3.

The overall RPV height permits natural circulation driving forces to produce abundant core coolant flow. An increased internal flow-path length relative to most prior BWRs is provided by a long “chimney” in the space, which extends from the top of the core to the entrance to the steam separator assembly. This chimney feature existed in the Humboldt Bay and Dodewaard natural circulation BWRs. The chimney and steam separator assembly are supported by a shroud assembly, which extends to the top of the core. The large RPV volume provides a large reserve of water above the core, which translates directly into a much longer period of time (compared to prior BWRs) before core uncovering can occur as a result of feedwater flow interruption or a LOCA. This gives an extended period of time during which automatic systems or plant operators can reestablish reactor inventory control using any of several normal, nonsafety-related systems capable of injecting water into the reactor. Timely initiation of these systems precludes the need for activation of emergency safety-related equipment. The large RPV volume also reduces the reactor pressurization rates that develop and can eventually lead to actuation of the safety-relief valves when the reactor is suddenly isolated from the normal heat sink.

The FMCRDs are mounted into permanently attached CRD housings. The CRD housings extend through, and are welded to CRD penetrations (stub tubes) formed in the RPV bottom head.

A flanged nozzle is provided in the top head for bolting on of the flange associated with the instrumentation for the initial vibration test of internals.

Sliding block type supports carry the vessel. The sliding supports are provided at a number of positions around the periphery of the vessel. One end of each sliding support is attached to a circumferential RPV flange, and the other end is captured into sets of guide blocks that are anchored to the pedestal support brackets. Stabilizers help the upper portion of the RPV resist horizontal loads. Lateral support among the CRD housings and in-core housings are provided by restraints that, at the periphery, are supported from CRD housing restraint beams.

The RPV insulation is supported from the shield wall surrounding the vessel. A steel frame that is independent of the vessel and piping supports insulation for the upper head and flange. Insulation access panels and insulation around penetrations are designed for ease of installation and removal for vessel inservice inspection and maintenance operations.

The RCPB portions of the RPV and appurtenances are classified as Quality Group A, Seismic Category I. RPV design, materials, manufacturing (e.g., welding), fabrication, testing (e.g., fracture toughness), material surveillance, examination and inspection requirements are provided in Section 5.3.

Access for examinations of the installed RPV is incorporated into the design of the vessel, reactor shield wall, and vessel insulation.

Reactor Pressure Vessel Internals

The reactor pressure vessel internals consist of core support structures and other equipment.

The core support structures locate and support the fuel assemblies, form partitions within the reactor vessel to sustain pressure differentials across the partitions, and direct the flow of coolant water. The structures consists of a shroud, shroud support, core plate, top guide, orificed fuel supports and control rod guide tubes (CRGTs).

The other reactor internals consist of control rods, feedwater spargers, SLC system distribution headers, in-core guide tubes, surveillance specimen holders, chimney, chimney partitions, chimney head and steam separator assembly, and the steam dryer assembly.

The shroud and chimney make up a stainless steel cylindrical assembly that provides a partition to separate the upward flow of coolant through the core from the downward recirculation flow outside the core. This partition separates the core region from the downcomer annulus.

The core plate consists of a circular stainless steel plate with round openings and is stiffened with a beam structure. The core plate provides lateral support and guidance for the CRGTs, in-core flux monitor guide tubes, peripheral fuel supports and startup neutron sources. The core plate also supports the last two items vertically.

The top guide consists of a circular plate with square openings for fuel assemblies. Each opening provides lateral support and guidance for four fuel assemblies or, in the case of peripheral fuel, less than four fuel assemblies. Holes are provided in the bottom surface of the top guide where the sides of the openings intersect, to anchor the in-core instrumentation detectors and start-up neutron sources.

The fuel assemblies are vertically supported in two ways depending upon whether they are located next to a control rod or not. The peripheral fuel assemblies, which are located at the outer edge of the active core, not adjacent to a control rod, are supported by the peripheral fuel supports. The peripheral fuel supports are welded to the core plate and each support one assembly. The peripheral fuel supports contain flow-restricting sections to provide the appropriate coolant flow rate to the peripheral fuel assemblies. The remaining fuel assemblies, which are adjacent to the control rods, are supported by the orificed fuel supports and CRGTs. Each orificed fuel support and CRGT supports four fuel assemblies vertically upward and provides lateral support to the bottom of the fuel. The orificed fuel support is supported in the CRGT that is supported laterally by the core plate.

The control rod passes through a cruciform opening in the center of the orificed fuel support. Each guide tube is designed as a guide for the lower end of the control rod. The lower end of the CRGT is supported by the control rod drive (CRD) housing, which in turn transmits the weight of the orificed fuel support and CRGT, and the four fuel assemblies to the reactor vessel bottom head. The upper end of the CRD housing is welded to a stub tube that is directly welded to the bottom of the vessel. Coolant flow, which has entered the lower plenum of the vessel, travels upward, adjacent to the guide tubes and enters the orificed fuel supports just below the core plate. The orificed fuel supports contain four flow-restricting openings that control coolant flow to the fuel assemblies.

The base of the CRGT is provided with a device for coupling to the FMCRD. The CRD is restrained from ejection, in the case of a stub tube to CRD housing weld failure, by the coupling of the drive with the guide tube base. In this event, the guide tube flange contacts the core plate and thus restrains the ejection. The coupling also prevents ejection if the CRD housing fails below the stub tube weld. In this event, the guide tube and fuel support remains supported by the CRD housing left intact above the stub tube weld.

The control rods are cruciform-shaped neutron absorbing members that can be inserted or withdrawn from the core by the FMCRD to control reactivity and reactor power.

Each of the feedwater lines is connected to a sparger via a RPV nozzle. The feedwater spargers are stainless steel headers located in the mixing plenum above the downcomer annulus. Each sparger, in two halves, with a tee connection at the middle, is fitted to the corresponding RPV feedwater nozzle. The sparger tee inlet is connected to the RPV nozzle safe end by a double thermal sleeve arrangement. Feedwater flow enters the center of the spargers and is discharged radially inward to mix the cooler feedwater with the downcomer flow from the steam separators and steam dryers.

In-core guide tubes (ICGTs) protect the in-core flux monitoring instrumentation from flow of water in the bottom head plenum. The ICGTs extend from the top of the in-core housing to the top of the core plate. The local power range monitoring (LPRM) detectors for the Power Range Neutron Monitoring (PRNM) subsystem and the detectors for the Startup Range Neutron Monitoring (SRNM) subsystem are inserted through the guide tubes.

A latticework of clamps, tie bars, and spacers give lateral support and rigidity to the ICGTs. The stabilizers are connected to the shroud or shroud support.

Surveillance specimen capsules, which are held in capsule holders mentioned earlier, are located at a common elevation in the core beltline region. The capsule holders are nonsafety-related internal components. Capsule holder brackets welded to the vessel cladding mechanically retain the capsule holders, which allow for capsule removal and re-installation.

As a natural circulation reactor, the ESBWR requires additional elevation head created by the density difference between the saturated water-steam mixture exiting the core and the subcooled water exiting the region just below the separators and the feedwater inlet. The chimney provides this elevation head or driving head necessary to sustain the natural circulation flow. The chimney is a long cylinder mounted to the top guide and which supports the steam separator assembly. The chimney forms the annulus separating the subcooled recirculation flow returning downward from the steam separators and feedwater, from the upward steam-water mixture flow exiting the core. Inside the chimney are partitions that separate groups of 16 fuel assemblies and thereby form smaller chimney sections limiting cross flow and flow instabilities.

The BWR direct cycle requires separation of steam from the steam-water mixture leaving the core. This is accomplished inside the RPV by passing the mixture sequentially first through an array of steam separators attached to a removable cover on the top of the chimney assembly, and then through standard BWR steam dryers. The steam dryer and the separator assembly is designed to provide outlet dry steam with a moisture content $\leq 0.1\%$.

The core support structures are classified as ASME Code Class CS, Seismic Category I. The design, materials, manufacturing, fabrication, examination, and inspection used in the

construction of the core support structures meet the requirements of ASME Code Section III, subsection NG, Core Support Structures.

These structures are code-stamped accordingly. Other reactor internals are designed per the guidelines of ASME Code NG-3000 and are constructed so as not to adversely affect the integrity of the core support structures as required by NG-1122.

Special controls on material fabrication processes are exercised when austenitic stainless steel is used for construction of RPV internals in order to avoid stress corrosion cracking during service.

Design and construction of the RPV internals ensure that the internals can withstand the effects of flow-induced vibration (FIV).

1.2.2.1.2 Nuclear Boiler System

The primary functions of the Nuclear Boiler System (NBS) are:

- To deliver steam from the RPV to the turbine main steam system (TMSS);
- To deliver feedwater from the Condensate and Feedwater System (C&FS) to the RPV;
- To provide overpressure protection of the RCPB;
- To provide automatic depressurization of the RPV in the event of a LOCA where the RPV does not depressurize rapidly; and
- With the exception of monitoring the neutron flux, to provide the instrumentation necessary for monitoring conditions in the RPV such as RPV pressure, metal temperature, and water level instrumentation.

The main steamlines (MSLs) are designed to direct steam from the RPV to the TMSS; the feedwater lines (FWLs) to direct feedwater from the C&FS to the RPV; the RPV instrumentation to monitor the conditions within the RPV over the full range of reactor power operation.

The NBS contains the valves necessary for isolation of the MSLs, FW lines, and their drain lines at the containment boundary.

The NBS contains the safety-relief valve discharge lines, including the steam quencher located in the suppression pool at the end of each discharge line.

The NBS also contains the RPV head vent line and non-condensable gas removal line.

Main Steamlines

The NBS contains the portion of the MSLs from their connection to the RPV to the boundary with the TMSS which occurs at the seismic interface located downstream of the outboard main steamline isolation valves (MSIVs).

The main steamlines are Quality Group A from the RPV out to and including the outboard MSIVs, and Quality Group B from the outboard MSIVs to the turbine stop valves. They are Seismic Category I from the RPV out to the seismic interface.

Main Steamline Flow Restrictor

The main steamline flow restrictor is essentially a flow restricting venturi built into the RPV MSL nozzle of each of the four main steamlines. The restrictor limits the coolant blowdown rate

from the reactor vessel in the event a main steamline break occurs anywhere downstream of the nozzle. The MSL flow restrictors thus limit offsite dose from postulated MSL breaks outside containment, while the MSIVs are closing. The flow restrictors also limit the intensity of the depressurization level swell and differential pressures momentarily developed on core internals following a MSL break.

The flow restrictors are designed and fabricated in accordance with the ASME Code and designed in accordance with ASME Fluid Meters Handbook. The flow restrictor has no moving parts.

The restrictors are also used to monitor steam flow and to initiate closure of the MSIVs when the steam flow exceeds pre-selected operational limits. The vessel dome pressure and the venturi throat pressure are used as the high and low pressure sensing locations.

Main Steamline Isolation Valves

Each MSIV assembly consists of a main steamline isolation valve, a pneumatic accumulator, connecting piping and associated controls.

There are two MSIVs welded into each of the four MSLs. On each MSL there is one MSIV inside the containment and one MSIV outside the containment. Each set of two MSIVs isolate their respective MSL upon receipt of isolation signal and close on loss of pneumatic pressure to the valve.

The MSIVs are Y-pattern globe valves. The main disc or poppet is attached to the lower end of the stem. Normal steam flow tends to close the valve, and higher inlet pressure tends to hold the valve closed. The Y-pattern configuration permits the inlet and outlet flow passages to be streamlined, which minimizes pressure drop during normal steam flow.

The primary actuation mechanism uses a pneumatic cylinder. The speed at which the valve opens and closes can be adjusted. Helical springs around the spring guide shafts close the valve if gas pressure in the actuating cylinder is lost.

The MSIV has a fast-closing time greater than or equal to the value used in the MSIV closure (non-accident) events and less than or equal to the value used in the MSLB accident analysis. During MSIV fast closure, N₂ or air pressure is admitted to the upper piston compartment. Admitting N₂ or air to both the upper and lower piston compartments tests the valve with a slow closing speed, which is based upon approximately 45-60 seconds for full stroke of the valve.

When all the MSIVs are closed, the combined leakage through the MSIVs for all four MSLs is less than or equal to the value used in the LOCA inside containment radiological analysis.

Feedwater Lines (FWLs)

The feedwater piping consists of two FWLs connecting to a feedwater supply header. Two containment isolation valves consisting of a simple check valve inside the drywell and a positive acting check valve outside the containment accomplish isolation of each FWL. Also included in this portion of the FWL is a manual maintenance valve located between the inboard isolation valve and the reactor nozzle. The feedwater line upstream of the outboard isolation valve contains an additional check valve, a remote manual motor-operated (MO) gate valve, and a seismic interface restraint. The outboard isolation valve and the MO gate valve provide a quality group transitional point in the FWLs.

The feedwater piping is Quality Group A from the RPV out to and including the outboard isolation valve, Quality Group B from the outboard isolation valve to and including the MO gate valve, and Quality Group D upstream of the MO gate valve. The feedwater piping, and connected piping that is 64 mm (2.5 inches) or larger in nominal diameter, are Seismic Category I from the RPV to the seismic interface.

Safety-Relief Valves

The nuclear pressure relief system consists of safety-relief valves (SRVs) located on the MSLs between the RPV and the inboard MSIV. The SRVs provide two main protection functions:

- **Overpressure Safety Operation:** The SRVs function as safety valves and open to prevent nuclear system overpressurization. They are self-actuating by inlet steam pressure.

The safety mode of operation is initiated when direct and increasing static inlet steam pressure overcomes the restraining spring and frictional forces acting against the inlet steam pressure at the valve disc. This moves the disc in the opening direction. The condition at which this actuation is initiated corresponds to the set-pressure value stamped on the nameplate of the valves.

The SRVs meet the requirements of ASME Code Section III. The rated capacity of the SRVs is sufficient to prevent a rise in pressure within the RPV to more than 120% of the design pressure during Anticipated Transients Without Scram (ATWS) events.

- **Automatic Depressurization Operation:** Ten of the SRVs open automatically during a LOCA to depressurize the reactor vessel. This is discussed separately, below.

The power supply is 250 V DC, Class 1E for the system. The SRV controls are classified as Class 1E.

Each SRV has one dedicated, independent pneumatic accumulator, which provides the safety-related, ensured nitrogen supply for opening the valve.

The SRVs are flange mounted onto forged outlet fittings located on the top of the main steamline piping in the drywell. The SRVs discharge through lines routed to quenchers in the suppression pool.

Automatic Depressurization System

The Automatic Depressurization System (ADS) function of the NBS depressurizes the RPV in sufficient time for the Gravity-Driven Cooling System (GDCCS) injection flow to replenish core coolant to maintain core temperature below design limits in the event of a LOCA. It also maintains the reactor depressurized for continued operation of GDCCS after an accident without need for power.

The ADS consists of SRVs and depressurization valves (DPVs) and their associated instrumentation and controls.

Some of the DPVs are flange-mounted on horizontal stub lines connected to the RPV at about the elevation of the MSLs. The other DPVs are flange-mounted on horizontal lines branching off from the MSLs. Upon actuation, the DPVs discharge into the drywell.

The SRVs and DPVs are actuated in groups of valves at staggered times by delay timers as the reactor undergoes a relatively slow depressurization. This minimizes reactor level swell during the depressurization, thereby enhancing the passive re-supply of coolant by the GDSCS.

The use of a combination of SRVs and DPVs to accomplish the ADS function improves ADS reliability against hypothetical common-mode failures of otherwise non-diverse ADS components. It also minimizes components and maintenance as compared to using only SRVs or only DPVs for this function. By using the SRVs for two different purposes, the number of DPVs required is minimized. By using DPVs for the additional depressurization capability needed beyond what the SRVs can provide, the total number of SRVs, SRV discharge lines, and quenchers in the suppression pool is minimized. The need for SRV maintenance, periodic calibration and testing, and the potential for simmering are minimized with this arrangement.

The ADS automatically actuates on a low RPV water level signal that persists for a preset time. When a coincident high drywell pressure signal is present, ADS actuates earlier and at a higher RPV water level. Two-out-of-four logic is used to activate the SRVs and DPVs. The persistence requirement for the low RPV water level signal ensures that momentary system perturbations do not actuate ADS when it is not required. The two-out-of-four logic ensures that a single failure does not cause spurious system actuation while also ensuring that a single failure cannot prevent initiation. Details of the actuation logic are provided in Subsection 7.3.1. The ADS may also be manually initiated from the main control room.

Depressurization Valves

The DPVs are of a non-leak/non-simmer/non-maintenance design. They are straight-through, squib-actuated, non-reclosing valves with a metal diaphragm seal. The valves are connected to an inlet pipe and an outlet pipe. Each valve provides about twice the depressurization capacity of an SRV. The DPV is closed with a cap covering the inlet chamber. The cap readily shears off at the metal diaphragm seal when impacted by the valve piston, which is actuated by the explosive initiator-booster. This opens the inlet hole through the valve. The sheared cap is hinged such that it drops out of the flow path and does not block the valve. The DPVs are designed so that there is no leakage across the cap throughout the life of the valve.

One booster assembly, which contains two initiators (squibs), is capable of actuating the tension bolt (shearing plunger). A battery-powered independent firing circuit actuates each initiator. Each initiator contains pin connections that are connected through a wire bridge in the bottom of the initiator. The firing of one initiator is adequate to activate the booster, which actuates the tension bolt and valve piston to open the valve. Nominal firing voltage is 250 V DC. However, the initiator-boosters are designed to function with any applied voltage between 185 and 310 V DC. The valve design and initiator-booster design are such that there is substantial thermal margin between operating temperature and the self-ignition point of the initiator-booster.

NBS Instrumentation

The NBS RPV instrumentation monitors and provides control inputs for operational variables during plant operation.

The NBS contains the instrumentation for monitoring the reactor pressure, metal temperature, and water level. The reactor pressure and water level instruments are used by multiple systems, both safety-related and nonsafety-related.

Pressure indicators and transmitters detect reactor vessel internal pressure from the same instrument lines used for measuring reactor vessel water level.

RPV coolant temperatures are determined by measuring saturation pressure (which gives the saturation temperature), outlet flow temperature to the RWCU/SDC system, and RPV bottom head drain line temperature. Temperatures of the reactor vessel outside surface (metal) are measured at the head flange and the bottom head locations. Temperatures needed for operation and for operating limits are obtained from these measurements.

The instruments that sense the water level are differential pressure devices calibrated for a specific RPV pressure (and corresponding liquid temperature). The water level measurement instrumentation is the condensate reference chamber type. Instrument reference zero for all the RPV water level ranges is the top of the active fuel. The following is a description of each water level range.

- Shutdown Range Water Level

This range is used to monitor the reactor water level during shutdown conditions when the reactor system is flooded for maintenance and head removal. The two RPV instrument taps used for this water level measurement are located at the top of the RPV head, and just below the dryer skirt.

- Narrow Range Water Level

This range is used to monitor reactor water level during normal power operation. This range uses the RPV taps near the top of the steam outlet nozzles and near the bottom of the dryer skirt. The Feedwater Control System uses this range for its water level control and indication inputs. The RPS also uses this range for scram initiation.

- Wide Range Water Level

This range is used to monitor reactor water level for events where the water level exceeds the range of the narrow range water level instrumentation, and is used to generate the low reactor water level trip signals, which indicate a potential LOCA. This range uses the RPV taps at the elevations near the top of the steam outlet nozzles and the nearest tap above the top guide.

- Fuel Zone Range Water Level

This range is provided for post-accident monitoring and provides the capability to monitor the reactor water level below the wide range water level instrumentation. This range uses the RPV taps at the elevations near the top of the steam outlet nozzles and the taps below the bottom of active fuel.

Thermocouples are located in the discharge exhaust pipes of the SRVs. The temperature signals go to a multipoint recorder with an alarm, and are activated by any temperature in excess of a set temperature, signaling that one of the SRV seats has started to leak.

Control room indication and alarms are provided for the important plant parameters monitored by the NBS.

NBS ASME Code Requirements

The major NBS mechanical components are designed to meet ASME Code Requirements as listed in Section 5.2.

1.2.2.1.3 RPV Natural Circulation Process

The ESBWR uses natural circulation to provide core flow. Natural circulation in the ESBWR is established due to the density differences between the water in the vessel annulus (outside the shroud and chimney) and the steam/water mixture inside the shroud and chimney. The colder, higher density water in the annulus creates a higher pressure or a driving head when compared to the hotter, lower density fluid (steam/water) in the core and chimney. The energy produced in the core of the reactor heats the water entering at the bottom of the core, and begins converting it to a steam/water mixture. In the core the subcooled water is first heated to the saturation temperature, and then as more heat is added boiling of the core coolant starts. As the coolant travels upward through the core the percent of saturated steam increases until at the exit of the core the average percent of saturated steam is approximately 18 weight %. This steam/water mixture travels upward through the chimney to the steam separators where centrifugal force separates the steam from the water. The separated, saturated water returns to the volume around the separators while the slightly “wet” steam travels upward to the steam dryer and eventually out the main steamline nozzles and piping to the turbine.

Cooler feedwater re-enters the vessel at the top of the annulus, where it mixes with the saturated water around the separators and subcools this water. The resulting mixture is subcooled only a few degrees below the saturation temperature. The cooler mixture then travels downward through the annulus to re-enter the core. The water therefore forms a recirculation loop within the vessel. The mass of steam leaving the vessel is matched by the mass of feedwater entering.

The chimney adds height to this density difference, in effect providing additional driving head to the circulation process. A forced circulation BWR acts in the same basic manner but uses the internal or external pumps to add driving head to this recirculation flow instead of the elevation head provided by the chimney. A pump has entrance and exit losses associated with it and the pump must overcome these losses as well as produce the driving head to overcome these losses.

1.2.2.2 Controls and Instrumentation

1.2.2.2.1 Rod Control and Information System

The Rod Control and Information System (RC&IS) is to safely and reliably provide:

- The capability to control reactor power level by controlling the movement of control rods in reactor core in manual, semiautomatic, and automated modes of plant operations.
- Display of summary information about control rod positions and status in the main control room.
- Transmission of fine motion control rod drive (FMCRD) status and control rod positions and status data to other plant systems (e.g., the Non-Essential Distributed Control and Information System).

- Automatic control rod run-in function of all operable control rods following a scram (scram follow function).
- Automatic enforcement of rod movement blocks to prevent potentially undesirable rod movements. These rod blocks do not have an effect on the scram insertion function.
- Manual and automatic insertion of all control rods by an alternate and diverse method [alternate rod insertion (ARI) motor run-in function].
- The capability to enforce a pre-established sequence for control rod movement when reactor power is below the low power setpoint.
- The capability to enforce fuel operating thermal limits when reactor power is above the low power setpoint.
- The capability to provide for Selected Control Rod Run In (SCRRI) function for mitigating a loss of feedwater heating event or for reducing power after a load rejection event or a turbine trip (that does not result in scram).

The RC&IS is classified as a nonsafety-related system, only has a non-safety control design basis, and is not required for the safe shutdown of the plant. A failure of the RC&IS does not result in gross fuel damage. However, the rod block function of RC&IS is used in limiting the effects of a rod withdrawal error, and prevention of local fuel operating thermal limits violations during normal plant operations. Therefore, the RC&IS is designed to be single-failure proof and highly reliable.

The RC&IS consists of several different types of cabinets (or panels), which contain special electronic/electrical equipment modules, and a dedicated operator interface on the main control panel in the MCR.

The RC&IS is a dual redundant system consisting of two independent channels for normal control rod position monitoring and control rod movements. The two channels receive the same but separate input signals and perform the same functions. For normal functions of the RC&IS, the two channels must always be in agreement and any disagreement between the two channels results in rod block. However, the protective function logic of the RC&IS (i.e., rod block) is designed such that the detection of a rod block condition in only one channel of RC&IS would result in a rod block.

In addition, the RC&IS includes a fiber-optic dual-channel multiplexing network that is used for transmission of rod position and status data from Remote Communication Cabinets (RCCs) to the Rod Action and Position Information (RAPI), and rod block/movement command from RAPI to RCCs. A summary description of each of the above functions is provided below.

Rod Action Control Subsystem (RACS):

The RACS consists of rod action and position information (RAPI) panels and Automated Thermal Limit Monitor (ATLM)/Rod Worth Minimizer (RWM) panel that provide for a dual redundant architecture. These panels are located in the back-panel area of the control room.

Remote Communication Cabinets (RCCs):

The RCCs contain a dual channel file control module (FCM) and several dual channel rod server modules (RSMs). The FCM interfaces with the RSMs and RAPI.

Induction Motor Controller Cabinets (IMCCs):

The IMCCs consist of induction motor control (IMC) equipment required for turning on and off the AC power required for energizing the FMCRD 3-Phase AC induction motor and its associated motor built-in brake for performing FMCRD movements.

Rod Brake Controller Cabinets (RBCCs):

The RBCCs contain electrical power supplies, electronic (or relay) logic, and other associated electrical equipment for the proper operation of the FMCRD holding brakes. Signals for brake disengagement or engagement are received from the associated rod server modules. The brake controller logic provides two separate (Channel A and Channel B) brake status signals to the associated rod server module.

RC&IS Multiplexing Network

The RC&IS multiplexing network consists of two independent channels. Fiber-optic communication links are used in this multiplexing network to handle communication between the RACS and the dual channel file control modules located in the remote communication cabinets.

The plant Essential Distributed Control and Information System (E-DCIS) network interfaces with FMCRD dual redundant separation switches (A and B) and provides the appropriate status signals to the RACS cabinets. These signals are used in the RC&IS logic for initiating rod block signals if a separation occurs. The E-DCIS provides these signals to the RC&IS via communication with the Non-Essential DCIS (NE-DCIS). The E-DCIS and NE-DCIS are not part of the RC&IS scope.

RC&IS Power Sources

RC&IS equipment derives its power from two different sources. The IMCCs and RBCCs receive their power from medium and low voltage AC power buses that are backed up by the plant standby diesel generators. All other RC&IS equipment derives power from two separate non-divisional AC power sources, at least one of which is an uninterruptible AC power supply (UPS).

1.2.2.2.2 Control Rod Drive System

The Control Rod Drive (CRD) system is composed of three major elements:

- the Fine Motion Control Rod Drive (FMCRD) mechanisms;
- the hydraulic control unit (HCU) assemblies; and
- the Control Rod Drive Hydraulic (CRDH) subsystem.

The FMCRDs provide electric-motor-driven positioning for normal insertion and withdrawal of the control rods and hydraulic-powered rapid control rod insertion (scram) for abnormal operating conditions. Simultaneous with scram, the FMCRDs also provide electric-motor-driven run-in of all control rods as a path to rod insertion that is diverse from the hydraulic-powered scram. The hydraulic power required for scram is provided by high-pressure water stored in the individual HCUs. Each HCU is designed to scram up to two FMCRDs. The HCUs also provide the flow path for purge water to the associated drives during normal operation. The CRDH

subsystem supplies high pressure demineralized water, which is regulated and distributed to provide charging of the HCU scram accumulators, purge water flow to the FMCRDs, and backup makeup water to the RPV when the feedwater flow is not available.

During power operation, the CRD system controls changes in core reactivity by movement and positioning of the neutron absorbing control rods within the core in fine increments via the FMCRD electric motors, which are operated in response to control signals from the RC&IS.

The CRD system provides rapid control rod insertion (scram) in response to manual or automatic signals from the Reactor Protection System (RPS), so that no fuel damage results from any plant transient.

The FMCRDs are mounted in housings welded into the RPV bottom head. Each FMCRD has a movable hollow piston tube that is coupled at its upper end, inside the reactor vessel, to the bottom of a control rod. The piston is designed such that it can be moved up or down, both in fine increments and continuously over its entire range, by a ball nut and ball screw driven by the electric motor. In response to a scram signal, the piston rapidly inserts the control rod into the core hydraulically using stored energy in the HCU scram accumulator. The scram water is introduced into the drive through a scram inlet connection on the FMCRD housing, and is then discharged directly into the reactor vessel via clearances between FMCRD parts. The FMCRD scram time requirements are provided in the plant-specific Technical Specifications.

The FMCRD design includes an electro-mechanical brake on the motor drive shaft and a ball check valve at the point of connection with the scram inlet line. These features prevent control rod ejection in the event of a failure of the scram insert line. An internal housing support is provided to prevent ejection of the FMCRD and its attached control rod in the event of a housing failure. It uses the outer tube of the drive to provide support. The outer tube, which is welded to the drive middle flange, attaches by a bayonet lock to the base of the control rod guide tube. The flange at the top of the control rod guide tube contacts the core plate and prevents any downward movement of the drive.

The FMCRD is designed to detect separation of the control rod from the drive mechanism. Two redundant and separate Class 1E switches detect separation of either the control rod from the hollow piston or the hollow piston from the ball nut. Actuation of either switch causes an immediate rod block and an alarm in the MCR, thereby preventing the occurrence of a rod drop accident. Consequently, a rod drop accident is not considered further for this design. (See Section 4.6.)

Each HCU provides sufficient volume of water stored at high pressure in a pre-charged accumulator to scram two FMCRDs at any reactor pressure. Each accumulator is connected to its associated FMCRDs by a hydraulic line that includes a normally closed scram valve. The scram valve opens by spring action but is normally held closed by pressurized control air. To cause scram, the RPS provides a de-energizing reactor trip signal to the solenoid-operated pilot valve that vents the control air from the scram valve. The system is "fail safe" in that loss of either electrical power to the solenoid pilot valve or loss of control air pressure causes scram. The HCUs are housed in the Reactor Building at the basemat elevation. This is a Seismic Category I structure, and the HCUs are protected from external natural phenomena such as earthquakes, tornados, hurricanes and floods, as well as from internal postulated accident

phenomena. In this area, the HCUs are not subject to conditions such as missiles, pipe whip, or discharging fluids.

The CRDH subsystem design provides the pumps, valves, filters, instrumentation, and piping to supply the high-pressure water for charging the HCUs and purging the FMCRDs. Two 100% capacity pumps (one on standby) supply the HCUs with water from the condensate treatment system and/or condensate storage tank for charging the accumulators and for supplying FMCRD purge water. The CRDH subsystem equipment is housed in the Seismic Category I portion of the Reactor Building to protect the system from floods, tornadoes, and other natural phenomena. The CRDH subsystem also has the capability to provide makeup water to the RPV while at high pressure as long as AC power is available.

The CRD system includes MCR indication and alarms to allow for monitoring and control during design basis operational conditions, including system flows, temperatures and pressures, as well as valve position indication and pump on/off status. Class 1E pressure instrumentation is provided on the HCU charging water header to monitor header performance. The pressure signals from this instrumentation are provided to the RPS, which initiates a scram if the header pressure degrades to a low-pressure setpoint. This feature ensures the capability to scram and safely shut down the reactor before HCU accumulator pressure can degrade to the level where scram performance is adversely affected following the loss of charging header pressure.

Components of the system that are required for scram (FMCRDs, HCUs and scram piping), are classified Seismic Category I. The balance of the system equipment (pumps, valves, filters, piping, etc.) is classified as Seismic Category II, with the exception of the Class 1E charging water header pressure instrumentation, which is Seismic Category I. The major CRD components and their design requirements are provided in Section 4.6.

The CRD system is separated both physically and electrically from the Standby Liquid Control (SLC) system.

1.2.2.2.3 Feedwater Control System

The Feedwater Control System (FWCS) provides logic for controlling the supply of feedwater flow to the reactor vessel in response to automatic or operator manual control signals. This control maintains reactor water level within predetermined limits for all operating conditions including startup. A fault-tolerant, triplicated, digital controller uses water level, steam flow and feedwater flow signals to form a three-element control strategy to accomplish this function. Single-element control based only on reactor water level is used when steam flow or feedwater flow signals are not available. During very low steam flow conditions during plant startup FWCS regulates the Reactor Water Cleanup/Shutdown Cooling (RWCU/SDC) system overboard flow to maintain reactor water level and to minimize feedwater temperature oscillations.

FWCS equipment consists of a Fault-Tolerant Digital Controller (FTDC), which is a triplicated, microprocessor based controller that executes the control software and logic required for reactor level control and other FWCS functions. There are three identical processing channels (operating in parallel) that receive inputs from other systems and issue actuator and speed demands, process measurement data, interlock and trip signals. The FTDC issues actuator demand signals to the Low Flow Control Valve (LFCV) and the RWCU/SDC overboard flow

control valve and a speed demand signal to the Feedwater Pump variable speed controllers, which are all components of other systems. The FWCS functions and modes are shown below.

Function	Modes
RPV water level control	Single Element (level only) Three Element (level, main steam flow, feedwater flow)
Variable speed feedwater pump speed demand	Manual Auto (speed control)
LFCV position demand	Manual Auto (level control)
RWCU/SDC Overboard Flow Control valve position demand	Manual Auto-level control
Automation	Power Generation and Control Subsystem (PGCS), of Plant Automation System, mode Not in PGCS mode

The FWCS does not perform or ensure any safety-related function, and thus, is classified as nonsafety-related.

The normal range of reactor water level is between Level 4 and Level 7. If either of these limits is reached during normal operation, an alarm occurs in the control room to alert the operator.

For a loss of feedwater heating event that results in a significant decrease in feedwater temperature, the Non-Essential Distributed Control and Information System (NE-DCIS) generates a signal that initiates a Selected Control Rod Run-In (SCRRI). This interlock limits the consequences of a reactor power increase due to cold feedwater. In addition, the temperature difference between feedwater lines A and B is monitored and alarmed if found to be excessive.

If high water Level 8 is reached, a signal is generated to initiate runback of the feedwater demand to zero and trip the main turbine. This protects the turbine from excessive moisture carryover in the main steam. This interlock is implemented in a physically separate controller to ensure a trip function is available upon a common-mode failure of the FWCS FTDCs.

In the event of low water Level 3, a level setpoint setdown is initiated. This aids level control in pressurization events (e.g., main turbine trip with failure of bypass valves). The water level setpoint is set down by a predetermined amount after a time delay of predetermined length following the low water level event. The level setpoint setdown function is reset after the level transient. This function decreases the incoming feedwater supply in order to avoid a high Level 8 trip from the resulting water level transient.

Upon receipt of an Anticipated Transient Without Scram (ATWS) trip signal from the ATWS logic cards of Safety System Logic and Control (SSLC) system, FWCS initiates a runback of feedwater pump feedwater demand to zero and closes the LFCV and the RWCU/SDC Overboard flow control valve. This reduces power and prevents dilution of the boron that would be injected to shut the reactor.

The total feedwater flow is displayed on the main control panel. The FWCS operating mode is selectable from the main control room. The FWCS microprocessors are located in the Control Building.

Digital controllers used for the FWCS are redundant, with diagnostic capabilities that identify and isolate failure of level input signals.

1.2.2.2.4 Standby Liquid Control System

The Standby Liquid Control (SLC) system provides an alternate method of reactor shutdown (i.e., without control rods) from full power to cold subcritical by the injection of a neutron absorbing solution into the RPV.

The SLC system interfaces with Class 1E 250 VDC divisional power for the squib-type injection valves; for the valve which isolates the accumulator after injection; for accumulator solution level measurement, trip, and alarm functions; and for the particular NBS instrumentation and SSLC control logic which generates the anticipated transient without scram (ATWS) signal for automatic SLC system initiation.

The SLC system has two independent 50% capacity trains, which include piping, valves, accumulator and instrumentation that can inject a neutron absorber solution into the reactor. The system is designed to operate over the range of reactor pressure conditions up to the elevated pressures of an ATWS event, and to inject sufficient neutron absorber solution to reach hot subcritical conditions after system initiation.

Instrumentation is provided to the operator for monitoring the status of the SLC system, and for alarming any off standard condition.

1.2.2.2.5 Neutron Monitoring System

The Neutron Monitoring System (NMS) (described in Subsection 7.2.2) provides indication of neutron flux in the core in all modes of reactor operation. The safety-related NMS functions are the startup range neutron monitor (SRNM), the local power range monitor (LPRM), and the average power range monitor (APRM), and the oscillation power range monitor (OPRM), which logic resides in the same hardware/software of the APRM. The nonsafety-related subsystem is the automated fixed in-core probe (AFIP) and the multi-channel rod block monitor (MRBM). The LPRMs and APRMs make up the power range neutron monitor (PRNM) subsystem. The safety-related portions of the NMS are classified as Seismic Category I and IEEE Class 1E.

The NMS provides signals to the RPS, the RC&IS, SSLC, NE-DCIS and the Plant Automation System. The NMS provides trip signals to the RPS for reactor scram on rising excessive neutron flux or too short a period for flux generation.

The safety-related subsystem of NMS consists of four divisions that correspond and interface with those of the RPS. This independence and redundancy ensure that no single failure interferes with the system operation.

The SRNM subsystem is comprised of multiple SRNM channels that are divided into divisions, and independently assigned to bypass groups such that some of the SRNM channels are allowed to be bypassed at any time while still providing the required monitoring and protection capability.

The LPRM function of the PRNM subsystem is comprised of LPRM assemblies evenly distributed throughout the cross-section of the core. There are four LPRM detectors within each LPRM assembly, evenly spaced from near the bottom of the fuel region to near the top of the fuel region. These detectors are assigned to four sets of detectors each. The signals from each set of LPRM detectors are assigned to one APRM channel, with these signals summed and averaged to form an APRM signal that represents the average core power. There are four divisions of APRM channels. Electrical and physical separation of the division is maintained and optimized to satisfy the safety-related system requirement. With the four divisions, redundancy criteria are met because a scram signal can still be initiated with a postulated single failure under allowed APRM bypass conditions.

The NMS instruments are primarily based on the digital measurement and control design practices that use digital design concepts. NMS instruments follow a modular design concept such that each modular unit or its subunit is replaceable upon repair service.

The SRNM subsystem covers the lower power range from the source range to 15% of rated reactor power. The PRNM subsystem overlaps the SRNM, covering the range from approximately 1% to 125% of rated reactor power.

The AFIP subsystem is comprised of sensors and their associated cables, as well as the signal processing electronic unit. The AFIP sensors are the gamma thermometer type. There are four AFIP gamma thermometer sensors evenly distributed across each LPRM assembly, with one gamma thermometer installed next to each LPRM detector. Consequently, there are AFIP sensors at all LPRM locations. The AFIP sensor cables are routed within the LPRM assembly and then out of the RPV through the LPRM assembly penetration to the vessel. The AFIP subsystem generates signals proportional to the axial power distribution at the radial core locations of the LPRM detector assemblies. The AFIP signal range is sufficiently wide to accommodate the corresponding local power range that covers from 1% to 125% of reactor rated power.

The AFIP gamma thermometer sensor has a very stable detector sensitivity that does not significantly change due to radiation exposure or other reactor conditions. The AFIP gamma thermometer can be calibrated by using a built-in calibration device inside the gamma thermometer/LPRM assembly. Due to its stable sensitivity and rugged hardware design, the AFIP sensor has a lifetime longer than that of the LPRM detectors. The AFIP sensors in an LPRM assembly are replaced together with the LPRM detectors when the whole LPRM assembly is replaced.

1.2.2.2.6 Remote Shutdown System

The Remote Shutdown System (RSS) provides the means to safely shut down the reactor from outside the main control room. The RSS provides remote manual control of the systems necessary to:

- achieve and maintain safe (hot) shutdown of the reactor after a scram;
- achieve subsequent cold shutdown of the reactor; and
- maintain safe conditions during shutdown.

The RSS is classified as a safety-related system. The RSS includes control interfaces with safety-related equipment.

1.2.2.2.7 Reactor Protection System

The Reactor Protection System (RPS) initiates an automatic and prompt reactor trip (scram) by means of rapid hydraulic insertion of all control rods whenever selected plant variables exceed preset limits. The primary function is to achieve a reactor shutdown before fuel damage occurs. The RPS also provides reactor status information to other systems, and causes an alarm in the MCR whenever selected plant variables approach the preset limits.

The RPS is a four-division safety protection system, differing from a reactor control system or a power generation system. The RPS and its components are safety-related. The RPS and the system electrical equipment are classified as Seismic Category I and IEEE Class 1E.

RPS descriptions are provided within Section 7.2.

The RPS initiates reactor trip signals within individual sensor channels when any one or more of the conditions listed below exists during reactor operation. Reactor scram results on any of the following conditions if system logic is satisfied.

- Drywell pressure high;
- Reactor power (neutron flux or simulated thermal power) exceeds limit for operating mode;
- Reactor power rapid increase (short period);
- Reactor vessel pressure high;
- Reactor water level low (Level 3);
- Reactor water level high (Level 8);
- Main steam isolation valves closed (Run mode only);
- CRD HCU accumulator charging header pressure low;
- Suppression pool temperature high;
- Turbine stop valve closure and insufficient turbine bypass available;
- Turbine control valve fast closure and insufficient turbine bypass available;
- Main condenser vacuum low;
- Loss of feedwater flow;
- Operator-initiated manual scram; or
- Reactor mode switch in “Shutdown” position.

The RPS is a four division safety-related system that consists of instrument channels, trip logic, trip actuators, manual controls, and scram logic circuitry that initiates the rapid insertion of control rods by hydraulic force to scram the reactor when unsafe conditions are detected. The RPS equipment resides in the SSLC system to perform its functions.

The RPS is divided into four redundant divisions of sensor channels, trip logics, and trip actuators, and two divisions of manual scram controls and logic circuitry. Each division has a separate IEEE Class 1E power supply taken from the safety-related UPS 120 VAC power supply. The automatic and manual scram initiation logic systems are independent of each other to initiate a reactor scram. The RPS design is such that, once a full reactor scram has been initiated automatically or manually, this scram condition seals-in such that the intended fast insertion of control rods into the reactor core will continue to completion. After a time delay, the design requires the scram logic to be reset to untripped state manually.

The RPS scram logic circuits are arranged so that coincident trips in two of the four divisions (2-out-of-4 logic) of sensor channels and in two of the four trip system outputs to the actuating devices are required to initiate a scram. This arrangement permits a single failure in one division to occur without either causing a scram or preventing the other three divisions from causing a scram. For example, the single failure may be in either system logic or the individual power supply for that division.

Each logic division and its associated power supply is separated both physically and electrically from the other divisions. This arrangement permits one division at a time to be taken out of service (bypassed) for testing or repair during reactor operation. The other divisions then perform the RPS function with system logic in a 2-out-of-3 arrangement.

1.2.2.2.8 Plant Automation System

The Plant Automation System (PAS) is classified as a power generation system, is not required for safety, and thus, is classified as nonsafety-related. Events requiring control rod scram are sensed and controlled by the safety-related RPS, which is completely independent of PAS. This system provides the capability for supervisory control of the entire plant by supplying setpoint commands to independent nonsafety-related automatic control systems as changing load demands and plant conditions dictate.

PAS provides supervisory control of reactor power during reactor startup, power generation and reactor shutdown by appropriate commands to change rod positions. PAS also controls the pressure setpoint or turbine bypass valve position during reactor heatup and depressurization (e.g., to control the reactor cooldown rate). PAS issues supervisory set points commands to sub loops of various secondary plant systems. PAS consists of redundant process controllers. The automation process is divided into phases corresponding to plant start-up, shutdown, and normal power generation. Each phase is then divided into several break-points or logical steps in plant operation. Automation proceeds under PAS control until the end of a break-point division is reached, at which time the operator must confirm that conditions are acceptable before automation sequence can continue.

PAS controls the overall plant startup, power operation, and shutdown functions under operator break-point control. PAS receives input from the Neutron Monitoring System, the NE-DCIS, the Steam Bypass and Pressure Control system, and the operator's control console. The output demand signals from PAS are sent to the RC&IS to position the control rods, and to the Steam Bypass and Pressure Control system for automatic load following operations.

PAS control functional logic is performed by redundant, microprocessor-based fault-tolerant digital controllers (FTDC). The FTDC performs many functions. It reads and validates inputs

from the NE-DCIS. It performs the specific power control calculations, processes the pertinent alarm and interlock functions, and then updates all system outputs to the NE-DCIS. To prevent computational divergence among the redundant processing channels, each channel performs a comparison check of its calculated results with other redundant channels. The internal FTDC architecture features redundant multiplexing interfacing units for communications between the NE-DCIS and the FTDC processing channels.

If any system or component condition is abnormal during execution of the prescribed sequences of operation, PAS automatically switches into the manual mode, and the operator can manipulate control rods and manage the plant using the normal controls. A failure of PAS does not prevent manual control of the reactor, nor does it prevent safe shutdown of the reactor.

PAS digital controllers are powered by redundant uninterruptible non-Class 1E power sources. No single power failure results in the loss of any PAS function.

1.2.2.2.9 Steam Bypass and Pressure Control System

The Steam Bypass and Pressure Control (SB&PC) system controls reactor pressure during plant startup, power generation, and shutdown modes of operation. This is accomplished through control of the turbine control valves and/or turbine bypass valves, such that susceptibility to reactor trip, turbine-generator trip, main steamline isolation and safety/relief valve opening is minimized. Triplicated fault tolerant digital controller using feedback signals from reactor vessel dome pressure sensors generate command signals for the turbine bypass valves and pressure regulation demand signals used by the Turbine Control System (TCS) to generate demand signals for the turbine control valves. For normal operation, the turbine control valves regulate reactor pressure. However, whenever the total steam flow demand from the SB&PC system exceeds the effective turbine control valve steam flow demand, the SB&PC system sends the excess steam flow directly to the main condenser through the turbine bypass valves.

Ability of the plant to load-follow the grid-system demands is accomplished by the aid of control rod actions. In response to the resulting steam production demand changes, the Steam Bypass and Pressure Control (SB&PC) system adjusts the demand signals sent to the TCS so that the TCS will adjust the turbine control valves to accept the control steam output change, thereby controlling pressure.

Controls and valves are designed such that steam flow is shut off upon complete loss of control system electrical power or hydraulic system pressure.

1.2.2.2.10 Distributed Control and Information System

The Distributed Control and Information System (DCIS) is composed of two separate systems: Non-Essential DCIS (NE-DCIS) and Essential DCIS (E-DCIS).

1.2.2.2.10.1 Non-Essential Distributed Control and Information System

The nonsafety-related NE-DCIS is the data communication method for all control systems, and certain individual control functions, that are not part of safety-related control systems. The NE-DCIS equipment is based upon fiber optics communications technology and computer controls. The system transfers data between control system equipment and the main control room. The NE-DCIS also includes network gateways, which allow the transfer of data between discrete data highway systems. All interconnections use fiber optic data links.

1.2.2.2.10.2 Essential Distributed Control and Information System

The Essential Distributed Control and Information System (E-DCIS) provides redundant data communications networks to support the monitoring and control of interfacing safety-related control and instrumentation systems. The system includes electrical devices and circuitry that connect field sensors, display devices, controllers, power supplies, and actuators, which are part of these safety-related systems. The E-DCIS also includes any associated data acquisition and communications software, if required, to support its distribution function of data and control. The system processes data from safety-related systems and safety-related trip or initiation data strictly through E-DCIS, while nonsafety-related data is processed through the Non-Essential DCIS.

The E-DCIS replaces most of the conventional, long-length, copper-conductor cables with a dual-redundant, fiber optic, data network to reduce the cost and complexity of separated divisions of cable runs that connect components of the plant protection and safety systems. The E-DCIS provides an electrically noise-free transmission path for plant sensor data and safety system control signals.

1.2.2.2.11 Leak Detection and Isolation System

The Leak Detection and Isolation System (LD&IS) detects and monitors leakage from the containment, preventing the release of radiological leakage from the reactor coolant boundary to the environment. The system initiates safety isolation functions by closure of inboard and outboard containment isolation valves.

The following functions are supported by the LD&IS:

- Containment isolation following a loss-of-coolant accident event;
- Main steamline isolation;
- Isolation condenser system process lines isolation;
- Reactor Water Cleanup/Shutdown Cooling system process lines isolation;
- Fuel and Auxiliary Pools Cooling System process lines isolation;
- Chilled Water System lines to drywell coolers isolation;
- Isolation of liquid drain lines for drywell sumps;
- Containment purge and vent lines isolation;
- Reactor building HVAC air exhaust ducts isolation;
- Fission products sampling line isolation;
- Monitoring of identified and unidentified leakages in the drywell;
- Monitoring of condensate flow from the drywell air coolers; and
- Monitoring of the vessel head flange seal leakage

The following leakage detection functions are provided by other plant systems:

- Monitoring of fission products in the drywell;

- Monitoring of plant sump levels and flow rates; and
- Monitoring of safety valve and safety/relief valve steam discharge and/or leakage.

The LD&IS monitors plant parameters such as flow, temperature, pressure, water level, etc., which are used to alarm and initiate the isolation functions.

At least two parameters are monitored for an isolation function. The signal parameters are processed by the Safety System Logic and Control (SSLC) system, which generates the trip signals for initiation of isolation functions.

The LD&IS safety-related functions have four divisional channels of sensors for each parameter. Two-out-of-four coincidence voting within a channel is required for initiation of the isolation function. The control and decision logic are of fail-safe design, which ensures isolation on loss of power. The logic is energized at all times and de-energizes to trip for isolation functions.

Loss of one divisional power or one monitoring channel does not cause inadvertent isolation of the containment. Different divisional isolation signals are provided to the inboard and outboard isolation valves.

The LD&IS is designed to allow periodic testing of each channel to verify it is capable of performing its intended function.

The safety-related portions of the LD&IS are classified Seismic Category I.

The LD&IS initiates isolation functions automatically. All isolation valves have individual manual control switches and valve position indication in the MCR. However, the isolation signal overrides any manual control to open the isolation valves.

Manual control switches in the control logic provide a backup to automatic initiation of isolation as well as capability for reset, bypass and test of functions.

The monitored plant parameters are measured and recorded by the NE-DCIS, and are displayed on demand. The abnormal indications and initiated isolation functions are alarmed in the MCR.

1.2.2.2.12 Safety System Logic and Control System

The Safety System Logic and Control (SSLC) system is the decision-making control logic segment of the automatic reactor protection and engineered safety features systems. SSLC processes automatic and manual demands for reactor trip (scram), nuclear system isolation, and engineered safety features actuation based upon sensed plant process parameters or operator request.

SSLC permits the above safety-related systems to provide protective action by implementing the protection logic functions of these safety-related systems. SSLC runs without interruption in all modes of plant operation to support the required safety-related functions.

The SSLC system includes the logic of the reactor protection system (RPS), main steam line isolation valve closure, leak detection and isolation system (LD&IS), and the initiation of the Standby Liquid Control (SLC) system associated with anticipated transient without scram (ATWS). The SSLC also includes the safety-related logic functions of engineering safety feature (ESF) functions. SSLC logic for ESF does not require operator intervention during normal operation.

The SSLC system is configured as a four-division data acquisition and control system, with each division containing an independent set of microprocessor-based, software-controlled logic processors. The four divisions exchange data via fiber optic data links to implement cross-channel data comparison.

The SSLC system acquires data from redundant sets of sensors of the interfacing safety-related systems and provides control outputs to the final component actuators. Data is received from the E-DCIS or directly hardwired from transmitters or sensors.

1.2.2.2.13 Diverse Instrumentation and Controls

Diverse instrumentation and controls are provided for the features addressed in Branch Technical Position (BTP) HICB-19 (1997) and Regulatory Guide 1.152. The diverse instrumentation and controls address concerns about common cause failures in software-based Reactor Protection System (RPS) and engineered safety features (ESF) systems. The BTP requires a diverse system to ensure proper operation of RPS and ESF functions in the event of a common cause type failure of the primary protection systems.

The diverse instrumentation and controls consist of three components, which address the diverse protection functions, as follows:

- (1) A set of protection logics that provide diverse means to scram the reactor via control rod insertion using separate and independent hardware and software from the primary RPS.
- (2) A set of ESF initiation logics that provide diverse means to initiate the ESF functions using separate and independent hardware and software from the primary ESF systems.
- (3) A set of alternate rod insertion (ARI) and associated logic (e.g., control rod run in) via control rod insertion through alternate means by opening the three sets of air header dump valves of the control rod drive system.

The ARI logic of (3) is part of the ATWS Mitigation Logic function.

Backup of Reactor Protection System Functions:

A set of diverse logic, using separate and independent hardware and software to scram the reactor via control rod insertion, is included in the diverse instrumentation and controls. For the ESBWR, it is sufficient to include a subset of the existing RPS scram logic functions in the diverse instrumentation and controls to ensure acceptable diverse protection results. This set of diverse protection logic for reactor scram, combined with other diverse backup scram protection and diverse ESF functions, provide the necessary diverse functions to meet the required design position called out in the BTP HICB 19. The following scram signals are included in the diverse instrumentation and controls:

- High Reactor Pressure;
- High Reactor Water Level (L8);
- Low Reactor Water Level (L3);
- High Drywell Pressure; and
- High Suppression Pool Temperature.

This diverse set of RPS scram logic resides in independent and separate hardware and software equipment from the primary RPS. The process variables sensors that provide input to this diverse set of logic use different sets of sensors from those used in the primary RPS. The diverse logic equipment is nonsafety-related with triple redundant channels. The power sources of this diverse equipment are from the nonsafety-related load groups. The scram initiation logic is “energize to actuate.” The trip logic is based on 2-out-of-3 voting.

Backup of ESF Functions:

The ESBWR has several ESF functions including Gravity-Driven Cooling System (GDSCS), Isolation Condenser System (ICS), Standby Liquid Control (SLC) system, and Automatic Depressurization System (ADS) function using safety relief valves (SRVs) and (if needed) depressurization valves (DPVs). To provide adequate diverse vessel depressurization and core cooling functions, the diverse instrumentation and controls include initiation logic for GDSCS, SRVs and DPVs that is diverse from the primary ESF function logic. This set of diverse logic for ESF function initiation, combined with other diverse backup scram protection and selected diverse RPS logic, provides the necessary diverse functions to meet the required design position called out in the BTP HICB 19.

This set of diverse ESF logic resides in separate and independent hardware and software equipment from the primary ESF systems. The process variables sensors that provide inputs to this diverse set of logic use different sets of sensors from those used in the primary ESF systems. The diverse logic equipment is nonsafety-related with triple redundant channels. The diverse equipment power source is nonsafety-related. The initiation logic is “energize to actuate” similar to the primary ESF. The trip logic is based on 2-out-of-3 voting.

Backup of ARI and associated functions:

The diverse instrumentation and controls includes the nonsafety-related alternate rod insertion (ARI) logic for reactor scram, which is also considered as part of ATWS mitigation logic. This logic generates the following signals to support the mitigation of an ATWS event:

- A signal to open the three sets of ARI air header dump valves in the Control Rod Drive (CRD) system on a high reactor vessel pressure signal, a low reactor water level signal, or a manual ATWS initiation signal.
- A signal to the Rod Control and Information System (RC&IS) to initiate electrical insertion of all operable control rods on a high reactor vessel pressure signal, a low reactor water level signal, or a manual ATWS initiation signal.

ARI/FMCRD Run-In logic resides in the nonsafety-related diverse instrumentation and controls as a triple channel system, powered by nonsafety-related load group power sources.

1.2.2.3 Radiation Monitoring Systems**1.2.2.3.1 Process Radiation Monitoring System**

The Process Radiation Monitoring System (PRMS) measures and provides for display of radioactivity levels in process and effluent gaseous and liquid streams, initiates protective actions, and activates alarms in the Main Control Room (MCR) on high radiation signals. The PRMS provides radiological monitoring during plant operation and following an accident.

Subsystems of the PRMS consist primarily of Radiation Detection Assemblies, off-line liquid and gaseous sampling panels/skids, in-line sample chambers and Signal Conditioning Units. The PRMS consists of independent subsystems, each of which contains between one and eight monitoring channels. The PRMS safety-related channel trip signals are provided as inputs to the Safety System Logic and Control (SSLC) for generation of protective action signals.

The primary functions of the PRMS are to:

- Monitor the various gaseous and liquid process streams and effluent releases and provide main control room display, recording and alarm capability;
- Initiate alarms in the main control room to warn operating personnel of high radiation activity; and
- Initiate the appropriate actions and controls to prevent further radioactivity releases to the environment.

This PRMS provides instrumentation for radiological monitoring, sampling and analysis of identified process and effluents streams throughout the plant. The process and effluent paths and/or areas listed below are monitored for potential high radioactivity releases. The radiation monitors of the first seven items are safety-related Class 1E instrumentation, while the remaining of the PRMS monitors are nonsafety-related.

- The Main Steamline (MSL) RMS continuously monitors the gamma radiation level of the main steamlines in the MSL tunnel area for high gross gamma radioactivity in the steam flow to the turbine. The subsystem provides input to logic that results in shutdown of the main turbine condenser mechanical vacuum pump (MVP) and MVP valve closure. However, this function is not safety-related.
- The Reactor Building HVAC Exhaust Vent RMS continuously monitors the gross gamma quantity of radioactivity being exhausted via this Exhaust duct and the Refueling Area Air Exhaust duct. The discharge point from the duct is monitored with four physically and electrically independent and redundant divisions. In the event of radioactive releases due to system failures in the Reactor Building, or due to a fuel handling accident, the Reactor Building HVAC exhaust fans are stopped.
- The Control Room Air Intake RMS consists of eight channels. Four divisionalized Radiation Detection Assemblies are mounted external to each ventilation intake duct for the Control Room HVAC. The Radiation Detection Assemblies continuously monitor the gamma radiation levels from each air intake plenum for the building or area containing the MCR and auxiliary rooms. The Control Room outside air intake is secured in the event of a high radiation levels in order to protect the operating staff.
- The Isolation Condenser Vent Discharge RMS continuously monitors the four Isolation Condenser Discharge Vents for gross gamma radiation by sixteen local detectors (four per isolation condenser vent). High radiation in the exhaust of a vent results in isolation of the affected Isolation Condenser loop.
- The Refuel Handling Area Air Exhaust RMS continuously monitors gamma radiation levels in the exhaust plenum of the HVAC exhaust ducts in the Refuel Handling Area of the Reactor Building with four divisions of Radiation Detection Assemblies and

channels. In the event of a radioactive release due to an accident while handling spent fuel, the Reactor Building HVAC exhaust fans are tripped off.

- The Fuel Building Main Area HVAC RMS consists of four channels that monitor the gamma radiation level of the air exiting the spent fuel pool and associated fuel handling areas as well as the rooms with the fuel pool cooling and cleanup equipment. In the event of radioactive releases due to an accident while handling spent fuel, Fuel Building HVAC exhaust fans are stopped.
- The Drywell Sump LCW/HCW Discharge RMS continuously monitors gamma radiation levels in the transfer pipes from the Drywell Low Conductivity Waste (LCW) and High Conductivity Waste (HCW) sumps to the Radwaste System. The two locations monitored are downstream of the Drywell LCW sump discharge pipe isolation valve and downstream of the Drywell HCW sump discharge isolation valve. Automatic isolation of the two sump discharge pipes occurs if high radiation levels are detected during liquid waste transfers.
- The Offgas Pre-Treatment sampling RMS has a single channel. The subsystem samples the Offgas stream at the discharge from the Offgas cooler and condenser. Typically, the first indication of a fuel failure is detected by this subsystem.
- The Offgas Post-Treatment RMS monitors the release of radiation at the discharge from the Offgas System, after the process stream has passed through the charcoal hold-up system. The subsystem consists of two independent skids and a gas sampler. The subsystem is equipped with a flow controller capable of continuously measuring the mass flows of both the main process and the sample and automatically maintaining the sample flow proportional to the process flow.
- The Charcoal Vault Ventilation Exhaust RMS, consisting of one channel, monitors the radioactivity exhausting in the ventilation air from the charcoal vault.
- The Turbine Building HVAC RMS consists of three subsystems. Both of first two subsystems, the Turbine Building Normal Ventilation Exhaust and the Turbine Building Compartment Area Exhaust, consist of two non-divisional channels each, continuously monitoring the air flow through the exhaust ducts from the Turbine Building, prior to combining with other flows to the Turbine Building Ventilation Vent, for radioactivity. The third subsystem, Turbine Building Exhaust channel is composed of a local sample panel that monitors gaseous, halogen and particulate radiation levels. The panel has provision for monitoring tritium.
- The Main Turbine Gland Seal Steam Condenser Exhaust RMS continuously monitors the gland seal steam offgas, discharged into the Turbine Building Ventilation System, for radioactive noble gases. A sampler, similar to the offgas post-treatment radiation monitor sampler, is capable of grabbing gaseous samples.
- The Radwaste Building Ventilation Exhaust RMS continuously monitors halogens, particulates and noble gas releases from the Radwaste Building vent to the atmosphere for both normal and accident conditions.
- The Liquid Radwaste Discharge RMS, consisting of a single channel, continuously monitors the gross gamma radiation level in the liquid effluent stream. The Liquid

Radwaste Discharge RMS initiates the closure of the Radwaste Discharge system isolation valves on high radiation level. A sampling skid is provided.

- The Drywell Fission Product RMS consists of two channels that monitor the drywell air space radiation levels for leakage detection. The Drywell Fission Product RMS monitors a continuous sample, extracted from the drywell, for the presence of radioactive particulates and noble gases. The subsystem shall be utilized to aid in meeting the detection requirements for reactor coolant leakage. The subsystem includes local sampling panels and a Signal Conditioner connected to each radiation detector assembly.
- The Reactor Component Cooling Water (RCCW) Intersystem Leakage RMS consists of two channels. These channels monitor for gross radiation levels that are indicative of leakage through the heat exchangers in the RCCW system.
- A single channel radiation monitor continuously monitors the Technical Support Center Ventilation intake duct. Upon detection of radioactivity at the outside air intake, the Air Handling Unit (AHU) outdoor air damper is closed and a filter train fan is started.
- The Fuel Building Ventilation Exhaust AHU RMS consists of four channels that monitor the radiation level of the air entering the Fuel Building Ventilation unit area exhaust AHUs.
- The Fuel Building Ventilation Stack RMS continuously monitors halogens, particulates and noble gases releases from the Fuel Building Vent to the atmosphere for both normal and accident conditions.
- The Stack RMS monitors particulate, iodine and gaseous concentrations in the main stack effluent for both normal and accident plant conditions. It is composed of three sampling channels that are designed to meet the requirements of both 10 CFR 20 for low level effluent releases and Regulatory Guide 1.97 for accident effluent releases. Provisions for monitoring tritium are also provided.

1.2.2.3.2 Area Radiation Monitoring System

The Area Radiation Monitoring System (ARMS) continuously monitors the gamma radiation levels within various key areas throughout the plant and provides an early warning to operating personnel when high radiation levels are detected so the appropriate action can be taken to minimize occupational exposure.

The ARMS consists of a number of channels, each consisting of a Radiation Detection Assembly and a Signal Conditioning Unit. When required, a local Auxiliary Unit with a display and audible alarm is also provided. Each ARMS radiation channel has two independently adjustable trip alarm circuits. One circuit is set to trip on High radiation and the other is set to trip on downscale indication (loss of sensor input). ARMS alarms in both the MCR and at plant local areas. Each ARM Signal Conditioning Unit is equipped with a test feature that monitors for gross failures and activates an alarm on loss of power or when a failure is detected.

This system is nonsafety-related. The radiation monitors are powered from the non-Class 1E 120 VAC sources.

The trip alarm setpoints are established in the field following equipment installation at the site. The exact settings are based on sensor location, background radiation levels, expected radiation levels, and low occupational radiation exposures.

1.2.2.4 Core Cooling Systems Used For Abnormal Events

1.2.2.4.1 Isolation Condenser System

The Isolation Condenser System (ICS) removes decay heat after any reactor isolation during power operations. Decay heat removal limits further pressure rise and keeps the RPV pressure below the SRV pressure setpoint. It consists of four independent loops, each containing a heat exchanger that condenses steam on the tube side and transfers heat by heating/evaporating water in the Isolation Condenser/Passive Containment Cooling (IC/PCC) pools, which are vented to the atmosphere.

The ICS is initiated automatically on a high reactor pressure, MSIV closure or a low water level signal. To start an IC into operation, a condensate return valve is opened whereupon the standing condensate drains into the reactor and the steam-water interface in the IC tube bundle moves downward below the lower headers to a point in the main condensate return line. The ICS can also be initiated manually from the MCR. A fail-open nitrogen piston-operated condensate return bypass valve is provided for each IC, which opens if the 250 V DC power is lost, or on a low reactor water level signal.

The ICS is isolated automatically when either a high radiation level or excess flow is detected in the steam supply line or condensate return line.

The IC/PCC pool is divided into subcompartments that are interconnected at their lower ends to provide full use of the water inventory for heat removal by any IC. The Fuel and Auxiliary Pools Cooling System (FAPCS) performs cooling and cleanup of IC/PCC pool water. During IC operation, IC/PCC pool water can boil, and the steam produced is vented to the atmosphere. This boil-off action of non-radioactive water is a safe means for removing and rejecting all reactor decay heat.

The IC/PCC pool has an installed capacity that provides at least 72 hours of reactor decay heat removal capability. The heat rejection process can be continued indefinitely by replenishing the IC/PCC pool inventory. A safety-related FAPCS makeup line is provided to convey emergency makeup water into the IC/PCC pool from a water supply outside of the reactor building. The flow path for this makeup can be established independent of FAPCS operation, simply by manually opening the isolation valve on the FAPCS makeup line located at grade level in the yard area external to the reactor building.

The ICS passively removes sensible and core decay heat from the reactor (i.e., heat transfer from the IC tubes to the surrounding IC/PCC pool water is accomplished by natural convection, and no forced circulation equipment is required) when the normal heat removal system is unavailable following any of the following events:

- Sudden reactor isolation at power operating conditions;
- During station blackout (i.e., unavailability of all AC power); and
- Anticipated Transient Without Scram (ATWS).

The ICs are sized to remove post-reactor isolation decay heat with 3 of 4 ICs operating and to reduce reactor pressure and temperature to safe shutdown conditions, with occasional venting of radiolytically generated noncondensable gases to the suppression pool. The heat exchangers (ICs) are independent of station AC power and function whenever normal heat removal systems are unavailable to maintain reactor pressure and temperature below limits.

The portions of the ICS (including isolation valves), which are located inside the containment and on the steam lines out to the IC flow restrictors, are designed to ASME Code Section III, Class 1, Quality Group A. Other portions of the ICS are ASME Code Section III, Class 2, Quality Group B. The IC/PCC pools are safety-related and Seismic Category I.

The control room operators can perform periodic surveillance testing of the ICS valves via remote manual switches that actuate the isolation valves and the condensate return valves. Status lights on the valves verify the opening and closure of the valves.

The essential monitored parameters for the IC/PCC pools are pool water level and pool radiation. IC/PCC pool water level monitoring is a function of the FAPCS, which is addressed in Subsection 1.2.2.6.2. IC/PCC pool radiation monitoring is a function of the PRMS, which is addressed in Subsection 1.2.2.3.1.

1.2.2.4.2 Emergency Core Cooling System — Gravity-Driven Cooling System

Emergency core cooling is provided by the Gravity-Driven Cooling System (GDCS) in conjunction with the ADS in case of a LOCA. When an initiation signal is received, the ADS depressurizes the reactor vessel and the GDCS injects sufficient cooling water to maintain the fuel cladding temperatures below temperature limits defined in 10 CFR 50.46.

In the event of a severe accident that results in a core melt with the molten core in the lower drywell region, GDCS floods the lower drywell cavity region with the water inventory of the three GDCS pools and the suppression pool (SP).

The GDCS is an engineered safety feature (ESF) system. It is classified as safety-related and Seismic Category I. GDCS instrumentation and DC power supply are IEEE Class 1E.

Basic system parameters are:

- Three independent subsystems
 - Short-term cooling (injection)
 - Long-term cooling (equalization)
 - Deluge (drywell flooding)
- Initiation signal: see Subsection 7.3.1
- A time delay between initiation and actuation for short-term water injection
- A time delay between initiation and actuation for long-term water injection
 - Permissive interlocked to RPV water level
- Deluge system initiated on high lower drywell floor temperature

- Squib valve firing logic is normally 2-out-of-4, but reverts to 2-out-of-3 logic and ignores the bypassed division when the division of sensors bypass is operated
- Manual actuation:
 - Two channels
 - Permissive: Interlocked to RPV low pressure signal for short- and long-term cooling subsystems and interlocked to RPV high-high drywell pressure
 - Logic is simultaneous operation of two switches of the same division
- Monitored parameters:
 - GDCS Pool water level
 - GDCS valve positions

The GDCS injects water into the downcomer annulus region of the reactor after a LOCA and reactor vessel depressurization. It provides short-term gravity-driven water makeup from three separate water pools located within the upper drywell at an elevation above the active core region. The system also provides long-term post-LOCA makeup from the suppression pool to meet long-term core decay heat boil-off requirements. Following any initiating event that progresses to severe accident conditions, the system floods the lower drywell region with water if the core melts through the RPV.

The GDCS is completely automatic in actuation and operation. A backup to automatic actuation is the ability to actuate by operator action.

The GDCS consists of four identical trains completely independent of each other both electrically and mechanically, with the exception of two trains sharing one of the GDCS pools. A confirmed low RPV water level signal actuates the ADS to reduce RPV pressure. When a coincident high drywell pressure signal is present, ADS initiates earlier and at a higher RPV water level. Details of the actuation logic are provided in Section 7.3.1. Simultaneously, short-term and long-term system timers in the GDCS logic start, which, after time-out and satisfying permissive conditions, actuate squib valves providing an open flow path from the respective water sources (GDCS pools and suppression pool, respectively) to the vessel.

The short-term system supplies gravity-driven flow to eight separate nozzles on the vessel with suction flow from the three separate GDCS pools. The long-term system supplies gravity-driven flow to four other nozzles with suction flow from the suppression pool through equalizing lines.

Both the short-term and long-term systems are designed to ensure that adequate reactor vessel inventory is provided assuming a LOCA in one GDCS line and failure of one GDCS injection (squib) valve to actuate in a separate GDCS train.

GDCS deluge lines, each having one squib actuated valve, provide a means of flooding the lower drywell cavity in the event of a core melt sequence which causes failure of the lower vessel head and allows molten fuel to reach the lower drywell cavity floor. These squib-activated valves are driven by logics receiving input signals from an array of temperature sensors located in the lower drywell.

GDCS pool level is the only essential system parameter that must be monitored in the main control room to verify system readiness and its proper function following initiation. Low level alarm instrumentation is included as part of GDCS.

1.2.2.5 Reactor Servicing Equipment

1.2.2.5.1 Fuel Service Equipment

The refueling and fuel-handling platforms are also included and are outlined in Subsection 1.2.2.5.5. Fuel servicing tools and equipment are not safety-related.

Fuel Preparation Machine

Two fuel preparation machines are mounted against the wall of the spent fuel storage pool. They have two primary uses. They are used to lower new fuel into the pool after the fuel has been inspected in the new fuel inspection stand and are used to inspect spent fuel when submerged in the storage pool and to aid in reconstitution of fuel found to be defective.

New Fuel Inspection Stand

The new fuel inspection stand is mounted in a pit on the refueling floor of the Fuel Building. The pit allows inspection of two fuel bundles over their full length. Channeling is also performed with the aid of the channel handling tool.

Channel Bolt Wrench

The channel bolt wrench is a long handled socket-end wrench used in the assembly or disassembly of the channel from the fuel bundle, by insertion or removal of the attaching bolt, while channeling or de-channeling fuel or reconstituting spent fuel in the fuel preparation machine.

Channel Handling Tool

The channel handling tool is a long handled clamping tool used to engage the channel for removal. It is manually operated and suspended from the channel handling boom that is located on the refueling floor of the fuel building adjacent to the fuel preparation machine.

General Purpose Grapple

The general purpose grapple is primarily for use in handling fuel or other light-weight components with a handle configuration approximating a fuel bail.

1.2.2.5.2 Miscellaneous Service Equipment

This equipment is generally used independently of other servicing equipment. Equipment requirements are that they operate underwater. The equipment is designed to be quickly decontaminated and can be stored with a minimum of effort by plant personnel. Typical service equipment would likely include:

Underwater Lights

Three types of lights are used: a general area light, a local area light, and a drop-type light.

Viewing Aids

Three types of viewing aids are used. A floating type viewing aid is the simplest. Another aid features an underwater viewing tube with a telescope. The last is an underwater, remotely controlled television camera with an internal light source.

Underwater Vacuum Cleaner

The underwater vacuum cleaner is used to clean any pool floor underwater and is remotely serviceable while submerged.

1.2.2.5.3 Reactor Pressure Vessel Servicing Equipment

These tools are used when the reactor is shut down and the RPV head is being removed or installed. Tools used typically consist of strongbacks, nut racks, stud tensioners, protectors, wrenches, etc. Lifting tools are designed for a safety factor of 10 or better with respect to the ultimate strength of the material used. Tools are designed for a 60-year life in the working environment.

1.2.2.5.4 RPV Internals Servicing Equipment

Instrument Strongback

The instrument strongback is used to aid in handling and replacement of Local Power Range Monitor (LPRM) and Startup Range Neutron Monitor (SRNM) dry tubes, in conjunction with support from the instrument handling tool.

Instrument Handling Tool

The instrument handling tool is connected to the wire terminal of the auxiliary hoist of the refueling platform and receives LPRMs or dry tubes from the strongback.

1.2.2.5.5 Refueling Equipment

The Reactor Building is supplied with a refueling machine for fuel movement and servicing the RPV.

Refueling Machine

The refueling machine is a gantry-type crane that spans the reactor vessel cavity and the buffer pool to handle fuel and perform other ancillary tasks in the Reactor Building. It is equipped with a traversing trolley on which is mounted a telescoping mast and integral fuel grapple. An auxiliary hoist is also provided. The machine is a rigid structure built to precise engineering standards to ensure accurate and repeatable positioning during the refueling process.

The refueling machine is classified as nonsafety-related, but designed as Seismic Category I.

The refueling machine is designed for automatic operation by a programmed computer located on the refueling machine. A position indicating system and travel limit computer are provided to locate the grapple over the vessel core and prevent collision with pool obstacles. The computer can control all direct refueling machine movements to any selected core location through the established XYZ coordinate system.

The mast grapple has a redundant load path (i.e., two independent 100% load support mechanisms) so that no single component failure results in a fuel bundle drop. Interlocks on the machine:

- Prevent hoisting a fuel bundle over the vessel unless an all-control-rods-in permissive is present;
- Limit vertical travel of the fuel grapple to provide shielding over the grappled fuel during transit; and
- Prevent lifting of fuel without grapple hook engagement and load engagement.

Fuel Handling Platform

The fuel handling platform is only used for fuel servicing and transporting tasks in the Fuel Building. It is equipped with a traversing trolley on which is mounted a telescoping mast and integral fuel grapple. An auxiliary hoist is also provided. The machine is a rigid structure built to precise engineering standards to ensure accurate and repeatable positioning while handling fuel.

The refueling machine is classified as nonsafety-related, but designed as Seismic Category I.

A position indicating system and travel limit computer are provided to locate the grapple over the spent fuel storage racks and prevent collision with pool obstacles. The mast grapple has a redundant load path (i.e., two independent 100% load support mechanisms) so that no single component failure results in a fuel bundle drop. Interlocks on the machine:

- Limit vertical travel of the fuel grapple to provide shielding over the grappled fuel during transit; and
- Prevent lifting of fuel without grapple hook engagement and load engagement.

1.2.2.5.6 Fuel Storage Facility

New and spent fuel storage facilities are required for fuel and associated equipment.

New Fuel Storage

New fuel is stored in the new fuel storage racks in the buffer pool of the Reactor Building. These are side-loading racks of stainless steel construction with neutron absorbing material. This ensures that a full array of loaded fuel remains subcritical by 5% Δk under all conditions.

Spent Fuel Storage

Spent fuel storage racks are of stainless steel construction with neutron absorbing material. This ensures that a full array of loaded spent fuel remains subcritical by 5% Δk under all conditions.

Adequate water shielding is always maintained in storage pools by the use of level sensors. All storage pools are constructed with stainless steel liners to form a leak-tight barrier. A leak detection system monitors liner integrity.

The thermal-hydraulic design of the rack provides sufficient natural convection cooling flow to remove decay heat without exceeding 100°C (212°F).

1.2.2.5.7 Under-Vessel Servicing Equipment

The primary functions of the under-vessel servicing equipment are to:

- Install and remove FMCRDs;

- Install and remove FMCRD packing sections and motors;
- Make connections to neutron detectors and gamma thermometers;
- Provide servicing tools; and
- Provide a work platform and CRD handling equipment.

Under-Vessel Platform

The under-vessel platform provides a working surface for personnel and equipment to the entire under-vessel area. This requires 360° rotational capability. The platform also provides the facility for operation of the FMCRD handling machine for the automatic removal of the FMCRDs.

1.2.2.5.8 FMCRD Maintenance Area

The FMCRD maintenance area is designed and equipped to perform FMCRD maintenance related activities, including decontamination of the FMCRD components, acceptance testing, and storing spare drives. Maintenance tasks use a combination of manual and remote operations to reduce radiation exposure to plant personnel and to reduce contamination of surrounding equipment during operation.

The FMCRD maintenance area is located in a shielded room near the drywell equipment entry door. The layout of the room permits a convenient and efficient sequencing of work while reducing exposure to personnel.

1.2.2.5.9 Fuel Cask Cleaning

Spent fuel cask cleaning is performed in two different areas of the plant. Spent fuel cask cleaning is performed at the receiving area in the Fuel Building if required to remove surface dirt accumulated during transportation. It is also performed in the cask pit following loading of spent fuel, under the jurisdiction of health physics personnel.

The receiving area of the plant has facilities for:

- Checking the cask for contamination;
- Cleaning the cask of road dirt;
- Inspection of the cask for damage;
- Attachment of the cask lifting yoke;
- Removal of head bolts and attachment of head lifting cables; and
- Moving the cask into the cask pit using the main Fuel Building crane.

The cask pit area in the Fuel Building includes:

- A deep drainable pit with gate access to the storage pool for underwater cask loading;
- An underwater area for the storage of the cask head and lifting yoke; and
- An area for high pressure cleaning and decontamination. This area is accessible for chemical and hand scrubbing, refastening the head, and for smear tests.

1.2.2.5.10 Fuel Transfer System

The ESBWR is equipped with an Inclined Fuel Transfer System (IFTS). In general the arrangement of the IFTS consists of a terminus at the upper end in the Reactor Building buffer pool that allows the fuel to be tilted from a vertical position to an inclined position prior to transport to the spent fuel pool. There is means to lower the transport device (i.e., a carriage), means to seal off the top end of the transfer tube, and a control system to affect transfer. The IFTS has lower terminus in the Fuel Building storage pool, and a means to tilt the fuel to be removed from the transport cart. There are controls contained in local control panels to affect transfer. There is a means to seal off the upper and lower end of the tube while allowing filling and venting of the tube.

There is sufficient redundancy and diversity in equipment and controls to prevent loss of load (i.e., carriage with fuel is released in an uncontrolled manner), and there are no modes of operation that allow simultaneous opening of any set of valves that could cause draining of water from the upper pool in an uncontrolled manner.

The IFTS has sufficient cooling such that a freshly removed fuel assembly can remain in the IFTS until it is removed without damage to the fuel or excessive overheating.

All IFTS components are not required to remain operable under all the anticipated ranges of the abnormal or accident plant environment. However, the IFTS tubes and supporting structure can withstand an SSE without failure of the basic structure or compromising the integrity of adjacent equipment and structures. Therefore, the portion of the IFTS transfer tube assembly from where it interfaces with the upper fuel pool, the portion of the tube assembly extending through the building, the drain line connection, and the lower spent fuel pool terminus equipment (i.e., tube, valve, support structure, and bellows) are designated as nonsafety-related and Seismic Category I. The remaining equipment is designated as nonsafety-related and Seismic Category NS.

The IFTS carriage primarily handles nuclear fuel using a removable insert, and is capable of handling control blades with a separate insert in the transfer cart.

For radiation protection, personnel access into areas of high radiation or areas immediately adjacent to the IFTS is controlled. Access to any area adjacent to the transfer tube is controlled through a system of physical controls, interlocks and an alarm. Specifically,

- Controls prevent personnel from inadvertently or unintentionally being left in those areas at the time the access doors are closed;
- During IFTS operation or shutdown, personnel are prevented from (a) either reactivating the IFTS while personnel are in a controlled maintenance area, or (b) entering a controlled IFTS maintenance area while irradiated fuel or components are in any part of the IFTS;
- Both an audible alarm and flashing red lights are provided both inside and outside any maintenance indicating IFTS operation;
- Radiation monitors with alarms are provided both inside and outside any maintenance area; and

- A system of keylocks in one of the IFTS main operation panels, with permissives that are interlocked through the main control room, is provided to allow access to any IFTS maintenance area.

1.2.2.5.11 Loose Parts Monitoring System

The Loose Parts Monitoring System (LPMS) detects loose metallic parts within the RPV. Detection of loose parts can provide the time required to avoid or mitigate safety-related damage to or malfunctions of primary system components. The LPMS detects structure-borne sound that can indicate the presence of loose parts impacting against the RPV internals. The system alarms when the signal amplitude exceeds a preset limit. The LPMS detection system can evaluate some aspects of selected signals. However, the system by itself does not diagnose the presence and location of a loose part. Review of LPMS data by an experienced loose parts monitoring engineer is required to confirm the presence of a loose part.

The LPMS continuously monitors the RPV and appurtenances for indications of loose parts. The LPMS consists of sensors, cables, signal conditioning equipment, alarming monitor, signal analysis and data acquisition equipment, and calibration equipment. The system alarm setting is set low enough to meet the sensitivity requirements, yet is designed to discriminate between normal background noises and the loose part impact signal to minimize spurious alarms.

The array of LPMS sensors consists of a set of sensor channels that are strategically mounted on the external surface of the primary pressure boundary at various elevations and azimuths at natural collection regions for potential loose parts. General mounting locations are at the

- Main steam outlet nozzle;
- Feedwater inlet nozzle; and
- Control rod drive housings.

The LPMS includes provisions for both automatic and manual start-up of data acquisition equipment with automatic activation in the event the preset alert level is reached or exceeded. The system also initiates an alarm to the control room personnel when an alert condition is reached.

1.2.2.6 Reactor Auxiliary Systems

1.2.2.6.1 Reactor Water Cleanup/Shutdown Cooling System

The Reactor Water Cleanup/Shutdown Cooling (RWCU/SDC) system has the following primary functions:

- Purify reactor coolant during normal operation and shutdown;
- Transfer sensible and core decay heat produced when the reactor is being shutdown or is in the shutdown condition;
- Provide decay heat removal and high pressure cooling of the primary coolant during periods of reactor isolation (hot standby);
- Implement the overboarding of excess reactor coolant during startup and hot standby;

- Maintain coolant flow from the reactor vessel bottom head to reduce thermal stratification;
- Warm the reactor coolant prior to startup and vessel hydro testing.

The system consists of two independent trains. Each train includes:

- One non-regenerative heat exchanger (NRHX);
- One regenerative heat exchanger (RHX);
- One low capacity cleanup (function) pump;
- One high capacity SDC pump;
- One demineralizer; and
- Associated valves and pipes.

The RWCU/SDC system is classified as a nonsafety-related system. However, its RCPB and containment isolation functions are safety-related, and thus, those functions are Seismic Category I and Class 1E. The electrical power supplies to the two trains are from separate diesel-backed electrical sources.

During normal plant operation, the system operates at reduced flow in the cleanup mode continuously withdrawing water from RPV. The water is cooled through the heat exchangers and is circulated by the cleanup pump to the demineralizer for removal of impurities. Purified water returns to the RHX where it is reheated, and then flows into the feedwater lines and is returned to the RPV. One train is in operation while the other is in standby.

Redundant trains permit shutdown cooling if only one train is available. The cooldown time is extended when using only one train. In the event of loss of preferred power and the most limiting single active failure, the RWCU/SDC systems brings the RPV to a $\leq 93.3^{\circ}\text{C}$ ($\leq 200^{\circ}\text{F}$) cold shutdown condition in conjunction with operation of the Isolation Condensers.

During hot standby and startup, excess water resulting from CRD system purge water injection and expansion during plant heatup is dumped, or overboarded, to the main condenser or the radwaste system to control reactor water level.

The RWCU/SDC system maintains the temperature difference between the reactor dome and the bottom head drain to preclude excessive thermal stratification.

Flow rate, pressure, temperature and conductivity are measured, recorded or indicated, and alarmed if appropriate, in the MCR.

Pumps are provided with interlocks for the automatic operation and with switch and status indication for manual operation from the MCR. Motor-operated isolation valves are automatically and manually actuated.

1.2.2.6.2 Fuel and Auxiliary Pools Cooling System

The Fuel and Auxiliary Pools Cooling System (FAPCS) consists of two redundant cooling and cleaning (C/C) trains, each with a pump, a heat exchanger and a water treatment unit for cooling and cleaning of pools except the Isolation Condenser and Passive Containment Cooling (IC/PCC) pools. A separate subsystem with its own pump, heat exchanger and water treatment

unit is dedicated for cooling and cleaning of the IC/PCC pools independent of the FAPCS C/C train operation during normal plant operation.

A four-valve bridge of motor-operated valves is attached to each end of the FAPCS C/C trains. With proper alignment of the motor-operated valves of these bridges, the C/C train is connected to one of the two pairs of suction and discharge piping loops to establish flow path for cooling and cleaning of the desired pool. One loop provides the flow path for serving the spent fuel pool and auxiliary pools, and the other loop for serving GDSCS pools and suppression pool.

The primary design function of FAPCS is to cool and clean pools located in the containment, reactor building and fuel building, during normal plant operation. Through its piping system, FAPCS provides flow paths for filling and makeup of these pools during normal plant operation and under post-accident condition, as necessary.

FAPCS is also designed to provide the following accident recovery functions in addition to the spent fuel pool cooling function:

- Suppression pool cooling (SPC);
- Drywell spray;
- Low pressure coolant injection of suppression pool water into the RPV; and
- Alternate Shutdown Cooling.

At least one FAPCS C/C train is available for continuous operation to cool and clean the water of the spent fuel pool during normal plant operation. The other train can be placed in standby mode or another operating mode. During refueling outages, both trains may be used to provide maximum cooling capacity for cooling the spent fuel pool, if needed.

Each FAPCS C/C train has sufficient flow and cooling capacity to maintain spent fuel pool bulk water temperature below the limit under normal spent fuel pool heat load conditions. Under the maximum spent fuel pool heat load conditions associated with a full core off-load and irradiated fuel in the spent fuel pool for 10 years of plant operations, both trains are needed to maintain the bulk temperature below the limit.

All FAPCS operating modes, except the SPC mode, are manually initiated and controlled by the operator from the main control room. The SPC mode is initiated either manually, or automatically on a high suppression pool water temperature signal. Proper instruments are provided for indication of operating conditions to aid the operator during the initiation and control of system operation. Provisions are included in the design to prevent inadvertent draining of the pools during FAPCS operation.

Containment isolation valves are provided on the lines that penetrate the primary containment. Containment isolation valves are powered from independent safety-related sources. Air-operated valves with containment isolation function are designed to close upon loss of its electric power supply.

The containment isolation valves that are not required to open to perform a post-accident recovery function are automatically closed upon receipt of a containment isolation signal from the LD&IS. The containment isolation valves on the suppression pool suction and return lines

and drywell spray lines are not automatically closed because these valves must be open when FAPCS performs an accident recovery function described above.

The FAPCS is a nonsafety-related system with the exception of piping and components required for containment isolation and for refilling of the IC/PCC pools and the spent fuel pool with emergency water supplies from offsite sources. The FAPCS piping and components that are required to provide safety-related and/or accident recovery functions have Quality Group B or C and Seismic Category I classification.

A detailed description of the FAPCS, including a listing of all pools serviced by FAPCS as well as system operations, is provided in Subsection 9.1.3.

1.2.2.7 Control Panels

1.2.2.7.1 Main Control Room Panels

The main control room (MCR) is comprised of an integrated set of operator interface panels (e.g., main control console, large display panel). The safety-related panels are seismically qualified and provide grounding, electrical independence and physical separation between safety divisions and between safety divisions and nonsafety-related components and wiring.

The main control room panels and other MCR operator interfaces are designed to provide the operator with information and controls needed to safely operate the plant in all operating modes, including startup, refueling, safe shutdown, and maintaining the plant in a safe shutdown condition. Human factors engineering principles have been incorporated into all aspects of the MCR design.

1.2.2.7.2 Radwaste Control Room Panels

The liquid and solid radwaste systems are operated from nonsafety-related control panels in the radwaste control room.

1.2.2.7.3 Local Control Panels and Racks

Local panels, control boxes, and instrument racks are provided as protective housings and/or support structures for electrical and electronic equipment to facilitate system operations at the local level. They are designed for uniformity using rigid steel structures capable of maintaining structural integrity as required under seismic and plant dynamic conditions. The term “local panels” includes local control boxes.

Local panels and racks containing equipment used for safety-related functions are classified as safety-related. They are located in areas in which there are no potential sources of missiles or pipe breaks that could jeopardize modules from more than one division. Each panel/rack containing equipment used for safety-related functions is qualified to Seismic Category I requirements, and provides grounding, electrical independence and physical separation between safety-related divisions and non-essential components and wiring.

Electrical power to divisional panels/racks is from AC or DC power sources of the same division as that of each panel/rack itself. Power to the non-essential panels/racks is from the non-essential AC and/or DC sources.

1.2.2.8 Nuclear Fuel

The following subsections describe the fuel rods, bundles and channels for the ESBWR.

1.2.2.8.1 Fuel Rods and Bundles

It is intended that the specific fuel to be used in any facility, which has adopted the certified design, be in compliance with NRC approved fuel design criteria. This strategy is intended to permit future use of enhanced/improved fuel designs as they become available. However, this approach is predicated on the assumption that future fuel designs are extensions of the basic fuel technology that has been developed for boiling water reactors. Key fuel characteristics are address in Sections 4.2 and 4.3.

The following is a summary of the principal requirements that must be met by the fuel supplied to any facility utilizing the certified design.

- NRC-approved analytical models and analysis procedures are applied;
- New design features are included in lead test assemblies;
- The generic post-irradiation fuel examination program approved by NRC is maintained;
- The fuel design thermal-mechanical analyses are performed;
- The fuel design evaluations are performed against acceptance criteria; and
- Flow pressure drop characteristics are included in the calculation of the operating limit minimum critical power ratio (OLMCPR).

1.2.2.8.2 Fuel Channel

Any specific fuel channel to be used in any facility, which has adopted the certified design, shall be in compliance with U.S. NRC approved fuel channel design criteria. This strategy is intended to permit future use of enhanced/improved fuel channel designs as they become available. However, this approach is predicated on the assumption that future fuel channel designs are extensions of the basic technology that has been developed for boiling water reactors. The key characteristic of this established BWR fuel channel technology is the use of zirconium-based (or equivalent) fuel channels, which preclude cross-flow in the core region.

The following is a summary of the principal requirements that must be met by the fuel channel supplied to any facility using the certified design:

- The material of the fuel channel shall be shown to be compatible with the reactor environment;
- The channel is evaluated to ensure that channel deflection does not preclude control rod drive operation; and
- The effects of channel bow are included in the fuel rod critical power evaluations.

1.2.2.9 Control Rods

The specific control rod to be used in any facility, which has adopted the certified design, shall be in compliance with U.S. NRC approved control rod design criteria. This strategy is intended to permit future use of enhanced/improved control rod designs as they become available. Key

characteristics and principal requirements of BWR control rods are provided within Sections 4.2, 4.3, 4.5 and 4.6.

1.2.2.10 Radioactive Waste Management System

1.2.2.10.1 Liquid Waste Management System

The Liquid Waste Management System (LWMS) collects, monitors, and treats liquid radioactive waste for plant reuse whenever practicable.

The LWMS consists of the following four subsystems:

- Equipment (low conductivity) drain subsystem;
- Floor (high conductivity) drain subsystem;
- Chemical drain subsystem; and
- Detergent drain subsystem.

The LWMS processing equipment is located in the radwaste building. Any discharge is such that concentrations and quantities of radioactive material and other contaminants are in accord with applicable local, state, and federal regulations.

All potentially radioactive liquid wastes are collected in sumps or drain tanks at various locations in the plant. These wastes are transferred to collection tanks in the radwaste building.

Waste processing is done on a batch basis. Each batch is sampled as necessary in the collection tanks to determine concentrations of suspended solids and chemical contaminants. Equipment drains and other low-conductivity wastes are treated by filtration and/or demineralization and are transferred to the condensate storage tank for reuse. Floor drains and other high conductivity wastes are treated by filtration, reverse osmosis process and ion exchange prior to being either discharged or recycled for reuse. Laundry drain wastes and other detergent wastes of low activity are treated by filtration, sampled, and released via the liquid discharge pathway. Chemical wastes are pre-conditioned by adding a chemical solution in the chemical drain collector tank, and transferred to floor drain collection tanks for further processing. Protection against inadvertent release of liquid radioactive waste is provided by design redundancy, instrumentation for the detection and alarm of abnormal conditions, automatic isolation, and administrative controls. Mobile processing equipment such as filtration, demineralization and reverse osmosis unit, and cross-connections with each subsystem are adopted to augment the waste processing capability and flexibility.

If the liquid is returned to the plant, it meets the purity requirements for condensate makeup. If the liquid is discharged, the activity concentration is consistent with the discharge criteria of 10 CFR 20 and dose commitment in 10 CFR 50, Appendix I.

1.2.2.10.2 Solid Waste Management System

The Solid Waste Management System (SWMS) is designed to control, collect, handle, process, package, and temporarily store prior to shipment solid radioactive waste generated as a result of normal operation, including anticipated operational occurrences, that includes filter backwash sludges, bead resins generated by the LWMS, RWCU/SDC, FAPCS, and condensate system, and concentrated wastes generated by the LWMS. Contaminated solids such as High Efficiency

Particulate Air and cartridge filters, rags, plastic, paper, clothing, tools, and equipment are sorted and packaged into several kinds of waste containers for off-site disposal. There is no liquid plant discharge from the SWMS.

The SWMS consists of the following four subsystems:

- Wet solid waste collection subsystem;
- Mobile wet solid waste processing subsystem;
- Dry solid waste accumulation and conditioning subsystem; and
- Container storage subsystem.

Spent bead resin sluiced from the RWCU/SDC system, FAPCS, condensate and LWMS are transferred by the wet solid waste collection subsystem to one-of-three spent resin tanks for decay and storage. Filter backwash sludges from the condensate system and LWMS are transferred to one-of-two phase separators. Concentrated wastes from LWMS are collected into a concentrated waste tank.

The mobile wet solid waste processing subsystem consists of built-in dewatering stations. High Integrity Containers (HIC) are filled with sludges from the phase separator, bead resin from the spent resin tanks, and concentrated wastes from the concentrated waste tank. Spent cartridge filters may also be placed in the HIC. Concentrated wastes may also be processed via thermal drying equipment.

Dry wastes consist of air filters, miscellaneous paper, rags, etc., from contaminated areas; contaminated clothing, tools, and equipment parts that cannot be effectively decontaminated; solid laboratory wastes; and wastes that may be non-contaminated. The activity of much of this waste is low enough to permit handling by contact. These wastes are collected in containers located in appropriate areas throughout the plant. The filled containers are sealed and moved to controlled-access enclosed area for temporary storage.

Connections are provided for mobile processing systems to augment the waste processing capability and flexibility.

Temporary storage for over one month's volume of packaged waste is provided in the radwaste building. Packaged waste includes high integrity containers, compactor boxes, shielded filter containers, and 208-liter (55-gallon) drums as necessary.

The SWMS is designed to package the radioactive solid waste for off-site shipment and burial, in accordance with the requirements of applicable NRC and DOT regulations, including Regulatory Guide 1.143, 10 CFR 61, 10 CFR 71, and 49 CFR 170 through 178.

1.2.2.10.3 Gaseous Waste Management System

The gaseous waste management system minimizes and controls the release of gaseous radioactive effluents by delaying, filtering, or diluting various offgas process and leakage gaseous releases, which may contain the radioactive isotopes of krypton, xenon, iodine, and nitrogen. The Offgas System (OGS) is the principal gaseous waste management subsystem. The various building HVAC systems perform other gaseous waste functions.

The OGS provides for holdup and decay of radioactive gases in the offgas from the steam jet air ejector (SJAE) and consists of process equipment along with monitoring instrumentation and control components.

The OGS design minimizes the explosion potential in the offgas process stream through recombination of radiolytic hydrogen and oxygen under controlled conditions. Although the OGS is nonsafety-related, it is capable of withstanding an internal hydrogen explosion and is designed to ASME Code Section VIII-Division I and the ASME B31.1 Piping Code.

The OGS includes redundant hydrogen/oxygen catalytic recombiners and ambient temperature charcoal beds to provide for process gas volume reduction and radionuclide retention/decay. The system processes the SJAE discharge during plant startup and normal operation before discharging the airflow to the plant stack.

A manually operated, three-way switch shall be provided in the MCR to allow operation of the charcoal absorbers in (1) AUTO, (2) TREAT or (3) BYPASS mode:

- (1) OGS start-ups are normally made in the AUTO mode, which provides valve alignment to send the offgas only through the first (guard bed) charcoal adsorber.
- (2) Normal OGS operation is in the TREAT mode, which provides valve alignment to send the offgas through both the guard bed and the main charcoal adsorber beds.
- (3) OGS operation in the BYPASS mode provides valve alignment to allow offgas flow to completely bypass the charcoal adsorbers. However, this mode of operation shall require simultaneous actuation of two manual switches by the plant operator from the Main Control Room.

1.2.2.11 Power Cycle

1.2.2.11.1 Turbine Main Steam System

The Turbine Main Steam System (TMSS) supplies steam generated in the reactor to the turbine, Moisture Separator Reheaters, steam auxiliaries and turbine bypass valves. The TMSS does not include the seismic interface restraint or main turbine stop or bypass valves.

The TMSS:

- Accommodates operational stresses such as internal pressure and dynamic loads without failures;
- Provides a seismically analyzed fission product leakage path to the main condenser;
- Includes suitable access and/or remote functions to permit in-service testing and inspections; and
- Closes the steam auxiliary valve(s) on a main steamline isolation valve (MSIV) isolation signal. These valves fail closed on loss of electrical power to the valve actuating solenoid or on loss of pneumatic pressure.

The TMSS main steam piping consists of four lines from the seismic interface restraint to the main turbine stop valves. The header arrangement upstream of the turbine stop valves allows the valves to be tested on-line and supplies steam to the power cycle auxiliaries, as needed.

The TMSS is nonsafety-related. However, the TMSS is analyzed, fabricated and examined to ASME Code Class 2 requirements, and classified as Seismic Category II. Inservice inspection shall be performed in accordance with ASME Section XI requirements for Code Class 2 piping. ASME authorized nuclear inspector and ASME Code stamping is not required.

Turbine MS piping and all branch lines 63.5 mm (2.5 inches) or larger in diameter, including the steam auxiliary valve(s), from the seismic interface restraint to the main stop and main turbine bypass valves are analyzed to demonstrate structural integrity under safe shutdown earthquake (SSE) loading conditions.

The TMSS is located in the steam tunnel and Turbine Building.

1.2.2.11.2 Condensate and Feedwater System

The Condensate and Feedwater System (C&FS) consists of the piping, valves, pumps, heat exchangers, controls and instrumentation and the associated equipment and subsystems, which supply the reactor with heated feedwater in a closed steam cycle utilizing regenerative feedwater heating. The C&FS extends from the main condenser outlet to the seismic interface restraint upstream of the second feedwater isolation valve outside of containment.

The C&FS provides a dependable supply of high quality feedwater to the reactor at the required flow, pressure and temperature. The condensate pumps take the deaerated condensate from the condenser hotwell and deliver it through the SJAE condenser, the gland steam condenser, the condensate filters and demineralizers, and through three strings of four low pressure feedwater heaters to the direct contact feedwater heater (feedwater tank). The reactor feed pumps take suction from the feedwater tank and discharge through high-pressure feedwater heaters to the reactor. Turbine extraction steam is used for multiple stages of feedwater heating. The drains from each stage of the low-pressure feedwater heaters are cascaded through successively lower pressure feedwater heaters to the main condenser. The drains for each stage of the high pressure feedwater heaters are cascaded to the feedwater tank.

The C&FS does not serve or support any safety function and has no safety design basis. Failure of this system cannot compromise any safety-related systems or prevent safe shutdown.

Portions of the system that are radioactive during operation are shielded with access control for inspections. Leakage is minimized with welded construction used wherever practicable. Relief discharges and operating vents are channeled through closed systems.

The C&FS piping is located in the steam tunnel and the turbine building. The feedwater system piping is analyzed for waterhammer loads that could potentially result from anticipated flow transients.

The C&FS has alarms and parameter displays in the main control room.

1.2.2.11.3 Condensate Purification System

The Condensate Purification System (CPS) continuously purifies and treats the condensate as required to maintain reactor feedwater purity, using filtration to remove solid corrosion products and ion exchange to remove condenser leakage and other dissolved impurities.

The CPS does not perform or support any safety-related function, and thus, has no safety design basis. No failure within the CPS could prevent safe shutdown.

Wastes from the CPS are collected in controlled areas and sent to the radwaste system for treatment and/or disposal.

The CPS is located in the turbine building.

The CPS has alarms and display for effluent conductivity in the main control room.

1.2.2.11.4 Main Turbine

The main turbine for the ESBWR Standard Plant has one high-pressure (HP) turbine and three low-pressure (LP) turbines. Other turbine configurations may be selected for plant-specific applications in order to obtain optimal thermal performance of the turbine plant at the site-specific conditions. An example of alternate turbine design is described in Appendix 10A of this document. The steam passes through two sets of moisture separator reheaters (MSRs) prior to entering the LP turbines. Steam exhausted from the LP turbines is condensed and degassed in the condenser. Steam is bled off from each turbine and is used to heat the feedwater.

The control system for the main turbine provides control and monitoring of turbine speed, load, and steam flow for startup, normal operation and shutdown by operating the main steam turbine stop valves, control valves, and combined intermediate valves. The main turbine system includes supervisory instrumentation that is provided for startup and shutdown monitoring, operational analysis and malfunction diagnosis.

The Main Turbine is equipped with a single-speed, electric motor-driven turning gear, which is used to rotate the turbine generator shafts slowly and continuously whenever the main turbine is not in service, and especially during startup and shutdown periods when turbine rotor temperature changes occur.

The turbine-generator (TG) system is enclosed within the turbine building. The turbine generator is orientated within the turbine building to be inline with the reactor building to minimize the potential for any high energy TG system generated missiles from damaging any safety-related equipment or structures.

1.2.2.11.5 Turbine Gland Seal System

The Turbine Gland Seal System (TGSS) provides steam and prevents the escape of radioactive steam from the turbine shaft/casing penetrations and valve stems and prevents air in-leakage through subatmospheric turbine glands.

The TGSS consists of a gland steam evaporator, a sealing steam pressure regulator, a sealing steam header, a gland steam condenser, two full capacity exhaust blowers and associated piping, valves and instrumentation.

The TGSS is nonsafety-related system.

The HP turbine shaft seals must accommodate a range of turbine shell pressure. The LP turbines shaft seals operate against a vacuum at all times. The gland seal outer portion steam air mixture is exhausted to the gland steam condenser via the seal vent annulus (i.e., end glands), which is maintained at a slight vacuum. The radioactive content of the sealing steam, which eventually exhausts to the plant vent and the atmosphere, makes a negligible contribution to overall plant radiation release because clean steam from the gland seal evaporator is normally used as seal steam during normal operation. In addition, the auxiliary steam system is designed to provide a

100% backup to the normal gland seal process steam supply. A full capacity gland steam condenser is provided and equipped with two 100% capacity blowers.

A continuous radiation monitor that is dedicated to the TGSS and installed on the gland steam condenser exhaust blower discharge monitors the TGSS effluents. High monitor readings are alarmed in the MCR. The system effluents are then discharged to the Turbine Building Compartment Exhaust system and the plant vent stack, where further effluent radiation monitoring is performed.

1.2.2.11.6 Turbine Bypass System

A Turbine Bypass System (TBS) can pass steam directly to the main condenser under the control of the pressure regulator. Steam is bypassed to the condenser whenever the reactor steaming rate exceeds the load permitted to pass to the turbine generator. The TBS in the ESBWR Standard Plant design has the capability to shed 110% of rated steam flow, which will facilitate shedding of 100% of the turbine generator rated load without reactor trip or operation of the SRVs. The pressure regulation system provides main turbine control valve and bypass valve flow demands, to maintain a nearly constant reactor pressure during normal plant operation.

The TBS, which does not perform or ensure any safety-related function, is classified as nonsafety-related. No failure within the TBS could prevent safe shutdown. However, the TBS is used to mitigate anticipated operational occurrences (which per 10 CFR 50, Appendix A, are defined as part of normal operations), and is analyzed to demonstrate structural integrity under the safe shutdown earthquake (SSE) loading conditions.

The TBS has two 50% subsystems. Each subsystem consists of two pairs of valve chests that are connected to the main steam header upstream of the main turbine stop valves, and dump lines that connect each regulating valve outlet to the condenser shell. Each chest houses three bypass valves, thus a total of 12 bypass valves make up the design 110% rated steam bypass capacity. No single failure could reduce the available bypass capacity to less than 50% of its rated capacity. Alternate steam bypass configurations meeting this redundancy requirement may be considered by the COL applicant.

Both automatic and manual control of the turbine bypass valves is provided. The turbine bypass valves are opened by a signal received from the SB&PC system whenever the actual steam pressure exceeds the preset steam pressure by a small margin. This occurs when the amount of steam generated by the reactor cannot be entirely used by the turbine. This bypass demand signal opens the first of the individual valves. As the bypass demand increases, additional bypass valves are opened, dumping the steam to the condenser. Pressure-reducing orifices are located at the condenser connections, and sparger piping distributes the steam within the condenser. The bypass valves are equipped with fast-acting servo valves to allow rapid opening of bypass valves upon turbine trip or generator load rejection.

The bypass valves automatically trip open upon load rejection or turbine trip. The bypass valves automatically trip closed whenever the condenser pressure increases to a preset value. Individual bypass valves also fail closed on loss of electrical power to their operator. Individual bypass valve hydraulic accumulators have sufficient capacity to stroke the valves at least three times after complete loss of power to the hydraulic oil pumps.

1.2.2.11.7 Main Condenser

The main condenser is designed to condense and deaerate the exhaust steam from the main turbine and provide a heat sink for the TBS.

The main condenser does not perform, ensure or support any safety-related function, and thus, has no safety design basis. It is, however, designed with necessary shielding and controlled access to protect plant personnel from radiation.

The main condenser for the ESBWR Standard Plant is a multi-pressure, triple-shell unit. However, nothing precludes the use of a single-pressure and parallel (instead of series) circulating water system because these features have no impact on the Nuclear Island. An example of parallel condenser configuration is described in Appendix 10A of this document. Circulating water flows through each of the single-pass tube bundles as cooling water to remove waste heat rejected by turbine-generator cycle.

Any leakage is into the shell side of the main condenser because the main condenser operates at a vacuum. Tube side or circulating water in-leakage is detected by measuring the conductivity of sample water extracted at selected locations in the condenser. In addition, conductivity is continuously monitored at the discharge of the condensate pumps and alarms are provided in the MCR.

During normal plant operation at power, the condenser is at vacuum and consequently no radioactive release can occur. Loss of vacuum sequentially leads to a control room alarm, turbine trip, RPS trip, turbine bypass and MSIV closure to prevent condenser overpressurization.

Ultimate overpressure protection is provided by rupture diaphragms on the turbine exhaust hoods.

The instrumentation and control features that monitor the performance to ensure that the condenser is in the correct operating mode include:

- Hotwell water level — Automatically controlled within preset limits. At minimum normal operating hotwell water level, and normal full load condensate flow rate, the condenser provides a two-minute minimum holdup time for N^{16} decay.
- Condenser pressure — Key overall performance indicator that initiates alarms and trips at preset levels.
- LP turbine exhaust hood temperature — Automatically initiates turbine exhaust water sprays to protect the turbine.
- Inlet and outlet circulating water temperature — Monitors performance only.
- Conductivity within the condenser and at the discharge of the condensate pumps — Initiates alarms at preset levels.

The potential for flooding from the main condenser is less than that from the Circulating Water (CIRC) system so only the CIRC flooding protection is needed. The Condenser pressure indicators are located above any potential flood level.

Spray pipes and baffles are designed to protect the main condenser internals from high-energy flow inputs.

Hydrogen buildup during operation is prevented by continuous evacuation of the main condenser.

Noncondensable gases are removed from the power cycle by the Condenser Air Removal system. The Main Condenser Evacuation System (MCES) removes power cycle noncondensable gases including the hydrogen and oxygen produced by radiolysis of water in the reactor and exhausts them to the Offgas system during plant power operation, or to the turbine building ventilation system exhaust during early plant startup. The MCES establishes and maintains a vacuum in the condenser by the use of steam jet air ejectors during power operation, and by a mechanical vacuum pump during early startup.

Steam jet air ejectors and condenser vacuum pumps are used to remove the noncondensable air/gases and associated water vapor from the main condenser shells. Two 100% capacity steam jet air ejector (SJAE) units and two 50% capacity condenser vacuum pumps are provided. One SJAE unit is normally in operation and the other is on standby.

1.2.2.11.8 Circulating Water System

The Circulating Water (CIRC) system provides cooling water for removal of the power cycle waste heat from the main condensers and transfers this heat to the normal power heat sink.

The CIRC system does not perform, ensure or support any safety-related function, and thus, has no safety design basis.

To prevent flooding of the turbine building, the CIRC system automatically isolates in the event of gross system leakage. The circulating water pumps are tripped and the pump and condenser valves are closed in the event of a system isolation signal from the condenser area high-high level switches. A condenser area high level alarm is provided in the MCR.

A reliable logic scheme is used (e.g., 2-out-of-3 logic) to minimize potential for spurious isolation trips.

1.2.2.12 Station Auxiliaries

1.2.2.12.1 Makeup Water System

The Makeup Water System (MWS) is comprised of two nonsafety-related subsystems: the demineralization subsystem and the storage and transfer subsystem. The demineralization subsystem produces the demineralized water that is used in non-safety applications. The storage and transfer subsystem distributes water throughout the entire plant. The MWS pumps and demineralization subsystem are only designed for normal power generation demineralized water requirements. During a shutdown/refueling condition, temporary off-site water treatment equipment and pumps are connected to the Demineralized Water Storage Tank and the demineralized water distribution network.

The demineralization subsystem consists of a modular reverse osmosis (RO) unit, two high pressure RO pumps, a RO product water catch tank, two RO product water forwarding pumps, and a modular mixed bed demineralizer unit. Cartridge filters and a chemical addition system are included to ensure optimum RO unit operation. The storage and transfer subsystem consists of a storage tank, transfer pumps, distribution piping, and valves. The system is housed in and

controlled from the water treatment building. System components in contact with the demineralized water are stainless steel. The storage tank is freeze-protected.

The MWS is a nonsafety-related system, and has no safety design basis other than provision for safety-related containment penetrations and isolation valves.

1.2.2.12.2 Condensate Storage and Transfer System

The Condensate Storage and Transfer System (CS&TS) stores condensate grade water and transfers it to plant water systems and supply points. End users include the main condenser hotwell, CRD system, RWCU/SDC system fill, FAPCS fill, suppression and GDCS pools fill, C&FS fill, and liquid and solid radwaste system flushing.

The CS&TS includes a storage tank and transfer pumps. Components in contact with the condensate are stainless steel. The storage tank is freeze-protected if required. A basin is built around the tank to ensure the entire tank content is contained if there is a leak.

The system does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.3 Reactor Component Cooling Water System

The Reactor Component Cooling Water System (RCCWS) cools reactor auxiliary equipment including the Chilled Water System, the RWCU/SDC non-regenerative heat exchangers, the FAPCS heat exchangers, Radwaste Building Equipment, and the Standby On-Site AC Power Supply Diesel Generators.

The RCCWS has two trains. Each train has three pumps, three heat exchangers, and a surge tank. Both trains share a chemical addition tank. The Plant Service Water System cools the RCCWS heat exchangers.

The RCCWS does not perform any safety-related function.

1.2.2.12.4 Turbine Component Cooling Water System

The Turbine Component Cooling Water System (TCCWS) cools turbine building auxiliary equipment including turbine lube oil coolers, offgas condensers, generator stator and hydrogen coolers and service air compressors.

The system does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.5 Chilled Water System

The Chilled Water System (CWS) consists of two independent and interconnected subsystems: the Nuclear Island Chilled Water Subsystem (NICWS) and the Balance-of-Plant Chilled Water Subsystem (BOPCWS). The CWS provides chilled water to the air handling units and fan-coil units in all the facilities of the plant.

The NICWS has two trains. Each train has a packaged water chiller unit with local control panel, pump, surge tank, air separator, and chemical feed tank. The BOPCWS only has one train

with two packaged water chiller units, including two local panels (one per chiller), two pumps (one per chiller), a surge tank, an air separator and a chemical feed tank. The NICWS condensers are cooled by the RCCWS and the BOPCWS condensers are cooled by the TCCWS.

With the exception of isolation of the containment penetration to the drywell coolers, CWS does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is primarily nonsafety-related and has no safety design basis.

1.2.2.12.6 Oxygen Injection System

The Oxygen Injection System (OIS) maintains the oxygen concentration in the condensate and feedwater to suppress corrosion and corrosion product release in the C&FS, and is located in the Turbine Building. The oxygen gas supply consists of a bulk liquid oxygen storage tank, liquid oxygen vaporizers, gaseous oxygen compressors, oxygen isolation skid, and the necessary piping, valves and controls. The oxygen injection module contains for each injection point two 100% capacity flow transmitters, one flow control valve, two manual flow control valves, one pressure transmitter, one manual vent, and one test connection. The oxygen injection module injects oxygen into condensate after condensate polishing and into feedwater downstream of the direct contact feedwater heater.

The OIS does not perform or ensure any safety-related function, and is not used to achieve or maintain safe shutdown. Therefore, the OIS is nonsafety-related and has no safety design basis.

1.2.2.12.7 Plant Service Water System

The Plant Service Water System (PSWS) consists of two independent and 100% redundant open trains that continuously supply cooling water to the Reactor Component Cooling Water System (RCCWS) and Turbine Component Cooling Water System (TCCWS) heat exchangers. Each PSWS train consists of two 50% capacity vertical pumps taking suction in parallel from a plant service water basin. During normal operation the primary source of cooling water for the PSWS is the cooling tower makeup pumps, with the PSWS pumps serving as a backup.

If the PSWS pumps are in operation, the PSWS mechanical draft cooling towers are used to reject the heat removed from RCCWS and TCCWS. Heat removed from the RCCWS and TCCWS is rejected to the main cooling tower basin when the cooling tower makeup pumps are in operation. Remotely operated isolation valves and a crosstie line permit routing of the heated plant service water to either cooling tower. The return header is provided with a flow element which is used for on-line monitoring, leak detection, and can also be used during initial start-up for heat exchanger pressure loss and pump performance calibration, prior to system balancing.

The PSWS does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.8 Service Air System

During normal operation, the Service Air System (SAS) provides a continuous supply of compressed air for general plant use and service air outlets. Each compressor train is equipped with an intercooler, after-cooler, moisture separator, and a service air receiver. A connection between the trains upstream of the air receivers ensures both air receivers are always pressurized when at least one compressor is operating. Both air compressor trains are connected to a

common header, which distributes air to the breathing air purifiers, Turbine Building, Reactor Building, and Radioactive Waste Building. SAS provides a backup source of compressed air for Instrument Air System (IAS).

The system is nonsafety-related and Seismic Category NS, except for the containment penetration, which is required to maintain containment integrity. The containment penetration portion is designed to ASME Section III, Class 2, Seismic Category I, and consists of a check valve inside containment and a manually operated valve outside containment.

1.2.2.12.9 Instrument Air System

During normal operation, the IAS provides dry, oil free, filtered compressed air for valve actuators, nonsafety-related instrument control functions, and general instrumentation and valve services outside of containment. The instrument and control systems inside containment are supplied by gaseous nitrogen from the High Pressure Nitrogen Supply System (HPNSS) during normal plant operation. During maintenance outages, the IAS provides compressed air to the nitrogen users located inside containment by way of the HPNSS piping. The IAS includes features that ensure operation over the full range of normal plant operations. The IAS operates during normal plant operation, plant startup and plant shutdown. The IAS is designed to be functional after a Safe Shutdown Earthquake (SSE).

The system is nonsafety-related and Seismic Category NS.

1.2.2.12.10 High Pressure Nitrogen Supply System

The High Pressure Nitrogen Supply System (HPNSS) consists of distribution piping between the Containment Inerting System (CIS) and the containment nitrogen users. The HPNSS is a backup to the CIS.

The containment high-pressure nitrogen consumers include the Nuclear Boiler System (NBS) Automatic Depressurization System (ADS) function Safety Relief Valve (SRV) accumulators and Isolation Condenser steam and condensate line Isolation Valve accumulators. These high-pressure nitrogen consumers are normally served by the CIS. The HPNSS provides high-pressure nitrogen gas to the nitrogen consumers during normal operating periods when the Containment Inerting System fails to maintain the required nitrogen supply pressure. The HPNSS provides a stored supply of high-pressure nitrogen gas that is sized to compensate for nitrogen leakage from the ADS function SRV accumulators during SRV actuation for a period of eight hours. However, the HPNSS is not required to provide makeup to the SRV accumulators during any design basis event involving SRV actuation.

This system is nonsafety-related and Seismic Category NS except for safety-related penetrations, and isolation valves. These components are safety-related, and Seismic Category I. The ADS function SRV accumulators and piping are part of the Nuclear Boiler System.

1.2.2.12.11 Auxiliary Boiler System

The Auxiliary Boiler System (ABS) consists of two package boilers. During plant startup and shutdown and at any other time when the main steam, extraction steam and/or clean steam from the gland steam evaporator (as applicable) is unavailable, the ABS provides the necessary steam at enough pressure to the various equipment items addressed below.

- To the feedwater system, to provide hot water during plant startup when decay heat is not present or is insufficient on its own to startup the plant in a timely manner (i.e., during initial plant startup and following any prolonged maintenance outage);
- To the Steam Jet Air Ejector, to maintain the motive power required to perform a continuous evacuation of the non-condensable gases from the Main Condenser and through the Offgas System;
- To the Turbine Gland Sealing System, to provide sealing steam to the main turbine during all modes of operation;
- To the Offgas System Preheaters, for Reheaters warming;
- To the Condenser, to deaerate the condensate in the hotwell (condenser sparging);
- Heating of water for various building heating, by supplying steam to the heat exchangers of the Hot Water System;
- Preoperational testing of Offgas System equipment;
- Chemical cleanup (flushing and cleaning systems after maintenance and prior to system initial startup); and
- Evaporation of liquid nitrogen for inerting of the Containment.

The ABS does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.12 Hot Water System

The Hot Water System supplies hot water for building heating. The system design will be plant-specific and includes components such as heat exchangers, circulating pumps, and a head/surge tank. The auxiliary boiler is used to heat the water. The system supplies hot water to ventilating systems in the reactor, control, fuel, turbine, electrical and radwaste buildings.

The Hot Water System does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.13 Hydrogen Water Chemistry System

The ESBWR includes the capability to connect a Hydrogen Water Chemistry (HWC) system, but the system itself is not part of the ESBWR Standard Plant design.

1.2.2.12.14 Process Sampling System

The Process Sampling System (PSS) collects representative liquid samples for monitoring water quality and measuring system and equipment performance. The PSS provides for continuous and periodic sampling of principal fluid process streams associated with plant operation. Process samples requiring continuous monitoring or special conditioning are routed to one of the PSS sample stations. These sample stations also include provisions for the collection of grab samples to be taken for further laboratory analyses as required.

The PSS does not perform or ensure any safety-related function, and is not required to achieve or maintain safe shutdown. Therefore, the system is nonsafety-related and has no safety design basis.

1.2.2.12.15 Zinc Injection System

The ESBWR includes the capability to connect a Zinc Injection System, but the system itself is not part of the ESBWR Standard Plant design.

1.2.2.12.16 Freeze Protection

The Freeze Protection System provides insulation, steam, and/or electrical heating for all external tanks and piping that may freeze during winter weather. This system is not part of the ESBWR Standard Plant design.

1.2.2.13 Station Electrical System

1.2.2.13.1 Electrical Power Distribution System

On-site power is supplied from either the plant turbine generator or an off-site power source depending on the plant operating status. During normal operation, plant loads are supplied from the main generator through the main and unit auxiliary transformers. A generator breaker allows the unit auxiliary transformers to stay connected to the grid to supply loads by backfeeding from the switchyard when the turbine is not online.

The isolated phase bus connects the main generator to the main transformer. The high voltage side of main transformer is connected to the generator breaker by aerial line. The unit auxiliary transformers connect to the off-site power system by aerial line or buried isolated cables. The unit auxiliary transformers power the metal clad switchgear via the non-segregated phase bus. This switchgear powers some large loads and load centers consisting of transformers and associated metal clad switchgear. The design includes four Isolation Power Center buses that supply the Class 1E battery chargers and provide backup power to the Uninterruptible AC power supply system.

Multiple individual voltage regulating transformers supply nonsafety-related control and instrument power.

1.2.2.13.2 Electrical Penetrations

All power, control and instrument circuits pass through the wall of the containment building in electrical penetration assemblies. Separate penetrations are provided for medium-voltage, low-voltage power, lighting, control, and instrument circuits.

Class 1E circuit separation groups designated Division 1, 2, 3, 4, and Non-Class 1E circuits run through separate penetration assemblies. These penetrations are located so that the physical separation is maintained between separation groups.

Electrical penetrations are provided for conduit and other raceways between fire areas, and the bottom entry through fire barriers into panels and switchgear. Fire integrity is maintained between fire areas by filling the penetration area around cables and around the raceway with a

fire retardant material. Penetrations in radiation areas are offset on each side of the barrier to prevent radiation streaming through the penetration.

Additional details on electrical penetrations are provided in Section 8.3.

1.2.2.13.3 Direct Current Power Supply

The plant Direct Current Power Supply System (DCPSS) consists of four independent 250 V DC Class 1E power supply subsystems, one each for divisions 1, 2, 3 and 4, and five independent non-Class 1E power supply subsystems consisting of three 250 V DC power supply subsystems and two 125 V DC power supply subsystems.

The safety-related (Class 1E) DC power supply subsystem provides power to the Class 1E Uninterruptible AC buses through inverters and to the loads required for safe shutdown.

Each of the four divisions of Class 1E DC power supply subsystems is separate and independent. These DC subsystems operate ungrounded (with ground detection circuitry) for increased reliability. Each division has a battery and a battery charger fed from its divisional 480V Isolation Power Center. There is a standby battery charger for charging the batteries of each division. This system is designed so that no single failure in any division prevents safe shutdown of the plant.

During a total loss of off-site power, the Class 1E system is powered automatically from two nonsafety-related standby onsite AC power supplies. If these are not available, each division of Class 1E isolates itself from the non-Class 1E system, and power to safety-related loads is provided uninterrupted by the Class 1E batteries. In divisions 1 and 2, the batteries are divided into two groups that are sized to power various safety-related loads for periods of 24 and 72 hours, respectively. The loads in divisions 3 and 4 are powered by 24-hour batteries.

The Class 1E DC power supply subsystem is designed to permit periodic testing for operability and functional performance to ensure that the full operational sequence transfers power and brings the system into operation.

The non-Class 1E DC power supply subsystem is normally supplied through non-Class 1E battery chargers from the non-Class 1E power centers. In the event that this power supply is lost, power is supplied from the non-Class 1E batteries. The non-Class 1E batteries are sized for a 2-hour duty cycle.

The nonsafety-related DC buses also supply power to the nonsafety-related inverters.

1.2.2.13.4 Standby On-Site AC Power Supply

A minimum of two separate nonsafety-related standby on-site diesel generators provide separate sources of on-site power for various load groups when the normal and alternate preferred power supplies are not available. COL applicant may employ additional diesel generators to reduce the sizes of the individual diesel generators. The standby on-site AC power supply system is configured to provide power to the permanent nonsafety-related buses.

Either the main generator or the normal preferred off-site power source normally energizes the plant buses. Transfer to the on-site standby diesel generators is automatic when all other power supplies capable of feeding the buses are not available. Should these power supplies fail, their supply breakers trip and the standby on-site power supply (diesel generators) is automatically

signaled to start. After the standby voltage and frequency reach normal values, the standby supply breakers close. After bus voltage is reestablished, large motor loads are sequentially started.

On a defense-in-depth basis, the Standby On-Site AC Power Supply system can provide power to vital safety-related loads. However, these loads are powered by uninterruptible power supplies (for AC loads) or safety-related DC power from Class 1E station batteries if the preferred power supply or the Standby On-Site AC Power Supply is not available.

1.2.2.13.5 Uninterruptible AC Power Supply

The Class 1E uninterruptible power supply (UPS) provides redundant, reliable power to the safety logic and control functions during normal, upset and accident conditions.

Each of the four divisions of this Class 1E uninterruptible power is separate and independent. Each division is powered from an inverter supplied from the divisional Isolation Power Center and the Class 1E DC bus. The DC bus receives its power from a divisional battery charger and battery.

A static bypass switch is provided for transferring the UPS AC load through a direct feed from the UPS inverter to the Isolation Power Center through a regulating transformer. A manual bypass switch is provided for maintenance purposes.

The non-Class 1E uninterruptible power supply system for the two power-distribution load groups in the plant is supplied from the 480 V AC power center in the same group. In addition, there is another uninterruptible power supply system used to supply the NE-DCIS loads.

Two dedicated uninterruptible power supply systems supply the TSC.

1.2.2.13.6 Instrument and Control Power Supply

The nonsafety-related Instrument and Control Power Supply provides single-phase power to instrument and control loads that do not require an uninterruptible power source.

1.2.2.13.7 Communications System

The Communications System includes a plant page/party-line (PA/PL) system, the private automatic branch telephone exchange (PABX), a sound-powered telephone system, an in-plant radio system and the evacuation alarm and remote warning system.

1.2.2.13.8 Lighting Power Supply

The lighting systems include: the normal, standby, emergency, and security lighting systems. The normal lighting system provides illumination under all normal plant conditions, including maintenance, testing, and refueling operations. It is powered from the nonsafety-related buses. The standby lighting system supplements the normal lighting system and supplements the emergency lighting system in selected area of the plant. The standby lighting system is normally supplied power from the main generator or the off-site power system, or alternately from the standby on-site AC power supply system. Both lighting systems are nonsafety-related.

Upon loss of the normal lighting system, the emergency lighting system provides illumination throughout the plant and, particularly, areas where emergency operations are performed (e.g.,

main control room, battery rooms, local control stations, ingress/egress routes). It includes self-contained DC battery-operated units for exit and stair lighting. The emergency lighting system supplies at least 108 lux (10 foot-candles) of lighting in those areas of the plant where emergency operations could require reading printed materials or instrument scales. In other areas this system provides illumination levels adequate for safe ingress or egress. Inside the main control room, emergency lighting is integrated with standby lighting.

The emergency lighting system is normally supplied from the four divisions of Class 1E Uninterruptible AC power system. The Class 1E batteries and the standby on site AC power supply system provide backup to the Class 1E UPS. Excluding the self-contained battery lighting units, the emergency lighting system is safety-related.

The security lighting system provides lighting for the security center, selected security areas, and the outdoor plant perimeter. The system is normally supplied power from the main generator or the off-site power system, or alternately from the standby on-site AC power supply system. The security lighting system is further backed up by a dedicated security standby diesel-generator and a dedicated uninterruptible power supply. The security lighting system is nonsafety-related.

The MCR emergency lighting system is supplied power from two divisions of the Class 1E Uninterruptible AC power system. The two 72-hour Class 1E batteries of divisions 1 and 2 provide power to the Class 1E 120 VAC 72-hour buses in the MCR. The standby on-site AC power supply provides backup to the battery chargers for Class 1E 72-hour 120 VAC power. Excluding the self-contained battery lighting units, the MCR emergency lighting system is safety-related.

1.2.2.14 Power Transmission

It is an interface requirement for the COL Applicant to provide information on the power transmission system. The interface point between the ESBWR design and the utility design for the normal preferred power supply occurs at the high voltage terminals of the main generator circuit breaker (switchyard side) and the high voltage terminals of the unit auxiliary transformers after a common tie point. The interface for the alternate preferred power supply occurs at the high voltage terminals of the reserve auxiliary transformers.

1.2.2.15 Containment and Environmental Control Systems

1.2.2.15.1 Containment System

The ESBWR containment, centrally located in the Reactor Building, features the same basic pressure suppression design concept previously applied in over three decades of BWR power generating reactor plants. The containment consists of a steel-lined, reinforced concrete containment structure in order to fulfill its design basis as a fission product barrier at the pressure conditions associated with a postulated pipe rupture.

Main features include the upper and lower drywell surrounding the RPV and a wetwell containing the suppression pool that serves as a heat sink during abnormal operations and accidents.

The containment is constructed as a right circular cylinder set on the reinforced concrete base mat of the reactor building. The drywell and wetwell design conditions are provided in Section 6.2.

The drywell comprises two volumes: an upper drywell volume surrounding the upper portion of the RPV and housing the steam and feedwater piping, the SRVs, GDCS pools, main steam drain piping and upper drywell coolers; and a lower drywell volume surrounding the lower portion of the RPV, housing the FMCRDs, neutron monitoring system, equipment platform, lower drywell coolers and two drywell sumps. The drywell top opening is enclosed with a steel head removable for refueling operations.

The gas space above the suppression pool serves as the LOCA blowdown reservoir for the upper and lower drywell nitrogen and non-condensable gases that pass through the twelve drywell-to-wetwell vertical vents, each with three horizontal vents located below the suppression pool surface. The suppression pool water serves as the heat sink to condense steam released into the drywell during a LOCA or steam from SRV actuations.

Access into the upper and lower drywells is provided through a double sealed personnel lock and an equipment hatch. The equipment hatch is removable only during refueling or maintenance outages. A hatch located in the Reactor Building provides access into the wetwell.

During plant startup, the Containment Inerting System, in conjunction with the containment purge system and the drywell cooling fans, is utilized to establish an inert gas environment in the containment with nitrogen to limit the oxygen concentration. This precludes combustion of any hydrogen that might be released subsequent to a LOCA. After the containment is inerted and sealed for plant power operation, small flows of nitrogen gas are added to the drywell and the wetwell as necessary to keep oxygen concentrations below 4% and to maintain a positive pressure for preventing air in-leakage. High-pressure nitrogen is also used for pneumatic controls inside the containment to preclude adding air to the inert atmosphere.

The containment structure has the capability to maintain its functional integrity at the pressures and temperatures that could follow a LOCA pipe break postulated to occur simultaneously with loss of off-site power. The containment structure is designed to accommodate the full range of loading conditions associated with normal and abnormal operations including LOCA-related design loads in and above the suppression pool (including negative differential pressure between the drywell, wetwell and the remainder of the Reactor Building), and safe shutdown earthquake (SSE) loads.

The containment structure is protected from, or designed to withstand, fluid jet forces associated with outflow from the postulated rupture of any pipe within the containment.

The containment design considers and utilizes leak-before-break (LBB) applicability only in regard to protection against dynamic effects associated with a postulation of rupture in high-energy piping. Subsection 3.6.3 and Appendix 3E describe the implementation of the LBB approach for excluding design against the dynamic effects from postulation of breaks in high energy piping. Protection against the dynamic effects from the piping systems not qualified by the exclusion from the dynamic effects caused by their failure is provided for the drywell structure. The drywell structure is provided protection against the dynamic effects of plant-generated missiles (Section 3.5).

The containment structure has design features to accommodate flooding to sufficient depth above the top of active fuel to permit safe removal of fuel assemblies from the reactor core after a postulated design basis accident (DBA).

The containment structure is configured to channel flow from postulated pipe ruptures in the drywell to the suppression pool through vents submerged in the suppression pool, which are designed to accommodate the energy of the blowdown fluid.

The containment structure and penetration isolation system, with concurrent operation of other accident mitigation systems, are designed to limit fission product leakage during and following a postulated DBA to values well below leakage calculated for allowable off-site doses.

In accordance with Appendix J to 10 CFR 50, the containment design includes provisions for testing at a reduced pressure below the peak calculated DBA LOCA pressure to confirm containment leakage is below the design limit. Special testing capabilities are provided during outages to measure local leakage, such as individual air locks, hatches, drywell head, piping, electrical and instrument penetrations. Other features are provided to measure isolation valve leakage and to measure the integrated containment leak rate. Results from the individual and integrated preoperational leak rate tests are recorded for comparison with subsequent periodic leak rate test results.

The design value for a maximum steam bypass leakage between the drywell and the wetwell through the diaphragm floor including any leakage through the wetwell-to-drywell vacuum breakers is limited. Satisfying this limit is confirmed by initial preoperational tests as well as by periodic tests conducted during refueling outages. These tests are conducted at differential pressure conditions between the drywell and wetwell that do not clear the drywell-to-wetwell horizontal vents.

A watertight barrier is provided between the open reactor and the drywell during refueling. This enables the reactor well to be flooded prior to removal of the reactor steam separator, dryer assembly and to facilitate underwater fuel handling operations. Piping, cooling air ducts and return air vent openings in the reactor well platform must be removed, vents closed and sealed watertight before filling the reactor well with water. The refueling bellows assembly is provided to accommodate the movement of the vessel caused by operating temperature variations and seismic activity.

Containment isolation is accomplished with inboard and outboard isolation valves on each piping penetration that are signaled to close on predefined plant parameters. Systems performing a post-LOCA function are capable of having their isolation valves reopened as needed.

Drywell coolers are provided to remove heat released into the drywell atmosphere during normal reactor operations.

1.2.2.15.2 Containment Vessel

The containment structure is a reinforced right circular cylindrical concrete vessel (RCCV). The RCCV supports the upper pools whose walls are integrated into the top slab of the containment to provide structural capability for LOCA and testing pressures.

1.2.2.15.3 Containment Internal Structures

The containment system's principal internal structure consists of the structural barrier separating the drywell from the wetwell. This barrier is comprised of the wetwell ceiling (diaphragm floor) and the inboard wall (vertical vent wall) separating the drywell from the wetwell. Both of these structural components are designed as steel structures filled with concrete. The vertical vent wall also provides a durable attachment point for the RPV horizontal stabilizers.

An all-steel reactor shield wall of appropriate thickness is provided, which surrounds the RPV to reduce gamma radiation shine on drywell equipment during reactor operation and protect personnel during shutdowns for maintenance and inservice inspections. The RPV insulation is supported from the internal surface of the reactor shield wall. The reactor shield wall is supported on top of the pedestal support structure.

Various drywell piping and equipment support structures are provided to support electric and instrument cable trays, drywell coolers, air distribution ductwork, steam and feedwater piping, and SRV discharge piping. Support is provided for isolation valves and piping of the ICS and PCCS. These miscellaneous steel structures also support access stairs, walkways, railings and gratings. Monorails are suspended from the ceiling of the drywell for hoists to work on NSSS equipment.

1.2.2.15.4 Passive Containment Cooling System

The Passive Containment Cooling System (PCCS) maintains the containment within its pressure limits for design basis accidents such as a LOCA. The system is passive, and after initiation, no components move.

The PCCS consists of six low pressure, totally independent loops, each containing a steam condenser (passive containment cooling condenser) that condenses steam on the tube side and transfers heat to water in a large cooling pool (IC/PCC pool), which is vented to the atmosphere.

Each PCCS condenser is located in a subcompartment of the IC/PCC pools. The IC/PCC pool subcompartments on each side of the Reactor Building communicate at their lower ends to enable full use of the collective water inventory, independent of the operational status of any given PCCS loop. There is no cross-connection between the two IC/PCC pools.

Each loop, which is open to the containment, contains a drain line to the GDSC pool and a vent discharge line, the end of which is submerged in the pressure suppression pool.

The PCCS loops are driven by the pressure difference created between the containment drywell and the wetwell during a LOCA. Consequently, they require no sensing, control, logic or power actuated devices for operation.

The PCCS is classified as safety-related and Seismic Category I.

Together with the pressure suppression containment system, the six PCC condensers limit containment pressure to less than its design pressure for at least 72 hours after a LOCA without make-up to the IC/PCC pools.

The PCC condensers are closed-loop extensions of the containment pressure boundary. Therefore, there are no containment isolation valves and they are always in "ready standby".

The PCCS can be periodically pressure-tested as part of overall containment pressure testing. The PCC loops can be isolated for individual pressure testing during maintenance.

During refueling outages, in-service inspection (ISI) of PCC condensers can be performed, if necessary, because ultrasonic testing of tube-to-heater welds and eddy current testing of tubes can be done with PCC condensers in place. The PCC condensers are located in the IC/PCC pools.

The essential monitored parameters for the IC/PCC pools are pool water level and pool radiation. IC/PCC pool water level monitoring is a function of the FAPCS, which is addressed in Subsection 1.2.2.6.2. IC/PCC pool radiation monitoring is a function of the PRMS, which is addressed in Subsection 1.2.2.3.1.

1.2.2.15.5 Containment Inerting System

The Containment Inerting System is designed to establish and maintain an inert atmosphere within the containment during all plant operating modes, except during plant shutdown for refueling or equipment maintenance and during limited periods of time to permit access for inspection at low reactor power. The objective of the system is to establish conditions that help preclude combustion of hydrogen and thereby prevent damage to safety-related equipment and structures.

The Containment Inerting System does not perform any safety-related function except for its containment isolation function. Failure of the Containment Inerting System does not compromise any safety-related system or component nor does it prevent a safe shutdown of the plant. The containment inerting process is a nonsafety-related readiness function, which is not used after the initiation of an accident, and thus, the Containment Inerting System is not a safety-related system.

The Containment Inerting System establishes an inert atmosphere (i.e., a very low oxygen concentration by volume) throughout the containment following an outage (or other occasions when the containment has become filled with air) and maintains it inert during normal conditions. The system maintains a slight positive pressure in the containment to prevent air (oxygen) in-leakage.

The Containment Inerting System is comprised of a pressurized liquid nitrogen storage tank, a steam-heated main vaporizer for large nitrogen flow, electric heater for vaporizing makeup flow, injection and exhaust lines, a bleed line, associated valves, controls, and instrumentation. All Containment Inerting System components are located inside the reactor building except the liquid nitrogen storage tank and the steam-heated main vaporizer, which are located in the yard.

The first of the injection lines is used only for makeup. It includes an electric heater to vaporize the nitrogen and to regulate the nitrogen temperature to acceptable injection temperatures. Remotely operated valves together with a pressure-reduction valve enable the operator to accomplish low rates of nitrogen injection into the drywell and wetwell airspace.

The second injection line is used when larger inerting flow rates are required. This line takes vaporized nitrogen from the steam-heated main vaporizer, uses remotely operated valves together with a pressure-reduction valve and injects nitrogen at points in common with makeup supply. The inerting and makeup lines converge to common injection points in the lower drywell and wetwell airspace.

The Containment Inerting System includes exhaust lines leading from the lower drywell and wetwell airspace at the opposite side from the injection points. The discharge line connects to the Reactor Building HVAC system exhaust where exhaust gases are processed by exhaust fans, filters, and radiation monitors before being diverted to the plant stack. A small bleed line bypassing a short portion of the main exhaust line, upstream of the fans, filters, and stack monitors, is also provided for manual pressure control of the containment during normal reactor heatup.

Redundant containment isolation valves provided in the inerting, makeup, exhaust and bleed lines close automatically upon receipt of an isolation signal from the LD&IS.

Upstream of the pressure-reduction valve in the makeup line, a small branch line is provided and connected to the HPNSS. This line is used for the initial charging of the HPNSS and for makeup to keep the HPNSS charged with nitrogen during normal plant operation.

During plant startup, a large flow of nitrogen from the liquid nitrogen storage tank is vaporized by the steam-heated vaporizer and injected into the drywell and the wetwell airspace. It is then mixed into the containment atmosphere by the drywell cooling fans. The exhaust line is kept open to displace containment resident atmosphere with nitrogen. Once the desired concentration of nitrogen is reached, the exhaust line is allowed to close. When the required inerted containment operating pressure is attained, the inerting process is terminated by the closure of the nitrogen supply shutoff valve and inerting isolation valves. The system is designed to inert the containment to $\leq 4\%$ oxygen by volume within four hours and to $\leq 2\%$ oxygen in the next eight hours. In the longer term, the system is required to maintain the containment atmosphere at less than 3% oxygen by volume during normal operation.

Following shutdown, the containment atmosphere is de-inerted to allow safe personnel access inside the containment. Breathable air from the Reactor Building HVAC system is injected to the drywell and wetwell airspace through the inerting injection line. The incoming air displaces containment gases (mostly nitrogen) into the exhaust line. The Reactor Building HVAC system exhaust fans, filters, and radiation detectors remove vented gases before diverting them to the plant stack. The system is designed to de-inert the containment to an oxygen concentration of $\geq 19\%$ within twelve hours.

1.2.2.15.6 Drywell Cooling System

The Drywell Cooling System (DCS) consists of four fan coil units (FCUs), two located in the upper drywell, and two in the lower drywell. The system uses the FCUs to deliver cooled air/nitrogen to various areas of the upper and lower drywell through ducts/diffusers. The DCS is a closed loop air/nitrogen recirculation-cooling system where no outside air is introduced into the system except when the containment is open. The DCS is manually controlled from the MCR. The DCS is cooled by the Nuclear Island Chilled Water Subsystem (NICWS).

Through the entire plant operating range, from startup to full load condition or from full load to shutdown, the DCS performs the following functions:

- Maintains temperature in the upper and lower drywell spaces within specified limits during normal operation;

- Accelerates drywell cooldown during the period from hot reactor shutdown to cold shutdown;
- Aids in complete purging of nitrogen from the drywell during shutdown;
- Maintains a habitable environment for plant personnel during plant shutdowns for refueling and maintenance; and
- Limits drywell temperature during loss of preferred power (LOPP).

The DCS is designed to maintain conditions in the upper and lower drywell during normal and plant shutdown modes of operation.

There are two direct-drive fans in each FCU. Each FCU motor is controlled manually from the MCR. Indicator lights show the status of each unit. Failure of an FCU with consequent temperature rise in the discharge stream or loss of flow actuates an alarm in the MCR.

Each upper drywell FCU has a cooling capacity of 50% of the upper drywell design cooling load under normal plant operating conditions. Likewise, each lower drywell FCU has a cooling capacity of 50% of the lower drywell design cooling load. All FCUs normally operate. Each FCU is composed of a cooling coil and two fans downstream of the coil. NICWS train A supplies cooling for one FCU, while NICWS train B supplies cooling for the other FCU. One of the fans operates while the other is on standby status. The standby fan automatically starts upon loss of the lead fan. During normal operation, if both fans of an FCU are out of commission, or the unit is not in service for some other reason, then both fans on the other unit in the area (upper or lower drywell) operate.

Cooled air/nitrogen leaving the FCUs enter a common plenum and is distributed to the various zones in the drywell through distribution ducts. Return ducts are not provided; the FCUs draw air/nitrogen directly from the upper or lower drywell.

A condensate collection pan is provided with each FCU. The condensate collected from all FCUs in the upper and the lower drywell is piped to an LD&IS flow meter to measure the condensation rate of unidentified leakages.

1.2.2.15.7 Containment Monitoring System

The Containment Monitoring System (CMS) shall provide the following functions:

- Drywell and Wetwell – Hydrogen, Oxygen concentrations and Gamma radiation levels Monitoring;
- Drywell and Wetwell Pressure Monitoring;
- Drywell/Wetwell Differential Pressure Monitoring;
- Upper Drywell Level Monitoring;
- Suppression Pool Water Level Monitoring;
- Suppression Pool Temperature Monitoring;
- Transmission of signals from dewpoint sensors that are used in Integrated Leak Rate Tests (ILRT);

- Post-Accident Sampling; and
- Lower Drywell (Post-LOCA) Pool Level Monitoring.

The safety-related portions of the CMS are Seismic Category I. Power to each subsystem is provided from uninterruptible Class 1E 120 VAC divisional sources.

Containment atmospheric and drywell monitoring:

The Containment Monitoring System (CMS) has two safety-related independent redundant divisions to monitor the gamma radiation dose rate and the concentrations of hydrogen and oxygen in the drywell and wetwell air during plant operation and following an accident. The channels, which measure gamma radiation in the drywell and wetwell air, are continuously displayed in the MCR.

The drywell pressure instruments provide signals to Leak Detection and Isolation System (LD&IS) and Reactor Protection System (RPS). A drywell pressure increase above normal values indicates the presence of reactor coolant leakage.

Safety-related differential pressure transmitters and nonsafety-related water level transmitters are connected between the drywell and the wetwell to provide, respectively, indication of proper functioning of the wetwell-drywell vacuum breaker system, and to measure containment flooding level in case of severe accident. The differential pressure instruments are also used for post-accident monitoring indications.

Two nonsafety-related channels of water level instrumentation monitor the Upper Drywell.

Two safety-related channels of water level instrumentation monitor the Lower Drywell.

Nonsafety-related dew points elements are located throughout the drywell and are used for containment absolute pressure calculations during containment ILRT.

In the post-accident operational mode, the function of the CMS is to continuously sample the oxygen and hydrogen contents in the containment, and display the results in the main control room. If the CMS indicates the presence of a potentially explosive gas mixture in the containment, the operator may use this information to assess containment integrity.

Suppression pool monitoring:

Suppression Pool Temperature Monitoring (SPTM) portion of CMS measures the suppression pool temperature and transmits the information to Safety System Logic and Control (SSLC). SSLC then averages the temperatures and sends the average bulk temperature to Reactor Protection System (RPS) for reactor scram. SPTM sends a signal to Fuel and Auxiliary Pools Cooling System (FAPCS) to initiate suppression pool cooling and cleaning function when necessary. It also provides signals to Reactor Component Cooling Water System (RCCWS) and for heat load shedding to increase suppression pool cooling. The SPTM consists of four redundant divisions with four levels of temperature elements within each division.

Suppression pool water level monitoring is provided to measure the inventory of suppression pool water. The suppression pool water level is monitored during all plant operating conditions and post accident conditions. Suppression pool water level monitoring consists of ten channels of water level detection sensors distributed into four safety-related narrow range and four wide-

range instruments. The narrow-range suppression pool water level signals are used to detect the uncovering of the first set of suppression pool temperature sensors below the pool surface.

When the suppression pool water level drops below the elevation of a particular set of temperature sensors, those sensor signals are not used in computing the average pool temperature.

Suppression pool temperature and level indications are displayed in the Main Control Room (MCR)

Two of the wide-range water level signals are used for displaying water level on the Remote Shutdown System.

Post-Accident Sampling Subsystem (PASS):

The PASS consists of sample holding rack, sampling rack, sample conditioning rack, local control panel, and shielding casks. All valves for PASS operation are operated remotely. The sampling system isolation valves are operated from the main control room and all other valves are operated from the local control panel. After the sample vessel has been isolated and removed, the piping is flushed with demineralized water.

The sample holding rack has an enclosure around the sample vessel to contain any leaks of liquids or gases. The liquids drain to the radwaste system and the gases go to the Reactor Building exhaust system.

The PASS isolation valves are connected to a reliable source of power that is available starting at least one hour after a LOCA. The isolation valves have Class 1E power and the panels and other equipment are powered with two offsite power supplies.

Gas samples are obtained from a sample line connected to other parts of the Containment Monitoring System. A vacuum pump is provided to transfer the gas sample from a sample holding rack to a sampling rack.

Means to reduce radiation exposure are provided, such as shielding, remotely operated valves and sample transporting casks.

1.2.2.16 Structures and Servicing Systems

1.2.2.16.1 Cranes, Hoists and Elevators

Large bridge cranes are provided in the Turbine Building, Fuel Building, Radwaste Building, and Reactor Building. Miscellaneous hoists and monorails are installed in the reactor, turbine and other buildings as necessary for maintenance and replacement of equipment. Elevators are installed in the reactor, turbine and other buildings as necessary.

1.2.2.16.2 Heating Ventilating and Air Conditioning

Reactor Building HVAC System (RBHV)

RBHVS includes the Clean Area HVAC (CLAVS), Contaminated Area HVAC (CONAVS) and Refueling and Pool Area HVAC (REPAVS) subsystems. The CLAVS serves areas considered to be clean (not potentially contaminated) during normal plant operation, plant start-up and plant shutdown. The CONAVS serves areas considered to be potentially contaminated during normal

plant operation, plant start-up and plant shutdown. The REPAVS serves the refueling area during normal plant operation, plant start-up and plant shutdown. The RBHVS subsystems do not perform any safety-related functions, except for automatic isolation of the building during accidents. Thus, all subsystems are classified as nonsafety-related, except for the dampers providing automatic isolation of the building during a potential radiological release event.

Control Building HVAC

The CBHVS includes the Control Room Habitability Area HVAC (CRHAHVS), Control Building General Area HVAC (CBGAHVS) and Emergency Breathing Air (EBAS) subsystems. The CBHVS is nonsafety-related and performs no safety-related functions, except for the Control Room Habitability Area (CRHA) envelope and EBAS, which are safety-related. The CRHAHVS serves the CRHA (Main Control Room and associated areas) during normal plant operation, plant start up and plant shutdown. The CBGAHVS serves the general areas of the Control Building during normal plant operation, plant start-up and plant shutdown. The EBAS equipment is located in its own building. EBAS supplies breathing and pressurization air to the Control Room Habitability Area during a potential radiological release event concurrent with a station blackout.

Turbine Building HVAC

The Turbine Building Ventilation System includes outside air intake louvers, dampers, filters, heating and cooling coils and three 50% capacity supply fans. The Balance-of-Plant Chilled Water Subsystem provides chilled water to local unit coolers and outside air intake coils when required. Three 50% capacity exhaust fans are provided. Local unit coolers and fans are provided in areas with high local heat loads. The system is nonsafety-related.

Fuel Building HVAC

The FBHVS includes the Fuel Building General Area HVAC (FBGAHV) and Fuel Building Fuel Pool Area HVAC (FBFPHV) subsystems. The FBGAHV serves the general areas of the Fuel Building during normal plant operation, plant start up and plant shutdown. The FBFPHV serves the spent fuel storage pool and equipment areas during normal plant operation, plant start up and plant shutdown. The FBHVS subsystems do not perform any safety-related functions, except for automatic isolation of the building during accidents. Thus, both subsystems are classified as nonsafety-related, except for the dampers providing automatic isolation of the building during a potential radiological release event.

Other Building HVAC

Ventilation for other buildings includes the Radwaste Building, Electrical Building, Service Building, Service Water Building, Administration Building, guard house, etc. All these systems are nonsafety-related, of conventional design and typically include redundant supply and exhaust fans, and air conditioning units. The Radwaste Building ventilation system also includes additional filtration and airborne radioactivity monitoring equipment.

1.2.2.16.3 Fire Protection System

The Fire Protection System (FPS) includes the fire protection water supply system, yard piping, water sprinkler, standpipe and hose systems, foam systems, smoke detection and alarm systems, and fire barriers.

Manual backups are provided for each of the automatic fire suppression systems, including two 100% capacity, fire water supplies.

The water supply system includes a motor-driven pump and two backup diesel-engine-driven pumps. Yard piping supplies fire water to all buildings. Fire hydrants are located throughout the site. Standpipes are provided within buildings as well as automatic sprinkler and deluge systems. Foam fire suppression systems are provided for the standby diesel generator and day tank rooms, outdoor diesel fuel oil storage tanks, and the turbine lube oil system and storage tanks. Smoke and heat detectors are located throughout the various buildings and are controlled by local panels and provide remote indication in the MCR.

The FPS is nonsafety-related. However, one source of fire water supply, one of the fire pumps, and the fire water main leading to and including the standpipes and systems for areas containing safe shutdown equipment are analyzed to withstand the effect of a Safe Shutdown Earthquake (SSE). They remain functional during and after an SSE.

1.2.2.16.4 Equipment and Floor Drainage System

The Equipment and Floor Drainage System (EFDS) consists of liquid waste collection piping, equipment drains, floor drains, vents, traps, cleanouts, collection sumps, sump pumps, tanks, valves, controls and instrumentation. The EFDS serves plant buildings (i.e., Reactor Building, Control Building, Fuel Building, Turbine Building, Electrical Building, Service Building, Radwaste Building and Service Water Building) with floor and equipment drains and consists of the following drain subsystems: clean, low conductivity waste (LCW), high conductivity waste (HCW), detergent, and chemical waste. All potentially radioactive drains are routed to the Liquid Waste Management System for processing.

The EFDS is nonsafety-related except for containment penetrations, isolation valves, and level switches for initiating containment isolation.

1.2.2.16.5 Reactor Building

The Reactor Building (RB) (Figures 1.2-1 through 1.2-11) houses the reactor system, reactor support and safety systems, concrete containment, essential power supplies and equipment, steam tunnel and refueling area. On the upper floor of the RB are the new fuel pool and small, spent fuel storage area, dryer/separator storage pool, refueling and fuel handling systems, and the upper connection to the incline fuel transfer system. The isolation condenser/passive containment cooling system pools are below the refueling floor. The RB shares a common wall and sits on a large common basemat with the Fuel Building. The RB is a Seismic Category I structure. The building is partially embedded.

1.2.2.16.6 Control Building

The Control Building (CB) (Figures 1.2-2 through 1.2-5 and Figure 1.2-11) houses the essential electrical, control and instrumentation equipment, the control room for the Reactor and Turbine Buildings, and the CB HVAC equipment. Structure below grade in the CB is a Seismic Category I structure that houses control equipment and operation personnel. Structure above grade is a Seismic Category II structure.

1.2.2.16.7 Fuel Building

The Fuel Building (FB) (Figures 1.2-1 through 1.2-8 and Figure 1.2-10) contains the spent fuel pool, cask loading area, fuel equipment and storage areas, lower connection to the inclined fuel transfer system, and other plant systems and equipment. The FB is a Seismic Category I structure except for the penthouse that houses HVAC equipment. The penthouse is a Seismic Category II structure. The FB is integrated with the RB, sharing a common wall between the RB and the FB and a large common foundation mat. The building is partially embedded.

1.2.2.16.8 Turbine Building

The Turbine Building (TB) (Figures 1.2-12 to 1.2-20) encloses the turbine-generator, main condenser, condensate and feedwater systems, condensate purification system, offgas system, turbine-generator support systems and bridge crane. The TB is a Seismic Category II nonsafety-related structure. The building is partially embedded. Shielding is provided for the turbine on the operating deck.

1.2.2.16.9 Radwaste Building

The Radwaste Building (RWB) (Figures 1.2-21 to 1.2-25) houses the equipment and floor drain tank(s), sludge phase separator(s), resin hold up tank(s), detergent drain collection tank(s), concentrated waste tank(s), chemical drain collection tank(s), associated pumps and mobile systems for the radioactive liquid and solid waste treatment systems. Tunnels connect the Radwaste Building to the reactor, fuel and turbine buildings. The RWB is a Non-Seismic Category structure. The RWB is designed according to the safety classifications defined in Regulatory Guide 1.143. The building is partially embedded.

1.2.2.16.10 Other Building Structures

The Electrical Building (Figures 1.2-26 through 1.2-33) houses the two nonsafety-related standby diesel generators, associated supporting systems and equipment, and nonsafety-related nonessential power supplies. The building is nonsafety-related and Seismic Category NS.

The Service Water Building houses the PSWS pumps and associated water storage, piping and valves. The building is nonsafety-related and Seismic Category NS.

The Emergency Breathing Air System (EBAS) building is a stand-alone structure, on its own foundation mat, adjacent to the Control Building. The EBAS building houses the compressed breathing air tank trains and their supporting equipment. The EBAS building is a Seismic Category I structure.

Other facilities include the Service Building, the Water Treatment Building, Administration Building, Training Center, Sewage Treatment Plant, warehouse, and hot and cold machine shops. These are all of conventional size and design.

1.2.2.17 Intake Structure and Servicing Equipment**1.2.2.17.1 Intake and Discharge Structures**

The intake and discharge structures (which apply for the standard plant design only) are adjacent to the cooling tower(s) and house the circulating water pumps, isolation valves, water treatment equipment, and associated electrical power and controls equipment. The structure and systems

are nonsafety-related. The COL applicant provides requirements for the intake and discharge structure.

1.2.2.18 Yard Structures and Equipment

1.2.2.18.1 Oil Storage and Transfer System

The major components of this system are the fuel-oil storage tank(s), pump(s), and day tank(s). Each standby diesel generator has its own individual supply components. Each fuel-oil pump is controlled automatically by day-tank level and feeds its day tank from the storage tank.

1.2.2.18.2 Site Security

The site security system typically includes features such as perimeter fencing, intrusion detection systems, vehicle barrier systems, closed circuit television equipment, defensive firing positions, site access control equipment (portal monitors, identification equipment, x-ray equipment, etc.), electronic lock/card reader building access control equipment, vehicle inspection bays, and computer-based monitoring and control stations, etc. as required to comply with the site security plan. The site security plan and requirements for the Site Security System shall be prepared and specified by the COL Applicant.

1.2.3 COL Information

The COL Applicant shall provide necessary design information on the cooling tower(s), stack location, intake and discharge structures and site security. It is also an interface requirement for the COL Applicant to provide information on the power transmission system. Other items to be provided by the COL Applicant are defined in subsequent chapters that go into more detail about plant systems.

1.2.4 References

None.

Figure 1.2-1. Nuclear Island Plan at Elevation –11500

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-74

Figure 1.2-2. Nuclear Island Plan at Elevation –6400

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-75

Figure 1.2-3. Nuclear Island Plan at Elevation –1000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-4. Nuclear Island Plan at Elevation 4650

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}

Figure 1.2-5. Nuclear Island Plan at Elevation 9060

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}

Figure 1.2-6. Nuclear Island Plan at Elevation 13570

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-79

Figure 1.2-7. Nuclear Island Plan at Elevation 17500

Security-Related Information - Withheld Under 10 CFR 2.390.

1.2-80

Figure 1.2-8. Nuclear Island Plan at Elevation 27000

Security-Related Information - Withheld Under 10 CFR 2.390.

1.2-81

Figure 1.2-9. Nuclear Island Plan at Elevation 34000

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}

Figure 1.2-10. Nuclear Island Elevation Section A-A

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-83

Figure 1.2-11. Nuclear Island Elevation Section B-B

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-84

Figure 1.2-12. Turbine Building Plan at Elevation –1400

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}

Figure 1.2-13. Turbine Building Plan at Elevation 4650

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}

Figure 1.2-14. Turbine Building Plan at Elevation 12000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-15. Turbine Building Plan at Elevation 20000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-16. Turbine Building Plan at Elevation 28000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-17. Turbine Building Plan at Elevation 33000 and 38000

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-90

Figure 1.2-18. Turbine Building Plan at Elevation Various

Security-Related Information - Withheld Under 10 CFR 2.390.

1.2-91

Figure 1.2-19. Turbine Building Elevation Section A-A

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-92

Figure 1.2-20. Turbine Building Elevation Section B-B

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-93

Figure 1.2-21. Radwaste Building Plan at Elevation -9350

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-22. Radwaste Building Plan at Elevation -2350

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-95

Figure 1.2-23. Radwaste Building Plan at Elevation 4650

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-96

Figure 1.2-24. Radwaste Building Plan at Elevation 10650

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-97

Figure 1.2-25. Radwaste Building Elevation Section A-A

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-98

Figure 1.2-26. Electrical Building Plan at Elevation 4650

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-27. Electrical Building Plan at Elevation 9800

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-100

Figure 1.2-28. Electrical Building Plan at Elevation 13000

{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-101

Figure 1.2-29. Electrical Building Plan at Elevation 18000

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-102

Figure 1.2-30. Electrical Building Plan at Elevation 22000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-31. Electrical Building Plan at Elevation 27000

Security-Related Information - Withheld Under 10 CFR 2.390.

Figure 1.2-32. Electrical Building Plan at Elevation Various

{}{}Security-Related Information - Withheld Under 10 CFR 2.390.{}{}
1.2-105

Figure 1.2-33. Electrical Building Elevation Section A-A
{{{Security-Related Information - Withheld Under 10 CFR 2.390.}}}
1.2-106

1.3 COMPARISON TABLES

This section highlights the principal design features of the ESBWR and compares its major features with those of other BWR facilities. The design of this facility is based on proven technology obtained during the development, design, construction, and operation of BWRs of similar types. Comparison tables include:

- Reactor System Design Characteristics, listed in Table 1.3-1;
- Emergency Core Cooling Systems and Safety-Related Containment Cooling Systems, listed in Table 1.3-2;
- Containment Design Characteristics, listed in Table 1.3-3; and
- Structural Design Characteristics, listed in Table 1.3-4.

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Thermal and Hydraulic (Section 4.4)				
Vessel inside diameter	m (in)	7.06 (278)	2.79 (110)	7.06 (278)
Number of fuel bundles		1132	156	872
Rated power	MWt	4500	163.4	3926
Design power (ECCS design basis)	MWt	4590	196	4005
Steam flow rate	Metric ton/hr (Mlb _m /hr)	8757 ⁽⁵⁾ (19.307)	256 (0.564)	7640 (16.843)
Core coolant flow rate	Metric ton/hr (Mlb _m /hr)	36,010 (79.388)	4500 (9.92)	52,200 (115.1)
Feedwater flow rate	Metric ton/hr (Mlb _m /hr)	8736 (19.260)	~243 (~0.54)	7624 (16.807)
Absolute pressure in steam dome	MPa (psia)	7.17 (1040)	7.10 (1030)	7.17 (1040)
Average power density	kW/liter	54.3	36.3	50.6
Maximum linear heat generation rate	kW/m (kW/ft)	44.0 (13.4)	50.1 (15.3)	44.0 (13.4)
Average linear heat generation rate	kW/m (kW/ft)	15.1 (4.6)	17.8 (5.4)	20.3 (6.2)
Average heat flux	kW/m ² (Btu/hr-ft ²)	458.53 (145,431)	367.57 (116,632)	524.86 (166,468)
Operating limit MCPR		1.30	N/A	1.17
Coolant enthalpy at core inlet	kJ/kg (Btu/lb _m)	1188 (510.9)	1240 (533.8)	1230 (527.7)
Maximum void fraction within fuel assemblies		0.89	0.64	0.75

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Core average exit quality	% steam	17	6.6	14.5
Feedwater temperature	°C (°F)	210-220 (410-428)	125 (257)	215.6 (420)
Design power peaking factor				
Maximum relative assembly power		1.33	1.30	1.40
Local peaking factor		1.36	1.15	1.25
Axial peaking factor		1.44	1.55	1.40
Total peaking factor		2.60	2.32	2.45
Nuclear (first core) (Section 4.3)				
Water/UO ₂ volume ratio (cold)		2.90	2.6	2.95
Reactivity with highest reactivity worth control rod out	Keff	<0.99	<0.99	<0.99
Initial average U ²³⁵ enrichment	(%)	2.00 ⁽³⁾	2.50	2.22
Initial cycle exposure	MWd/MTU (MWd/STU)	10,580 ⁽³⁾ (9,600)	17,600 (16,000)	10,945 (9,950)
Fuel Assembly (Section 4.2)				
Fuel rod array		10x10	6x6	8x8
Number of fuel rods per assembly		92	36	62
Fuel rod cladding material		Zircaloy-2	Zircaloy-2	Zircaloy-2
Overall length	cm (in)	379 (149.1)	179 (70.5)	447 (176)

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Weight of UO ₂ per assembly	kg (lbm)	144 (317)	68.9 (152)	197 (435)
Weight of fuel assembly (includes channel without UO ₂)	kg (lbm)	79 (174)	101 (223)	78 (172)
Fuel Channel (Section 4.2)				
Thickness	mm (in)	3.05/1.91 (0.120 / 0.075)	1.5 (0.06)	2.5 (0.100)
Cross section dimension	mm (in)	140 (5.52)	110 (4.35)	139 (5.48)
Material		Zircaloy-2	Zircaloy-4	Zircaloy-4
Core Assembly (Section 4.1)				
Number of fuel assemblies		1132	156	872
Fuel weight as UO ₂	kg (lbm)	162,928 (359,194)	10,750 (23,704)	172,012 (379,221)
Core diameter (equivalent)	mm (in)	5883 (231.6)	1788 (70.4)	5164 (203.3)
Active fuel length	mm (in)	3048 (120)	1793 (70.6)	3708 (146)
Reactor Control System (Chapters 4 and 7)				
Method of variation of reactor power		Control rods	Control rods	Control rods and core flow
Number of control rods		269	37	205
Shape of control rods		Cruciform	Cruciform	Cruciform
Pitch of control rods	mm (in)	309.88 (12.20)	305 (12.01)	309.88 (12.20)

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Control material in rods		B ₄ C granules compacted in stainless steel tubes	B ₄ C granules compacted in stainless steel tubes	B ₄ C granules compacted in stainless steel tubes
Type of control rod drives		Bottom entry electric hydraulic fine motion	Bottom entry locking piston	Bottom entry electric hydraulic fine motion
Type of temporary reactivity control for initial core		Burnable poison; gadolinia urania fuel rods	Removable borated steel curtains	Burnable poison; gadolinia urania fuel rods
In-core neutron instrumentation (Chapters 4 and 7)				
Total number of LPRM detectors		256	24	208
Number of in core LPRM penetrations		64	8	52
Number of LPRM detectors per penetration (assembly)		4	3	4
Total nuclear instrument penetrations		76	20	62
Startup range neutron monitor		12	N/A	10
Power range monitors range		1% - 125%	1% - 125%	1% - 125%
Number of local power range monitors		256	24	208
Number of average power range monitors (APRM) channels		4	None	4
Number and type of in-core neutron sources		6 Sb-Be or Cf-252	2	5 Sb-Be

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Reactor Vessel (Section 5.3)				
Material		Low-alloy steel/ stainless and Ni-Cr-Fe Alloy clad	Low-alloy steel/stainless clad	Low-alloy steel/stainless and Ni-Cr-Fe Alloy clad
Design gauge pressure	MPa (psig)	8.62 (1250)	8.62 (1250)	8.62 (1250)
Design temperature	°C (°F)	302 (575)	302 (575)	302 (575)
Inside diameter (min)	mm (in)	7061 (278)	2794 (110)	7061 (278)
Inside height	mm (in)	27,560 (1085)	12,090 (476)	21,056 (829)
Minimum base metal thickness (cylindrical section)	mm (in)	174 (6.85)	80 (3.15)	174 (6.85)
Minimum cladding thickness	mm (in)	3.2 (~1/8)	3.175 (~1/8)	3.2 (~1/8)
Reactor Coolant Recirculation (Chapter 5)				
Number of recirculation loops		Natural circulation internal to reactor vessel	Natural circulation internal to reactor vessel	Forced recirculation internal to reactor vessel ⁽⁴⁾
Recirculation pump flow rate	m ³ /s (gpm)	N/A	N/A	19.26 (30,516) per pump
Number of jet pumps		N/A	N/A	N/A
Main Steamlines (Subsection 5.4.9)				
Number of steamlines		4	1	4

Table 1.3-1
Comparison of Reactor System Design Characteristics

Design Characteristic ^{(1) (2)}	Units	ESBWR	BWR/1 Dodewaard	ABWR
Design Pressure	MPa (psig)	8.62 (1250)	8.62 (1250)	8.62 (1250)
Design temperature	°C (°F)	302 (575)	302 (575)	302 (575)
Pipe diameter	mm (in)	711 (28)	300 (12)	711 (28)
Pipe material		Carbon steel	Carbon steel	Carbon steel
Isolation Condenser (Subsection 5.4.6)				
Number of loops		4	1	N/A
Type		Vertical Tubes connected to Horizontal Drums	Shell and tube	N/A
Heat transfer/loop	MW (Btu/s)	33.75 (3.2x10 ⁴)	9.8 (9.3x10 ³)	N/A
Pool capacity		72 hours decay heat	8 hours decay heat	N/A

Notes for Table 1.3-1:

- (1) Parameters are relative to rated power.
- (2) Fuel and core design data in this table is representative and may be modified in a COL application consistent with fuel licensing acceptance criteria described in Appendix 4B.
- (3) Representative estimate – subject to future optimization for specific plant energy plan.
- (4) ABWR uses Reactor Internal Pumps (RIPs).
- (5) Steam flow will vary somewhat with design feedwater temperature. Value shown here is for feedwater temperature of 215.6°C (420°F).

Table 1.3-2. Comparison of Emergency Core Cooling Systems and Safety-Related Containment Cooling Systems

System	Units	ESBWR	ABWR
High Pressure ECC Systems			
High Pressure Core Flooder (HPCF)			
Number of loops		None	2
Reactor Core Isolation Cooling (RCIC)			
Number of loops		None	1
Automatic Depressurization System (Section 6.3)			
Number of SRVs		10	8
Number of DPVs		8	None
Capacity of SRVs	kg/hr (lb _m /hr)	4.5 x 10 ⁶ (9.8 x 10 ⁶)	2.9 x 10 ⁶ (6.4 x 10 ⁶)
Capacity of DPVs	kg/hr (lb _m /hr)	6.9 x 10 ⁶ (15.2 x 10 ⁶)	N/A
Low Pressure ECCS Systems (Section 6.3)			
Low Pressure Flooder (LPFL) mode of Residual Heat Removal (RHR)			
Number of loops		None	3
Number of pumps		N/A	3
Minimum rated flow per loop	m ³ /s (gpm)	N/A	2.65 (4,200)
Gravity-Driven Cooling System			
Number of loops		4 ⁽¹⁾	None
Number of pumps		0	N/A

Table 1.3-2. Comparison of Emergency Core Cooling Systems and Safety-Related Containment Cooling Systems

System	Units	ESBWR	ABWR
Capacity per division	m ³ /s (gpm)	0.139 ⁽²⁾ (2200)	N/A
Containment Cooling System (Section 6.2)			
Residual Heat Removal (RHR)			
Number of loops		None	3
Number of pumps		N/A	3
Number of heat exchangers		N/A	3
Heat exchanger type		N/A	Horizontal U-Tube/Shell
Passive Containment Cooling System			
Number of pumps		0	N/A
Number of heat exchangers		6	N/A
Heat exchanger type		Vertical Tubes connected to Horizontal Drums	N/A
Heat transfer/unit	MW (Btu/s)	11.0 ⁽³⁾ (1.0435x10 ⁴)	N/A
Number of cooling pools		6 ⁽⁴⁾	N/A
Cooling pool capacity		72 hrs decay heat	N/A

Notes for Table 1.3-2:

- (1) Interfacing with 3 GDSCS pools.
- (2) Reported GDSCS flow rate is after quasi steady-state is reached with a 13.8 kPa (2 psid) back pressure.
- (3) The heat transfer is based on (a) pure saturated steam condensing in the tubes at 308 kPa, and (b) pool water at 102°C and open to atmosphere.
- (4) The PCCS pools are two sets of three pools. The three pools in each set are connected to each other.

Table 1.3-3
Comparison of Containment Design Characteristics

Component ⁽¹⁾	Units	ESBWR	BWR/1 Dodewaard	ABWR
Primary Containment (Chapter 3)				
Type		Pressure suppression	Pressure suppression	Pressure suppression
Construction		Reinforced concrete with steel liner; steel structure	Drywell / wetwell vessel	Reinforced concrete with steel liner; steel structure
Drywell		Concrete cylinder	Steel cylinder	Concrete cylinder
Wetwell		Concrete cylinder	Two cylindrical vessels	Concrete cylinder
Wetwell internal design gauge pressure	MPa (psig)	0.310 (45)	0.490 (71.0)	0.310 (45)
Drywell internal design gauge pressure	MPa (psig)	0.310 (45)	0.490 (71.0)	0.310 (45)
Drywell total free volume	m ³ (ft ³)	7206 (254,477)	327 (11,548)	7,350 (259,563)
Wetwell free volume (at high water level)	m ³ (ft ³)	5467 (193,065)	426 (15,044)	5,960 (210,475)
Pressure-suppression pool water volume (at low water level)	m ³ (ft ³)	4383 (154,784)	406 (14,337)	3,580 (126,426)
Submergence of vent pipe below pressure suppression pool surface (at high water level)	m (ft)	1.95 to 4.69 (6.4 to 15.4)	1 (3.28)	3.6 to 6.3 (11.8 to 20.8)

Table 1.3-3
Comparison of Containment Design Characteristics

Component ⁽¹⁾	Units	ESBWR	BWR/1 Dodewaard	ABWR
Design temperature of drywell	°C (°F)	171 (340)	150 (302)	171 (340)
Leakage rate	% weight in free volume / day	0.5	0.5	0.5

Note for Table 1.3-3:

(1) Where applicable, containment parameters are based on rated power.

Table 1.3-4
Comparison of Structural Design Characteristics

Component	Units	ESBWR	ABWR
Reactor Building (Chapter 3)			
Type		Low Leakage	Controlled Leakage
Lower Level Construction		Reinforced Concrete	Reinforced Concrete
Upper Level Construction		Reinforced Concrete	Reinforced Concrete
Roof		Reinforced Concrete	Reinforced Concrete
Design in-leakage rate	% free volume/day	100 (at 0.25 in H ₂ O)	50 (at 0.25 in H ₂ O)
Seismic Design (Section 3.7)			
Safe Shutdown Earthquake	horizontal g vertical g	(1)	0.30 0.30
Wind Design (Subsection 3.3.2)			
Tornado translational	km/hr (mi/hr)	113 (70)	97 (60)
Tornado tangential	km/hr (mi/hr)	531 (330)	483 (300)

Note for Table 1.3-4:

- (1) Peak ground acceleration of 0.30g per Regulatory Guide 1.60 spectra with addition of North Anna ESP site-specific characteristics.

1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS

GE has developed, designed, and constructed BWRs since 1955. Table 1.4-1 lists the GE reactors completed or under construction.

Table 1.4-1**Commercial Nuclear Reactors Completed and Under Construction By General Electric**

Station	Utility Name (at time of plant order)	Original Rated MWe	Year of Order	Year of Low Power License
Dresden 1	Commonwealth Edison	207	1955	1959
Humboldt Bay	Pacific Gas & Electric	70	1958	1962
KAHL	Germany	15	1958	1961
Garigliano	Italy	150	1959	1964
Big Rock Point	Consumers Power	72	1959	1963
JPDR	Japan	11	1960	1963
KRB	Germany	237	1962	1967
Tarapur 1	India	190	1962	1967
Tarapur 2	India	190	1962	1969
Dodewaard	GKN	52	1963	1968
Oyster Creek	GPU	640	1963	1969
Nine Mile Point 1	Niagara Mohawk	610	1963	1969
Dresden 2	Commonwealth Edison	794	1965	1969
Pilgrim	Boston Edison	670	1965	1972
Millstone 1	Northeast Utilities	652	1965	1970
Tsuruga	Japan Atomic Power Co.	340	1965	1970
Santa Maria de Garoña	Nuclenor	440	1965	1971
Fukushima 1	Tokyo Electric Power Co.	439	1966	1971
KKM (Mühleberg)	BKW	306	1966	1972

Table 1.4-1

Commercial Nuclear Reactors Completed and Under Construction By General Electric

Station	Utility Name (at time of plant order)	Original Rated MWe	Year of Order	Year of Low Power License
Dresden 3	Commonwealth Edison	794	1966	1971
Monticello	Northern States Power	548	1966	1970
Quad Cities 1	Commonwealth Edison	789	1966	1972
Browns Ferry 1	TVA	1067	1966	1973
Browns Ferry 2	TVA	1067	1966	1974
Quads Cities 2	Commonwealth Edison	789	1966	1972
Vermont Yankee	Vermont Yankee	515	1966	1972
Peach Bottom 2	Philadelphia Electric Co.	1065	1966	1973
Peach Bottom 3	Philadelphia Electric Co.	1065	1966	1974
FitzPatrick	PASNY	821	1968	1974
Shoreham	LILCO	820	1967	1984
Cooper	Nebraska Public Power District	778	1967	1974
Browns Ferry 3	TVA	1067	1967	1977
Limerick 1	Philadelphia Electric Co.	1100	1967	1984
Limerick 2	Philadelphia Electric Co.	1100	1967	1988
Hatch 1	Georgia Power Corp.	786	1967	1974
Fukushima 2	Tokyo Electric Power Co.	762	1967	1975
Brunswick 1	Carolina P&L	821	1968	1977
Brunswick 2	Carolina P&L	821	1968	1974

Table 1.4-1

Commercial Nuclear Reactors Completed and Under Construction By General Electric

Station	Utility Name (at time of plant order)	Original Rated MWe	Year of Order	Year of Low Power License
Duane Arnold	Iowa Electric	545	1968	1974
Fermi 2	Detroit Edison	1093	1968	1987
Hope Creek 1	PSE&G	1067	1969	1984
Chinshan 1	Taiwan Power Co.	610	1969	1978
Caorso	ENEL	822	1969	1977
Hatch 2	Georgia Power	786	1970	1978
La Salle 1	Commonwealth Edison	1078	1970	1982
La Salle 2	Commonwealth Edison	1078	1970	1983
Susquehanna 1	Pennsylvania P&L	1050	1967	1982
Susquehanna 2	Pennsylvania P&L	1050	1968	1984
Chinshan 2	Taiwan Power Co.	610	1970	1979
Hanford 2 (now Columbia Station)	WPPSS	1100	1971	1983
Nine Mile Point 2	Niagara Mohawk	1100	1971	1987
Grand Gulf 1	SERI	1250	1971	1982
Fukushima 6	Tokyo Electric Power Co.	1135	1971	1979
Tokai	Japan Atomic Power Co.	1135	1971	1977
Riverbend	Gulf States Utilites	940	1972	1985
Perry	Cleveland Electric	1205	1972	1981
Laguna Verde 1	CFE	660	1972	1988

Table 1.4-1

Commercial Nuclear Reactors Completed and Under Construction By General Electric

Station	Utility Name (at time of plant order)	Original Rated MWe	Year of Order	Year of Low Power License
Leibstadt	Kernkraftwerk Leibstadt AG	940	1972	1984
Kuosheng 1	Taiwan Power Co.	992	1972	1981
Kuosheng 2	Taiwan Power Co.	992	1972	1982
Clinton	Illinois Power	950	1973	1986
Cofrentes	Hidroelectrica Española	975	1973	1985
Laguna Verde 2	CFE	660	1973	1994
Kashiwazaki 6	Tokyo Electric Power Co.	1300	1987	1996
Kashiwazaki 7	Tokyo Electric Power Co.	1300	1987	1997
Lungmen 1	Taiwan Power Co.	1300	1996	
Lungmen 2	Taiwan Power Co.	1300	1996	

1.5 REQUIREMENTS FOR FURTHER TECHNICAL INFORMATION

This section presents the background for the evolution of the ESBWR design, the methodology used to assess the need for further technical information, the computer code used for analysis and design, and the major SBWR/ESBWR Test Programs.

1.5.1 Evolutionary Design

The ESBWR design is an evolutionary step in boiling water reactor (BWR) design, which traces its commercial demonstration and operating plant history back before 1960 and represents hundreds of reactor years of successful licensed plant operation. Table 1.5-1 and Figure 1.5-1 summarize the evolution of the BWR design. Since its inception, the BWR has had plant simplification as a goal for each product improvement, as illustrated in Figure 1.5-2. The ESBWR, as described in this DCD, has major simplifying improvements drawn from predecessor designs, such as pressure-suppression containment, natural circulation, isolation condenser handling of waste heat, and gravity-driven makeup water systems. Key design features of predecessor designs are listed in Table 1.5-1. The incorporation of these features from predecessor designs has been accomplished with safety in mind and has emphasized employment of passive means of dealing with operational transients and hypothetical loss-of-coolant accidents (LOCAs). The result of this particular design assemblage of previously licensed plant features is a simplified operator response to these events. Most plant upset conditions are dealt with in essentially the same manner that is typical for the hypothetical steamline break. In addition, operator response times for all hypothetical events have been relaxed from minutes for previously licensed reactors to days for the ESBWR. Most features of the ESBWR have been taken directly from licensed commercial BWRs and reviewed and redesigned, as appropriate, for the ESBWR. (See Table 1.5-2.) The ESBWR draws together the best of previously licensed plant features to continue the simplification process. As an example, the evolution of the containment is shown in Figure 1.5-3.

1.5.2 Analysis and Design Tools

As implied in Subsection 1.5.1, there is now an immense amount of data available from operating plants and from the testing and licensing efforts done to license the predecessor designs and individual plants. The vast database of feature performance in licensed reactors, combined with the recent thorough licensing review of the ABWR, provides an extremely well-qualified foundation from which to make the modest extrapolations to the ESBWR. To make that extrapolation, GE has developed one computer code (TRACG) to use for design and for three out of the four most limiting licensing analyses. GE has chosen to develop the TRACG code, validated by the operating plant experience and appropriate testing, in order to analyze the challenges to the fuel (10 CFR 50.46 and Appendix K, Section 6.3), the challenges to the containment (Section 6.2), and many of the anticipated operational occurrences (AOOs) (MCPR, Chapter 15). The radiological responses to hypothetical accidents (LOCAs) are presented also in Chapter 15, but do not use TRACG for analysis. Thus, TRACG draws from the very large database of licensed BWRs, which includes all features of the ESBWR (albeit in various configurations) and appropriate testing, and allows direct application to ESBWR design and analysis (Table 1.5-2).

1.5.2.1 TRACG

The TRACG Code and its application to the ESBWR are documented in a series of GE Nuclear Energy Topical Reports, References 1.5-1 through 1.5-5.

TRACG is a GE proprietary version of the Transient Reactor Analysis Code (TRAC). It is a best-estimate code for analysis of BWR transients ranging from simple operational transients to design basis LOCAs, stability, and anticipated transients without scram (ATWS).

Background

TRAC was originally developed for pressurized water reactor (PWR) analysis by Los Alamos National Laboratory (LANL), the first PWR version of TRAC being TRAC-P1A. The development of a BWR version of TRAC started in 1979 in a close collaboration between GE and Idaho National Engineering Laboratory. The objective of this cooperation was the development of a version of TRAC capable of simulating BWR LOCAs. The main tasks consisted of improving the basic models in TRAC for BWR applications and developing models for the specific BWR components. This work culminated in the mid-eighties with the development of TRACB04 at GE and TRAC-BD1/MOD1 at INEL, which were the first major versions of TRAC having BWR LOCA capability. Due to the joint development effort, these versions were very similar, having virtually identical basic and component models. The GE contributions were jointly funded by GE, the Nuclear Regulatory Commission (NRC) and Electric Power Research Institute (EPRI) under the REFILL/REFLOOD and FIST programs.

The development of the BWR version has continued at GE since 1985. The objective of this development was to upgrade the capabilities of the code to include transient, stability and ATWS applications. During this phase, major developments included the implementation of a core kinetics model and addition of an implicit integration scheme into TRAC. The containment models were upgraded for simplified boiling water reactor (SBWR) applications, and the simulation of the BWR fuel bundle was also improved. TRACG was the end result of this development.

Scope and Capabilities

TRACG is based on a multi-dimensional two-fluid model for the reactor thermal hydraulics and a three-dimensional neutron kinetics model.

The two-fluid model used for the thermal hydraulics solves the conservation equations for mass, momentum and energy for the gas and liquid phases. TRACG does not include any assumptions of thermal or mechanical equilibrium between phases. The gas phase may consist of a mixture of steam and a noncondensable gas, and the liquid phase may contain dissolved boron. The thermal-hydraulic model is a multi-dimensional formulation for the vessel component and a one-dimensional formulation for all other components.

The conservation equations for mass, momentum and energy are closed through an extensive set of basic models consisting of constitutive correlations for shear and heat transfer at the gas/liquid interface as well as at the wall. The constitutive correlations are flow regime dependent and are determined based on a single flow regime map, which is used consistently throughout the code.

In addition to the basic thermal-hydraulic models, TRACG contains a set of component models for BWR components, such as channels, steam separators and dryers. TRACG also contains a

control system model capable of simulating the major BWR control systems such as RPV pressure and water level.

The neutron kinetics model is consistent with the GE BWR core simulator PANACEA. It solves a modified one-group diffusion model with six delayed neutron precursor groups. Feedback is provided from the thermal-hydraulic model for moderator density, fuel temperature, boron concentration and control rod position.

The TRACG structure is based on a modular approach. The TRACG thermal-hydraulic model contains a set of basic components, such as pipe, valve, tee, channel, steam separator, heat exchanger and vessel. System simulations are constructed using these components as building blocks. Any number of these components may be combined. The number of components, their interaction, and the detail in each component are specified through code input. Consequently, TRACG has the capability to simulate a wide range of facilities, ranging from simple separate effects tests to complete BWR plants.

TRACG has been extensively qualified against separate effects tests, component performance data, integral system effects tests and full-scale BWR plant data. A detailed documentation of the qualification is contained in the TRACG qualification report, Reference 1.5-2.

1.5.2.2 Scope of Application of TRACG to ESBWR

The total effort and extent of qualification performed on TRACG, since its inception in 1979, now exceeds, both in extent and breadth, that of any other engineering computer program GE has submitted to the NRC for design application approval. The application of TRACG for ESBWR LOCA analysis has been approved by the NRC [Reference 1.5-3]. For Anticipated Operational Occurrences (AOOs), the TRACG methodology approved for operating BWRs is employed [Reference 1.5-4]. TRACG application for ESBWR stability analysis is contained in Reference 1.5-5.

Anticipated Operational Occurrences Analysis

TRACG is used to perform safety analyses of the AOOs described in Chapter 15 and the ASME reactor vessel overpressure protection event within Section 5.2.

The analysis determines the most limiting event for the AOOs in terms of Critical Power Ratio (CPR) and establishes operating limit minimum CPR (OLMCPR). The OLMCPR includes the statistical CPR adder, which accounts for uncertainty in calculated results arising from uncertainties associated with the TRACG model, initial conditions, and input parameters, as well as uncertainties associated with the critical power correlation. Sensitivity analysis of important parameters affecting the transient results is performed using TRACG. Concepts derived from the Code Scaling, Applicability, and Uncertainty (CSAU) methodology [References 1.5-6, 1.5-7] are utilized for quantifying the uncertainty in calculated results.

The analysis also determines the most limiting overpressure protection events in terms of peak vessel pressure. The results are used to demonstrate adequate pressure margin to the reactor vessel design limit with the ESBWR design safety/relief valve capacity. The overpressure protection analysis is performed based on conservative initial conditions and input values.

ATWS Analysis

TRACG is used for evaluation of the ATWS events in Chapter 15. The analysis determines the most limiting ATWS events in terms of reactor vessel pressure, heat flux, neutron flux, peak cladding temperature, suppression pool temperature, and containment pressure. The results are used to demonstrate the capability of the ESBWR mitigation design features to comply with the ATWS licensing criteria.

ECCS-LOCA Analysis

TRACG is used for evaluation of the complete spectrum of postulated break sizes and locations, together with possible single active failures, in Section 6.3. This evaluation determines the worst-case break and single failure combinations. The results are used to demonstrate the ESBWR Emergency Core Cooling System (ECCS) capability to comply with the licensing acceptance criteria.

A sensitivity analysis of important parameters affecting LOCA results is performed using TRACG. For the ESBWR, the LOCA analysis results show no core uncover for any LOCA. Based on the sensitivity studies, a bounding calculation is performed for the minimum water level inside the shroud for use as the licensing basis. The ESBWR LOCA results have large margin with respect to the licensing acceptance criteria.

Containment Analysis

TRACG is also used for evaluation of containment response during a LOCA. The analysis determines the most limiting LOCA for containment (or Design Basis Accident, DBA) in terms of containment pressure and temperature responses. The DBA is determined from consideration of a full spectrum of postulated LOCAs. The results are used to demonstrate compliance with the ESBWR containment design limits. Sensitivity of the containment response to parameters identified as important is evaluated using TRACG to assess the effect of uncertainties of these parameters on the containment responses. Based on the sensitivity studies, a bounding calculation is performed for the containment pressure and temperature response for use as the licensing basis.

1.5.3 Testing

The ESBWR test and analysis program description is provided in Reference 1.5-8, which provides detailed justification for the adequacy of the test database for application to safety analysis.

The Phenomena Identification and Ranking Table (PIRT) discussed in Section 2 of Reference 1.5-8 identifies specific governing phenomena, of which a significant fraction were concluded to be "important" in prediction of ESBWR transient and LOCA performance. Most of these phenomena are common to those for operating BWRs. TRACG has been extensively qualified against separate effects tests, component performance tests, integral systems tests and plant operating data listed in Reference 1.5-8. This 'base' qualification is documented in the TRACG Qualification Report [Reference 1.5-2]. This section examines specific SBWR/ESBWR-related tests and test facilities beyond the previous qualification database.

Early in the SBWR program, the need for one piece of information for which there was no information in the data base was identified, i.e., a heat transfer correlation for steam

condensation in tubes in the presence of noncondensable gases. A test program was conducted to secure this information, reported to the NRC in Reference 1.5-9.

The Single Tube Condensation Test Program was conducted to investigate steam condensation inside tubes in the presence of noncondensibles. The work was independently conducted at the University of California at Berkeley (UCB) and at the Massachusetts Institute of Technology (MIT). The work was initiated in order to obtain a data base and a correlation for heat transfer in similar conditions as would occur in the SBWR/ESBWR PCCS tubes during a DBA LOCA. Three researchers utilized three separate experimental configurations at UCB, while two researchers utilized one configuration at MIT. The researchers ran tests with pure steam, steam/air, and steam/helium mixtures with representative and bounding flow rates and noncondensable mass fractions. The experimenters found the system to be well behaved for all tests, with either of the noncondensibles, for forced flow conditions similar to the ESBWR design. The results of the tests at UCB have become the basis for the condensation heat transfer correlation used in the TRACG computer code.

While all SBWR/ESBWR features are extrapolations from current and previous designs, two features (specifically, the Passive Containment Cooling System and the Gravity-Driven Cooling System) represent the two most challenging extrapolations. Therefore, it was decided, for these two cases, to obtain additional test data, which could be used to demonstrate the capabilities of TRACG to successfully predict SBWR/ESBWR performance over a range of conditions and scales. Blind (in some cases double blind) predictions of test facility response use only the internal correlations of TRACG. No "tuning" of the TRACG inputs was performed, and no modifications to the coding were anticipated as a result of these tests.

For the case of the PCCS, the steady state heat exchanger performance was predicted in full-vertical-scale 3-tube (GIRAFFE), 20-tube (PANDA), and prototypical 496-tube (PANTHERS) configurations, over the range of steam and noncondensable conditions expected for the SBWR. This process addresses scale and geometry differences between the basic phenomena tests performed in single tubes, and larger scales including prototype conditions. Transient performance was similarly investigated at two different scales in both GIRAFFE and PANDA.

TRACG GDCS performance predictions were performed against the GIST and GIRAFFE/SIT test series. Pre-test predictions have also been performed for the PANTHERS and PANDA steady state tests.

Compliance with 10 CFR 52.47 Requirements

10 CFR 52.47(b)(2)(i)(A) requires in part that:

- The performance of each safety feature of the design has been demonstrated through analysis, appropriate test programs, experience, or a combination thereof.
- Interdependent effects among the safety features of the design have been found acceptable by analysis, appropriate test programs, experience, or a combination thereof.
- Sufficient data exist on the safety features of the design to assess the analytical tools used for safety analysis over a sufficient range of operating conditions, transient conditions, and specified accident sequences, including equilibrium core conditions.

The ESBWR meets the above requirements, as discussed below:

- ESBWR plant features have been used in earlier BWR designs and most continue in operation today after many years and over a very large number of combined plant operating years of service. While the details of the particular plant feature design for the ESBWR may differ somewhat from those in current plants, the function of each feature is substantially the same. This experience constitutes a sufficient database to meet the requirements of 10 CFR 52.47(b)(2)(i)(A)(1).
- In those scenarios in which ESBWR safety features come into operation, no other systems are required and, therefore, system interactions are not an issue, or the system designs are similar in the ESBWR and the operating plants having the feature. The operating plant feature(s) perform under the same general conditions and for the same scenarios as are anticipated to occur in the ESBWR. The operating plant database is sufficient to meet requirements of 10 CFR 52.47(b)(2)(i)(A)(2) and (3).
- Feature performance has been predicted with the TRACG computer program. TRACG has been qualified by comparison to data from experiments and operating BWRs over a wide range of reactor conditions, including temperatures and pressures during which the features are expected to operate. The TRACG analyses add to the confidence that the features would perform as expected and reinforce the GE position that the requirements of 10 CFR 52.47(b)(2)(i)(A)(1), (2) and (3) have been met. The NRC safety evaluation report for Reference 1.5-3 concludes that no further testing in support of the thermal hydraulic behavior of the design is necessary.

The detailed design of specific ESBWR plant equipment is, in some cases, not specified in the ESBWR DCD; in some instances, only the design requirements of the equipment are given. When this is the case, a requirement for hardware testing is not appropriate under the certification program. However, because the ESBWR-specific hardware design differs from that currently in use, GE believes that testing before application of a specific equipment design in a plant should be planned. Therefore, testing of plant hardware is done prior to or during startup testing of the plant.

For any ESBWR constructed, equipment performance will be demonstrated. For example, overall testing of the heat rejection capability of the ICs is to be included as part of the plant startup test program. No ESBWR plant will operate until plant-specific tests confirm that each IC meets the performance requirements. Full-scale tests of an IC module in the PANTHERS test facility, as well as experience with condensing heat exchangers in many industries give high confidence that the requirements will be met.

1.5.3.1 Major ESBWR Unique Test Programs

As noted previously, the vast majority of data supporting the ESBWR design were generated using the design of the previous BWR product lines. ESBWR-unique certification and confirmatory tests applicable to its design are listed below.

GIST (Confirmatory)

GIST is an experimental program conducted by GE to demonstrate the Gravity-Driven Cooling System (GDCS) concept and to collect data to qualify the TRACG computer code for ESBWR applications. Simulations were conducted of Design Basis Accident LOCAs representing main steamline break, bottom drain line break, GDCS line break, and a non-LOCA loss of inventory.

Test data have been used in the qualification of TRACG to ESBWR and documented in Reference 1.5-10. Tests were completed in 1988 and documented by GE in 1989. GIST data have been used for validation of certain features of TRACG

GIRAFFE (Certification)

GIRAFFE [Reference 1.5-11] is an experimental program conducted by the Toshiba Corporation to investigate thermal-hydraulic aspects of the Passive Containment Cooling System (PCCS). Fundamental steady state tests on condensation phenomena in the PCC tubes were conducted. Simulations were run of DBA LOCAs; specifically, the main steamline break. GIRAFFE data have been used to substantiate PANDA and PANTHERS data at a different scale and to support validation of certain features of TRACG. Also, two additional series of tests have been conducted in the GIRAFFE facility: The first (GIRAFFE/Helium) demonstrates the operation of the PCCS in the presence of lighter-than-steam noncondensable gas; the second (GIRAFFE/SIT) provides additional information regarding potential system interaction effects in the late blowdown/early GDCS period.

PANDA (Certification)

PANDA [Reference 1.5-11] is an experimental program run by the Paul Scherrer Institut in Switzerland. PANDA is a full-vertical-scale 1/25 volume scale model of the SBWR system designed to model the thermal-hydraulic performance and post-LOCA decay heat removal of the PCCS. Both steady state and transient performance simulations have been conducted. Testing at the same thermal-hydraulic conditions as previously tested in GIRAFFE and PANTHERS allows scale-specific effects to be quantified. Blind pre-test analyses using TRACG was submitted to the NRC prior to start of the testing. PANDA data have been used directly for validation of certain features of TRACG.

PANTHERS (Certification)

PANTHERS [Reference 1.5-11] is an experimental program performed by SIET in Italy, with the dual purpose of providing data for TRACG qualification and demonstration testing of the prototype PCCS and IC heat exchangers. Steam and noncondensibles were supplied to prototype heat exchangers over the complete range of SBWR conditions to demonstrate the capability of the equipment to handle post-LOCA heat removal. Testing was performed at the same thermal-hydraulic conditions as in GIRAFFE and PANDA. Blind pre-test analyses of selected test conditions using TRACG were submitted to the NRC prior to the start of testing. PANTHERS data are used directly for validation of certain features of TRACG.

In addition to thermohydraulic testing, an objective of PANTHERS was to demonstrate the structural adequacy of the heat exchangers to exceed the SBWR/ESBWR expected lifetime requirement. This was accomplished by pre- and post-test nondestructive examination, following cycling of the equipment in excess of requirements.

Additional PANDA Tests (Confirmatory)

A supplementary program (TEPSS) [Reference 1.5-12] has also been performed in the PANDA test facility to test an earlier ESBWR configuration with the GDCS pool connected to the wetwell gas space rather than the drywell. These tests confirm the expected increased margin to the containment design pressure for this ESBWR configuration. This series of tests also

included injection of Helium, providing data on PCCS performance with light noncondensable gases at an additional scale.

Scaling of Tests

A discussion of scaling of the major SBWR and ESBWR tests is contained in References 1.5-13 and 1.5-14. These reports contain a complete discussion of the features and behavior of the SBWR and ESBWR during challenging events. The analysis includes the general (Top-Down approach) scaling considerations, the scaling of specific (Bottom-Up approach) phenomena, and the scaling approach for the specific tests discussed above. The scaling analysis shows that the SBWR and ESBWR tests represent the ESBWR response without significant distortions, and can be used for qualification of the TRACG code for ESBWR applications.

1.5.4 References

- 1.5-1 GE Nuclear Energy, "TRACG Model Description," NEDE-32176P, Class III (GE proprietary), Revision 2, December 1999.
- 1.5-2 GE Nuclear Energy, "TRACG Qualifications," NEDE-32177P, Class III (GE proprietary), Revision 2, January 2000.
- 1.5-3 GE Nuclear Energy, "TRACG Application for ESBWR," NEDC-33083P-A, Class III (GE proprietary), March 2005.
- 1.5-4 GE Nuclear Energy, "TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analysis," NEDE-32906P-A, Class III (GE proprietary), Revision 1, April 2003.
- 1.5-5 GE Nuclear Energy, "TRACG Application for ESBWR Stability Analysis," NEDC-33083P, Class III (GE proprietary), Supplement 1, December 2004.
- 1.5-6 USNRC, "Quantifying Reactor Safety Margins," NUREG/CR-5249, EGG-2552.
- 1.5-7 B. E. Boyack, et al, "Quantifying Reactor Safety Margins," Nuclear Engineering and Design (Parts 1-4), 119 (1990), Elsevier Science Publishers B. V. (North Holland).
- 1.5-8 GE Nuclear Energy, "ESBWR Test and Analysis Program Description," NEDC-33079P, Class III (GE proprietary), Revision 1, March 2005.
- 1.5-9 GE Nuclear Energy, MIT and UCB Separate Effects Tests for PCCS Tube Geometry, "Single Tube Condensation Test Program," NEDC-32301, March 1994.
- 1.5-10 GE Nuclear Energy, "Simplified BWR Program Gravity-Driven Cooling System (GDSCS) Integrated Systems Test," GEF-00850, October 1989.
- 1.5-11 GE Nuclear Energy, "SBWR Testing Summary Report," NEDC-32606P, Class III (GE proprietary), November 1996.
- 1.5-12 GE Nuclear Energy, "ESBWR Test Report," NEDC-33081P, Class III (GE proprietary), Revision 1, May 2005.
- 1.5-13 GE Nuclear Energy, "Scaling of the SBWR Related Tests," NEDC-32288P, Class III (GE proprietary), Rev. 1, October 1995.

1.5-14 GE Nuclear Energy, “ESBWR Scaling Report,” NEDC-33082P, Class III (GE proprietary), December 2002.

Table 1.5-1
Evolution of the General Electric BWR


Product Line Number	Year of Introduction	Characteristic Plants/Features
BWR/1	1955	Dresden 1, Big Rock Point, Humboldt Bay, KRB, Dodewaard <ul style="list-style-type: none"> • Natural circulation (Humboldt Bay, Dodewaard only) • First internal steam separation • Isolation condenser (IC) • Pressure Suppression Containment
BWR/2	1963	Oyster Creek <ul style="list-style-type: none"> • Large direct cycle
BWR/3/4	1965/1966	Dresden 2/Browns Ferry <ul style="list-style-type: none"> • First jet pump application • Improved ECCS: spray and flood • Reactor core isolation cooling system
BWR/5	1969	La Salle, NMP-2 <ul style="list-style-type: none"> • Improved ECCS systems • Valve recirculation flow control
BWR/6	1972	Grand Gulf, Perry, Clinton <ul style="list-style-type: none"> • Improved jet pumps and steam separators • Reduced fuel duty: 13.4 kW/ft (44 kW/m) • Improved ECCS performance • Gravity Containment Flooder • (option) Solid-state nuclear system protection system (Clinton only) • (option) Compact control room
ABWR	1996	<ul style="list-style-type: none"> • Fine Motion Control Rod Drives • Internal Recirculation Pumps
SBWR / ESBWR		Gravity Flooder, IC, Passive Containment Cooling, Natural Circulation

Table 1.5-2
ESBWR Features and Related Experience

ESBWR Feature	Plants	Testing
IC	Dodewaard, Dresden 1,2,3, Big Rock Pt., Tarapur 1,2, Nine Mile Pt 1, Oyster Creek, Millstone 1, Tsuruga, Santa Maria de Garoña, Fukushima 1	Operating Plants
Natural Circulation	Dodewaard Humboldt Bay	Operating Plants
Squib valves	BWR/1-6 and ABWR SLC Injection Valves	Operating Plants IEEE 323 Qualification Testing
Gravity Flooder	Perry, Clinton, Grand Gulf Upper Pool Dump System, Suppression Pool Flooder System	Operating Plants Preoperational Testing
Internal Steam Separators	BWR/1-6 and ABWR	Operating Plants
Chimney (Core to Steam Separators)	Dodewaard, Humboldt Bay	Operating Plants
FMCRDs	ABWR	ABWR Test/ Development Program (Demonstration at La Salle Plant)
Automatic Depressurization Valves (DPVs)	All BWRs	Operating Plants
Pressure Suppression	BWR/1-6 and ABWR	Mk I, Mk II, Mk III and ABWR Tests
Horizontal Vents	BWR/6 and ABWR, Perry, Grand Gulf, Clinton, River Bend, etc.	ABWR Testing

Table 1.5-2
ESBWR Features and Related Experience


ESBWR Feature	Plants	Testing
Quenchers	BWR/2–6 and ABWR	Operating Plants
PCC (Dual Function Heat Exchangers)	Operating Plants, RHR HX Steam Condensing Mode	Operating Plants, PANDA, GIRAFFE, SIET
Solid State Control System (NSPS)	ABWR, Clinton	Operating Plants, Clinton



Evolution of the BWR

Figure 1.5-1. Evolution of the GE BWR

Evolution of the ESBWR Reactor Design



AR0103- 1

Figure 1.5-2. Evolution of the BWR Reactor Design




Figure 1.5-3. Comparison of BWR Containments

1.6 MATERIAL INCORPORATED BY REFERENCE

Table 1.6-1 lists all GE reports that are incorporated in whole or in part by reference in the ESBWR DCD Tier 2.

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
22A4365AB 22A4365	General Electric Company, "Containment Loads Report (CLR), Mark III Containment," 22A4365AB, Class III (Proprietary), Revision 4, January 25, 1980, and 22A4365, Class I (Non-proprietary), Revision 0, January 25, 1980.	3B
22A7007	General Electric Company, "GESSAR II, BWR/6 Nuclear Island Design," 22A7007, Class III (Proprietary) and Class I (Non-proprietary), Revision 19, May 28, 1985 (Appendix 3B, Containment Hydrodynamic Loads and Appendix 15B, Generic Rod Withdrawal Error Analysis).	3B Chapter 16 B3.2.2
23A6100	General Electric Company, "Advanced Boiling Water Reactor, Standard Safety Analysis Report," 23A6100, Class III (Proprietary) and Class I (Non-proprietary), Revision 8, May 13, 1996 (Appendix 3B, Containment Hydrodynamic Loads and Appendix 5A, Detection and Sizing Capability Test for RG 1.150).	3B, 5.2
APED-5640	R. L. Crowther, "Xenon Considerations in Design of Boiling Water Reactors," APED-5640, June 1968.	4.3
APED-5750	General Electric Company, "Design and Performance of General Electric Boiling Water Reactor Main Steam Line Isolation Valves," APED-5750, March 1969.	5.4
APEX-510	General Electric Company, "Polynomial Approximation of Gamma Ray Buildup Factors for a Point Isotropic Source", APEX-510, November 1958.	12.3
GEAP-5620	AEC, M.B. Reynolds, "Failure Behavior in ASTM A106B Pipes Containing Axial Through-Wall Flaws," GEAP-5620, AEC Research and Development Report, April 1968.	3E, Chapter 16 B3.3 B3.4

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
GEAP-5716	USAEC, "Reactor Primary Coolant System Rupture Study Quarterly Progress Report No. 14," July-September, 1968, GEAP-5716, AEC Research and Development Report, December 1968	3E
GEFR-00850	"Simplified BWR Program Gravity-Driven Cooling System (GDSCS) Integrated Systems Test," October 1989	1.5
GEFR-00879	GE Nuclear Energy, "Depressurization Valve Development Test Program Final Report," GEFR-00879, October 1990.	6.3
NEDO-10299A	General Electric Company, "Core Flow Distribution in a Modern Boiling Water Reactor as Measured in Monticello," NEDO-10299A, October 1976.	4.4
NEDO-10527	J. Paone and J. A. Woolley, "Rod Drop Accident Analysis for Large Boiling Water Reactors, Licensing Topical Report," March 1972, NEDO-10527, Supplements 1 and 2	15.3
NEDO-10722A	General Electric Company, "Core Flow Distribution in a General Electric Boiling Water Reactor as Measured in Quad Cities Unit 1," NEDO-10722A, August 1976.	4.4
NEDO-10871	General Electric Company, "Technical Derivation of BWR 1971 Design Basis Radioactive Material Source Terms," NEDO-10871, March 1973.	11.1
NEDE-10958-PA NEDO-10958-A	General Electric Company, "General Electric BWR Thermal Analysis Basis (GETAB): Data Correlation and Design Application," NEDE-10958-PA, Class III (proprietary), and NEDO-10958-A, Class I (non-proprietary), January 1977.	4.4, 4B, Chapter 16 B2.1.1
NEDO-11209-04a	"GE Nuclear Energy Quality Assurance Program Description," Class I (non-proprietary), NEDO-11209-04a, Revision 8, March 31, 1989	1.9, 10.3, 17.1

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDO-20533	General Electric Company, "The General Electric Mark III Pressure Suppression Containment Analytical Model," NEDO-20533, Class I (Non-proprietary), Revision 0, June 1974.	3B
NEDO-20964	R. C. Stirn, "Generation of Void and Doppler Reactivity Feedback for Application to BWR Design," NEDO-20964, December 1975.	4.3
NEDO-21000	GE Nuclear Energy, "Investigation of Cause of Cracking in Austenitic Stainless Steel Piping, NEDO-21000 Volume 1 and 2, Class 1, Revision 0, July 1975	3E
NEDO-21143-1	General Electric Co., "Radiological Accident Evaluation - The CONAC03 Code," NEDO-21143-1, December 1981.	11.3, 15.3
NEDO-21159	General Electric Company, "Airborne Releases From BWRs for Environmental Impact Evaluations," NEDO-21159, March 1976.	11.1
NEDE-21175-3-P-A	GE Nuclear Energy, "BWR Fuel Assembly Evaluation of Combined Safe Shutdown Earthquakes (SSE) and Loss-of-Coolant Accident (LOCA) Loadings (Amendment 3)," NEDE-21175-3-P-A, October 1984 (GE proprietary).	3.9
NEDO-21215	General Electric Company, "Brunswick Steam Electric Plant Unit 1 Safety Analysis Report for Plant Modifications to Eliminate Significant In-Core Vibrations," NEDO-21215, March 1976.	4.4
NEDO-21231	NEDO-21231, "Banked Position Withdrawal Sequence," January 1977.	Chapter 16 B3.1 B3.3
NEDE-21354-P	General Electric Company, "BWR Fuel Channel Mechanical Design and Deflection," NEDE-21354-P, September 1976 (GE proprietary).	3.9

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDO-21471	General Electric Company, “Analytical Model for Estimating Drag Forces on Rigid Submerged Structures caused by LOCA and Safety Relief Valve Ramshead Air Discharges,” NEDO-21471, Class I (Non-proprietary), Revision 0, September 1977.	3B
NEDO-21471-01	General Electric Company, “Analytical Model for Estimating Drag Forces on Rigid Submerged Structures Caused by LOCA and Safety Relief Valve Ramshead Air Discharges, Supplement for X-Quencher Air Discharges,” NEDO-21471-01, Class I (Non-proprietary), Revision 0, October 1979.	3B
NEDE-21544-P NEDO-21544	General Electric Company, “Mark II Pressure Suppression Containment Systems: An Analytical Model of the Pool Swell Phenomenon,” NEDE-21544-P, Class III (Proprietary), Revision 0, December 1976, and NEDO-21544, Class I (Non-proprietary), Revision 0, December 1976.	3B
NEDE-21596-P NEDO-21596	General Electric Co., “Mark III Confirmatory Test Program - $1/\sqrt{3}$ Scale Condensation and Stratification Phenomena – Test Series 5807,” NEDE-21596-P, Class III (Proprietary), Revision 0, March 1977, and NEDO-21596, Class I (Non-proprietary), Revision 0, March 1977.	3B
NEDO-21778-A	General Electric Co., “Transient Pressure Rises Affecting Fracture Toughness Requirements for Boiling Water Reactors,” NEDO-21778-A, December 1978.	Chapter 16 B3.4.4
NEDE-24011-P-A NEDO-24011	GE Nuclear Energy, “GESTAR II General Electric Standard Application for Reactor Fuel,” NEDE-24011-P-A (GE Proprietary) and NEDO-24011 (non-proprietary), latest revision	4B, 15.0, 15.3, 15.5
NEDO-24210	General Electric Co., “PISYS Analysis of NRC Benchmark Problems,” NEDO-24210, August 1979.	3D

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDE-24222 NEDO-24222	General Electric Company, "Assessment of BWR Mitigation of ATWS, Volume II (NUREG 0460 Alternate No. 3)," NEDE-24222, Class III (proprietary), December 1979, and NEDO-24222, Class I (non-proprietary), February 1981.	15.0, 15.5
NEDE-24302-P NEDO-24302	General Electric Co, "Mark II Containment Program, Generic Chugging Load Definition Report," NEDE-24302-P, Class III (Proprietary), Revision 0, April 1981, and NEDO-24302, Class I (Non-proprietary), Revision 0, July 1981.	3B
NEDE-24326-1-P	GE Nuclear Energy, "General Electric Environmental Qualification Program," NEDE-24326-1-P, Proprietary Document, January 1983.	3.9, 3.10, 3.11 Appendix 3I
NEDE-25100-P NEDO-25100 NEDO-25100-EA	General Electric Company, "Mark II Containment Supporting Program, Caorso Safety Relief Valve Discharge Tests, Phase I Test Report," NEDE-25100-P, Class III (Proprietary), Revision 0, May 1979, NEDO-25100, Class I (Non-proprietary), Revision 0, August 1979, and NEDO-25100-EA, Class I (Non-proprietary), Revision 0, February 1981.	3B
NEDE-25118	General Electric Company, "Mark II Containment Supporting Program, Caorso Safety Relief Valve Discharge Tests, Phase II Apparent Test Results Report," NEDE-25118, Class III (Proprietary), Revision 0, August 1979.	3B
NEDO-25153	General Electric Company, "Analytical Model for Estimating Drag Forces on Rigid Submerged Structures Caused by Steam Condensation and Chugging, Mark III Containments" NEDO-25153, Class I (Non-proprietary), Revision 0, July 1979.	3B
NEDE-25273	General Electric Co., "Scaling Study of the General Electric Pressure Suppression Test Facility, Mark III Long-Range Program, Task 2.2.1," NEDE-25273, Class III (Proprietary), Revision 0, March 1980.	3B

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDO-25370	General Electric Company, "Anticipated Chemical Behavior of Iodine under LOCA Conditions," NEDO-25370, January 1981.	15.4
NEDE-30640	General Electric Company, "Evaluation of Proposed Modifications to the GESSAR II Design," NEDE-30640, Class III (Proprietary), June 1984.	19.4
NEDO-30832-A	General Electric Company, "Elimination of Limit on BWR Suppression Pool Temperature for SRV Discharge With Quenchers," NEDO-30832-A, Class I (Non-proprietary), Revision 0, May 1995.	3B
NEDC-30851-P-A	NEDC-30851-P-A, "Technical Specification Improvement Analysis for BWR Control Rod Block Instrumentation," October 1988.	Chapter 16 B3.3
NEDE-31152P	GE Nuclear Energy, "GE Fuel Bundle Designs," NEDE-31152P, Revision 8, April 2001.	4.2
NEDC-31336P-A	GE Nuclear Energy, "General Electric Instrument Setpoint Methodology, " Licensing Topical Report NEDC-31336P-A (NRC Accepted), Class III (GE Proprietary), September 1996	7.2
NEDC-31393	General Electric Company, "Containment Horizontal Vent Confirmatory Test, Part I," NEDC-31393, Class III (Proprietary), Revision 0, March 1987.	3B
NEDC-31858P	GE Nuclear Energy, "BWROG Report for Increasing MSIV Leakage Rate Limits and Elimination of Leakage Control Systems," NEDC-31858P (GE proprietary), February 1991.	15.4
NEDO-31897 NEDC-31897P-A	GE Nuclear Energy, "Generic Guidelines For General Electric Boiling Water Reactor Power Uprate," Licensing Topical Report NEDO-31897, Class I (Non-proprietary), February 1992; and NEDC-31897P-A, Class III (Proprietary), May 1992.	1C.2

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDO-31960-A	GE Nuclear Energy, "BWR Owners' Group Long-Term Stability Solutions Licensing Methodology," NEDO-31960-A, November 1995.	4D
NEDO-31984 NEDC-31984P, Supplements 1 and 2	GE Nuclear Energy, "Generic Evaluations For General Electric Boiling Water Reactor Power Uprate," Licensing Topical Report NEDO-31984, Class I (Non-proprietary), March 1992; NEDC-31984P, Class III (Proprietary), July 1991; and Supplements 1 and 2.	1C.2
NEDE-32176P	GE Nuclear Energy, J. G. M. Andersen, et al., "TRACG Model Description," NEDE-32176P, Revision 2, December 1999.	1.5, 1A, 4D
NEDE-32177P	GE Nuclear Energy, J. G. M. Andersen, et al., "TRACG Qualification," NEDE-32177P, Revision 2, January 2000.	1.5, 1A, 4D
NEDE-32178P	GE Nuclear Energy, Licensing Topical Report, "Application of TRACG Model to SBWR Licensing Safety Analysis," NEDE-32178P, Class III (Proprietary), February 1993.	Appendix 1A
NEDC-32288P	"Scaling of the SBWR Related Tests," Class III (GE proprietary), Revision 1, October 1995	1.5
NEDC-32301	MIT and UCB Separate Effects Tests for PCCS Tube Geometry, "Single Tube Condensation Test Program," March 1994	1.5
NEDC-32424P-A NEDO-32424	GE Nuclear Energy, "Generic Guidelines for General Electric Boiling Water Reactor EPU," (ELTR1), Licensing Topical Reports NEDC-32424P-A, Class III (Proprietary), February 1999; and NEDO-32424, Class I (Non-proprietary), April 1995.	1C.2

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDC-32523P-A NEDC-32523P-A, Supplement 1 Volumes I and II	GE Nuclear Energy, “Generic Evaluations of General Electric Boiling Water Reactor EPU,” (ELTR2), Licensing Topical Reports NEDC-32523P-A, Class III (Proprietary), February 2000; NEDC-32523P-A, Supplement 1 Volume I, February 1999; and Supplement 1 Volume II, April 1999.	1C.2
NEDC-32601-P-A	NEDC-32601-P-A, “Methodology and Uncertainties for Safety Limit MCPR Evaluations”, August 1999.	Chapter 16 B2.1.1
NEDC-32606P	“SBWR Testing Summary Report,” Class III (GE proprietary), November 1996	1.5
NEDC-32694-P-A	NEDC-32694-P-A, “Power Distribution Uncertainties for Safety Limit MCPR Evaluations”, August 1999.	Chapter 16 B2.1.1
NEDO-32708	General Electric Co., “Radiological Accident Evaluation - The CONAC04A Code,” NEDO-32708, August 1997.	15.4
NEDC-32725P	GE Nuclear Energy, J. R. Fitch, et al., “TRACG Qualification for SBWR,” NEDC-32725P, Revision 1, Vol. 1 and 2, August 2002	4D
NEDC-32868P	Global Nuclear Fuel, “GE14 Compliance With Amendment 22 of NEDE-24011-P-A (GESTAR II)”, NEDC-32868P, Revision 1, September 2000.	4.3
NEDE-32906P-A NEDO-32906-A	J. G. M. Andersen, et al., “TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analysis,” Class III (GE proprietary), Revision 1, April 2003, Class I (non-proprietary), June 2003	1.5, 4.4, 4D Chapter 16, B2.1.1
NEDE-32906P, Supplement 1-A.	GE Nuclear Energy, F. T. Bolger and M. A. Holmes, “TRACG Application for ATWS Overpressure Transient Analysis,” NEDE-32906P, Supplement 1-A, November 2003.	4D

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDC-32983P-A NEDO-32983-A	GE Nuclear Energy, “GE Methodology to RPV Fast Neutron Flux Evaluations,” Licensing Topical Report NEDC-32983P-A, Class III (Proprietary), August 2000, and NEDO-32983-A, Class I (Non-proprietary), December 2001.	5.3
NEDC-32992P-A	GE Nuclear Energy, J. S. Post and A. K. Chung, “ODYSY Application for Stability Licensing Calculations,” NEDC-32992P-A, July 2001.	4D
NEDO-33004-A NEDC-33004P-A	GE Nuclear Energy, “Licensing Topical Report Constant Pressure Power Uprate,” NEDO-33004-A, Class I (Non-proprietary), July 2003; NEDC-33004P-A, Class III (Proprietary,) July 2003.	1C.2
NEDC-33079P	“ESBWR Test and Analysis Program Description,” Class III (GE proprietary), Revision 1, March 2005	1.5
NEDC-33080P	GE Nuclear Energy, J. R. Fitch, et al., “TRACG Qualification for ESBWR,” NEDC-33080P, Revision 1, May 2005.	4D
NEDC-33081P	“ESBWR Test Report,” Class III (GE proprietary), Revision 1, May 2005	1.5
NEDC-33082P	“ESBWR Scaling Report,” Class III (GE proprietary), December 2002	1.5
NEDC-33083P-A	“TRACG Application for ESBWR,” Class III (GE proprietary), March 2005	1.5, 4D, 6.2, 6.3
NEDC-33083P, Supplement 1	GE Nuclear Energy, B.S.Shiralkar, et al, “TRACG Application for ESBWR Stability Analysis,” NEDC-33083P, Supplement 1, December 2004.	1.5, 4.3, 4D
NEDO-33175	GE Nuclear Energy, “Classification of ESBWR Abnormal Events and Determination of Their Safety Analysis Acceptance Criteria,” NEDO-33175, Revision 2, E&A 2, August 2005.	15.0

Table 1.6-1
Referenced Reports

Report No.	Title	Section No.
NEDO-33181	GE Nuclear Energy, “ESBWR Design and Certification Program Quality Assurance Plan,” NEDO-33181, Revision 1, October 2005.	17.1
NEDC-33201P	GE Nuclear Energy, “ESBWR Design Certification Probabilistic Risk Assessment,” NEDC-33201P, September 2005.	19
NEDO-33217	GE Nuclear Energy, “Man Machine Interface System and Human Factors Engineering Implementation Plan,” October 2005.	18.1, 18E

Note: Table 1.6-1 has not yet been fully updated based on Revision 1 of all chapters.

1.7 DRAWINGS AND OTHER DETAILED INFORMATION

This Design Control Document Tier 2 does not directly provide proprietary or safeguards information because a DCD is available to the public. For example, detailed proprietary design drawings are not included. As needed, proprietary and safeguards information are referenced and supplied separately. This DCD constitutes requirements that a site-specific plant design shall meet. Therefore, the design/safety features and functions shown on the design related drawings provided herein are required to be included in the site-specific design drawings. For example, a system's site-specific piping and instrumentation diagram (P&ID) is required to provide all the features shown on that system's DCD Tier 2 simplified P&ID.

1.7.1 Electrical, Instrumentation and Control Drawings

Where appropriate, non-proprietary (simplified, as needed) electrical, instrumentation and control drawings are provided within this DCD Tier 2. These drawings provide design information or show how the subject systems and components perform their associated safety function(s).

1.7.2 Piping and Instrumentation Diagrams

The extensive level of detail in a fully engineered P&ID can provide far more information than is needed to demonstrate safety. This high level of detail would not clearly highlight the safety aspects of the system and thus can make it more difficult to understand the basic functions of the system. Where appropriate, simplified P&IDs are provided throughout this DCD Tier 2. These P&IDs provide needed design information or demonstrate how the subject systems and components perform their associated safety function(s).

1.7.3 Other Detailed Information

Where appropriate, simplified site buildings and individual structure drawings are provided within this DCD Tier 2. These drawings provide needed layout/design information or demonstrate how the site or subject structure performs its associated safety function(s).

Other detailed information is provided by reference in the applicable Tier 2 locations.

Table 1.7-1 lists the standard piping designations and specifications used in the DCD Tier 2 drawings.

Table 1.7-1
Piping Designations and Specifications for DCD Drawings

Standard Line Designation	Service	Operating Fluid Temperature Range	Primary Rating	Material
AA	Condensate / Reactor Water	-30 to 260°C (-20 to 500°F)	150 LB	Carbon Steel
AB	Condensate / Reactor Water	-30 to 260°C (-20 to 500°F)	150 LB	Stainless Steel
AC	Steam	up to 260°C (500°F)	150 LB	Carbon Steel
AD **	Service Water	5 to 40°C (40 to 105°F)	150 LB	Carbon Steel
AE	Radwaste	-30 to 260°C (-20 to 500°F)	150 LB	Carbon Steel
AF	Radwaste	-30 to 260°C (-20 to 500°F)	150 LB	Stainless Steel
AG	Demineralized Water	See note *	150 LB	Aluminum
AH	Steam Condensate	up to 260°C (500°F)	150 LB	Carbon Steel
AL	Fuel Oil	-30 to 260°C (-20 to 500°F)	150 LB	Carbon Steel
AM	Instrument Air	10 to 46°C (50 to 115°F)	150 LB	Stainless Steel
AN	Gaseous Nitrogen	10 to 177°C (50 to 350°F)	150 LB	Stainless Steel
AO	Gaseous Nitrogen	10 to 120°C (50 to 250°F)	150 LB	Stainless Steel
AP	Component Cooling Water	10 to 60°C (50 to 140°F)	150 LB	Carbon Steel
AQ	Demineralized Water	10 to 60°C (50 to 140°F)	150 LB	Stainless Steel
AR	Equipment/ Floor Drains	10 to 60°C (50 to 140°F)	150 LB	Stainless Steel
AS	Service Air	10 to 46°C (50 to 115°F)	150 LB	Stainless Steel
AT	Fire Water	0 to 38°C (32 to 100°F)	150 LB	HDPE
AU	Fire Water	0 to 38°C (32 to 100°F)	150 LB	Carbon Steel

Table 1.7-1

Piping Designations and Specifications for DCD Drawings

Standard Line Designation	Service	Operating Fluid Temperature Range	Primary Rating	Material
AV	Fire Water	0 to 38°C (32 to 100°F)	150 LB	Galvanized Steel
AW	Fire Water	0 to 38°C (32 to 100°F)	150 LB	Stainless Steel
BA	Condensate / Reactor Water	-30 to 260°C (-20 to 500°F)	300 LB	Carbon Steel
BB	Condensate / Reactor Water	-30 to 260°C (-20 to 500°F)	300 LB	Stainless Steel
BC	Steam	up to 260°C (500°F)	300 LB	Carbon Steel
BD	Service Water	-30 to 260°C (-20 to 500°F)	300 LB	Carbon Steel
BE	Steam Condensate	up to 260°C (500°F)	300 LB	Carbon Steel
BF	Offgas	-30 to 260°C (-20 to 500°F)	300 LB	Carbon Steel
BG	Liquid Nitrogen	-196 to 65.5°C (-320 to 150°F)	300 LB	Stainless Steel
BH	Gaseous Nitrogen	10 to 120°C (50 to 250°F)	300 LB	Stainless Steel
DA	Condensate / Reactor Water	-30 to 345°C (-20 to 650°F)	600 LB	Carbon Steel
DB	Condensate / Reactor Water	-30 to 345°C (-20 to 650°F)	600 LB	Stainless Steel
DC	Steam	up to 345°C (650°F)	600 LB	Carbon Steel
DD	Offgas	-30 to 260°C (-20 to 500°F)	600 LB	Carbon Steel
DE	Offgas	-45 to 120°C (-50 to 250°F)	600 LB	Carbon Steel
DF	Offgas	-30 to 260°C (-20 to 500°F)	600 LB	Stainless Steel
DG	Gaseous Nitrogen	10 to 120°C (50 to 250°F)	600 LB	Stainless Steel

Table 1.7-1
Piping Designations and Specifications for DCD Drawings

Standard Line Designation	Service	Operating Fluid Temperature Range	Primary Rating	Material
EA	Condensate / Reactor Water	-30 to 345°C (-20 to 650°F)	900 LB	Carbon Steel
EB	Condensate / Reactor Water	-30 to 345°C (-20 to 650°F)	900 LB	Stainless Steel
EC	Steam	up to 345°C (650°F)	900 LB	Carbon Steel
ED	Boiler Feedwater	up to 345°C (650°F)	900 LB	Carbon Steel
EF	Boiler Feedwater	up to 345°C (650°F)	900 LB	Low Alloy Steel
FA	Offgas	-30 to 260°C (-20 to 500°F)	1500 LB	Low Alloy Steel
FB	Offgas	-30 to 480°C (-20 to 900°F)	1500 LB	Low Alloy Steel
FC	Condensate / Reactor Water	up to 65°C (up to 150°F)	1500 LB	Carbon Steel
FD	Condensate / Reactor Water, Liquid and Gaseous Nitrogen, Boron Solution	-196 to 260°C (-320 to 500°F)	1500 LB	Stainless Steel
FE	Feedwater System	up to 240°C (464°F)	1500 LB	Carbon Steel
GA	Offgas	-30 to 480°C (-20 to 900°F)	2500 LB	Low Alloy Steel
GB	Gaseous Nitrogen	10 to 120°C (50 to 250°F)	2500 LB	Stainless Steel

Notes:

- * Under special requirements and as part of a module
- ** Plant Service Water System requires carbon steel for fresh water applications. Sites taking service water from a brackish water source will require alternate alloy materials (e.g., SB804 pipe with titanium heat exchangers).

1.8 INTERFACES FOR STANDARD DESIGNS

This section is based on SRP 1.8 and Regulatory Guide 1.70 Appendix A, to provide the interfaces for those portions of the plant for which this DCD does not seek certification.

1.8.1 Identification of NSSS Safety-Related Interfaces

Table 1.8-1 cross references the Nuclear Steam Supply System (NSSS) safety-related systems and supporting interface areas with the matching portions of the plant and the associated Tier 2 section(s)/subsection(s).

There are no interface requirements for which this DCD does not seek certification for any of the safety-related systems.

1.8.2 Identification of BOP Interfaces

Table 1.8-2 cross references the Balance of Plant (BOP) systems and supporting interface areas with the matching portions of the plant and the associated Tier 2 section(s)/subsection(s). Except for post-accident main control room atmosphere control, the ESBWR has no safety-related BOP system, i.e., all service/cooling/makeup water and all other HVAC systems are nonsafety-related. Therefore, it is not the intent of Table 1.8-2 to address all of the BOP systems, but Table 1.8-2 does address the major BOP systems.

Conceptual designs for the following systems are included in the DCD for the purposes of allowing the NRC to evaluate the overall acceptability of the design. However, the final details of these conceptual designs are subject to change due to site-specific conditions.

1.8.2.1 *Circulating Water System (CIRC)*

The circulating water system includes those portions outside the Turbine Building walls as well as the specific design interfaces with the main condenser. The circulating water system is designed to remove heat from the main condenser and transport it to the atmosphere. A conceptual design utilizing two natural-draft cooling towers is presented in Section 10.4.

1.8.2.2 *Plant Service Water System (PSWS)*

The Plant Service Water System, designed to remove heat from the Reactor and Turbine Component Cooling Water Systems (RCCWS and TCCWS), is provided. The conceptual design consists of two trains and utilizes two forced-draft cooling towers. PSWS is discussed in Subsection 9.2.1.

1.8.2.3 *Off-site Electrical Power*

The offsite power transmission system is not included as part of the standard design. A conceptual design is presented and discussed in Sections 8.1 and 8.2.

1.8.2.4 *Makeup Water System (MWS)*

The Makeup Water System (MWS) provides for the production and distribution of demineralized water. The demineralized water portion of the MWS is a site-specific design element. The MWS conceptual design is discussed in Subsection 9.2.3.

1.8.2.5 Potable and Sanitary Water

Potable and Sanitary Water systems are outside the scope of the certified design. It is assumed that the COL applicant will provide overall facilities for distribution and collection of potable and sanitary water (Subsection 9.2.4).

1.8.2.6 Communications Systems

The communications systems of the ESBWR are described in Subsection 9.5.2. Interfaces with the local telecommunications provider are assumed. In addition, communication links between the on-site nonsafety-related Non-Essential Distributed Control and Information System (NE-DCIS) and other on-site and offsite facilities such as the Technical Support Center, Emergency Operations Facility and the simulator will be provided after the site-specific details are known.

Table 1.8-1
Matrix of NSSS Interfaces

Interface Areas	Items on Matching Portion of Plant												
	Feedwater System	Main Steam System	Component Cooling Water Systems (nonsafety-related)	Offsite Power System	Onsite AC Power System	Containment	Safety-Related Ventilation System	Radwaste Management	Control Building	DC Power Supply	Reactor Building	Fuel Building	Location(s) in DCD
System Interface Areas (safety-related portions)													
Reactor Pressure Vessel System	X	X				X							5.2, 5.3
Nuclear Boiler System	X	X				X			X	X	X		5.2
Isolation Condenser System		X				X			X	X	X		5.4.6
Control Rod Drive System			X		X	X			X	X	X		4.6
Leak Detection and Isolation System		X				X			X	X	X		7.3.3
Standby Liquid Control System						X			X	X	X		9.3.5
Neutron Monitoring System						X			X	X	X		7.2.2
Essential DCIS		X				X			X	X	X		7.9.1
Reactor Protection System		X				X			X	X	X		7.2
Safety System Logic and Control	X	X				X			X	X	X		7.3.4
Process Radiation Monitoring System		X			X	X			X		X	X	7.5.3
Containment Monitoring System					X	X			X		X		7.5.2
Gravity-Driven Cooling System						X			X	X			6.3.2
Fuel and Auxiliary Pools Cooling System			X		X	X			X	X	X	X	9.1.3
Main Control Room Panels					X		X		X	X			18.4
MCR Equipment Room Panels					X		X		X	X			18.4

Table 1.8-1
Matrix of NSSS Interfaces

Interface Areas	Items on Matching Portion of Plant												
	Feedwater System	Main Steam System	Component Cooling Water Systems (nonsafety-related)	Offsite Power System	Onsite AC Power System	Containment	Safety-Related Ventilation System	Radwaste Management	Control Building	DC Power Supply	Reactor Building	Fuel Building	Location(s) in DCD
Remote Shutdown System	X	X	X		X				X	X	X		7.4.2
Passive Containment Cooling System						X			X		X		6.2.2
Containment Inerting System									X		X		6.2.6
Reactor Water Cleanup / SDC	X		X		X	X		X	X	X	X		5.4.8
Suppression Pool Temperature Monitoring Subsystem						X			X	X	X		7.5.5
Onsite AC Power				X									8.3
Supporting Interface Areas													
Flood Protection	X		X						X		X	X	3.4
Missile Protection ¹									X		X	X	3.5
Pipe Whip Protection	X	X											3.6
Mechanical Systems and Components	X	X	X		X	X	X	X	X	X	X	X	3.9
Seismic and Dynamic Qualification of Mechanical and Electrical Equipment	X	X				X	X	X	X	X	X	X	3.10
Environmental Design of Mechanical and Electrical Equip.	X	X				X	X	X	X	X	X	X	3.11
Inservice Inspection of Class 2 and 3 Components	X	X	X										6.6
Fire Protection ²									X		X	X	9.5.1

¹ Protection against turbine missiles is included in DCD Section 3.5.

² IC/PCC pool and spent fuel pool makeup via permanent FAPCS piping connected directly to the site Fire Protection System is included in DCD Appendix 1D.

Table 1.8-2
Matrix of BOP Interfaces

Interface Areas	Items on Matching Portion of Plant												
	Switchyard	(Nonsafety-related) Heat Sinks and Water Supplies	Intake Structure	Inservice Inspection Program	Initial Test Program	10 CFR 50 App. I Program	Meteorology	Seismic Design Parameters	Wind and Tornado Parameters	Geology	Probable Maximum Flood	Other (specify)	Location(s) in DCD
Interface Areas for Structures, Systems and Components (nonsafety-related portions)													
Plant Service Water System		X	X		X								9.2.1
Reactor Component Cooling Water System		X			X								9.2.2
Makeup Water System		X											9.2.3
Condensate Storage and Transfer System		X			X								9.2.6
Chilled Water System		X			X								9.2.7
Turbine Component Cooling Water System		X			X								9.2.8
Circulating Water System		X	X		X								10.4.5
Non-Essential DCIS	X				X								7.9.2
Fire Protection Program					X								9.5.1
Onsite AC Power System	X				X								8.3.1
Compressed Air Systems					X								9.3.1
Process and Post Accident Sampling Systems					X								9.3.2
Equipment and Floor Drain Systems					X								9.3.3
Instrument Air System					X								9.3.6
Service Air System					X								9.3.7

Table 1.8-2
Matrix of BOP Interfaces

Interface Areas	Items on Matching Portion of Plant												
	Switchyard	(Nonsafety-related) Heat Sinks and Water Supplies	Intake Structure	Inservice Inspection Program	Initial Test Program	10 CFR 50 App. I Program	Meteorology	Seismic Design Parameters	Wind and Tornado Parameters	Geology	Probable Maximum Flood	Other (specify)	Location(s) in DCD
High Pressure Nitrogen Supply System					X								9.3.8
Air Conditioning, Heating, Cooling and Ventilation Systems					X								9.4
Liquid Waste Management System		X		X	X	X							11.2
Offgas System				X	X	X							11.3.2
Solid Waste Management System						X							11.4
Effluent Monitoring and Sampling					X	X	X						11.5
Main Condenser System		X	X										10.4.1
Main Condenser Evacuation System					X	X							10.4.2
Process Radiation Monitoring System					X	X							11.5
Feedwater Control System					X								7.7.3
Steam Bypass and Pressure Control System					X								7.7.5
Area Radiation Monitoring System					X								7.5.4
Turbine Bypass System					X								10.4.4
Process and Post Accident Sampling Systems					X								9.3.2

1.9 CONFORMANCE WITH STANDARD REVIEW PLAN AND APPLICABILITY OF CODES AND STANDARDS

1.9.1 Conformance with Standard Review Plan

This subsection provides the information required by 10 CFR 50.34(h) showing conformance with the Standard Review Plan (SRP). The summary of differences from requirements in each SRP section is presented on a section by section basis in Tables 1.9-1 through 1.9-19. If no difference is indicated, the ESBWR design does not deviate from the requirements in the SRP section. (See Subsection 1.9.4.1 for COL information.)

1.9.2 Applicability to Regulatory Criteria

Standard Review Plans, Branch Technical Positions, Regulatory Guides and Industrial Codes and Standards, which are applicable to the ESBWR design, are provided in Tables 1.9-20, 1.9-21 and 1.9-22. Applicable revisions are also shown. The applicability column of Tables 1.9-20 and 1.9-21 refers to whether or not the requirement is applicable during Design Certification of the ESBWR. Standard Review Plans, Branch Technical Positions, and Regulatory Guides that apply only during detailed design, construction, fabrication and erection are indicated by a dash in the applicability column and a comment.

1.9.3 Applicability of Experience Information

Table 1.9-23 lists NUREGs that have been included as references in the ESBWR DCD or that impact the COL applicant. Appendix 1C addresses applicability of US NRC Generic Letters and Bulletins. (See Subsection 1.9.4.2 for COL information.)

1.9.4 COL information

1.9.4.1 SRP Deviations

The SRP sections to be addressed by the COL applicant are indicated in the comments column of Table 1.9-20 as “COL Applicant.” Where applicable the COL applicant will provide the information required by 10 CFR 50.34(h) similar to Tables 1.9-1 through 1.9-19 (see Subsection 1.9.1).

1.9.4.2 Experience Information

The experience information to be addressed by the COL applicant is indicated in the comment column of Table 1.9-23 as “COL Applicant” (see Subsection 1.9.3).

1.9.5 References

- 1.9-1 Electric Power Research Institute, “Advanced Light Water Reactor Utility Requirements Document,” Revision 6, May 1997.
- 1.9-2 GE Nuclear Energy; “GE Nuclear Energy Quality Assurance Program Description,” NEDO-11209-04a, Class I (non-proprietary), Revision 8, March 31, 1989.

Table 1.9-1
Summary of Differences from SRP Section 1

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
1.8		None	

Notes for Tables 1.9-1 through 1.9-19:

- (1) None in column 3 means the ESBWR design does not deviate from the requirements in the indicated SRP Section.
- (2) COL Applicant to provide in column 3 means the topic of the SRP is not applicable to the design certification and will be supplied later by the COL applicant in a SAR submittal.

Table 1.9-2
Summary of Differences from SRP Section 2

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
2.1.1-2.5.3	See Table 2.0-1.	Limits are imposed on selected SRP Section II acceptance criteria by (1) the envelope of the ESBWR Standard Plant site parameters and (2) evaluation assumptions.	2.0
2.5.4	Subsection 2.5.4.9. In meeting the requirements of References 3, 6 and 7, the earthquake design basis analysis is acceptable if a brief summary of the safe shutdown and operating basis earthquakes (SSE and OBE) is presented and references are included to Subsections 2.5.2.6 and 2.5.2.7.	The ESBWR will be based on a single earthquake (SSE) design.	3.7
2.5.5	The secondary source of emergency cooling water should survive the operating basis earthquake (OBE) and design basis flood.	The ESBWR will be based on a single earthquake (SSE) design.	3.7

Table 1.9-3
Summary of Differences from SRP Section 3

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Section/Subsection Where Discussed
3.2.1		None	
3.2.2		None	
3.3.1		None	
3.3.2		None	
3.4.1		None	
3.4.2		None	
3.5.1		None	
3.5.2		None	
3.5.3		None	
3.6.1 and 3.6.2	II—Postulated pipe rupture.	Large bore piping can utilize leak before break option as provided in GDC-4 October 27, 1987, “Modification of General Design Criterion 4.”	3.6 and 3.6.3
3.7.1 and 3.7.3	II- Two earthquakes, the SSE and the OBE shall be considered in the design.	The ESBWR will be based on a single earthquake (SSE) design.	3.7.1 and 3.7.3
3.7.2		None	
3.7.3	II.9—For multiply supported equipment use envelope RS and;	Independent Support Motion Response Spectrum methods acceptable for use.	3.7.3.9
3.7.3	Combine responses from inertia effects with anchor displacements by absolute sum.	Combine responses from inertia effects with anchor displacements by SRSS.	3.7.3.9
3.7.3	II.2 – Determination of number of OBE cycles	The ESBWR is based on a single earthquake (SSE) design, two SSE events with 10 peak stress cycles per event are used.	3.7.3.2
3.7.4		None	

Table 1.9-3
Summary of Differences from SRP Section 3

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Section/Subsection Where Discussed
3.8.1		None	
3.8.2		None	
3.8.3		None	
3.8.4		None	
3.8.5		None	
3.9.1		None	
3.9.2		None	
3.9.3		None	
3.9.4		None	
3.9.5		None	
3.9.6		None	
3.10		None	
3.11		None	

Table 1.9-4
Summary of Differences from SRP Section 4

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
4.2		None	
4.3		None	
4.4	II.3.b – NEDO-31960 as basis for stability methodology.	Stability methodology based on TRACG ESBWR Stability LTR, NEDE-33083, Supplement 1.	4.4
4.5.1		None	
4.5.2		None	
4.6		None	

Table 1.9-5
Summary of Differences from SRP Section 5

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
5.2.1.1		None	
5.2.1.2		None	
5.2.2		None	
5.2.3	II.3.b.(3)—Reg Guide 1.71, Welding Qualification for Areas of Limited Accessibility.	Alternate position employed.	5.2.3.4
5.2.4	II.1—Inspection of Class 1 pressure-containing components.	Some welds inaccessible for volumetric examination.	5.2.4.2
5.2.5		None	
5.3.1		None	
5.3.2		None	
5.3.3		None	
5.4.1.1		Not applicable to the ESBWR	
5.4.2.1		Not applicable to the ESBWR	
5.4.2.2		Not applicable to the ESBWR	
5.4.6		Not applicable to the ESBWR	
5.4.7	Except of RCPB portions for structural integrity, none of the criteria apply.	No safety-related RHR system, the ESBWR uses a nonsafety-related RWCU/SDC system	
5.4.8		None	
5.4.11		Not applicable to the ESBWR	
5.4.12		None	

Table 1.9-6
Summary of Differences from SRP Section 6

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
6.1.1		None	
6.1.2	A coating system to be applied inside a containment is acceptable if it meets the regulatory positions of Regulatory Guide 1.54 and the standards of ASTM D3842 and ASTM D3911	Due to impracticability of using these special coatings on all equipment, exception is made on small-size equipment where, in case of a LOCA, the paint debris is not a safety hazard. Exceptions include such items as electronic/electrical trim, covers, face plates and valve handles.	6.1.2.1
6.2.1	Listed in acceptance criteria of 6.2.1.1.C, 6.2.1.2, 6.2.1.3 and 6.2.1.4	Not applicable	
6.2.1.1C	Design provision for automatic actuation of wetwell spray 10 minutes following a LOCA signal	The ESBWR does not need wetwell sprays	6.2.1.1
6.2.1.1C	Monthly vacuum valve operability test	Operability tests only performed during refueling outages	6.2.1.1
6.2.1.2		None	
6.2.1.3	Sources of energy during LOCA	All sources considered, but ESBWR analysis uses different correlations than stated in 10 CFR 50, Appendix K, for decay heat and metal-water reaction rate.	
6.2.1.4		Not applicable to the ESBWR	
6.2.1.5		Not applicable to the ESBWR	

Table 1.9-6
Summary of Differences from SRP Section 6

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
6.2.2	Containment heat removal systems should meet the redundancy and power source requirements for an engineered safety feature; i.e., system should be designed to accommodate a single active failure.	Passive Containment Cooling System is a passive system, therefore single active failure is not applicable. Power is not required for system operation	
6.2.3		None.	
6.2.4	One isolation valve inside and one isolation valve outside containment	ESBWR design takes specific exceptions to GDC 55 and GDC 56, while satisfying the intent. (1) FAPCS suppression pool suction line contains one isolation valve outside containment; (2) ICS piping contains two isolation valves inside containment; and (3) Containment Inerting System piping contains two isolation valves outside containment.	6.2.4.3 9.1.3.7 Tables 6.2-23 to 6.2-30 Tables 6.2-36 to 6.2-38
6.2.4	Purge and vent valve closure times on the order of ≤ 5 seconds may be necessary	Purge and vent valves for ICS will close in ≤ 30 seconds (estimated value to be confirmed during detailed design).	6.2.4.3 plus Tables 6.2-24, 6.2-26, 6.2-28 and 6.2-30
6.2.5	II.4, 5, 6, 7, 8,14	Not Applicable. ESBWR containment is inerted to limit oxygen concentration. Flammability control system is not required per 10 CFR 50.44	6.2.5 and 9.4.9
6.2.6		None	

Table 1.9-6
Summary of Differences from SRP Section 6

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
6.2.7		None	
6.3	The requirements of Task Action Plan Item II.K.3(15) of NUREG-0737 and NUREG-0718, which involves isolation of HPCI and RCIC for BWR plants, must also be satisfied.	Not applicable to the ESBWR. There are no RCIC or HPCI systems in the ESBWR design.	
6.4		None	
6.5.1		Not applicable to the ESBWR	
6.5.2		Not applicable to the ESBWR	
6.5.3		None	
6.5.4		Not applicable to the ESBWR	
6.5.5		Not applicable to the ESBWR. Guidance provided is specific to Mark I, II and III containments and cannot be applied to the ESBWR containment design.	
6.6		None	
6.7		Not applicable to the ESBWR	

Table 1.9-7
Summary of Differences from SRP Section 7

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
7.0		(See below for App. 7.0-A)	
App. 7.0-A	<p>Review Process for Digital Instrumentation and Control Systems, Version 11.0, June 24, 1997</p> <p>Section A: Software development process characteristics: BTP HICB-14, Section 3.1: “All planning documents should be evaluated for the following process characteristics: consistency, style, traceability, unambiguity and verifiability. Each plan should be internally consistent, and the complete set of plans should be mutually consistent.” “It should be possible to verify that the plans have been followed during the software project.”</p>	The approach to Software Management and QA complies with the intent of the SRP and BTP14 but is implemented in a set of acceptable equivalent alternative and mutually consistent plans, which applied in total, comprise the general requirements.	Appendix 7B Software Quality Program for Design and Development of Hardware and Software
7.1, 7.3	10 CFR 50.34(f), TMI Action Items II.K.3.13; II.K.3.15; II.K.3.21; II.K.3.22	Not applicable to the ESBWR design.	7.1.2.2, 7.3.1.2.3
7.1, 7.4, 7.5, 7.6	10 CFR 50.55a(h)	IEEE 279 superseded by IEEE 603	7.1.2.2, 7.4.2.3, 7.5.2.3, 7.5.3.1, 7.6.1.3

Table 1.9-7
Summary of Differences from SRP Section 7

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
7.1, 7.5, 7.9	SRM to SECY 93-087 II.T	Requirements for Class 1E equipment and circuits are not applicable to the ESBWR.	7.1.2.2, 7.5.2.3, 7.5.3.1, 7.9.2.4
7.1	Regulatory Guide 1.22	Some actuators and digital sensors, because of their locations, cannot be fully tested during actual reactor operation.	7.1.2.2
7.1, 7.3	Regulatory Guide 1.75	Alternate positions are described.	7.1.2.2, 7.3.1.1.3, 7.3.1.2.3
7.1, 7.2, 7.3	Regulatory Guide 1.118	Clarifications and testing exceptions are presented.	7.1.2.2, 7.2.1.3, 7.3.1.1.3
7.2, 7.3	BTP HICB-3	The ESBWR has no coolant pump and the BTP Position One does not apply to ESBWR.	7.2.1.3, 7.2.2.3.2, 7.3.1.1.3, 7.3.1.2.3, 7.3.4.3
7.3	BTP-HICB-6	The ESBWR has no recirculation pump and has no active ECCS pumps. Therefore, this BTP is not applicable.	7.3.1.1.3, 7.3.1.2.3, 7.3.4.3
7.3	BTP-HICB-8	DPVs, SRVs and squib valves cannot be tested during reactor operation.	7.3.1.1.3, 7.3.1.2.3
7.2, 7.3, 7.4	BTP HICB-13	Not applicable to the ESBWR design.	7.2.1.3, 7.3.1.2.3, 7.3.4.3, 7.4.4.3
7.4	Regulatory Guide 1.53	Clarification of single failure requirements for RSS.	7.4.2.3
7.6	50.34(f)(2)(v)(I.D.3)	The HP/LP interlock does not have a bypass feature.	7.6.1.3
7.6	GDC 25	The HP/LP interlocks do not involve reactivity control. Thus, GDC 25 is not applicable.	7.6.1.3
7.7, 7.9	Regulatory Guide 1.151	Clarification relative to FWCS, not applicable to SB&PC and NE-DCIS	7.7.3.3, 7.7.5.3, 7.9.2.4
App. 7.1-B		Not applicable to a DCD	

Table 1.9-7**Summary of Differences from SRP Section 7**

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
App. 7.1-C		Editorial, no specific action is involved.	

Table 1.9-8
Summary of Differences from SRP Section 8

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
8.1	GDC 2	None	
8.1	GDC 4	None	
8.1	GDC 5	The ESBWR is a single-unit plant. Therefore, this GDC is not applicable	8.3.1.2.1 Analysis, GDC 5
8.1	GDC 17	None	
8.1	GDC 18	None	
8.1	GDC 50	None	
8.1	RG 1.6	The ESBWR does not need or have safety-related standby AC power sources.	8.3.2 DC Power Systems
8.1	RG 1.9	The ESBWR diesel-generator units are not safety related, nor is AC power needed to achieve safe shutdown.	8.1.6.3
8.1	RG 1.32	Safety-related DC power sources are provided to support passive core cooling and containment integrity safety functions. No offsite or diesel-generator-derived AC power is required for 72 hours.	8.3.2, 8.1.6.3
8.1	RG 1.47	None	
8.1	RG 1.53	None	
8.1	RG 1.63	None	
8.1	RG 1.75	DC light bulbs and fixtures are not seismically qualified, but are seismically supported.	8.3.2.2.2 RGs
8.1	RG 1.81	The ESBWR Standard Plant is designed as a single-unit plant. Therefore this RG is not applicable. (Same as GDC 5)	8.3.1.2.1

Table 1.9-8
Summary of Differences from SRP Section 8

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
8.1	RG 1.106	None	
8.1	RG 1.108	The ESBWR does not need or have safety-related diesel generator units or standby power sources; therefore this Reg Guide 1.108 is not applicable.	N/A
8.1	RG 1.118	None (This is a COL licensing requirement.)	8.3.4.12
8.1	RG 1.128	None	
8.1	RG 1.129	None (This is a COL licensing requirement)	8.3.4.14
8.1	RG 1.153	None	
8.1	RG 1.155	The ESBWR does not require AC power to achieve safe shutdown. Thus ESBWR meets the intent of RG 1.155.	15.5.5, Special Event Evaluations
8.1	RG 1.160	Maintenance Rule development is addressed by the COL applicant.	N/A
8.1	BTP ICSB 4	Not BWR applicable (PWR)	N/A
8.1	BTP ICSB 8	The ESBWR can achieve safe shutdown without AC power, and the diesel-generator sets are not safety-related. Therefore this criterion is not applicable.	N/A
8.1	BTP ICSB 11	This is a COL licensing requirement.	8.3.4.6
8.1	BTP ICSB 18	None	
8.1	BTP ICSB 21	None	
8.1	BTP PSB 1	This is a COL Licensing requirement.	8.3.4.6
8.1	BTP PSB 2	None (This BTP does not apply since the diesel-generator sets do not serve a safety-related function)	N/A

Table 1.9-8
Summary of Differences from SRP Section 8

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
8.1	NUREG/CR-0660	Not applicable, the ESBWR does not use safety-related diesels to achieve safe shutdown.	N/A
8.1	NUREG-0737	(PWR Applicable Only)	N/A
8.1	NUREG-0718, Revision 1	This is a Licensing Requirement for Pending Applications for Construction Permits and Manufacturing License. (TMI Item I.D.3) COL Requirement.	N/A
8.1	TMI Action Item II.E.3.1, Emergency Power Supply for Pressurizer Heater	This item is applicable only to PWRs and does not apply to the ESBWR.	N/A
8.1	TMI Action Item II.G.1, Emergency Power for Pressurizer Equipment	This item is applicable only to PWRs and does not apply to the ESBWR.	N/A

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.1.1		None	
9.1.2		None	
9.1.3	II.1.c – Acceptance criteria for meeting GDC 5.	ESBWR is designed for single unit plant.	
9.1.3	II.1.d, e, f, g and h – Acceptance criteria for meeting GDCs 44, 45, 46, 61 and 63 by the FAPCS safety-related function and components.	ESBWR FAPCS provides nonsafety-related cooling and cleaning functions. Although the FAPCS is not required to meet the requirements of GDCs 44, 45, 46, 61 and 63, it meets the intent of these GDCs.	9.1.3
9.1.4		None	
9.1.5		None	
9.2.1	II.4, II.6	Not Applicable, PSWS is nonsafety-related.	9.2.1
9.2.2	II.4, II.5	Not Applicable, RCCWS is nonsafety-related and ESBWR does not have reactor coolant pumps	9.2.2
9.2.3		None	
9.2.4	II.1, II.2	See Subsection 9.2.9 for COL license information requirements of Potable and Sanitary Water Systems.	9.2.9
9.2.5	II.1 (Reg Guide 1.27 C-1), II.3.d (Reg Guide 1.27) II.3.d (Reg Guide 1.72)	Requirement is to provide 30 day water makeup capability during accident An acceptable external water source will be defined by the COL applicant.	9.2.9

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.2.6	II.1.c	Not Applicable, Condensate Storage Facility is nonsafety-related	
9.3.1		See Sections 9.3.6 (IAS), 9.3.7 (SAS), 9.4.9 (CIS), and 9.3.8 (HPNSS).	9.3.6, 9.3.7, 9.3.8 and 9.4.9
9.3.2		Post Accident Sampling (PAS) has been incorporated into the Containment Monitoring System (CMS).	7.5.2
9.3.3		None	
9.3.4		Not applicable to the ESBWR	
9.3.5		None	
9.4.1		None	
9.4.2		None	
9.4.3		None	
9.4.4		None	
9.4.5		The engineered safety features described in Chapter 6 do not require a separate ventilation system. This section is not applicable to ESBWR.	

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.5.1	Section C.8.1.2.c of BTP SPLB 9.5-1 recommends that automatic suppression capability should be provided in the Control Room Complex as described in Regulatory Guide 1.189. Section 6.1.2 of Regulatory Guide 1.189 states in part: "Peripheral rooms in the control room complex should have automatic water suppression ..."	ESBWR design does not include a sprinkler system in the Control Building offices around the Main Control Room.	9.5.1.12.1.2
9.5.1	Section C.8.1.2.c of BTP SPLB 9.5-1 recommends cable raceways under raised floors should be reviewed to determine if adequate fire detection and suppression are provided for potential fires in these areas. Section 6.1.2.1 of Regulatory Guide 1.189 states in part: "...Fully enclosed electrical raceways located in under-floor and ceiling spaces, if over 0.09 m ² (1 sq ft) in cross-sectional area, should have automatic fire suppression inside."	ESBWR design does not include any fixed fire suppression system in the under-floor area	9.5.1.12.1.3

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.5.1	Section C.7.1.4 of BTP SPLB 9.5-1 recommends that electrical cabinets should be protected as described in Regulatory Guide 1.189. Section 6.1.2.2 of Regulatory Guide 1.189 states in part: "Smoke detectors should be provided in the control room, cabinets, and consoles."	ESBWR design does not include any smoke detectors within cabinets or consoles.	9.5.1.12.1.1

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.5.1	Section C.8.1.4 of BTP SPLB 9.5-1 recommends protecting computer rooms with fire protection systems as described in Regulatory Guide 1.189. Section 6.1.4 of Regulatory Guide 1.189 states in part: "Computer rooms for computers performing functions important to safety that are not part of the control room complex should be separated from other areas of the plant by barriers having a minimum fire resistance rating of 3 hours and should be protected by automatic detection and fixed automatic suppression."	ESBWR design does not include any fixed fire suppression systems for safety-related computer rooms	9.5.1.12.1.6

Table 1.9-9**Summary of Differences from SRP Section 9**

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.5.1	Section C.8.1.8.b of BTP SPLB 9.5-1 recommends that diesel day tanks comply with Regulatory Guide 1.189. Section 6.1.8 of Regulatory Guide 1.189 states in part: "Day tanks with total capacity up to 4164 L (1100 gallons) may be located in the diesel generator area under the following conditions: a. The day tank is located in a separate enclosure with fire resistance rating of at least 3 hours."	ESBWR design will likely include day tanks with a larger capacity than 4164 L (1100 gallons).	9.5.1.12.1.4

Table 1.9-9
Summary of Differences from SRP Section 9

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
9.5.1	Section C.8.1.8.c of BTP SPLB 9.5-1 recommends that impacts of suppression systems on operating generators should be addressed in the fire hazard analysis. Section 6.1.8 of Regulatory Guide 1.189 states in part: "Automatic fire suppression should be installed to suppress or control any diesel generator or lubricating oil fires. Such systems should be designed for operation when the diesel is running without affecting the diesel."	ESBWR design does not place restrictions on sprinkler head position or direction in diesel generator rooms.	9.5.1.12.1.5
9.5.2		None	
9.5.3		None	
9.5.4	All	Not Applicable. See Table 1.9-20. The Standard ESBWR DG and auxiliary systems are not safety-related and have no safety design basis.	9.5.4.1
9.5.5	All	Not Applicable. See Table 1.9-20.	9.5.5.1
9.5.6	All	Not Applicable. See Table 1.9-20.	9.5.6.1
9.5.7	All	Not Applicable. See Table 1.9-20.	9.5.7.1
9.5.8	All	Not Applicable. See Table 1.9-20.	9.5.8.1

Table 1.9-10
Summary of Differences from SRP Section 10

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
10.2	10 CFR Part 50, Appendix A, GDC 4	None	
10.2	RG 1.68	None	
10.2	BTP ASB 3-1	None	
10.2	BTP MEB 3-1	None	
10.2.3	10 CFR Part 50, Appendix A, GDC 4	None	
10.2.3	ASME Boiler and Pressure Vessel Code, Sections III, V, & XI	None	
10.2.3	ASTM E-208, Annual Book of ASTM Standards, Part 31	None	
10.2.3	4ASTM A-370, Annual Book of ASTM Standards, Parts 1,2,3,4, or 31	None	
10.2.3	J. A. Begley and W. A. Logsdon, Scientific Paper 71-1E7-MSLRF-P1, Westinghouse Electric Corp., July 26, 1971.	None	
10.2.3	F. J. Witt and T. R. Mager, ORLN-TM-3894, Oak Ridge Natl. Lab. (1972)	None	
10.3	10 CFR Part 50, Appendix A, GDC 2	None	
10.3	10CFR50, Appendix A, GDC 4	None	
10.3	10CFR50, Appendix A, GDC 5	The ESBWR is a single-unit plant. Therefore this Code is not applicable.	N/A

Table 1.9-10
Summary of Differences from SRP Section 10

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
10.3	10CFR50, Appendix A, GDC 34	GDC 34 pertains to PWR plants. This is not applicable to the ESBWR design.	N/A
10.3	RG 1.26	None	
10.3	RG 1.29	None	
10.3	RG 1.115	None	
10.3	RG 1.117	None	
10.3	BTP ASB 3-1	None	
10.3	BTP RSB 3-1	None	
10.3	BTP RSB 3-2	None	
10.3	BTP RSB 5-1	None	
10.3	NUREG 0138	PWR only, not applicable to ESBWR	
10.3.6	10CFR50, Appendix A, GDC 1	None	
10.3.6	ASME B&PV Code, Sect. III, subsection NB, NC, & ND & Appendix I, Sect. II, Parts A, B, & C: & Sect. IX; ASME	None	
10.3.6	SRP Sect. 5.4.2.1	This is applicable only to PWR plants with Steam Generators, not the ESBWR Plant.	N/A
10.3.6	SRP Sect. 5.2.3	None	
10.3.6	RG 1.85	None	
10.3.6	RG 1.71	None	
10.3.6	RG 1.37	None	
10.3.6	ANSI Standard N 45.2.2-1973	None	
10.3.6	10CFR50, 50.55a, "Codes & Standards"	None	

Table 1.9-10**Summary of Differences from SRP Section 10**

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
10.3.6	10CFR50, Appendix A, General Design Criteria 35, "Emergency Core Cooling."	None	
10.3.6	10CFR50, Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants."	None	
10.4.1	10CFR50, Appendix A, "Control of Releases of Radioactive Materials to the Environment."	None	
10.4.1	RG 1.68	None	
10.4.2	10CFR50, Appendix A, GDC 60, and GDC 64, "Monitoring Radioactive Releases."	None	
10.4.2	"Standards for Steam Surface Condensers," 6 th Ed., Heat Exchanger Institute (1970).	None	
10.4.2	RG 1.26	None	
10.4.2	RG 1.33	"Quality Assurance Program Requirements (Operation)" is a COL responsibility, not applicable for this DCD review.	N/A
10.4.2	RG 1.123	None	
10.4.3	10CFR50, Appendix A, GDC 60 and GDC 64.	None	
10.4.3	RG 1.26	None	

Table 1.9-10
Summary of Differences from SRP Section 10

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
10.4.3	RG 1.33	See 10.4.2, COL responsibility.	N/A
10.4.3	RG 1.123	None	
10.4.4	10CFR50, Appendix A, GDC 4	None	
10.4.4	10CFR50, Appendix A, GDC 34, "Residual Heat Removal"	None	
10.4.4	RG 1.68	None	
10.4.4	BTP ASB 3-1	None	
10.4.4	BTP MEB 3-1	None	
10.4.5	10CFR50, GDC 4	None	
10.4.6	10CFR50, Appendix A, GDC 14	None	
10.4.6	RG 1.56	None	
10.4.6	BTP ASB 3-1	None	
10.4.6	BTP MTEB 5-3	This is a PWR requirement, not applicable to the ESBWR design.	N/A
10.4.7	10CFR50, App A, GDC 2	None	
10.4.7	10CFR50, App A, GDC 4	None	
10.4.7	10CFR50, App A, GDC 5	The ESBWR Standard Design is a single unit plant and therefore will not share Structures, Systems, and Components.	N/A
10.4.7	10CFR50, App A, GDC 44	None	
10.4.7	10CFR50, App A, GDC 45	None	
10.4.7	10CFR50, App A, GDC 46	None	
10.4.7	RG 1.29	None	

Table 1.9-10
Summary of Differences from SRP Section 10

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
10.4.7	BTP ASB 10.2	This is a PWR requirement, not applicable to the ESBWR design.	N/A
10.4.8 (PWR)	N/A	This SRP is only applicable to PWR plants.	N/A
10.4.9 (PWR)	N/A	This SRP is only applicable to PWR plants.	N/A

Table 1.9-11
Summary of Differences from SRP Section 11

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
11.1	II.9—BWR GALE Code	Alternate computer code.	
11.2		None	
11.3	II.A.7—Potential Releases	1) Activity from charcoal tanks not included in final release tabulations 2) Total Flow is evaluated for 1 hour, not 2 hours	11.3.7.1
11.4	On site storage facility	COL Applicant to Supply. (On site storage facility is a separate building from Radwaste Building)	11.4
11.5		None	

Table 1.9-12
Summary of Differences from SRP Section 12

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
12.1		None	
12.2		None	
12.3 - 12.4		None	
12.5		None	

Table 1.9-13
Summary of Differences from SRP Section 13

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
13.1.1		Not applicable to a DCD*	
13.1.2 - 13.1.3		Not applicable to a DCD*	
13.2		Not applicable to a DCD*	
13.2.1		Not applicable to a DCD*	
13.2.2		Not applicable to a DCD*	
13.3		Not applicable to a DCD*	
13.4		Not applicable to a DCD*	
13.5		Not applicable to a DCD*	
13.5.1		Not applicable to a DCD*	
13.5.2		Not applicable to a DCD*	
13.6		Not applicable to a DCD*	

* To be supplied the COL applicant.

Table 1.9-14
Summary of Differences from SRP Section 14

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
14.2		None	

Table 1.9-15
Summary of Differences from SRP Section 15

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
15.0.1			
15.0.2		None.	
15.1.1 – 15.1.4		ESBWR does not follow order of events in SRP	
15.1.1 – 15.1.4 and others	II.D Criteria 2 – Requires critical power ratio (CPR) to remain above MCPR safety limit for incidents of moderate frequency	ESBWR is licensed to the fraction of rods in transition boiling instead of to a CPR safety limit. See discussion under (c) of the Technical Rationale for this SRP.	15.2
15.1.1 – 15.1.4	II.D.6.b – Specifies a 0.8 multiplier on the reactivity insertion rate.	ESBWR applies an approved TRACG statistical uncertainty for control rod reactivity, and a conservative, Technical Specification rod motion specification.	15.2, 15.3, 5.2
15.1.5		Not applicable to the ESBWR	
15.2.1 – 15.2.5		ESBWR does not follow order of events in SRP	
15.2.6		ESBWR does not follow order of events in SRP	
15.2.7		ESBWR does not follow order of events in SRP	
15.2.8	Any activity release must be such that the calculated doses at the site boundary are a small fraction of the 10 CFR Part 100 guidelines.	Dose acceptance criterion of 25 mSv (2.5 rem) Total Effective Dose Equivalent (TEDE) used.	15.0.2.3, 15.4.7.5.5, 15.4.9.5.5
15.3.1 - 15.3.2		Not applicable to the ESBWR	

Table 1.9-15
Summary of Differences from SRP Section 15

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
15.3.3 - 15.3.4		Not applicable to the ESBWR	
15.4.1		ESBWR does not follow order of events in SRP	
15.4.2		ESBWR does not follow order of events in SRP	
15.4.3		ESBWR does not follow order of events in SRP	
15.4.4 - 15.4.5		Not applicable to the ESBWR	
15.4.6		Not applicable to the ESBWR	
15.4.7		ESBWR does not follow order of events in SRP	
15.4.8		Not applicable to the ESBWR	
15.4.9		Not applicable to the ESBWR. Discussion is provided to show this event cannot occur with ESBWR FMCRD design.	15.4.6
15.5.1 - 15.5.2		Not applicable to the ESBWR	
15.6.1		ESBWR does not follow order of events in SRP	
15.6.2	Doses at exclusion area and low population zone boundaries are less than 300 mSv (30 rem) for the thyroid and 25 mSv (2.5 rem) for the whole-body doses.	Dose acceptance criterion of 25 mSv (2.5 rem) Total Effective Dose Equivalent (TEDE) used.	15.0.2.3, 15.4.8.5.3
15.6.3		Not applicable to the ESBWR	
15.6.4		ESBWR does not follow order of events in SRP. Radiological analysis assumptions superseded by SRP 15.0.1.	

Table 1.9-15**Summary of Differences from SRP Section 15**

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
15.6.5		ESBWR does not follow order of events in SRP. Radiological analysis assumptions superseded by SRP 15.0.1.	
15.7.1		SRP deleted	
15.7.2		SRP deleted	
15.7.3		ESBWR does not follow order of events in SRP	
15.7.4		ESBWR does not follow order of events in SRP. Radiological analysis assumptions superseded by SRP 15.0.1.	
15.7.5	Doses at exclusion area and low population zone boundaries are less than 750 mSv (75 rem) for the thyroid and 60 mSv (6 rem) for the whole-body doses.	Dose acceptance criterion of 63 mSv (6.3 rem) Total Effective Dose Equivalent (TEDE) used.	15.0.2.3, 15.3.17.2
15.8		ESBWR does not follow order of events in SRP	

Table 1.9-16
Summary of Differences from SRP Section 16

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
16.0	NUREG-0123	ESBWR is based on NUREG-1433 and NUREG-1434	Chapter 16

Table 1.9-17
Summary of Differences from SRP Section 17

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
17.1	II.1 – Applicant is responsible for overall QA program	GE and its ESBWR Team Members are responsible for their own QA programs.	17.1.1, 17.1.2
17.1	II.3, 10, 11 and 13 – Meet identified quality-related Regulatory Guides	Alternate positions employed for specific Regulatory Guides.	17.1.3, 17.1.10, 17.1.11, 17.1.13
17.2		Not applicable to a DCD	
17.3		Not applicable to a DCD	

Table 1.9-18
Summary of Differences from SRP Section 18

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
18.0	18.0, Revision 1		
18.1		As discussed in SRP 18.0, Revision 1, because technology is continually advancing, details of the HFE design need not be complete before the NRC issuance of a design certification. As such, this presentation under 10 CFR Part 52 primarily focuses on the HFE design process.	
18.2		None	
18.3		None	
18.4		None	
18.5		None	
18.6		None	
18.7		None	
18.8		None	
Appendix A		None	
Appendix B		None	
Appendix C		None	
Appendix D		None	
Appendix E		None	
Appendices F and H		The inventory and supporting analysis of emergency operation information and controls specific to ESBWR will be developed in COL and captured in Appendices F and H, as well as in the HFE Issues Tracking System.	
Appendix G		None	

Table 1.9-19
Summary of Differences from SRP Section 19

SRP Section	Specific SRP Acceptance Criteria	Summary Description of Difference	Subsection Where Discussed
19.0		Not applicable to ESBWR.	
19.1		Not applicable to ESBWR.	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
<u>Chapter 1 Introduction and General Description of Plant</u>					
1.8	Interfaces for Standard Designs	2	Draft 04/1996	Yes	
<u>Chapter 2 Site Characteristics</u>					
2.1.1	Site Location and Description	2	07/1981	—	BSP (see notes)
2.1.2	Exclusion Area Authority and Control	2	07/1981	—	BSP
2.1.3	Population Distribution	2	07/1981	—	BSP
2.2.1– 2.2.2	Identification of Potential Hazards in Site Vicinity	2	07/1981	—	BSP
2.2.3	Evaluation of Potential Accidents	2	07/1981	—	BSP
2.3.1	Regional Climatology	2	07/1981	—	BSP
2.3.2	Local Meteorology	2	07/1981	—	BSP
2.3.3	Onsite Meteorological Measurements Programs	2	07/1981	—	BSP
	Appendix A	2	07/1981	—	BSP
2.3.4	Short-Term Diffusion Estimates for Accidental Atmospheric Releases	1	07/1981	—	BSP
2.3.5	Long-Term Diffusion Estimates	2	07/1981	—	BSP
2.4.1	Hydrologic Description	2	07/1981	—	BSP
	Appendix A	2	07/1981	—	BSP
2.4.2	Floods	3	04/1989	—	BSP
2.4.3	Probable Maximum Flood (PMF) on Streams and Rivers	3	04/1989	—	BSP
2.4.4	Potential Dam Failures	2	07/1981	—	BSP
2.4.5	Probable Maximum Surge and Seiche Flooding	2	07/1981	—	BSP
2.4.6	Probable Maximum Tsunami Flooding	2	07/1981	—	BSP
2.4.7	Ice Effects	2	07/1981	—	BSP

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
2.4.8	Cooling Water Canals and Reservoirs	2	07/1981	—	BSP
2.4.9	Channel Diversions	2	07/1981	—	BSP
2.4.10	Flood Protection Requirements	2	07/1981	—	BSP
2.4.11	Cooling Water Supply	2	07/1981	—	BSP
2.4.12	Groundwater	2	07/1981	—	BSP
	BTP HGEB 1	2	07/1981	—	BSP
2.4.13	Accidental Releases of Liquid Effluents in Ground and Surface Waters	2	07/1981	—	BSP
2.4.14	Technical Specifications and Emergency Operation Requirements	2	07/1981	—	BSP
2.5.1	Basic Geologic and Seismic Information	3	03/1997	—	BSP
2.5.2	Vibratory Ground Motion	3	03/1997	—	BSP
2.5.3	Surface Faulting	3	03/1997	—	BSP
2.5.4	Stability of Subsurface Materials and Foundations	2	07/1981	—	BSP
2.5.5	Stability of Slopes	2	07/1981	—	BSP
<u>Chapter 3 Design of Structures, Components, Equipment, and Systems</u>					
3.2.1	Seismic Classification	1	07/1981	Yes	
3.2.2	System Quality Group Classification	1	07/1981	Yes	
	Appendix A (Formerly BTP RSB 3-1)	1	07/1981	Yes	
	Appendix B (Formerly BTP RSB 3-2)	1	07/1981	Yes	
	Appendix C	1	07/1981	No	PWR Only
	Appendix D	1	07/1981	—	Never issued
3.3.1	Wind Loadings	2	07/1981	Yes	
3.3.2	Tornado Loadings	2	07/1981	Yes	
3.4.1	Flood Protection	2	07/1981	Yes	
3.4.2	Analysis Procedures	2	07/1981	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli- cable?	Comments
3.5.1.1	Internally Generated Missiles (Outside Containment)	2	07/1981	Yes	
3.5.1.2	Internally Generated Missiles (Inside Containment)	2	07/1981	Yes	
3.5.1.3	Turbine Missiles	2	07/1981	Yes	
3.5.1.4	Missiles Generated by Natural Phenomena	2	07/1981	Yes	
	BTP ASB 3-2	2	07/1981	—	Superseded by RG 1.117
3.5.1.5	Site Proximity Missiles (Except Aircraft)	1	07/1981	Yes	
3.5.1.6	Aircraft Hazards	2	07/1981	Yes	
3.5.2	Structures, Systems, and Components to be Protected from Externally Generated Missiles	2	07/1981	Yes	
3.5.3	Barrier Design Procedures	1	07/1981	Yes	
	Appendix A	0	07/1981	Yes	
3.6.1	Plant Design for Protection Against Postulated Piping Failures in Fluid Systems Outside Containment	3	Draft 04/1996	Yes	
	BTP SPLB-3-1	3	Draft 04/1996	Yes	
	Appendix A to SPLB 3-1	3	Draft 04/1996	Yes	
	Appendix B to SPLB 3-1	3	Draft 04/1996	Yes	
	Appendix C to SPLB 3-1	3	Draft 04/1996	Yes	
3.6.2	Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping	2	Draft 04/1996	Yes	
	BTP EMEB-3-1	2	Draft 04/1996	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
3.6.3	Leak-Before-Break Evaluation Procedures	0	Draft 03/1987	—	Not credited. Option available for possible future use during COL
3.7.1	Seismic Design Parameters	2	08/1989	Yes	
	Appendix A	0	08/1989	Yes	
3.7.2	Seismic System Analysis	2	08/1989	Yes	
	Appendix A	0	08/1989	Yes	
3.7.3	Seismic Subsystem Analysis	2	08/1989	Yes	
3.7.4	Seismic Instrumentation	1	07/1981	Yes	
3.8.1	Concrete Containment	1	07/1981	Yes	
	Appendix	0	07/1981	Yes	
3.8.2	Steel Containment	1	07/1981	Yes	applies only to Drywell Head
3.8.3	Concrete and Steel Internal Structures of Steel or Concrete Containments	1	07/1981	Yes	
3.8.4	Other Seismic Category I Structures	1	07/1981	Yes	
	Appendix A	0	07/1981	Yes	
	Appendix B	0	07/1981	Yes	
	Appendix C	0	07/1981	Yes	
	Appendix D	0	07/1981	Yes	
3.8.5	Foundations	1	07/1981	Yes	
3.9.1	Special Topics for Mechanical Components	3	Draft 04/1996	Yes	
3.9.2	Dynamic Testing and Analysis of Systems, Components, and Equipment	3	Draft 04/1996	Yes	
3.9.3	ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures	2	Draft 04/1996	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	Appendix A	1	04/1984	Yes	
3.9.4	Control Rod Drive Systems	2	04/1984	Yes	
3.9.5	Reactor Pressure Vessel Internals	3	Draft 04/1996	Yes	
3.9.6	Inservice Testing of Pumps and Valves	3	Draft 04/1996	Yes	
3.9.7	Risk-Informed Inservice Testing	0	08/1998	—	COL
3.9.8	Review of Risk-Informed Inservice Inspection of Piping	0	09/2003	—	COL
3.10	Seismic and Dynamic Qualification of Mechanical and Electrical Equipment	3	Draft 04/1996	Yes	
3.11	Environmental Qualification of Mechanical and Electrical Equipment	3	Draft 04/1996	Yes	
<u>Chapter 4 Reactor</u>					
4.2	Fuel System Design	3	Draft 04/1996	Yes	
	Appendix A	3	Draft 04/1996	Yes	
4.3	Nuclear Design	3	Draft 04/1996	Yes	
	BTP CPB 4.3-1	3	Draft 04/1996	No	PWR Only.
4.4	Thermal and Hydraulic Design	2	Draft 04/1996	Yes	
	Appendix	1	07/1981	—	Deleted
4.5.1	Control Rod Drive Structural Materials	3	Draft 04/1996	Yes	
4.5.2	Reactor Internal and Core Support Materials	3	Draft 04/1996	Yes	
4.6	Functional Design of Control Rod Drive System	2	Draft 04/1996	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
<u>Chapter 5 Reactor Coolant System and Connected Systems</u>					
5.2.1.1	Compliance with the Codes and Standard Rule, 10 CFR 50.55a	3	Draft 04/1996	Yes	
5.2.1.2	Applicable Code Cases	2	07/1981	Yes	
5.2.2	Overpressure Protection	3	Draft 04/1996	Yes	
	BTP RSB 5-2	3	Draft 04/1996	No	PWR only
5.2.3	Reactor Coolant Pressure Boundary Materials	3	Draft 04/1996	Yes	
	BTP MTEB 5-7	2	07/1981	—	Superseded by NUREG-0313
5.2.4	Reactor Coolant Pressure Boundary Inservice Inspection and Testing	2	Draft 04/1996	Yes	
5.2.5	Reactor Coolant Pressure Boundary Leakage Detection	1	07/1981	Yes	
5.3.1	Reactor Vessel Materials	2	Draft 04/1996	Yes	
5.3.2	Pressure-Temperature Limits	2	Draft 04/1996	Yes	
	BTP EMCB 5-2	2	Draft 04/1996	Yes	
5.3.3	Reactor Vessel Integrity	2	Draft 04/1996	Yes	
5.4	Preface	1	07/1981	—	Deleted
5.4.1.1	Pump Flywheel Integrity (PWR)	1	07/1981	No	PWR only
5.4.2.1	Steam Generator Materials	2	07/1981	No	PWR only
	BTP MTEB 5-3	2	07/1981	No	PWR only
5.4.2.2	Steam Generator Tube Inservice Inspection	2	Draft 04/1996	No	PWR only.

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
5.4.6	Reactor Core Isolation Cooling System (BWR)	4	Draft 04/1996	Yes	ESBWR uses ICS and CRD cooling water.
5.4.7	Residual Heat Removal (RHR) System	4	Draft 04/1996	Yes	ESBWR uses ICS and RWCU/SDC.
	BTP RSB 5-1	4	Draft 04/1996	Yes	ESBWR uses ICS and RWCU/SDC
5.4.8	Reactor Water Cleanup System (BWR)	3	Draft 04/1996	Yes	
5.4.11	Pressurizer Relief Tank	2	07/1981	No	PWR only
5.4.12	Reactor Coolant System High Point Vents	0	07/1981	Yes	
Chapter 6 Engineered Safety Features					
6.1.1	Engineered Safety Features Materials	2 ¹	Draft 04/1996	Yes	
	BTP MTEB 6-1	2	Draft 04/1996	No	PWR only
6.1.2	Protective Coating Systems (Paints) – Organic Materials	3	Draft 04/1996	Yes	
6.2.1	Containment Functional Design	2	07/1981	Yes	
6.2.1.1.A	PWR Dry Containments, Including Subatmospheric Containments	2	07/1981	No	PWR only
6.2.1.1.B	Ice Condenser Containments	2	07/1981	No	PWR only
6.2.1.1.C	Pressure-Suppression Type BWR Containments	6	08/1984	Yes	
	Appendix A	2	01/1983	Yes	
	Appendix B	0	01/1983	Yes	

¹ Should have been labeled Draft Rev. 3. Replaces Rev. 2 version issued in July 1981.

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
6.2.1.2	Subcompartment Analysis	2	07/1981	Yes	
6.2.1.3	Mass and Energy Release Analysis for Postulated Loss-of-Coolant Accidents	1	07/1981	Yes	
6.2.1.4	Mass and Energy Release Analysis for Postulated Secondary System Pipe Ruptures	1	07/1981	No	PWR only
6.2.1.5	Minimum Containment Pressure Analysis for Emergency Core Cooling System Performance Capability Studies	2	07/1981	No	PWR only
	BTP CSB 6-1	2	07/1981	No	PWR only
6.2.2	Containment Heat Removal Systems	4	10/1985	Yes	
6.2.3	Secondary Containment Functional Design	2	07/1981	Part	Applies to part of Reactor Bldg. Design relies on holdup only.
	BTP CSB 6-3	2	07/1981	Yes	
6.2.4	Containment Isolation System	2	07/1981	Yes	
	BTP CSB 6-4	2	07/1981	Yes	
6.2.5	Combustible Gas Control in Containment	3	Draft 2003	Yes	See also 12/2003 revision to 10 CFR 50.44
	Appendix A	2	07/1981	Yes	
	BTP CSB 6-2	2	07/1981	—	Superseded by Reg. Guide 1.7
6.2.6	Containment Leakage Testing	2	07/1981	Yes	
6.2.7	Fracture Prevention of Containment Pressure Boundary	0	07/1981	Yes	
6.3	Emergency Core Cooling System	3	Draft 04/1996	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	BTP RSB 6-1	3	Draft 04/1996	No	PWR only
6.4	Control Room Habitability Systems	3	Draft 04/1996	Yes	
	Appendix A	3	Draft 04/1996	Yes	
6.5.1	ESF Atmosphere Cleanup Systems	2	07/1981	No	No Standby Gas Treatment
6.5.2	Containment Spray as a Fission Product Cleanup System	2	12/1988	No	Drywell Spray function not credited
6.5.3	Fission Product Control Systems and Structures	2	07/1981	Yes	
6.5.4	Ice Condenser as a Fission Product Cleanup System	3	12/1988	No	PWR only
6.5.5	Pressure Suppression Pools as a Fission Product Cleanup System	0	12/1988	Partial	ESBWR uses different containment design than discussed.
6.6	Inservice Inspection of Class 2 and 3 Components	1	07/1981	Yes	
6.7	Main Steam Isolation Valve Leakage Control System (BWR)	2	07/1981	No	No MSIV LCS
<u>Chapter 7 Instrumentation and Controls</u>					
7.0	Instrumentation and Controls – Overview of Review Process	4	06/1997	Yes	
	Appendix 7.0-A Review Process for Digital Instrumentation and Control Systems	4	06/1997	Yes	
7.1	Instrumentation and Controls – Introduction	4	06/1997	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli- cable?	Comments
	Table 7-1 Acceptance Criteria and Guidelines for Instrumentation and Controls Systems Important to Safety	4	06/1997	Yes	
	Appendix 7.1-A	4	06/1997	Yes	
	Appendix 7.1-B	4	06/1997	Yes	
	Appendix 7.1-C	4	06/1997	Yes	
7.2	Reactor Trip System	4	06/1997	Yes	
7.3	Engineered Safety Features Systems	4	06/1997	Yes	
7.4	Safe Shutdown Systems	4	06/1997	Yes	
7.5	Information Systems Important to Safety	4	06/1997	Yes	
7.6	Interlock Systems Important to Safety	4	06/1997	Yes	
7.7	Control Systems	4	06/1997	Yes	
7.8	Diverse Instrumentation and Control Systems	4	06/1997	Yes	
7.9	Data Communication Systems	4	06/1997	Yes	
	Appendix 7-A Branch Technical Positions (HICB)	4	06/1997	Yes	
HICB-1	Guidance on Isolation of Low-Pressure Systems from the High-Pressure Reactor Coolant System	4	06/1997	Yes	
HICB-2	Guidance on Requirements on Motor-Operated Valves in the Emergency Core Cooling System Accumulator Lines	4	06/1997	No	PWR only
HICB-3	Guidance on Protection System Trip Point Changes for Operation with Reactor Coolant Pumps Out of Service	4	06/1997	No	ESBWR does not use reactor coolant pumps
HICB-4	Guidance on Design Criteria for Auxiliary Feedwater Systems	4	06/1997	No	PWR only
HICB-5	Guidance on Spurious Withdrawals of Single Control Rods in Pressurized Water Reactors	4	06/1997	No	PWR only

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
HICB-6	Guidance on Design of Instrumentation and Controls Provided to Accomplish Changeover from Injection to Recirculation Mode	4	06/1997	No	No recirculation mode for ESBWR
HICB-7	Not used			—	
HICB-8	Guidance on Application of Regulatory Guide 1.22	4	06/1997	Yes	
HICB-9	Guidance on Requirements for Reactor Protection System Anticipatory Trips	4	06/1997	Yes	
HICB-10	Guidance on Application of Regulatory Guide 1.97	4	06/1997	Yes	
HICB-11	Guidance on Application and Qualification of Isolation Devices	4	06/1997	Yes	
HICB-12	Guidance on Establishing and Maintaining Instrument Setpoints	4	06/1997	Yes	
HICB-13	Guidance on Cross-Calibration of Protection System Resistance Temperature Detectors	4	06/1997	No	RTDs are not used in the protection systems of the ESBWR
HICB-14	Guidance on Software Reviews for Digital Computer-Based Instrumentation and Control Systems	4	06/1997	Yes	
HICB-15	Not used			—	
HICB-16	Guidance on the Level of Detail Required for Design Certification Applications Under 10 CFR Part 52	4	06/1997	Yes	
HICB-17	Guidance on Self-Test and Surveillance Test Provisions	4	06/1997	Yes	
HICB-18	Guidance on Use of Programmable Logic Controllers in Digital Computer-Based Instrumentation and Control Systems	4	06/1997	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
HICB-19	Guidance on Evaluation of Defense-in-Depth and Diversity in Digital Computer-Based Instrumentation and Control Systems	4	06/1997	Yes	
HICB-20	Not used			—	
HICB-21	Guidance on Digital Computer Real-Time Performance	4	06/1997	Yes	
	Appendix 7-B General Agenda, Station Site Visits	4	06/1997	—	COL (see notes)
<u>Chapter 8 Electric Power</u>					
8.1	Electric Power-Introduction	3	Draft 04/1996	Yes	
	Table 8-1 Acceptance Criteria and Guidelines for Electric Power Systems	3	Draft 04/1996	Yes	
8.2	Offsite Power System	4	Draft 04/1996	Yes	Interface (see notes).
	Appendix A	4	Draft 04/1996	Yes	Interface.
	Appendix B	4	Draft 04/1996	Yes	
8.3.1	AC Power Systems (Onsite)	3	Draft 04/1996	Yes	
	Appendix	2	07/1981	—	Superseded by BTP PSB-2, which in turn was replaced by IEEE-387
8.3.2	DC Power Systems (Onsite)	3	Draft 04/1996	Yes	
	Appendix 8-A – Branch Technical Positions (PSB)	3	Draft 04/1996	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli- cable?	Comments
	BTP ICSB 2 (PSB)	2	07/1981	—	Deleted. Replaced by IEEE-387
	BTP ICSB 4 (PSB)	3	Draft 04/1996	No	
	BTP ICSB 8 (PSB)	3	Draft 04/1996	Yes	
	BTP ICSB 11 (PSB)	3	Draft 04/1996	Yes	
	BTP ICSB 15 (PSB)	2	07/1981	—	Deleted
	BTP ICSB 17 (PSB)	2	07/1981	—	Superseded by Reg. Guide 1.9
	BTP ICSB 18 (PSB)	3	Draft 04/1996	Yes	
	BTP ICSB 21 (PSB)	3	Draft 04/1996	Yes	
	BTP PSB 1	3	Draft 04/1996	Yes	
	BTP PSB 2	3	Draft 04/1996	Yes	
	Appendix 8-B – General Agenda, Station Site Visits	1	Draft 04/1996	—	COL
<u>Chapter 9 Auxiliary Systems</u>					
9.1.1	New Fuel Storage	3	Draft 04/1996	Yes	
9.1.2	Spent Fuel Storage	4	Draft 04/1996	Yes	
9.1.3	Spent Fuel Pool Cooling and Cleanup System	1	07/1981	Yes	
9.1.4	Light Load Handling System (Related to Refueling)	2	07/1981	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	BTP ASB 9-1	2	07/1981	—	Superseded by NUREG-0554
9.1.5	Overhead Heavy Load Handling Systems	0	07/1981	Yes	
9.2.1	Station Service Water System	5	Draft 04/1996	Yes	
9.2.2	Reactor Auxiliary Cooling Water Systems	3	06/1986	Yes	
9.2.3	Demineralized Water Makeup System	2	07/1981	Yes	
9.2.4	Potable and Sanitary Water Systems	2	07/1981	—	Interface
9.2.5	Ultimate Heat Sink	2	07/1981	—	Interface
	BTP ASB 9-2	2	07/1981	Yes	
9.2.6	Condensate Storage Facilities	2	07/1981	Yes	
9.3.1	Compressed Air System	1	07/1981	Yes	
9.3.2	Process and Post-Accident Sampling Systems	2	07/1981	Yes	
9.3.3	Equipment and Floor Drainage System	2	07/1981	Yes	
9.3.4	Chemical and Volume Control System (PWR) (Including Boron Recovery System)	3	Draft 04/1996	No	PWR only.
9.3.5	Standby Liquid Control System (BWR)	3	Draft 04/1996	Yes	
9.4.1	Control Room Area Ventilation System	2	07/1981	Yes	
9.4.2	Spent Fuel Pool Area Ventilation System	2	07/1981	Yes	
9.4.3	Auxiliary and Radwaste Area Ventilation System	2	07/1981	Yes	
9.4.4	Turbine Area Ventilation System	2	07/1981	Yes	
9.4.5	Engineered Safety Feature Ventilation System	2	07/1981	No	ESF ventilation not required in ESBWR design
9.5.1	Fire Protection Program	4	10/2003	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	BTP SPLB 9.5-1	4	10/2003	Yes	
	Appendix A to BTP SPLB 9.5-1	4	10/2003	No	
	Appendix B to BTP SPLB 9.5-1	4	10/2003	Yes	
	Appendix C to BTP SPLB 9.5-1	4	10/2003	No	
	Appendix D to BTP SPLB 9.5-1	4	10/2003	No	
	Appendix E to BTP SPLB 9.5-1	4	10/2003	No	
9.5.2	Communication Systems	2	07/1981	Yes	
9.5.3	Lighting Systems	2	07/1981	Yes	
9.5.4	Emergency Diesel Engine Fuel Oil Storage and Transfer System	2	07/1981	No	ESBWR Diesels are non-safety
9.5.5	Emergency Diesel Engine Cooling Water System	2	07/1981	No	ESBWR Diesels are non-safety
9.5.6	Emergency Diesel Engine Starting System	2	07/1981	No	ESBWR Diesels are non-safety
9.5.7	Emergency Diesel Engine Lubrication System	2	07/1981	No	ESBWR Diesels are non-safety
9.5.8	Emergency Diesel Engine Combustion Air Intake and Exhaust System	2	07/1981	No	ESBWR Diesels are non-safety
Chapter 10 Steam and Power Conversion System					
10.2	Turbine Generator	2	07/1981	Yes	
10.2.3	Turbine Disk Integrity	1	07/1981	Yes	
10.3	Main Steam Supply System	3	04/1984	Yes	
10.3.6	Steam and Feedwater System Materials	2	07/1981	Yes	
10.4.1	Main Condensers	2	07/1981	Yes	
10.4.2	Main Condenser Evacuation System	2	07/1981	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli- cable?	Comments
10.4.3	Turbine Gland Sealing System	2	07/1981	Yes	
10.4.4	Turbine Bypass System	2	07/1981	Yes	
10.4.5	Circulating Water System	2	07/1981	Yes	
10.4.6	Condensate Cleanup System	2	07/1981	Yes	
10.4.7	Condensate and Feedwater System	3	04/1984	Yes	
	BTP ASB 10-2	3	04/1984	No	PWR only
10.4.8	Steam Generator Blowdown System (PWR)	3	Draft 04/1996	No	PWR only
10.4.9	Auxiliary Feedwater System (PWR)	2	07/1981	No	PWR only
	BTP ASB 10-1	2	07/1981	No	PWR only
<u>Chapter 11 Radioactive Waste Management</u>					
11.1	Source Terms	3	Draft 04/1996	Yes	
11.2	Liquid Waste Management Systems	3	Draft 04/1996	Yes	
11.3	Gaseous Waste Management Systems	3	Draft 04/1996	Yes	
	BTP ETSB 11-5	3	Draft 04/1996	Yes	
11.4	Solid Waste Management Systems	3	Draft 04/1996	Yes	
	BTP ETSB 11-3	3	Draft 04/1996	Yes	
	Appendix 11.4-A	3	Draft 04/1996	Yes	
11.5	Process and Effluent Radiological Monitoring Instrumentation and Sampling Systems	3	07/1981	Yes	
	Appendix 11.5-A	1	07/1981	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
<u>Chapter 12 Radiation Protection</u>					
12.1	Assuring That Occupational Radiation Exposures are As Low As Is Relatively Achievable	2	07/1981	Yes	
12.2	Radiation Sources	3	Draft 04/1996	Yes	
12.3–12.4	Radiation Protection Design Features	3	Draft 04/1996	Yes	
12.5	Operational Radiation Protection Program	3	Draft 04/1996	—	COL
<u>Chapter 13 Conduct of Operations</u>					
13.1.1	Management and Technical Support Organization	4	11/1999	—	COL
13.1.2–13.1.3	Operating Organization	5	07/2005	—	COL
13.2	Training	2	07/1981	—	Replaced by SRP Sections 13.2.1 and 13.2.2
13.2.1	Reactor Operator Training	2	Draft 12/2002	—	COL. Draft for comments.
13.2.2	Training for Non-Licensed Plant Staff	2	Draft 12/2002	—	COL. Draft for comments.
13.3	Emergency Planning	2	07/1981	—	COL
13.4	Operational Review	2	07/1981	—	COL
13.5	Plant Procedures	2	07/1981	—	Replaced by SRP Sections 13.5.1 and 13.5.2
13.5.1	Administration Procedures	0	07/1981	—	COL
13.5.2	Operating and Maintenance Procedures	1	07/1985	—	COL

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	Appendix A	0	07/1985	—	COL
13.5.2.1	Operating and Emergency Operating Procedures	1	Draft 12/2002		Draft for comments
13.6	Physical Security	2	07/1981	Yes	Primarily COL; Safeguards information provided for certification
<u>Chapter 14 Initial Test Program</u>					
14.1	Initial Plant Test Programs – PSAR	2	07/1981		Deleted
14.2	Initial Plant Test Programs – FSAR	2	07/1981	Yes	
14.2.1	Generic Guidelines for Extended Power Uprate Testing Programs	0	Draft 12/2002	No	Draft for comments
14.3	Standard Plant Design, Initial Test Program – Final Design Approval (FDA)	2	07/1981		Deleted
<u>Chapter 15 Accident Analysis</u>					
15.0	Introduction	2	07/1981	Yes	
15.0.1	Radiological Consequence Analyses Using Alternate Source Terms	0	07/2000	Yes	ESBWR does not follow SRP's order of events
15.0.2	Review of Transient and Accident Analysis Methods	0	Draft 01/2003	Yes	Draft for comments. ESBWR does not follow SRP's order of events
15.1.1–15.1.4	Decrease in Feedwater Temperature, Increase in Feedwater Flow, Increase in Steam Flow, and Inadvertent Opening of a Steam Generator Relief or Safety Valve	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.1.5	Steam System Piping Failures Inside and Outside of Contamination (PWR)	3	Draft 04/1996	No	PWR only

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
	Appendix A	3	Draft 04/1996	No	PWR only
15.2.1–15.2.5	Loss of External Load, Turbine Trip, Loss of Condenser Vacuum, Closure of Main Steam Isolation Valve (BWR), and Steam Pressure Regulator Failure (Closed)	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.2.6	Loss of Nonemergency AC Power to the Station Auxiliaries	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.2.7	Loss of Normal Feedwater Flow	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.2.8	Feedwater System Pipe Breaks Inside and Outside Containment (PWR)	2	Draft 04/1996	Part	Portions applicable to BWR are considered
15.3.1–15.3.2	Loss of Forced Reactor Coolant Flow Including Trip of Pump and Flow Controller Malfunctions	2	Draft 04/1996	No	No forced Recirc Systems in ESBWR
15.3.3–15.3.4	Reactor Coolant Pump Rotor Seizure and Reactor Coolant Pump Shaft Break	3	Draft 04/1996	No	No forced Recirc Systems in ESBWR
15.4.1	Uncontrolled Control Rod Assembly Withdrawal from a Subcritical or Low Power Startup Condition	3	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.4.2	Uncontrolled Control Rod Assembly Withdrawal at Power	3	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
15.4.3	Control Rod Misoperation (System Malfunction or Operator Error)	3	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.4.4–15.4.5	Startup of an Inactive Loop or Recirculation Loop at an Incorrect Temperature, and Flow Controller Malfunction Causing an Increase in BWR Core Flow Rate	2	Draft 04/1996	No	No forced Recirc Systems in ESBWR
15.4.6	Chemical and Volume Control System Malfunction That Results in a Decrease in the Boron Concentration in the Reactor Coolant (PWR)	2	Draft 04/1996	No	PWR only
15.4.7	Inadvertent Loading and Operation of a Fuel Assembly in an Improper Position	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.4.8	Spectrum of Rod Ejection Accidents (PWR)	3	Draft 04/1996	No	PWR only
	Appendix A	2	Draft 04/1996	No	PWR only
15.4.9	Spectrum of Rod Drop Accidents (BWR)	3	Draft 04/1996	Yes	Radiological analysis assumptions superceded by SRP 15.0.1.
	Appendix A	3	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.5.1–15.5.2	Inadvertent Operation of ECCS and Chemical and Volume Control System Malfunction That Increases Reactor Coolant Inventory	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
15.6.1	Inadvertent Opening of a PWR Pressurizer Relief Valve or a BWR Relief Valve	2	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.6.2	Radiological Consequences of the Failure of Small Lines Carrying Primary Coolant Outside Containment	3	Draft 04/1996	Yes	Radiological analysis assumptions superceded by SRP 15.0.1.
15.6.3	Radiological Consequences of Steam Generator Tube Failure (PWR)	3	Draft 04/1996	No	PWR only
15.6.4	Radiological Consequences of Main Steam Line Failure Outside Containment (BWR)	3	Draft 04/1996	Yes	Radiological analysis assumptions superceded by SRP 15.0.1.
15.6.5	Loss-of-Coolant Accidents Resulting from Spectrum of Postulated Piping Breaks Within the Reactor Coolant Pressure Boundary	3	Draft 04/1996	Yes	Radiological analysis assumptions superceded by SRP 15.0.1.
	Appendix A	2	Draft 04/1996	No	ESBWR does not follow SRP's order of events
	Appendix B	2	Draft 04/1996	No	ESBWR does not follow SRP's order of events
	Appendix C	2	07/1981	—	Deleted
	Appendix D	2	Draft 04/1996	No	See 6.7 above
15.7.1	Waste Gas System Failure	1	07/1981	—	Deleted

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
15.7.2	Radioactive Liquid Waste System Leak or Failure (Released to Atmosphere)	1	07/1981	—	Deleted
15.7.3	Postulated Radioactive Release Due to Liquid-Containing Tank Failures	2	07/1981	Yes	ESBWR does not follow SRP's order of events
15.7.4	Radiological Consequences of Fuel Handling Accidents	2	Draft 04/1996	Yes	Radiological analysis assumptions superceded by SRP 15.0.1.
15.7.5	Spent Fuel Cask Drop Accidents	3	Draft 04/1996	Yes	ESBWR does not follow SRP's order of events
15.8	Anticipated Transients Without Scram	1	07/1981	Yes	ESBWR does not follow SRP's order of events
	Appendix	1	07/1981	—	Deleted
<u>Chapter 16 Technical Specifications</u>					
16.0	Technical Specifications	1	07/1981	Yes	
16.1	Risk-Informed Decisionmaking: Technical Specifications	0	08/1998	—	COL
<u>Chapter 17 Quality Assurance</u>					
17.1	Quality Assurance During the Design and Construction Phases	2	07/1981	Yes	
17.2	Quality Assurance During the Operations Phase	2	07/1981	—	COL
17.3	Quality Assurance Program Description	0	08/1990	—	COL
<u>Chapter 18 Human Factors Engineering</u>					
18.0	Human Factors Engineering	1	02/2004	Yes	

Table 1.9-20

NRC Standard Review Plans and Branch Technical Positions Applicability to ESBWR

SRP No.	SRP Title or BTP	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
18.1	Control Room	0	09/1984	Yes	
	Appendix A	0	09/1984	Yes	
18.2	Safety Parameter Display System	0	01/1985	Yes	
	Appendix A	0	01/1985	Yes	
<u>Chapter 19 Severe Accidents</u>					
19	Use of Probabilistic Risk Assessment in Plant-specific, Risk-informed Decisionmaking: General Guidance	1	11/2002	No	Will consider on a case-by-case basis
19.1	Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities	0	02/2004	No	Will consider on a case-by-case basis

Notes for Table 1.9-20:

- (1) Interface – The items refer to a feature that is at the boundary of the certification scope and can affect or influence the design.
- (2) COL (Combined Operating License) – The responsibility for the item is with the licensee or plant designer, either during the COL phase or later during the life of the plant.
- (3) BSP (Bounding Site Parameter) – The requirements must be met by the plant site location chosen by the licensee.

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.1	Net Positive Suction Head for Emergency Core Cooling and Containment Heat Removal System Pumps	0	11/1970	No	No pumps in these safety-related functions for ESBWR
1.2	Thermal Shock to Reactor Pressure Vessels	0	11/1970	No	Withdrawn 7/31/1991
1.3	Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Boiling Water Reactors	2	06/1974	No	Superseded by RG 1.183 for new plants.
1.4	Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Pressurized Water Reactors	2	06/1974	No	PWR only
1.5	Assumptions Used for Evaluating the Potential Radiological Consequences of a Steam Line Break Accident for Boiling Water Reactors	0	03/1971	No	Superseded by RG 1.183 for new plants.
1.6	Independence Between Redundant Standby (Onsite) Power Sources and Between Their Distribution Systems	0	03/1971	Yes	No safety-related Diesel Generators for ESBWR. URD intent – see Table 1.9-21a
1.7	Control of Combustible Gas Concentrations in Containment	3	05/2003	Yes	see Table 1.9-21a for optimization comment
1.8	Qualification and Training of Personnel for Nuclear Power Plants	3	05/2000	—	COL. See note 1 and Table 1.9-21b

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.9	Selection, Design, Qualification and Testing of Emergency Diesel Generator Units Used as Class 1E Onsite Electric Power Systems at Nuclear Power Plants	3	07/1993	No	No safety-related Diesel Generators for ESBWR. URD intent – see Table 1.9-21a
1.11	Instrument Lines Penetrating Primary Reactor Containment (Safety Guide 11) and Supplement to Safety Guide 11, Backfitting Considerations	0	03/1971	Yes	Supplement issued 02/1972
1.12	Nuclear Power Plant Instrumentation for Earthquakes	2	03/1997	Yes	
1.13	Spent Fuel Storage Facility Design Basis	1	12/1975	Yes	URD Intent – see Table 1.9-21a. See also proposed Rev 2 published 12/1981 as CE 913-5.
1.14	Reactor Coolant Pump Flywheel Integrity	1	08/1975	No	PWR only
1.16	Reporting of Operating Information – Appendix A Technical Specifications	4	08/1975	—	COL
1.17	Protection of Nuclear Power Plants Against Industrial Sabotage	1	06/1973	No	Withdrawn 7/5/1991
1.20	Comprehensive Vibration Assessment Program for Reactor Internals During Preoperational and Initial Startup Testing	2	05/1976	Yes	Performed During Power Ascension Testing

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.21	Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants	1	06/1974	Yes	
1.22	Periodic Testing of Protection System Actuation Functions	0	02/1972	Yes	
1.23	Onsite Meteorological Programs	0	02/1972	Yes	BSP. See also proposed Rev 1 published 04/1986 as ES 926-4.
1.24	Assumptions Used for Evaluating the Potential Radiological Consequences of a Pressurized Water Reactor Gas Storage Tank Failure	0	03/1972	No	PWR only
1.25	Assumptions Used for Evaluating the Potential Radiological Consequences of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors	0	03/1972	No	Superceded by RG 1.183 for new plants.
1.26	Quality Group Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants	3	02/1976	—	See Table 1.9-21a for URD optimization comment and Table 1.9-21b
1.27	Ultimate Heat Sink for Nuclear Power Plants	2	01/1976	Yes	URD intent – see Table 1.9-21a

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.28	Quality Assurance Program Requirements (Design and Construction)	3	08/1985	—	See Table 1.9-21b. See also proposed Rev 4 published 11/1992 as DG-1010.
1.29	Seismic Design Classification	3	09/1978	—	See Table 1.9-21a for intent comment and Table 1.9-21b
1.30	Quality Assurance Requirements for the Installation, Inspection, and Testing of Instrumentation and Electric Equipment	0	08/1972	—	See Table 1.9-21a for intent comment and Table 1.9-21b
1.31	Control of Ferrite Content in Stainless Steel Weld Metal	3	04/1978	Yes	
1.32	Criteria for Power Systems for Nuclear Power Plants	3	03/2004	Yes	URD intent – see Table 1.9-21a
1.33	Quality Assurance Program Requirements (Operation)	2	02/1978	—	COL. See also proposed Rev 3 published 11/1980 as RS 902-4.
1.34	Control of Electroslag Weld Properties	0	12/1972	Yes	
1.35	Inservice Inspection of UngROUTED Tendons in Prestressed Concrete Containment Structures	3	07/1990	No	Prestressed Concrete not used
1.35.1	Determining Prestressing Forces for Inspection of Prestressed Concrete Containments	0	07/1990	No	Prestressed Concrete not used

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.36	Nonmetallic Thermal Insulation for Austenitic Stainless Steel	0	02/1973	Yes	
1.37	Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants	0	03/1973	—	See Table 1.9-21b
1.38	Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage, and Handling of Items for Water-Cooled Nuclear Power Plants	2	05/1977	—	See Table 1.9-21b
1.39	Housekeeping Requirements for Water-Cooled Nuclear Power Plants	2	09/1977	—	See Table 1.9-21b
1.40	Qualification Tests of Continuous-Duty Motors Installed Inside the Containment of Water-Cooled Nuclear Power Plants	0	03/1973	No	No continuous-duty pumps in containment for ESBWR
1.41	Preoperational Testing of Redundant On-site Electric Power Systems to Verify Proper Load Group Assignments	0	03/1973	Part	No safety-related Diesel Generators for ESBWR. Therefore, only DC portions are applicable. URD intent – see Table 1.9-21a
1.43	Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components	0	05/1973	Yes	Special testing requirements not applicable due to materials selected.
1.44	Control of the Use of Sensitized Stainless Steel	0	05/1973	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.45	Reactor Coolant Pressure Boundary Leakage Detection Systems	0	05/1973	Yes	
1.47	Bypassed and Inoperable Status Indication for Nuclear Power Plant Safety Systems	0	05/1973	Yes	
1.49	Power Levels of Nuclear Power Plants	1	12/1973	Part	Power limitation outdated. Power multiplier of 1.02 still applicable.
1.50	Control Preheat Temperature for Welding of Low-Alloy Steel	0	05/1973	Yes	
1.52	Design, Inspection, and Testing Criteria for Air Filtration and Adsorption Units of Post-Accident Engineered-Safety-Feature Atmosphere Cleanup Systems in Light-Water-Cooled Nuclear Power Plants	3	06/2001	No	URD optimization – see Table 1.9-21a
1.53	Application of the Single-Failure Criterion to Nuclear Power Plant Protection Systems	2	11/2003	Yes	
1.54	Service Level I, II, and III Protective Coatings Applied to Water-Cooled Nuclear Power Plants	1	07/2000	Yes	
1.56	Maintenance of Water Purity in Boiling Water Reactors	1	07/1978	Yes	
1.57	Design Limits and Loading Combinations for Metal Primary Reactor Containment System Components	0	06/1973	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.58	Qualification of Nuclear Power Plant Inspection, Examination, and Testing Personnel		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991
1.59	Design Basis Floods for Nuclear Power Plants	2	08/1977	Yes	Errata published 07/30/1980
1.60	Design Response Spectra for Seismic Design of Nuclear Power Plants	1	12/1973	Yes	
1.61	Damping Values for Seismic Design of Nuclear Power Plants	0	10/1973	Yes	URD optimization – see Table 1.9-21a
1.62	Manual Initiation of Protective Actions	0	10/1973	Yes	
1.63	Electric Penetration Assemblies in Containment Structures for Nuclear Power Plants	3	02/1987	Yes	
1.64	Quality Assurance Requirements for the Design of Nuclear Power Plants		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991
1.65	Materials and Inspections for Reactor Vessel Closure Studs	0	10/1973	Yes	
1.68	Initial Test Programs for Water-Cooled Reactor Power Plants	2	08/1978	Yes	
1.68.1	Preoperational and Initial Startup Testing of Feedwater and Condensate Systems for Boiling Water Reactor Power Plants	1	01/1977	Yes	
1.68.2	Initial Startup Test Program to Demonstrate Remote Shutdown Capability for Water-Cooled Nuclear Power Plants	1	07/1978	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.68.3	Preoperational Testing of Instrument and Control Air Systems	0	04/1982	Yes	
1.69	Concrete Radiation Shields for Nuclear Power Plants	0	12/1973	Yes	
1.70	Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants	3	11/1978	Yes	URD intent – see Table 1.9-21a
1.71	Welder Qualifications for Areas of Limited Accessibility	0	12/1973	—	COL
1.72	Spray Pond Piping Made From Fiberglass-Reinforced Thermosetting Resin	2	11/1978	No	
1.73	Qualification Tests of Electric Valve Operators Installed Inside the Containment of Nuclear Power Plants	0	01/1974	Yes	URD optimization – see Table 1.9-21a
1.74	Quality Assurance Terms and Definitions		Super-ceded		See Table 1.9-21b. Withdrawn 09/21/1989
1.75	Physical Independence of Electric Systems	3	02/2005	Yes	URD intent – see Table 1.9-21a.
1.76	Design Basis Tornado for Nuclear Power Plants	0	04/1974	Yes	URD optimization – see Table 1.9-21a
1.77	Assumptions Used for Evaluating a Control Rod Ejection Accident for Pressurized Water Reactors	0	05/1974	No	PWR Only. Superceded by RG 1.183 for new plants.

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.78	Evaluating the Habitability of a Nuclear Power Plant Control Room During a Postulated Hazardous Chemical Release	1	12/2001	Yes	
1.79	Preoperational Testing of Emergency Core Cooling Systems for Pressurized Water Reactors	1	09/1975	No	PWR only
1.81	Shared Emergency and Shutdown Electric Systems for Multi-Unit Power Plants	1	01/1975	No	ESBWR is a single unit plant
1.82	Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident	3	11/2003	Part	No ECCS pumps in ESBWR
1.83	Inservice Inspection of Pressurized Water Reactor Steam Generator Tubes	1	07/1975	No	PWR only
1.84	Design and Fabrication and Materials Code Case Acceptability, ASME Section III	32	06/2003	Yes	
1.85	Materials Code Case Acceptability, ASME Section III, Division 1			No	Withdrawn 06/2003. Guidance incorporated into Rev. 32 of RG 1.84
1.86	Termination of Operating Licenses for Nuclear Reactors	0	06/1974	—	COL
1.87	Guidance for Construction of Class 1 Components in Elevated-Temperature Reactors (Supplement to ASME Section III Code Cases 1592, 1593, 1594, 1595, and 1596)	1	06/1975	No	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.88	Collection, Storage, and Maintenance of Nuclear Power Plant Quality Assurance Records		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991
1.89	Environmental Qualification of Certain Electric Equipment Important to Safety for Nuclear Power Plants	1	06/1984	Yes	Source term requirements superceded by RG 1.183.
1.90	Inservice Inspection of Prestressed Concrete Containment Structures with Grouted Tendons	1	08/1977	No	Reinforced Concrete used
1.91	Evaluations of Explosions Postulated to Occur on Transportation Routes Near Nuclear Power Plants	1	02/1978	—	COL
1.92	Combining Modal Responses and Spatial Components in Seismic Response Analysis	1	02/1976	Yes	URD optimization – see Table 1.9-21a. See also proposed Rev 2 published 08/2001 as DG-1108.
1.93	Availability of Electric Power Sources	0	12/1974	Part	No safety-related diesels. Therefore, only DC portion (Item 5) is applicable. URD intent: see Table 1.9-21a

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.94	Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants	1	04/1976	—	See Table 1.9-21b. See also proposed Rev 2 published 09/1979 as RS 908-5.
1.95	Protection of Nuclear Power Plant Control Room Operators Against an Accidental Chlorine Release	1	01/1977	No	Withdrawn 12/26/2001. Guidance incorporated in Rev. 1 of RG 1.78
1.96	Design of Main Steam Isolation Valve Leakage Control Systems for Boiling Water Reactor Nuclear Power Plants	1	06/1976	No	No MSIV LCS. URD optimization – see Table 1.9-21a
1.97	Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident	3	05/1983	Yes	URD optimization – see Table 1.9-21a
1.98	Assumptions Used for Evaluating the Potential Radiological Consequences of a Radioactive Offgas System Failure in a Boiling Water Reactor	0	03/1976	No	Superseded by BTP ESTB 11-5 in SRP 11.3.
1.99	Radiation Embrittlement of Reactor Vessel Materials	2	05/1988	Yes	URD optimization – see Table 1.9-21a
1.100	Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants	2	06/1988	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.101	Emergency Planning and Preparedness for Nuclear Power Reactors	4	07/2003	—	COL
1.102	Flood Protection for Nuclear Power Plants	1	09/1976	Yes	
1.105	Setpoints for Safety-Related Instrumentation	3	12/1999	Yes	
1.106	Thermal Overload Protection for Electric Motors on Motor-Operated Valves	1	03/1977	Yes	
1.107	Qualifications for Cement Grouting for Prestressing Tendons in Containment Structures	1	02/1977	No	Reinforced Concrete used
1.108	Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants	1	08/1977	No	Withdrawn 8/5/1993. No safety-related Diesel Generators for ESBWR. URD intent – see Table 1.9-21a
1.109	Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I	1	10/1977	Yes	
1.110	Cost-Benefit Analysis for Radwaste Systems for Light-Water-Cooled Nuclear Power Plants	0	03/1976	Yes	
1.111	Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors	1	07/1977	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.112	Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light-Water-Cooled Power Reactors	0-R	05/1977	Yes	
1.113	Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I	1	04/1977	—	COL
1.114	Guidance to Operators at the Controls and to Senior Operators in the Control Room of a Nuclear Power Unit	2	05/1989	—	COL
1.115	Protection Against Low-Trajectory Turbine Missiles	1	07/1977	Yes	
1.116	Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems	0-R	05/1977	—	See Table 1.9-21b
1.117	Tornado Design Classification	1	04/1978	Yes	
1.118	Periodic Testing of Electric Power and Protection Systems	3	04/1995	Yes	
1.120	Fire Protection Guidelines for Nuclear Power Plants	1	11/1977	No	Withdrawn 08/15/2001
1.121	Bases for Plugging Degraded PWR Steam Generator Tubes	0	08/1976	No	PWR only
1.122	Development of Floor Design Response Spectra for Seismic Design of Floor-Supported Equipment or Components	1	02/1978	Yes	URD optimization – see Table 1.9-21a
1.123	Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.124	Service Limits and Loading Combinations for Class 1 Linear-Type Component Supports	1	01/1978	Yes	
1.125	Physical Models for Design and Operation of Hydraulic Structures and Systems for Nuclear Power Plants	1	10/1978	Yes	
1.126	An Acceptable Model and Related Statistical Methods for the Analysis for Fuel Densification	1	03/1978	Yes	
1.127	Inspection of Water-Control Structures Associated with Nuclear Power Plants	1	03/1978	—	COL
1.128	Installation Design and Installation of Large Lead Storage Batteries for Nuclear Power Plants	1	10/1978	Yes	
1.129	Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Nuclear Power Plants	1	02/1978	—	COL
1.130	Service Limits and Loading Combinations for Class 1 Plate-and-Shell-Type Component Supports	1	10/1978	Yes	
1.131	Qualification Tests of Electric Cables, Field Splices, and Connections for Light-Water-Cooled Nuclear Power Plants	0	08/1977	Yes	See also proposed Rev 1 published 08/1979 as RS 050-2.
1.132	Site Investigations for Foundations of Nuclear Power Plants	2	10/2003	—	COL
1.133	Loose-Part Detection Program for the Primary System of Light-Water-Cooled Reactors	1	05/1981	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.134	Medical Evaluation of Licensed Personnel at Nuclear Power Plants	3	03/1998	—	COL
1.135	Normal Water Level and Discharge at Nuclear Power Plants	0	09/1977	Yes	
1.136	Materials, Construction, and Testing of Concrete Containments (Articles CC-1000, -2000, and -4000 through -6000 of the “Code for Concrete Reactor Vessels and Containments”	2	06/1981	Yes	
1.137	Fuel-Oil Systems for Standby Diesel Generators	1	10/1979	No	No safety-related Diesel Generators for ESBWR. URD intent – see Table 1.9-21a
1.138	Laboratory Investigations of Soils and Rocks for Engineering Analysis and Design of Nuclear Power Plants	2	12/2003	—	COL
1.139	Guidance for Residual Heat Removal	0	05/1978	Yes	URD optimization – see Table 1.9-21a
1.140	Design, Inspection, and Testing Criteria for Air Filtration and Adsorption Units of Normal Atmosphere Cleanup Systems in Light-Water-Cooled Nuclear Power Plants	2	06/2001	Yes	
1.141	Containment Isolation Provisions for Fluid Systems	0	04/1978	Yes	
1.142	Safety-Related Concrete Structures for Nuclear Power Plants (Other than Reactor Vessels and Containments)	2	11/2001	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.143	Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants	2	11/2001	Yes	
1.144	Auditing of Quality Assurance Programs for Nuclear Power Plants		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991
1.145	Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants	1	11/1982	—	COL. Reissued 02/1983 to correct page 1.145-7.
1.146	Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants		Super-ceded		See Table 1.9-21b. Withdrawn 07/31/1991
1.147	Inservice Inspection Code Case Acceptability – ASME Section XI, Division 1	13	01/2004	—	COL. Reprint of 06/2003 version with corrections
1.148	Functional Specification for Active Valve Assemblies in Systems Important to Safety in Nuclear Power Plants	0	03/1981	Yes	
1.149	Nuclear Power Plant Simulation Facilities for Use in Operator Training and License Examinations	3	10/2001	—	COL
1.150	Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations	1	02/1983	Yes	
1.151	Instrument Sensing Lines	0	07/1983	Yes	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.152	Criteria for Digital Computers in Safety Systems of Nuclear Power Plants	1	01/1996	Yes	See DG-1130, which will become Rev. 2
1.153	Criteria for Safety Systems	1	06/1996	Yes	
1.154	Format and Contents of Plant-Specific Pressurized Thermal Shock Safety Analysis Reports for Pressurized Water Reactors	0	01/1987	No	PWR only
1.155	Station Blackout	0	08/1988 reissue with corrected tables	Part	No emergency AC power required for ESBWR. Only coping analysis applicable. URD intent – see Table 1.9-21a
1.156	Environmental Qualification of Connection Assemblies for Nuclear Power Plants	0	11/1987	Yes	
1.157	Best-Estimate Calculations of Emergency Core Cooling System Performance	0	05/1989	Yes	
1.158	Qualification of Safety-Related Lead Storage Batteries for Nuclear Power Plants	0	02/1989	Yes	
1.159	Assuring the Availability of Funds for Decommissioning Nuclear Reactors	1	10/2003	—	COL
1.160	Monitoring the Effectiveness of Maintenance at Nuclear Power Plants	2	03/1997	—	COL
1.161	Evaluation of Reactor Pressure Vessels with Charpy Upper-Shelf Energy Less Than 50 Ft-Lb.	0	06/1995	No	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.162	Format and Content of Report for Thermal Annealing of Reactor Pressure Vessels	0	02/1996	—	COL
1.163	Performance-Based Containment Leak-Test Program	0	09/1995	Yes	
1.164	(Not yet issued)				
1.165	Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motion	0	03/1997	Yes	
1.166	Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Post-Earthquake Actions	0	03/1997	—	COL
1.167	Restart of a Nuclear Power Plant Shut Down by a Seismic Event	0	03/1997	No	
1.168	Verification, Validation, Reviews, and Audits for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	1	02/2004	—	COL
1.169	Configuration Management Plans for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	0	09/1997	—	COL
1.170	Software Test Documentation for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	0	09/1997	—	COL
1.171	Software Unit Testing for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	0	09/1997	—	COL
1.172	Software Requirements Specifications for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	0	09/1997	—	COL

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.173	Developing Software Life Cycle Processes for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	0	09/1997	—	COL
1.174	An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions On Plant-Specific Changes to the Licensing Basis	1	11/2002	Not directly	ESBWR is a new design. This approach can be used to evaluate design features.
1.175	An Approach for Plant-Specific, Risk-Informed Decisionmaking: Inservice Testing	0	08/1998	—	COL
1.176	An Approach for Plant-Specific, Risk-Informed Decisionmaking: Graded Quality Assurance	0	08/1998	—	COL
1.177	An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications	0	08/1998	—	COL
1.178	An Approach For Plant-Specific Risk-Informed Decisionmaking for Inservice Inspection of Piping	1	09/2003	—	COL
1.179	Standard Format and Content of License Termination Plans for Nuclear Power Reactors	0	01/1999	No	
1.180	Guidelines for Evaluating Electromagnetic and Radio-Frequency Interference in Safety-Related Instrumentation and Control Systems	1	10/2003	—	COL
1.181	Content of the Updated Final Safety Analysis Report in Accordance with 10 CFR 50.71(e)	0	09/1999	—	COL

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.182	Assessing and Managing Risk Before Maintenance Activities at Nuclear Power Plants	0	05/2000	—	COL
1.183	Alternative Radiological Source Terms For Evaluating Design Basis Accidents at Nuclear Power Reactors	0	07/2000	Yes	Mandatory for new plants. Optional for existing facilities.
1.184	Decommissioning of Nuclear Power Reactors	0	08/2000	No	
1.185	Standard Format and Content for Post-Shutdown Decommissioning Activities Report	0	07/2000	No	
1.186	Guidance and Examples of Identifying 10 CFR 50.2 Design Bases	0	12/2000	—	COL
1.187	Guidance for Implementation of 10 CFR 50.59, Changes, Tests, and Experiments	0	11/2000	—	COL
1.188	Standard Format and Content for Applications to Renew Nuclear Power Plant Operating Licenses	0	07/2001	No	
1.189	Fire Protection for Operating Nuclear Power Plants	0	04/2001	Yes	See BTP SPLB 9.5-1 of SRP 9.5.1 for details of applicability.
1.190	Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence	0	03/2001	Yes	
1.191	Fire Protection Program for Nuclear Power Plants During Decommissioning and Permanent Shutdown	0	05/2001	No	

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.192	Operation and Maintenance Code Case Acceptability, ASME OM Code	0	06/2003	—	COL
1.193	ASME Code Cases Not Approved For Use	0	06/2003	Yes	
1.194	Atmospheric Relative Concentrations for Control Room Radiological Habitability Assessment at Nuclear Power Plants	0	06/2003	—	COL
1.195	Methods and Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light-Water Nuclear Power Reactors	0	05/2003	No	Not applicable when using RG 1.183 alternate source terms
1.196	Control Room Habitability at Light-Water Nuclear Power Reactors	0	05/2003	Yes	
1.197	Demonstrating Control Room Envelope Integrity at Nuclear Power Reactors	0	05/2003	Yes	
1.198	Procedures and Criteria for Assessing Seismic Soil Liquefaction at Nuclear Power Plant Sites	0	11/2003	—	COL
1.199	Anchoring Components and Structural Supports in Concrete	0	11/2003	Yes	
1.200	An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities	0	02/2004	No	Will consider on a case-by-case basis
1.201	(Not yet issued)				

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
1.202	Standard Format and Content of Decommissioning Cost Estimates for Nuclear Power Reactors	0	02/2005	No	
5.1	Serial Numbering of Fuel Assemblies for Light-Water-Cooled Nuclear Power Reactors	0	12/1972	No	Withdrawn 01/15/1998
5.7	Entry/Exit Control for Protected Areas, Vital Areas, and Material Access Areas	1	05/1980	Yes	
5.12	General Use of Locks in the Protection and Control of Facilities and Special Nuclear Materials	0	11/1973	Yes	
5.44	Perimeter Intrusion Alarm Systems	3	10/1997	Yes	
5.61	Intent and Scope of the Physical Protection Upgrade Rule Requirements for Fixed Sites	0	06/1980	Yes	Safeguards information provided
5.65	Vital Area Access Controls, Protection of Physical Security Equipment, and Key and Lock Controls	0	09/1986	Yes	
5.66	Access Authorization Program for Nuclear Power Plants	0	06/1991	Yes	Shared with COL
8.2	Guide for Administrative Practices in Radiation Monitoring	0	02/1973	—	COL
8.5	Criticality and Other Interior Evacuation Signals	1	03/1981	Yes	
8.8	Information Relevant to Ensuring that Occupational Radiation Exposures at Nuclear Power Stations Will Be As Low As Is Reasonably Achievable	3	06/1978	Yes	See also second proposed Rev 4 issued 05/1982 as OP 618-4.

Table 1.9-21
NRC Regulatory Guides Applicability to ESBWR

RG No.	Regulatory Guide Title	Appl. Rev.	Issued Date	ESBWR Appli-cable?	Comments
8.10	Operational Philosophy for Maintaining Occupational Radiation Exposures As Low As Is Reasonably Achievable	1-R	05/1977	Yes	
8.19	Occupational Radiation Dose Assessment in Light-Water Reactor Power Plants – Design Stage Man-Rem Estimates	1	06/1979	Yes	
8.27	Radiation Protection Training for Personnel at Light-Water-Cooled Nuclear Power Plants	0	03/1981	—	COL
8.38	Control of Access to High and Very High Radiation Areas of Nuclear Plants	0	06/1993	Yes	

Note for Table 1.9-21:

- (1) COL (Combined Operating License) – The responsibility for the item is with the licensee or plant designer, either during the COL phase or later during the life of the plant.

Table 1.9-21a
EPRI Intent and Optimization Topics

Reg. Guide	Topic Type	URD* Section	Comment
1.6	Intent	4.12	Passive safety systems will use DC-derived power systems that are designed with the required independence.
1.7	Optim	2.5.2	Use a passive plant-specific physically-based source term.
1.9	Intent	4.13	Passive safety systems do not require diesel generators.
1.13	Intent	4.14	ESBWR will comply with spent fuel storage facility requirements by keeping spent fuel covered with a loss of AC power for 72 hours.
1.26	Optim	2.3.1.2 (4)	The Main Steamline downstream of the seismic interface restraint is to be considered Seismic Category II and Quality Group B.
1.27	Intent	4.15.3	Passive decay heat removal systems provide the ultimate heat sink function so a separate reservoir is not required.
1.29	Optim	2.3.1.2 (4)	The Main Steamline downstream of the seismic interface restraint is to be considered Seismic Category II and Quality Group B.
1.30	Intent	4.16	AC power systems quality assurance requirements are consistent with design requirements in 10 CFR 50 Appendix B.
1.32	Intent	4.17	Safety-related DC power sources are provided to support passive core cooling and containment integrity safety functions. No offsite or diesel-generator-derived AC power is required for 72 hours.
1.41	Intent	4.18	Safety-related DC-derived power load groups will be tested. Minimal safety-related (inverter-derived) AC power testing is required.
1.52	Optim	2.5.2	Use of a Passive plant-specific physically-based source term eliminates the need for additional systems.
1.61	Optim	2.1.1.2 (4)	ASME Code case N-411 for SSE uses a higher damping value (more realistic).
1.70	Intent	4.19.3	Safety analysis reports will be provided that describe the design in a similar scope.
1.73	Optim	2.5.2	Use a passive plant-specific physically-based source term.

Table 1.9-21a
EPRI Intent and Optimization Topics

Reg. Guide	Topic Type	URD* Section	Comment
1.75	Intent	4.20.3	Safe shutdown relies only upon DC-derived power and will meet the design requirements for physical independence.
1.76	Optim	2.1.2.2	Basis will be from National Severe Storms Forecast Center (NSSFC) for a 147.5 m/s (330 mph) tornado.
1.92	Optim	2.1.1.2	Revise analysis method to permit algebraic combination of high frequency modes for vibratory loads with significant high frequency input 33 - 100 Hz. Reference to OBE provisions deleted.
1.93	Intent	4.22	The ESBWR is designed to shut down safely without reliance on offsite or diesel-generator-derived AC power.
1.96	Optim	2.3.1.2	Leakage control not required.
1.96	Optim	2.5.2	Use a passive plant-specific physically-based source term.
1.97	Optim	2.3.2.2	PASS simplification.
1.97	Optim	2.1.3.3	Offsite Emergency planning simplification.
1.99	Optim	2.1.1.2	Revise for equipment to remain functional for "continued operation of the plant" and for OBE classification.
1.108	Intent	4.23	The ESBWR is designed with passive safety systems to maintain core cooling and containment integrity without reliance on offsite or diesel-generator-derived AC power.
1.122	Optim	2.1.1.2	Revised to allow spectral shifting techniques as an alternative.
1.137	Intent	4.24	The ESBWR is designed to shut down safely without reliance on offsite or diesel-generator-derived AC power.
1.139	Optim	2.5.6	Passive decay heat removal system without Cold Shutdown requirement. The NRC, in a June 30, 1994 staff requirements memorandum (SRM), has approved the position proposed in SECY-94-084, "Policy and Technical Issues Associated with the Regulatory Treatment of Non-Safety Systems in Passive Plant Designs." This position accepts 215.6°C (420°F) or below, rather than the cold shutdown specified in RG 1.139, "Guidance for Residual Heat Removal," as the safe stable condition that the passive decay heat removal system must be capable of achieving and maintaining following non-LOCA events.

Table 1.9-21a
EPRI Intent and Optimization Topics

Reg. Guide	Topic Type	URD* Section	Comment
1.155	Intent	4.25	The ESBWR is designed to shut down safely without reliance on offsite or diesel-generator-derived AC power for 72 hours, which exceeds station blackout requirements.

* Volume III, Chapter 1, Appendix B of Reference 1.9-1.

Table 1.9-21b
ESBWR Compliance with Quality Related Regulatory Guides

<u>Reg. Guide</u>	<u>Rev.</u>	<u>Comments</u>
1.8	3	No exceptions.
1.26	3	No exceptions.
1.28	3	Exception. *
1.29	3	No exceptions.
1.30	0	No exceptions.
1.37	0	Exception *
1.38	2	Exception *
1.39	2	No exceptions.
1.58	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3, exception *
1.64	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3, exception *
1.74	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3.
1.88	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3, exception *
1.94	1	No exceptions.
1.116	0-R	Exception *.
1.123	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3, exception *
1.144	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3.
1.146	withdrawn	Superseded by Reg. Guide 1.28, Rev. 3, exception *

* NRC accepted alternate positions as documented in Table 2-1 of Reference 1.9-2.

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
Acoustical Society of America (ASA)		
S3.4-1980	1986 (R 2003)	Procedures for Computation of Loudness of Noise
S3.5-1997	1997 (R 2002)	Methods of Calculation of the Speech Intelligibility Index
Air-Conditioning and Refrigeration Institute (ARI)		
410-01	2001	Force-circulation Air-cooling and Air-heating Coils
430-99	1999	Central Station Air Handling Units
450-99	1999	Water-Cooled Refrigerant Condensers, Remote Type
550/590-03	2003	Water Chilling Packages Using the Vapor Compression Cycle
575-94	1994	Method of Measuring Machinery Sound Within an Equipment Space
Air Movement and Control Association (AMCA)		
99-03	2003	Standards Handbook
201-02	2002	Fans and Systems
202-98	1998	Troubleshooting
210-99	1999	Laboratory Methods of Testing Fans for Rating – Addenda A, August 21, 2001
301	1990	Methods for Calculating for Sound Ratings from Laboratory Test Data
302	1973	Sone Rating Applications Publication
303-79	1979	Sound Power Level Ratings Applications Publication
801-01	2001	Industrial Process/ Power Generation Fans: Specification Guidelines
American Association of State Highway and Transportation Officials (AASHTO)		
LTS-4	2001	Standard Specifications for Structural Supports for Highway Signs, Luminaries, and Traffic Signals
American Concrete Institute (ACI)		
211.1-91	1991 (R 2002)	Standard Practice for Selecting Proportions for Normal, Heavy Weight, and Mass Concrete
212.1R-81	1981 (R 1986)	Admixtures for Concrete
212.2R-81	1981 (R 1986)	Guide for Use of Admixtures in Concrete

² The listing of a code or standard does not necessarily mean that it is applicable in its entirety.

Table 1.9-22

Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
212.3R-04	2004	Chemical Admixtures for Concrete
214R-02	2002	Evaluation of Strength Test Results of Concrete
301-99	1999	Specifications for Structural Concrete
304R-00	2000	Guide for Measuring, Mixing, Transporting, and Placing Concrete
305R-99	1999	Hot Weather Concreting
306R-88	1988 (R 2002)	Cold Weather Concreting
307/307R	1998	Design and Construction of Reinforced Concrete Chimneys
308.1	1998	Standard Practice for Curing Concrete
309R-96	1996	Guide for Consolidation of Concrete
311.4R-00	2000	Guide for Concrete Inspection
315-99	1999	Details and Detailing of Concrete Reinforcement
318-05	2005	Building Code Requirements for Structural Concrete and Commentary
349-01	2001	Code Requirements for Nuclear Safety-Related Concrete Structures (ACI 349-01)
359-95	1995	Code for Concrete Reactor Vessels and Containments (See ASME Boiler & Pressure Vessel Code, Section III NCA and D2)
530-02	2002	Building Code Requirements for Masonry Structures (ACI 530-02/ASCE 5-02/TMSV402-02)
American Institute of Steel Construction (AISC)		
360-05	2005	Specification for Structural Steel Buildings (Also endorsed by ANSI)
M015L-91	1991	Manual of Steel Construction Load and Resistance Factor Design, 1st Edition
M016-89	1989	Manual of Steel Construction Allowable Stress Design, 9th Edition
N690-94	1994 (R 2004)	Specification for the Design, Fabrication, and Erection of Steel Safety-Related Structures for Nuclear Facilities – Supplement 2: October 2004
American Iron and Steel Institute (AISI)		
CF02-1		Cold-Formed Steel Framing Design Guide (Latest edition based on the 1996 edition and 2000 supplement of the AISI Specification for the Design of Cold-Formed Steel Structural Members)
SG02-1 and SG02-2	2001	North American Specification for the Design of Cold-Formed Steel Structural Members, and Commentary
SG05-1e	2004	Supplement 2004 to the North American Specification for the Design of Cold-Formed Steel Structural Members, 2001 Edition

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
American National Standards Institute (ANSI)		
C37.32-1990	1990	Switchgear High-Voltage Air Switches, Bus Supports, and Switch Accessories - Schedules of Preferred Ratings, Manufacturing Specifications, and Application Guide – Revised and Re-designated as ANSI/NEMA C37.32-1996. See IEEE C37.32-2002.
C37.46-1981	1981	Specification for Power Fuses and Fuse Disconnecting Switches (See NEMA C37.46-2000)
C37.50-1989	1989	Switchgear – Low-Voltage AC Power Circuit Breakers Used in Enclosures – Test Procedures (See NEMA C37.50-1989)
C37.51-2003	2003	Switchgear – Metal Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies – Conformance Test Procedures (See NEMA C37.51-2003)
C39.1-1981	1981 (R 1992)	Electrical Analog Indicating Instruments
C50.10-1990	1990	General Requirements for Synchronous Machines
C50.13	1989	Standard for Rotating Electrical Machinery – Cylindrical-Rotor Synchronous Generators
CGA G-7.1	2004	Commodity Specification for Air
N13.1-1969	1969 (R 1993)	Guide for Sampling Airborne Radioactive Materials in Nuclear Facilities
N14.6-1993	1993	Radioactive Materials - Special Lifting Devices for Shipping Containers Weighing 10,000 Pounds (4500 kg) or More
N320	1979	Performance Specifications for Reactor Emergency Radiological Monitoring Instrumentation (Also under IEEE)
N323	1978	Radiation Protection Instrumentation Test and Calibration (Also under IEEE)
N323A	1997	Radiation Protection Instrumentation Test and Calibration, Portable Survey Instruments (Also under IEEE)
American Nuclear Insurers (ANI)		
Manual	1976	Basic Fire Protection for Nuclear Power Plants
—	—	Standard Method of Fire Test of Cable and Pipe Penetration Fire Stops
American Nuclear Society (ANS)		
2.2-2002	2002	Earthquake Instrumentation Criteria for Nuclear Power Plants
2.3-1983	1983	Standard for Estimating Tornado and Extreme Wind Characteristics at Nuclear Power Sites
2.7-1982	1982	Guidelines for Assessing Capability for Surface Faulting at Nuclear Power Sites

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
2.8	1992	Determining Design Basis Flooding at Power Reactor Sites
2.10-1979	1979	Guidelines for Retrieval, Review, Processing and Evaluation of Records Obtained from Seismic Instrumentation
2.11-1978	1978 (R 1989)	Guidelines for Evaluating Site-Related Geotechnical Parameters at Nuclear Power Sites
2.12-1978	1978	Guidelines for Combining Natural and External Man-Made Hazards at Power Reactor Sites
3.2-1994	1994 (R 1999)	Administrative Controls and Quality Assurance for the Operational Phase of Nuclear Power Plants
4.5-1980	1980 (R 1988)	Criteria for Accident Monitoring Functions in Light-Water-Cooled Reactors
5.1	1994	Decay Heat Power in LWRs
6.4	1997 (R 2004)	Nuclear Analysis and Design of Concrete Radiation Shielding for Nuclear Power Plants
10.4-1987	1987 (R 1998)	Guidelines for the Verification and Validation of Scientific and Engineering Computer Programs for the Nuclear Industry
18.1-1999	1999	Radioactive Source Term for Normal Operation of Light Water Reactors
52.1-1983	1983 (R 1988)	Nuclear Safety Criteria for the Design of Stationary Boiling Water Reactor Plants
55.1-1992	1992 (R 2000)	Solid Radioactive Waste Processing System for Light-Water-Cooled Reactor Plants
55.4-1993	1993 (R 1999)	Gaseous Radioactive Waste Processing Systems for Light Water Reactor Plants
55.6-1993	1993 (R 1999)	Liquid Radioactive Waste Processing System for Light Water Reactor Plants
56.2-1984	1984 (R 1989)	Containment Isolation Provisions for Fluid Systems After a LOCA
56.3-1977	1977 (R 1987)	Overpressure Protection of Low Pressure Systems Connected to the Reactor Coolant Pressure Boundary
56.5-1979	1979 (R 1987)	PWR and BWR Containment Spray System Design Criteria
56.7-1978	1978 (R 1987)	Boiling Water Reactor Containment Ventilation Systems
56.8-2002	2002	Containment System Leakage Testing Requirements
56.10-1982	1982 (R 1987)	Subcompartment Pressure and Temperature Transient Analysis in Light Water Reactors
56.11-1988	1988	Design Criteria for Protection Against the Effects of Compartment Flooding in Light Water Reactor Plants

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
57.1-1992	1992 (R 1998)	Design Requirements for Light Water Reactor Fuel Handling Systems
57.2-1983	1983	Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants
57.3-1983	1983	Design Requirements for New Fuel Storage Facilities at Light Water Reactor Plants
57.5-1996	1996	Light Water Reactor Fuel Assembly Mechanical Design and Evaluation
58.2-1988	1988	Design Basis for Protection of Light Water Nuclear Power Plants Against Effects of Postulated Pipe Rupture
58.4-1979	1979	Criteria for Technical Specifications for Nuclear Power Stations
58.6-1996	1996 (R 2001)	Criteria for Remote Shutdown of Light Water Reactors
58.8-1994	1994 (R 2001)	Time Response Design Criteria for Safety-Related Operator Actions
58.9-1981	1981 (R 2002)	Single Failure Criteria for Light Water Reactor Safety-Related Fluid Systems
58.11-1995	1995 (R 2002)	Design Criteria for Safe Shutdown Following Selected Design Basis Events in Light Water Reactors
58.14-1993	1993	Safety and Pressure Integrity Classification Criteria for Light Water Reactors
58.21-2003	2003	External Events in PRA Methodology
59.2-1985	1985	Safety Criteria for HVAC Systems Located Outside Primary Containment
59.51-1997	1997	Fuel Oil Systems for Safety-Related Emergency Diesel-Generators
59.52-1998	1998	Lubricating Oil Systems for Safety-Related Emergency Diesel-Generators
HPSSC-6.8.1	1981	Location and Design Criteria for Area Radiation Monitoring Systems for Light Water Nuclear Reactors
American Petroleum Institute (API)		
610-04	2004	Centrifugal Pumps Petroleum, Petrochemical, and Natural Gas Industries Tenth Edition: ISO 13709 Adoption
620-02	2002	Design and Construction of Large, Welded, Low-Pressure Storage Tanks – Tenth Edition
650-98	1998	Welded Steel Tanks for Oil Storage – Tenth Edition
661-02	2002	Air Cooled Heat Exchangers for General Refinery Service, Fifth Edition: ISO 13706: 2000/ISO 13706 Adoption
American Society for Quality (ASQ)		
C1-1996	1996	Specifications of General Requirements for a Quality Program

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
American Society of Civil Engineers (ASCE)		
4-98	1998 ©2000	Seismic Analysis of Safety-Related Nuclear Structures and Commentary
7-02	2002	Minimum Design Loads for Buildings and other Structures
American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE)		
15-2001	2001	Safety Standard for Refrigeration Systems
30-1995	1995	Methods of Testing Liquid-Chilling Packages
33-2000	2000	Methods of Testing Forced Circulation Air Cooling and Air Heating Coils
51-1999	1999	Laboratory Methods of Testing Fans for Aerodynamic Performance Rating
52-1976	1976	Testing Air-Cleaning Devices Used in General Ventilation for Removing Particulate Matter
52.1-1992	1992	Gravimetric and Dust-Spot Procedures for Testing Air-Cleaning Devices Used in General Ventilation for Removing Particulate Matter
52.2-1999	1999	Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size
62-2001	2001	Ventilation for Acceptable Indoor Air Quality
American Society of Mechanical Engineers (ASME)		
A17.1-2004	2004	Safety Code for Elevators and Escalators
AG-1-2003	2003	Code on Nuclear Air and Gas Treatment
B1.20.1-1983	1983 (R 2001)	Pipe Threads, General Purpose (Inch)
B16.5-2003	2003	Pipe Flanges and Flanged Fittings NPS ½ Through NPS 24 Metric/Inch Standard – Revision of ASME B16.5-1996
B16.10-2000	2000 (R 2003)	Face-to-Face and End-to-End Dimension of Valves
B16.34-1996	1996	Valves – Flanged, Threaded and Welding End
B16.42-1998	1998	Ductile Iron Pipe Flanges and Flanged Fittings, Classes 150 and 300
B19.1	1995	Safety Standard for Air Compressor Systems
B30.2-2001	2001	Overhead and Gantry Cranes (Top Running Bridge, Single or Multiple Girder, Top Running Trolley Hoist)
B30.9-2003	2003	Slings
B30.10-1999	1999	Hooks
B30.11-1998	1998	Monorail and Underhung Cranes – Addenda A – July 15, 1999

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
B30.16-2003	2003	Overhead Hoists (Underhung)
B31.1-2004	2004	Power Piping
B31.3-2002	2002	Process Piping
B31.5-2001	2001	Refrigeration Piping and Heat Transfer Components
B36.10-2004	2004	Welded and Seamless Wrought Steel Pipe
B96.1-1999	1999	Welded Aluminum-Alloy Storage Tanks
MFC-3M-1989	1989 (R 1995)	Measurement of Fluid Flow in Pipes using Orifice, Nozzle and Venturi – Errata – September 1990
N45.2-1977	1977	QA Program Requirements for Nuclear Facilities (ANSI/AICHE N46.2-1977 see also NQA-1 and NQA-2)
N45.2.1-1980	1980	Cleaning of Fluid Systems and Associated Components for Nuclear Power Plants (See also NQA-1 and NQA-2)
N45.2.2-1978	1978	Packaging, Shipping, Receiving, Storage, and Handling of Items for Nuclear Power Plants, QA Cases – December 1978 (See also NQA-1 and NQA-2)
N45.2.6-1978	1978	Qualifications of Inspection, Examination and Testing Personnel for Nuclear Power Plants (See also NQA-1 and NQA-2)
N45.2.9-1979	1979	Requirements for the Collection, Storage, and Maintenance of QA Records for Nuclear Power Plants (See also NQA-1 and NQA-2)
N509-2002	2002	Nuclear Power Plant Air-Cleaning Units and Components
N510-1989	1989 (R 1995)	Testing of Nuclear Air-Treatment Systems – Errata: January 1991
NOG-1-2002	2002	Rules for Construction of Overhead and Gantry Cranes (Top Running Bridge, Multiple Girder)
NQA-1-1989	1989	Quality Assurance Program Requirements for Nuclear Facilities, with Addenda 1a-1989, 1b-1991, and 1c-1992 (Note: more recent versions exist)
NQA-1A-1999	1999	Addenda to ANSI/ASME NQA-1-1997 Edition Quality Assurance Requirements for Nuclear Facility Applications
NQA-2-1989	1989	Quality Assurance Requirements for Nuclear Facility Applications; Special Notice – June 1992 (Consolidated with NQA-1-1989 into NQA-1-1994 Edition)
PTC 6-1996	1996	Steam Turbines
PTC 6A-2000	2000	Appendix A to PT6, the Test Code for Steam Turbines
PTC 8.2-1990	1990	Centrifugal Pumps
PTC 17-1973	1973 (R 2003)	Reciprocating Internal-Combustion Engines

Table 1.9-22

Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
PTC 23-2003	2003	Atmospheric Water Cooling Equipment
PTC 25-2001	2001	Pressure Relief Devices
PTC 26-1962	1962	Speed Governing Systems for Internal Combustion Engine Generator Units
TDP-1-1998	1998	Recommended Practices for the Prevention of Water Damage to Steam Turbines Used for Electric Power Generation (Fossil)
TDP-2-1985	1985	Recommended Practices for the Prevention of Water Damage to Steam Turbines Used for Electric Power Generation (Nuclear)
BPVC Sec I	2004	Boiler & Pressure Vessel Code (BPVC) Section I, Power Boilers
BPVC Sec II	2004	BPVC Section II Part A Ferrous Material Part B Non-Ferrous Material Part C Welding Rods, Electrodes, and Filler Metals Part D Properties
BPVC Sec III	2004	BPVC Section III, Rules for Construction of Nuclear Power Plant Components Division 1: NB, NC, NCA, ND, NE, NF, NG Division 2: CC, NCA Code for Concrete Reactor Vessels and Containments
BPVC Sec V	2004	BPVC Section V: Nondestructive Examination
BPVC Sec VIII	2004	BPVC Section VIII: Div. 1 Rules for Construction of Pressure Vessels Div. 2 Pressure Vessel, Alternative Rules
BPVC Sec IX	2004	BPVC Section IX, Qualification Standard for Welding and Brazing Procedures Welder, Brazers and Welding and Brazing Operators
BPVC Sec XI	2004	BPVC Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components
BPVC OM Code	2004	BPVC Code for Operation and Maintenance of Nuclear Power Plants
ASME Steam Tables	1967	Thermodynamic and Transport Properties of Steam
American Society for Testing and Materials (ASTM)		
A36/A36M-04	2004	Standard Specification for Carbon Structural Steel
A106/A106M-04b	2004	Standard Specification for Seamless Carbon Steel Pipe for High Temperature Service
A126-04	2004	Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings
A240/A240M-05	2005	Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
A307-04	2004	Standard Specification for Carbon Steel Bolts and Studs, 60 000 PSI Tensile Strength
A325-04b	2004	Standard Specification for Structural Bolts, Steel, Heat Treated, 120/105 ksi Minimum Tensile Strength
A370-05	2005	Standard Test Methods and Definitions for Mechanical Testing of Steel Products
A395/A395M-99	1999 (R 2004)	Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures
A513-00	2000	Standard Specification for Electric-Resistance-Welded Carbon and Alloy Steel Mechanical Tubing
A516/A516M-05e1	2005	Standard Specification for Pressure Vessel Plates, Carbon Steel, for Moderate- and Lower-Temperature Service
A519-03	2003	Standard Specification for Seamless Carbon and Alloy Steel Mechanical Tubing
A530/A530M-04a	2004	Standard Specification for General Requirements for Specialized Carbon and Alloy Steel Pipe
A536-84	1984 (R 2004)	Standard Specification for Ductile Iron Castings
A572/A572M-04	2004	Standard Specification for High-Strength Low-Alloy Columbium-Vanadium Structural Steel
A576-90b	1990 (R 2000)	Standard Specification for Steel Bars, Carbon, Hot-Wrought, Special Quality
A615/A615M-05a	2005	Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement
A709/A709M-05	2005	Standard Specification for Carbon and High-Strength Low-Alloy Structural Steel Shapes, Plates, and Bars and Quenched-and-Tempered Alloy Structural Steel Plates for Bridges
A887-89	1989 (R 2004)	Standard Specification for Borated Stainless Steel Plate, Sheet, and Strip for Nuclear Application
B8-04	2004	Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft
B61-02	2002	Standard Specification for Steam or Valve Bronze Castings
B62-02	2002	Standard Specification for Composition Bronze or Ounce Metal Castings
C33	2003	Standard Specification for Concrete Aggregates
C150-05	2005	Standard Specification for Portland Cement
C260-01	2001	Standard Specification for Air-Entraining Admixtures for Concrete
C494/C494M-05	2005	Standard Specification for Chemical Admixtures for Concrete
C618-05	2005	Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete

Table 1.9-22

Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
D512-04	2004	Standard Test Methods for Chloride Ion In Water
D635-03	2003	Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position
D975Rev C-04	2004	Standard Specification for Diesel Fuel Oils
D3350	2004	Standard Specification for Polyethylene Plastics Pipe and Fittings Materials
D3843-00	2000	Standard Practice for Quality Assurance for Protective Coatings Applied to Nuclear Facilities
E84-04	2004	Standard Test Method for Surface Burning Characteristics of Building Materials
E119Rev. A-00	2000	Standard Test Methods for Fire Tests of Building Construction and Materials
E185-02	2002	Standard Practice for Design of Surveillance Programs for Light-Water Moderated Nuclear Power Reactor Vessels
E399-90	1990 (R 1997)	Standard Test Method for Plane-Strain Fracture Toughness of Metallic Materials
E621-94, E1	1994 (R 1999)	Standard Practice for Use of Metric (SI) Units in Building Design and Construction (Committee E-6 Supplement to E380)
E741-00	2000	Quality Standard Test Method for Determining Air Change in a Single Zone by Means of a Tracer Gas Dilution
E814-02	2002	Standard Test Method for Fire Tests of Through – Penetration Fire Stops
E1820-01	2001	Standard Test Method for Measurement of Fracture Toughness
SI 10-02	2002	International System of Units (SI): The Modern Metric System – Revision to IEEE/ASTM SI 10-1997
American Water Works Association (AWWA)		
C200-97	1997	Steel Water Pipe – 6 in. (150mm) and Larger, 2nd Edition
C203-02	2002	Coal-Tar Protective Coatings and Linings for Steel Water Pipelines – Enamel and Tape – Hot Applied
C303-02	2002	Reinforced Concrete Pressure Pipe, Steel Cylinder Type, Pretensioned for Water and Other Liquids
D100-96	1996	Welded Steel Tanks for Water Storage
American Welding Society (AWS)		
A4.2M/A4.2:97	1997	Standard Procedures for Calibrating Magnetic Instruments to Measure the Delta Ferrite Content of Austenitic and Duplex Ferritic-Austenitic Stainless Steel Weld Metal
D1.1/D1.1M:04	2004	Structural Welding Code – Steel – Errata 1:2004; Errata
D1.3:98	1998	Structural Welding Code - Sheet Steel - Errata
D1.4:98	1998	Structural Welding Code - Reinforcing Steel - Errata

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
D1.6:99	1999	Structural Welding Code – Stainless Steel
D9.1M/9.1:2000	2000	Sheet Metal Welding Code
D14.1:97	1997	Specification for Welding of Industrial and Mill Cranes and Other Material Handling Equipment
D14.6:96	1996	Specification for Welding of Rotating Elements of Equipment
Anti-Friction Bearing Manufacturers Association (ABMA)		
4-94	1994 (R 1999)	Tolerance Definition and Gaging Practices for Ball and Roller Bearings
9-90	1990	Load Ratings and Fatigue Life for Ball Bearings
11-90	1990 (R 1999)	Load Ratings and Fatigue Life for Roller Bearings
Consumer Electronics Association (CEA)		
EIA-RS-160	1951	Sound Systems
EIA-276-A-80	1980	Acceptance Testing of Dynamic Loud Speakers
EIA-278-B-76	1976	Mounting Dimensions for Loudspeakers
EIA-299-A-68	1968 (R 1975)	Loudspeakers, Dynamic, Magnetic Structures and Impedence
426-A-80	1980	Loudspeakers, Power Routing, Full Range
Cooling Technology Institute (CTI)		
ATC-105 (00)	2000	Acceptance Test Code for Water Cooling Towers
STD-146 (95)	1995	Standard for Water Flow Measurement
Electric Power Research Institute (EPRI)		
NP-3915	1985	Guidelines for Nuclear Power Plant Performance Data Acquisition
NP-4946-SR	1988	BWR Normal Water Chemistry Guidelines
NP-5380	1987	NCIG-01 – Visual Weld Acceptance Criteria for Structural Welding at Nuclear Power Plants, Revision 2, September 1987.
NP-5479	1993	Application Guidelines for Check Valves in Nuclear Power Plants, Revision 1
TR-102323	2004	Guidelines for Electromagnetic Interference Testing on Power Plants, Rev. 3
TR-103515-R2	2000	BWR Water Chemistry Guidelines
Electronic Components Assemblies Materials Association (ECA)		
310-D-92	1992	Cabinets, Racks, Panels, and Associated Equipment

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
405-72	1972 (R 1979)	Recommended Test Methods for Flutter Measurement of Instrumentation Magnetic Tape Recorder/Reproducers
Electronic Industries Alliance (EIA)		
EIA-RS-160-51	1951	Sound Systems (Also under CEA)
TIA-204-D-89	1989	Minimum Standard for Land Mobile Communications, FM or PM Receivers, 25-866 MHz
220-B-88	1988	Minimum Standards for Land Mobile Communications Continuous Tone-Controlled Squelch Systems (CTCSS)
276-A-80	1980	Dynamic Loudspeakers Acceptance Testing (Also under CEA)
278-B-76	1976	Mounting Dimensions for Loudspeakers (Also under CEA)
299-A-68	1968 (R 1975)	Loudspeakers, Dynamic, Magnetic Structures and Impedance (Also under CEA)
310-D-92	1992	Racks, Panels, and Associated Equipment (Also under ECA)
TIA-316-C-90	1990	Minimum Standards for Portable/Personal Radio Transmitters, Receivers, and Transmitter/Receiver Combinations, Land Mobile Communications FM or PM Equipment, 25-1000 MHz
374-A-02	2002	Land Mobile Signaling Standard (Also under TIA)
405-72	1972 (R 1979)	Flutter Measurement for Instrumentation Magnetic Tape Recorders/Reproducers (Also under CEA)
422-B	1994 (R 2000)	Electrical Characteristics of Balanced Voltage Digital Interface Circuits (Also under TIA as TIA/EIA-422-B-94)
426-A-80	1980	Loudspeakers, Power Rating, Full Range (Also under CEA)
450-78	1978	Standard Form for Reporting Measurement of Land Mobile, Base Station, and Portable/Personal Radio Receivers in Compliance with FCC Part 15 Rules (Also under TIA)
TIA/EIA-464-13-02	2002	Requirements for Private Branch Exchange (PB) Switching Equipment – Revision of TIA-464A and Incorporation of TIA-464-A-1 (Also under TIA)
TIA-4720000-A-93	1993	Generic Specification for Fiber Optic Cable
Fluid Controls Institute Inc. (FCI)		
FCI 70-2	2003	Quality Control Standard for Control Valve Seat Leakage
Hydraulic Institute (HI)		
ANSI/HI 9.8	1998	American National Standard for Centrifugal and Vertical Pump Intake Design
Various IDs	2000	Standards for Centrifugal, Rotary and Reciprocating Pumps

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
Illuminating Engineering Society of North America (IESNA)		
HB-9-00	2000	IESNA Lighting Handbook, 9th Edition – Errata July 29, 2004
RP-1-04	2004	Office Lighting
RP-7-01	2001	Lighting Industrial Facilities – ANSI Approved – Errata 2001; Errata July 20, 2004
RP-8-00	2000	Roadway Lighting – ANSI Approved – Errata July 20, 2004
Institute of Electrical and Electronics Engineers (IEEE)		
1-2000	2000	Recommended Practice – General Principles for Temperature Limits in the Rating of Electric Equipment and for the Evaluation of Electrical Insulation
7-4.3.2-2003	2003	IEEE Standard Criteria for Digital Computers in Safety Systems of Nuclear Power Generating Systems
32-1972	1972 (R 1997)	Standard Requirements, Terminology, and Test Procedure for Neutral Grounding Devices
67-1972	1972 (R 1980)	Guide for Operation and Maintenance of Turbine Generators
80-2000	2000	Guide for Safety in AC Substation Grounding
98-2002	2002	Standard for the Preparation of Test Procedures for Thermal Evaluation of Solid Electrical Insulating Materials
100-2000	2000	The Authoritative Dictionary of IEEE Standards Terms Seventh Edition
101-1987	1987 (R 2004)	Guide for the Statistical Analysis of Thermal Life Test Data
112-2004	2004	Standard Test Procedure for Polyphase Induction Motors and Generators
115-1995	1995 (R 2002)	Guide: Test Procedures for Synchronous Machines: Part I – Acceptance and Performance Testing, Part II – Test Procedures and Parameter Determination for Dynamic Analysis
122-1991	1991 (R 2003)	Recommended Practice for Functional and Performance Characteristics of Control Systems for Steam Turbine-Generator Units
142-1991	1991	Recommended Practice for Grounding of Industrial and Commercial Power Systems – Green Book Correction Sheet May 1993, Corrected Edition April 1996
281-1984	1984 (R 1994)	Standard Service Conditions for Power System Communication Equipment
300-1988	1988 (R 1999)	Standard Test Procedures for Semiconductor Charged-Particle Detectors
301-1988	1988 (R 1999)	Standard Test Procedures for Amplifiers and Preamplifiers Used with Detectors of Ionizing Radiation
308-2001	2001	Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
309-1999	1999	Standard Test Procedures and Bases for Geiger-Mueller Counters – ANSI N42.3
317-1983	1983 (R 2003)	Standard for Electric Penetration Assemblies in Containment Structures for Nuclear Power Generating Stations
323-2003	2003	Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations
336-1985	1985 (R 1991)	Standard Installation, Inspection and Testing Requirements for Power, Instrumentation, and Control Equipment at Nuclear Facilities
338-1987	1987 (R 2000)	Standard Criteria for the Periodic Surveillance Testing of Nuclear Power Generating Station Safety Systems
344-2004	2004	Recommended Practice for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations
352-1987	1987 (R 2004)	Guide for General Principles of Reliability Analysis of Nuclear Power Generating Station Safety Systems (including errata dated 4 April 1994)
379-2000	2000	Standard Application of the Single Failure Criterion to Nuclear Power Generating Station Safety Systems
381-1977	1977 (R 1984)	Standard Criteria for Type Tests of Class 1E Modules Used in Nuclear Power Generating Stations
382-1996	1996 (R 2004)	Standard for Qualification of Actuators for Power-Operated Valve Assemblies with Safety-Related Functions for Nuclear Power Plants
383-2003	2003	Standard for Qualifying Class 1E Electric Cables and Field Splices for Nuclear Power Generating Stations
384-1992	1992 (R 1998)	Standard Criteria for Independence of Class 1E Equipment and Circuits
387-1995	1995 (R 2001)	Standard Criteria for Diesel-Generator Units Applied as Standby Power for Nuclear Power Generating Stations
420-2001	2001	Standard for the Design and Qualification of Class 1E Control Boards, Panels, and Racks Used in Nuclear Power Generating Stations
450-2002	2002	Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications
484-2002	2002	Recommended Practice for Installation Design and Installation of Vented Lead-Acid Batteries for Stationary Applications
485-1997	1997 (R 2003)	Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications
497-2002	2002	Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations
519-1992	1992	Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
535-1986	1986 (R 1994)	Standard for Qualification of Class 1E Lead Storage Batteries for Nuclear Power Generating Stations
572-1985	1985 (R 2004)	Standard for Qualification of Class 1E Connection Assemblies for Nuclear Power Generating Stations
577-2004	2004	Standard Requirements for Reliability Analysis in the Design and Operation of Safety Systems for Nuclear Facilities
603-1998	1998	Standard Criteria for Safety Systems for Nuclear Power Generating Stations
622-1987	1987 (R 1994)	Recommended Practice for the Design and Installation of Electric Heat Tracing Systems for Nuclear Power Generating Stations
628-2001	2001	Standard Criteria for the Design, Installation, and Qualification of Raceway Systems for Class 1E Circuits for Nuclear Power Generating Stations
649-1991	1991 (R 2004)	Standard for Qualifying Class 1E Motor Control Centers for Nuclear Power Generating Stations
650-1990	1990 (R 1998)	Standard for Qualification of Class 1E Static Battery Chargers and Inverters for Nuclear Power Generating Stations
690-2004	2004	Standard for the Design and Installation of Cable Systems for Class 1E Circuits in Nuclear Power Generating Stations
730-2002	2002	Standard for Software Quality Assurance Plans – IEEE Computer Society Document
741-1997	1997 (R 2002)	Standard Criteria for the Protection of Class 1E Power Systems and Equipment in Nuclear Power Generating Stations
765-2002	2002	Standard for Preferred Power Supply (PPS) for Nuclear Power Generating Stations
802.1D-2004	2004	Standard for Local and Metropolitan Area Networks Media - Access Control (MAC) Bridges – IEEE Computer Society Document; Amendment 1: 802.1-17a September 23, 2004
802.3-2002	2002	Standard for Information Technology Telecommunications and Information Exchange Between Systems Local and Metropolitan Area Networks Specific Requirements Part 3: Carrier Sense Multiple Access with Collision Detection (CSMA/CD) Access Method and Physical Layer Specifications – IEEE Computer Society Document; Amendment AE: June 13, 2002; Amendment AK: February 9, 2004; Amendment AH: June 24, 2004
802.5-1998	1997 (R 2003)	Information Technology – Telecommunication and Information Exchange Between Systems- Local and Metropolitan Area Networks – Part 5: Token Ring Access Method and Physical Layer Specification – IEEE Computer Society Document; Corrigendum 802.5w-2000; Amendment 802.5v-2001; ISO/IEC 8802-5
828-2005	2005	Standard for Software Configuration Management Plans – IEEE Computer Society Document
829-1998	1998	Standard for Software Test Documentation – IEEE Computer Society Document

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
835-1994	1994 (R 2000)	Standard Power Cable Capacity Tables – Supersedes IPCEA P-46-246
944-1986	1986 (R 1996)	Recommended Practice for the Application and Testing of Uninterruptible Power Supplies for Power Generating Stations
946-2004	2004	Recommended Practice for the Design of DC Auxiliary Power Systems for Generating Stations
1012-2004	2004	Standard for Software Verification and Validation – IEEE Computer Society Document
1023-2004	2004	Recommended Practice for the Application of Human Factors Engineering to Systems, Equipment, and Facilities of Nuclear Power Generating Stations and Other Nuclear Facilities
1050-2004	2004	Guide for Instrumentation and Control Equipment Grounding in Generating Stations
1082-1997	1997 (R 2003)	Guide for Incorporating of Human Action Reliability Analysis for Nuclear Power Generating Stations
1205-2000	2000	Guide for Assessing, Monitoring and Mitigating Aging Effects on Class 1E Equipment Used in Nuclear Power Generating Stations
C2	2002	National Electrical Safety Code
C37.04-1999	1999	Standard Rating Structure for AC High-Voltage Circuit Breakers Amendment A: February 25, 2003
C37.04a-2003	2003	Amendment 1 – Capacitance Current Switching
C37.06-2000	2000	AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis - Preferred Ratings and Related Required Capabilities – Replaces NEMA C37.06-2000 (Also endorsed by ANSI)
C37.09-1999	1999	Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis
C37.010-1999	1999	Application Guide for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis (Also endorsed by ANSI)
C37.11-1997	1997 (R 2003)	Standard Requirements for Electrical Control for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis – Revision of ANSI C37.11-1979
C37.13-1990	1990 (R 1995)	Standard for Low-Voltage AC Power Circuit Breakers Used in Enclosures
C37.14-2002	2002	Standard for Low-Voltage DC Power Circuit Breakers Used in Enclosures
C37.16-2000	2000	Low-Voltage Power Circuit Breakers and AC Power Circuit Protectors - Preferred Ratings, Related Requirements, and Application Recommendations – Replaces NEMA C 37.16-2000 (Also endorsed by ANSI)
C37.17-1997	1997	American National Standard for Trip Devices for AC and General-Purpose DC Low-Voltage Power Circuit Breakers – Replaces NEMA C37.17-1997 (Also endorsed by ANSI)

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
C37.20.1-2002	2002	Metal-Enclosed Low-Voltage Power Circuit-Breaker Switchgear
C37.20.2-1999	1999	Standard for Metal-Clad Switchgear
C37.20.3-2001	2001	Metal-Enclosed Interrupter Switchgear
C37.21-1985	1985 (R 1998)	Control Switchboards
C37.32-2002	2002	High-Voltage Switches, Bus Supports and Accessories Schedule of Preferred Ratings Construction Guidelines and Specifications – Revision ANSI C37.32 – Now copyrighted by IEEE
C37.82-1987	1987 (R 2004)	Standard for Qualification of Switchgear Assemblies for Class 1E Applications in Nuclear Power Generating Stations
C37.90-1989	1989 (R 1994)	Standard for Relays and Relay Systems Associated with Electric Power Apparatus
C37.90.1-2002	2002	Standard for Surge Withstand Capability (SWC)
C37.98-1987	1987 (R 1999)	Standard for Seismic Testing for Relays
C37.100-1992	1992 (R 2001)	Standard Definitions for Power Switchgear
C37-101-1993	1993	Guide for Generator Ground Protection
C37-102-1995	1995	Guide for AC Generator Protection
C57.13-1993	1993 (R 2003)	Standard Requirements for Instrument Transformers
C57.12.00-2000	2000	Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers
C57.12.01-1998	1998	General Requirements for Dry-Type Distribution and Power Transformers Including those with Solid Cast and/or Resin-Encapsulated Windings
C57.12.51-1981	1981 (R 1998)	Requirements for Ventilated Dry-Type Transformers 501 kVa and Larger Three Phase, High-Voltage 601 to 34,500 volts Low Voltage 208Y/120 to 4160 volts (Also endorsed by ANSI)
C57.12.70-2000	2000 (R 2003)	Standard Terminal Markings and Connections for Distribution and Power Transformers
C57.12.80-2002	2002	Standard Terminology for Power and Distribution Transformers
C57.12.90-1999	1999	Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers
C57.15-1999	1999	Standard Requirements, Terminology, and Test Code for Step-Voltage Regulators
C57.93-1995	1995 (R 2001)	Guide for Installation of Liquid-Immersed Power Transformers

Table 1.9-22

Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
C63.4-2003	2003	American National Standard for Methods of Measurement of Radio-Noise Emissions from Radio-Noise Field Strength 0.015 to 25 Megacycles/Second, Low Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz – Revision 7 – ANSI C63.4-2001
N42.5-1965	1965 (R 1991)	Bases for GM Counter Tubes
N42.18-1980	1980 (R1991)	Specification and Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents-Re designation of N13.10-74
N320-1979	1979 (R 1993)	Performance Specifications for Reactor Emergency Radiological Monitoring Instrumentation
N323-1978	1978 (R 1993)	Radiation Protection Instrumentation Test and Calibration
N323A-1997	1997	Radiation Protection Instrumentation Test and Calibration, Portable Survey Instruments
Instrument Society of America (ISA)		
7.0.01-1996	1996	Quality Standard for Instrument Air (Formerly ANSI/ISA S70.01-1996)
67.02.01-1999	1999	Nuclear Safety-Related Instrument Sensing Line Piping and Tubing Standards for Use in Nuclear Power Plants (Formerly ANSI/ISA – 67.02-.01-1999)
d67.03.01-1997	Draft 1997	Standard for Light Water Reactor Coolant Pressure Boundary Leak Detection
67.04.01-2000	2000	Setpoints for Nuclear Safety-Related Instrumentation (Formerly ANSI/ISA – S67.04.01-2000)
International Code Council (ICC)		
IFC	2003	International Fire Code
IBC	2003	International Building Code
IMC	2003	International Mechanical Code
International Electrotechnical Commission (IEC)		
880	1986	Software for Computers in the Safety Systems of Nuclear Power Stations
880 Supplement 1 Draft	1996	Software for Computers in the Safety Systems of Nuclear Power Stations
International Standards of Organization (ISO)		
8802-3-00	2000	Information Technology – Telecommunications and Information Exchange Between Systems – Local and Metropolitan Area Networks – Specific Requirements – Part 3: Carrier Sense Multiple Access with Collision Detection (CSMA/CD) Access Method and Physical Layer Specifications – Sixth Edition; Supersedes IEEE Std. 802.3

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
Manufacturers Standardization Society of the Valve and Fittings Industry, Inc (MSS)		
SP 67A-02	2002	Butterfly Valves
National Electrical Manufacturers Association (NEMA)		
250-2003	2003	Enclosures for Electrical Equipment (1000 Volts maximum)
AB 3-2001	2001	Molded Case Circuit Breakers and Their Application
C18.1M, Part 1-2001	2001	Portable Primary Cells and Batteries with Aqueous Electrolyte – General and Specifications
C18.1M, Part 2-2003	2003	American National Standard For Portable Primary Cells and Batteries with Aqueous Electrolyte – Safety Standard
C37.46-2000	2000	High Voltage Expulsion and Current – Limitary Type Power Class Fuses and Fuse Disconnecting Switches – Now copyrighted by NEMA
C37.50-1989	1989 (R 1995)	Switchgear – Low-Voltage AC Power Circuit Breakers Used in Enclosures – Test Procedures
C37.51-2003	2003	Switchgear – Metal-Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies – Conformance Test Procedures
C57.12.51-1981	1981 (R 1998)	Requirements for Ventilated Dry – Type Power Transformers, 501kVA and Larger, Three-Phase, with High-Voltage 601 to 34,500 Volts, Low-Voltage 208Y/120 to 4160 Volts
CC 1-2002	2002	Electric Power Connection for Substations
ICS 1-2000	2000	Industrial Control and Systems: General Requirements
ICS 2-2000	2000	Industrial Control and Systems: Controllers, Contactors, and Overload Relays, 600 Volts – Addenda Errata May 23, 2002
ICS 2.3-1995	1995 (R 2002)	Instructions for the Handling, Installation, Operation and Maintenance of Motor Control Centers Rated Not More Than 600 Volts
ICS 3-1993	1993 (R 2000)	Industrial Control and Systems Factory Built Assemblies – Errata: October 25, 2004
ICS 4-2000	2000	Industrial Automation Control Products and Systems Sections Terminal Blocks
ICS 6-1993	1993 (R 2001)	Industrial Control Systems Enclosures
KS 1-2001	2001	Enclosed and Miscellaneous Distribution Equipment Switches (600 Volts Maximum)
LA 1-1992	1992 (R 1999)	Surge Arresters
MG 1-2003	2003	Motors and Generators, Revision 1: 2004
PB 1-2000	2000	Panelboards
PE 5-1996	1996 (R 2003)	Utility-Type Electric Battery Chargers

Table 1.9-22
Industrial Codes and Standards² Applicable to ESBWR

Code or Standard Number	Year	Title
SG 3-1990	1990	Low-Voltage Power Circuit Breakers
SG 4-2000	2000	Alternating-Current High-Voltage Circuit Breakers
SG 5-1990	1990	Power Switchgear Assemblies
SM 24-1991	1991 (R 2002)	Land-Based Steam Turbine Generator Sets 0 to 33,000 kW
ST 20-1992	1992 (R 1997)	Dry-Type Transformers for General Applications
VE 1-2002	2002	Metal Cable Tray Systems – CSA C22.2 No 126.1-02
WC 3-1980	1980	Rubber – Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy (ICEA S-19-81) (R 1986) Revision 1 – January 1983, Revision No. 2 – December 1984, Revision No. 3 – August 1986, Revision No. 4 – July 1987, Revision No. 5 – May 1988, Revision No. 6 – May 1989
WC 5-1992	1992	Thermoplastic-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy-Superseded by NEMA WC 70, WC 71, and WC 74; Supersedes ICEA S-61-402; Revision No. 1 – December 7, 1993; Revision No. 2 – December 1996
WC 7-1988	1988 (R 1991)	Cross-Linked-Thermosetting-Polyethylene-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy –Superseded by NEMA WC 70, WC 71, and WC 72; Supersedes ICEA NO. S-66-524; Revision No. 1 – September 1991; Revision 2 – July 16, 1992; Revision No. 3 – December 1996; Revision No. 4 – September, 1998
WC 8-1988	1988	Ethylene-Propylene-Rubber-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy – Superseded by NEMA WC 70, WC 71, and WC 74; Supersedes ICEA S-68-516; Revision No. 1 – September 1991; Revision No. 2 – July 1992; Revision No. 3 – December 1996
WC 51-2003	2003	Ampacities of Cables Installed in Cable Trays (Also known as ANSI/ICEA P-54-440)
National Fire Protection Association (NFPA)		
NFPA 10	2002	Standard for Portable Fire Extinguishers
NFPA 11	2002	Standard for Low-, Medium- and High-Expansion Foam Systems
NFPA 12	2000	Standard on Carbon Dioxide Extinguishing Systems
NFPA 13	2002	Standard for the Installation of Sprinkler Systems
NFPA 14	2003	Standard for the Installation of Standpipe and Hose Systems
NFPA 15	2001	Standard for Water Spray Fixed Systems for Fire Protection
NFPA 16	2003	Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems
NFPA 20	2003	Standard for the Installation of Stationary Pumps for Fire Protection

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
NFPA 22	2003	Standard for Water Tanks for Private Fire Protection
NFPA 24	2002	Standard for the Installation of Private Fire Service Mains and their Appurtenances
NFPA 30	2003	Flammable and Combustible Liquids Code
NFPA 37	2002	Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines
NFPA 50A	1999	Standard for Gaseous Hydrogen Systems at Consumer Sites
NFPA 69	2002	Standard on Explosion Prevention Systems
NFPA 70	2005	National Electrical Code
NFPA 72	2002	National Fire Alarm Code
NFPA 75	2003	Standard for the Protection of Information Technology Equipment
NFPA 80	1999	Standard for Fire Doors and Windows
NFPA 80A	2001	Recommended Practice for Protection of Buildings from Exterior Fire Exposures
NFPA 90A	2002	Standard for the Installation of Air-Conditioning and Ventilating Systems
NFPA 90B	2002	Standard for the Installation of Warm Air Heating and Air-Conditioning Systems
NFPA 91	2004	Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists and Noncombustible Particulate Solids
NFPA 92A	2000	Recommended Practice for Smoke-Control Systems
NFPA 101	2003	Life Safety Code
NFPA 101A	2004	Guide on Alternative Approaches to Life Safety
NFPA 110	2002	Standard for Emergency and Standby Power Systems
NFPA 204	2002	Standard for Smoke and Heat Venting
NFPA 214	2000	Standard on Water-Cooling Towers
NFPA 251	1999	Standard Methods of Tests of Fire Endurance of Building Construction and Materials
NFPA 252	2003	Standard Methods of Fire Tests of Door Assemblies
NFPA 255	2000	Standard Method of Test of Surface Burning Characteristics of Building Materials
NFPA 321	1991	Standard on Basic Classification of Flammable and Combustible Liquids – Incorporated into NFPA 30

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
NFPA 497	2004	Recommended Practice for the Classification of Flammable Liquids, Gases, or Vapors and of Hazardous (Classified) Locations for Electrical Installation in Chemical Process Areas
NFPA 750	2003	Standard on Water Mist Fire Protection Systems
NFPA 780	2004	Standard for the Installation of Lightning Protection Systems
NFPA 804	2001	Standard for Fire Protection for Advanced Light Water Reactor Electric Generating Plants
NFPA 1961	2002	Standard on Fire Hose
NFPA 1963	2003	Standard for Fire Hose Connections
NFPA 1964	2003	Standard for Spray Nozzles
NFPA 2001	2004	Standard for Clean Agent Fire Extinguishing Systems
Sheet Metal and Air Conditioning Contractors' National Association (SMACNA)		
1208	1990	HVAC Systems Duct Design, 3rd Edition
1481	1995	HVAC Duct Construction Standards – Metal and Flexible, 2nd Edition with Addendum No. 1, Nov. 1997
Steel Structures Painting Council (SSPC)		
PA-1-00	2000	Shop, Field and Maintenance Painting of Steel
PA-2-04	2004	Measurements of Dry Coating Thickness with Magnetic Gages
SP-1-82	1982	Solvent Cleaning (Editorial Changes September 1, 2000)
SP-5-00	2000	White Metal Blast Cleaning – NACE No. 1 - 2000
SP-6-00	2000	Commercial Blast Cleaning – NACE No. 3 -2000
SP-10-00	2000	Near-White Blast Cleaning – NACE No. 2 -2000
Telecommunications Industry Association (TIA)		
TIA/EIA-603-93	1993	Land Mobile FM or PM Communications Equipment Measurement and Performance Standards – Replaces TIA-204D, 2202-B, TIA-316-C, and 152-C; Addendum 1 – March 1988
374-A-02	2002	Land Mobile Signaling Standard
TIA/EIA-422-B-94	1994	Electrical Characteristics of Balanced Voltage Digital Interface Circuits
450-78	1978	Standard Form for Reporting Measurements of Land Mobile Base Station and Portable/Personal Radio Receivers in Compliance with FCC Part 15 Rules

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
TIA/EIA-464-B-02	2002	Requirements for Private Branch Exchange (PBX) Switching Equipment – Revision of TIA-464-A and Incorporation of TIA-464-A-1 (Also see TIA-464-C-2002)
464-C-2002	2002	Requirements for Private Branch Exchange (PBX) Switching Equipment
TIA-4720000-A-93	1993	Generic Specification for Fiber Optic Cable
Underwriters Laboratories, Inc. (UL)		
Directory	2004	Fire Protection Equipment Directory
1	2000	UL Standard for Safety Flexible Metal Conduit, 10th Edition (with revisions up to and including July 30, 2004)
6	2004	UL Standard for Safety Electrical Rigid Metal Conduit Steel, 13th Edition
44	1999	UL Standard for Thermoset-Insulated Wires and Cables, 15th Edition (Reprint with Revisions through and Including November 1, 2001)
50	1995	UL Standard for Safety Enclosures for Electrical Equipment, 11th Edition (Reprint with Revision through and Including September 12, 2003)
67	1993	UL Standard for Safety Panelboards, 11th Edition (Revisions through and Including November 3, 2003)
83	2003	UL Standard for Safety Thermoplastic-Insulated Wires and Cables, 12th Edition (Reprint with Revision through and Including March 1, 2004)
94	1996	UL Standard for Safety Tests for Flammability of Plastic Materials for Parts in Devices and Appliances, 5th Edition (Reprinted with Revisions through and Including December 12, 2003)
489	2002	UL Standard for Safety Molded-Case Circuit Breakers, Molded-Case Switches, and Circuit-Breaker Enclosures, 10th Edition (Reprint with Revisions through and Including May 28, 2004)
508	1999	UL Standard for Safety Industrial Control Equipment, 17th Edition (Reprint with Revisions through and Including December 2, 2003)
555	1999	UL Standard for Safety Fire Dampers, 6th Edition (Reprint with Revisions through and Including January 2, 2002)
651	1995	UL Standard for Safety Schedule 40 and 80 Rigid PVC Conduit, 6th Edition (Reprint with Revisions through and Including August 2, 2004)
797	2004	UL Standard for Safety Electrical Metallic Tubing – Steel, 8th Edition
845	1995	UL Standard for Safety for Motor Control Centers, 4th Edition (Reprint with Revisions through Including April 5, 2004)
875	2004	UL Standard for Safety Electric Dry-Bath Heaters, 8th Edition
886	1994	UL Standard for Safety Outlet Boxes and Fittings for Use in Hazardous (Classified) Locations, 10th Edition (Reprint with Revisions through and Including April 13, 1999)
900	2004	UL Standard for Safety Air Filter Units, 7th Edition

Table 1.9-22**Industrial Codes and Standards² Applicable to ESBWR**

Code or Standard Number	Year	Title
924	1995	UL Standard for Safety Emergency Lighting and Power Equipment, 8th Edition (Reprint with revisions through and Including July 11, 2001)
1096	1988	UL Standard for Safety Electric Central Air Heating Equipment, 4th Edition
1950	1995	UL Standard for Safety Information Technology Equipment, Including Electrical Business Equipment; Third Edition
Others		
CMAA70	2004	Crane Manufacturers Association of America, Specification No. 70
DEMA	—	Standard Practices for Low and Medium Speed Stationary Diesel and Gas Engines
Factory Mutual (FM)	—	Factory Mutual Approval Guide
390.02	1964	Gear Classification Manual by AGMA
HMR No. 52	1982	National Weather Service Publication: “Application of Probable Maximum Precipitation Estimates United States East of the 105th Meridan”
HEI	2002	Standards for Steam Surface Condenser, 9th Edition
SNT-TC-1A	1992	Recommended Practice for Non-Destructive Testing by American Society for Nondestructive Testing (Note 2001 version exists)
TEMA	1999	Standards of Tubular Exchanger Manufacturers Association, Eighth Edition
—	2000	Aluminum Design Manual by Aluminum Association

Notes:

Other Organizations that are Referenced Without Specific Standards Listed:

Department of Transportation (DOT)

Federal Aviation Administration (FAA)

Federal Occupational Safety and Health Administration (OSHA)

Table 1.9-23
NUREGs Referenced in ESBWR DCD

No.	Issue Date	Title	Comment/ Section where Discussed
75/014	10/1975	An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants (WASH-1400)	19.2
75/067	10/1975	Technical Report -- Investigation and Evaluation of Cracking in Austenitic Stainless Steel Piping of Boiling Water Reactor Plants	16B
0016 Rev. 1	01/1979	Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Boiling Water Reactors	11.1, 11.2, 12.2
0123		Standard Technical Specifications for General Electric Boiling Water Reactors (superceded by NUREG 1433 and 1434)	1.9
0138	11/1976	Staff Discussion of Fifteen Technical Issues Listed in Attachment to November 3, 1976, memorandum from Director, NRR to NRR Staff (PWR only – Not applicable to ESBWR)	1.9
0313 Rev. 2	6/1988	Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping	1.9, 1.11, 5.2
0324	09/1977 (Draft)	XOQDOQ Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations (superceded by NUREG/CR-2919)	2.3
0460	03/1980	Anticipated Transients Without Scram for Light Water Reactors	1.6, 15
0484 Rev. 1	05/1980	Methodology for Combining Dynamic Responses	3.9
0554	05/1979	Single-Failure-Proof Cranes for Nuclear Power Plants	1.9, 9.1
0562	06/1979	Fuel Rod Failure as a Consequence of Departure from Nucleate Boiling or Dryout	16B
0588	12/1979	Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment	1.11, 3.10, 3.11, 7.5
0609	01/1981	Asymmetric Blowdown Loads on PWR Primary Systems	6.2
0612	07/1980	Control of Heavy Loads at Nuclear Power Plants	1.11, 9.1
0619	4/1980	BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking	1.11, 3.9
0654	10/1980	Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants	9.5, 18.6, 19.2; COL Applicant
0660	5/1980	NRC Action Plan Developed as a Result of the TMI-2 Accident	1A
0661 Supp. 1	8/1982	Safety Evaluation Report – Mark I Containment Long-Term Program – Resolution of Generic Technical Activity A-7	1.11

Table 1.9-23
NUREGs Referenced in ESBWR DCD

No.	Issue Date	Title	Comment/ Section where Discussed
0694	06/1980	TMI-Related Requirements for New Operating Licenses	2.2, 7.1
0696	12/1980	Functional Criteria for Emergency Response Facilities	1A, 13.3; COL Applicant
0700 Rev. 2	03/2002	Human-System Interface Design Review Guidelines	1A, 18.1
0711 Rev. 2	01/2004	Human Factors Engineering Program Review Model	18.1, 18.11
0718	06/1981	Licensing Requirements for Pending for Construction Permits and Manufacturing License	1A, 1.9, 7.1, 8.1
0737	11/1980	Clarification of TMI Action Plan Requirements	1.9, 1.10, 1.11, 5.2, 5.4, 6.3, 7.1, 8.1, 11.5, 12.5, 13.5, 16, 18.1, 18.2, 18.4
0737 Supp.1	12/1982	Clarification of TMI Action Plan Requirements	7.9, 13.5, 16, 18.1, 18.4
0744 Rev. 1	10/1982	Resolution of the Task A-11 Reactor Vessel Materials Toughness Safety Issue	1.11, 3E
0775 Supp	12/1989	Issuance of Supplement to the Final Environmental Statement – Comanche Peak Steam Electric Station, Units 1 and 2	19.4
0783	11/1982	Suppression Pool Temperature Limits for BWR Containments	16
0800	7/1981	Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition	Throughout
0808	8/1981	Mark II Containment Program Load Evaluation and Acceptance Criteria	1.11
0927 Rev. 1	03/1984	Evaluation of Water Hammer Occurrence in Nuclear Power Plants	1.11
0933	06/2004	A Prioritization of Generic Safety Issues (Main Report and Supplements 1-28)	1.11, 6.2, 19.1
0974 Supp	8/1989	Supplement to the Final Environmental Statement – Limerick Generating Station, Units 1 and 2	19.4
1000	4/1983 8/1983	Generic Implications of ATWS Events at the Salem Nuclear Power Plant (Volumes 1 and 2)	1.11

Table 1.9-23
NUREGs Referenced in ESBWR DCD

No.	Issue Date	Title	Comment/ Section where Discussed
1048 Supp. 6	07/1986	Safety Evaluation Report Relating to the Operation of Hope Creek Generating Station	3.5
1061	1984- 1985	Report of the U.S. Nuclear Regulatory Commission Piping Review Committee," U.S. Nuclear Regulatory Commission, (Vol. 1) August 1984, (Vol. 2) April 1985, (Vol. 3) November 1984, (Vol. 4) December 1984, (Vol. 5) April 1985.	3.6, 3E
1116	1985	A Review of the Current Understanding of the Potential for Containment Failure from In-Vessel Steam Explosions	19.3
1150	01/1991	Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants	19.4
1367	11/1992	Functional Capability of Piping Systems	3.9
1433 Rev. 3	03/2004	Standard Technical Specifications General Electric Plants, BWR/4	1.9, 1.11
1434 Rev. 3	03/2004	Standard Technical Specifications General Electric Plants, BWR/6	1.9, 1.11, 16.0
1437	04/1996	Generic Environmental Impact Statement for License Renewal of Nuclear Plants	19.4
1465	1995	Accident Source Terms for Light-Water Nuclear Power Plants	3.11, 3H, 15.4
1482 Rev. 1		Guidelines for Inservice Testing at Nuclear Power Plants	3.9
1503	07/1994	Final Safety Evaluation Report Related to the Certification of the Advanced Boiling Water Reactor Design	15.0
1524	08/1996	Proceedings of the Second Steam Explosion Review Group (SERG-2) Workshop	19.3
1792	04/2005	Good Practices for Implementing Human Reliability Analysis (HRA)	18.7
BR-0058 Rev. 4	09/2004	Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission	19.4
CP-0024	03/1982	JI-R Curve Characteristics of Piping Material and Welds, Volume 3	3E
CR-0660	02/1979	Enhancement of Onsite Diesel Generator Reliability	1.9, 8.1
CR-0737		TMI Lessons Learned	8.1
CR-1119	06/1980	Piping Inelastic Fracture Mechanics Analysis	3E
CR-1278	08/1983	Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Applications	18.7, 19.2

Table 1.9-23
NUREGs Referenced in ESBWR DCD

No.	Issue Date	Title	Comment/ Section where Discussed
CR-1327	04/1980	Security Lighting Planning Document for Nuclear Fixed Site Facilities	9.5
CR-1677	08/1985	Piping Benchmark Problems Dynamic Analysis Independent Support Motion Response Spectrum Method	3D
CR-2239	12/1982	Technical Guidance for Siting Criteria Development	19.2, 19.4
CR-2300	01/1983	PRA Procedures Guide (Volumes 1 and 2)	19.2
CR-2861	11/1982	Image Analysis for Facility Siting: A Comparison of Low and High-Attitude Image Interpretability for Land Use/Land Cover Mapping	1.11
CR-2919	09/1982	XOQDOQ Computer Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations	12.2
CR-2963	06/1983	Planning Guidance for Nuclear Power Plant Decontamination	1.11
CR-3464	04/1983	The Application of Fracture Proof Design Postulating Circumferential Through-Wall Cracks	3E
CR-3740	04/1984	J-Integral Tearing Instability Analyses for 8-Inch Diameter ASTM A10.6 Steel Pipe	3E
CR-3908	12/1985	Survey of the State of the Art in Mitigation Systems	19.4
CR-4013	04/1986	LADTAP II Technical Reference and User Guide	12.2
CR-4025	08/1985	Design and Feasibility of Accident Mitigation Systems for Light Water Reactors	19.4
CR-4287	06/1985	Environmentally Assisted Cracking in Light Water Reactors: Annual Report, October 1983 – September 1984 (ANL-85-33)	5.2
CR-4551	12/1990	Evaluation of Severe Accident Risks: Quantification of Major Input Parameters, MACCS Input	19.2
CR-4575	09/1986	Predictions of JR Curves with Large Crack Growth from Small Specimen Data	3E
CR-4653	03/1987	GASPAR II Technical Reference and User Guide	12.2
CR-4772	02/1987	Accident Sequence Evaluation Program Human Reliability Analysis Procedure	18.7, 19.2
CR-4780	01/1988	Procedures for Treating Common-Cause Failures in Safety and Reliability Studies, (Volume 1)	19.2
CR-4920	7/1988	Assessment of Severe Accident Prevention and Mitigation Features	19.4
CR-5128	04/1991	Evaluation and Refinement of Leak Rate Estimation Models	3E
CR-5249	12/1989	Quantifying Reactor Safety Margins - Application of the Code Scaling, Applicability, and Uncertainty Evaluation Methodology to a Large-Break, Loss-of-Coolant Accident	1.5, 4D

Table 1.9-23
NUREGs Referenced in ESBWR DCD

No.	Issue Date	Title	Comment/ Section where Discussed
CR-5423	08/1991	The Probability of Liner Failure in a Mark-I Containment	19.3
CR-5497	10/1998	Common-Cause Failure Parameter Estimations	19.2
CR-5695	03/1991	A Process for Risk-Focused Maintenance	17.4
CR-5750	12/1998	Rates of Initiating Events at US Nuclear Power Plants: 1987-1995	15A, 19.2
CR-5801	04/1993	Procedure for Analysis of Common-Cause Failures in Probabilistic Safety Analysis	19.2
CR-6025	11/1993	The Probability of Mark-I Containment Failure by Melt-Attack of the Liner	19.3
CR-6075	12/1994	The Probability of Containment Failure by Direct Containment Heating in Zion	19.3
CR-6083	08/1993	Reviewing Real-Time Performance of Nuclear Reactor Safety Systems	7.1
CR-6090	09/1993	The PLC and Its Application in Nuclear Reactor Protection Systems	7.1
CR-6350	05/1996	A Technique for Human Error Analysis (ATHEANA)	18.7
CR-6613	05/1998	Code Manual for MACCS2: User's Guide	19.2
CR-6728	10/2001	Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-Consistent Ground Motion Spectra Guidelines	3.7
CR-6883	08/2005	The SPAR-H Human Reliability Analysis Method	18.7

Note: Table 1.9-23 has not yet been fully updated based on Revision 1 of all chapters.

1.10 SUMMARY OF COL ITEMS

Combined License applicants referencing the ESBWR certified design will be required to provide site-specific information, verification that the interface criteria are satisfied, information related to operating procedures, and other information required to support the ESBWR design certification. The description of information to be provided by the Combined License applicant is found in the DCD sections applicable to the specific information. Table 1.10-1 is a listing of the Combined License information items and the DCD location of the description of the information.

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Number of Plant Units	1.1.2.3
Confirm Rated Thermal and Electrical Power Output on a Site-Specific Basis	1.1.2.7
Turbine Bypass System Configuration (optional)	1.2.2.11.6
Standby On-Site AC Power Supply Configuration (optional)	1.2.2.13.4
Power Transmission	1.2.2.14
Intake and Discharge Structures	1.2.2.17.1
Site Security	1.2.2.18.2
Cooling Tower(s), Stack Location, Intake and Discharge Structures, Power Transmission and Site Security	1.2.3
As-Built Fuel and Core Design Data	Table 1.3-1
Potable and Sanitary Water	1.8.2.5
Conformance with Standard Review Plan	1.9.1
Applicability of Experience Information	1.9.3
SRP Deviations	1.9.4.1
Experience Information	1.9.4.2
Summary of Differences from SRP	Tables 1.9-8 thru 1.9-11, 1.9-13 and 1.9-18
NRC Standard Review Plans and Branch Technical Positions Applicability	Table 1.9-20
NRC Regulatory Guides Applicability to ESBWR	Table 1.9-21
NUREGs Referenced in ESBWR DCD	Table 1.9-23
Reliability of Open Cycle Service Water Systems	Table 1.11-1, Issue 51
Site Specific Environmental Impact Statement addressing Issues B-38 to B-41, B43 and C-16	Table 1.11-1
Prepare for Decommissioning of Unit at Appropriate Point in Plant Lifetime	Table 1.11-1, Item B-64
Compliance with 10 CFR 50.54, SRP 13.1.2 and Reg Guide 1.114	Table 1.11-1, Issue HF1.1

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Ensure Establishment of Interdisciplinary Design Review Group and Reviews for Site-Specific Design and Construction Work	Table 1.11-1, Issues HF5.1 and HF5.2
Address Various TMI Items in Table	Table 1A-1
Chemical Radiological Analysis	Table 1B-4
NRC Generic Communications	1C.1
Identify Additional Sources of Readily Available Water	1D.1
Provide Assurance that Site-Specific Design has Reliable Means to Refill IC/PCC and Spent Fuel Pool	1D.1
Prepare Update to PRA to Incorporate Site-Specific Design Elements and Frequencies	1D.2
Review Plant Against RTNSS Criteria in Table 1D-1 and Implement RTNSS Program as needed	1D.4
Site Characteristics	2.0
Site Location and Description	2.1.1
Exclusion Area Authority and Control	2.1.2
Population Distribution	2.1.3
Identification of Potential Hazards in Site Vicinity	2.2.1 – 2.2.2
Evaluation of Potential Accidents	2.2.3
Regional Climatology	2.3.1
Local Meteorology	2.3.2
Onsite Meteorological Measurement Programs	2.3.3
Short-Term Diffusion Estimates for Accidental Atmospheric Releases	2.3.4
Long-Term Diffusion Estimates	2.3.5
Hydrologic Description	2.4.1
Floods	2.4.2
Probable Maximum Flood on Streams and Rivers	2.4.3
Potential Dam Failures	2.4.4
Probable Maximum Surge and Seiche Flooding	2.4.5
Probable Maximum Tsunami Flooding	2.4.6

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Ice Effects	2.4.7
Cooling Water Canals and Reservoirs	2.4.8
Channel Diversions	2.4.9
Flooding Protection Requirements	2.4.10
Cooling Water Supply	2.4.11
Groundwater	2.4.12
Accidental Releases of Liquid Effluents in Ground and Surface Waters	2.4.13
Technical Specifications and Emergency Operation Requirements	2.4.14
Basic Geologic and Seismic Information	2.5.1
Vibratory Ground Motion:	2.5.2
Surface Faulting	2.5.3
Stability of Subsurface Materials and Foundations	2.5.4
Stability of Slopes	2.5.5
Site Location and Description Information in Accordance with SRP 2.1.1	Table 2.0-1
Site-Specific Exclusion Area Authority and Control Information in Accordance with SRP 2.1.2.	Table 2.0-1
Describe the Population Distribution in Accordance with SRP 2.1.3	Table 2.0-1
Identify Potential Hazards in the Site Vicinity, in Accordance with SRP 2.2.1 - 2.2.2	Table 2.0-1
Evaluation of Potential Accidents	Table 2.0-1
Regional Climatology	Table 2.0-1
Local Meteorology	Table 2.0-1
Onsite Meteorological Measurement Programs	Table 2.0-1
Short-Term Diffusion Estimates for Accidental Atmospheric Releases	Table 2.0-1
Long-Term Diffusion Estimates	Table 2.0-1
Hydraulic Description Maximum Ground Water Level	Table 2.0-1
Protection of Below-Grade Penetrations and Access Openings from Floods	Table 2.0-1
Probable Maximum Flood on Streams and Rivers	Table 2.0-1

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Potential Dam Failures Seismically Induced	Table 2.0-1
Probable Maximum Surge and Seiche Flooding	Table 2.0-1
Probable Maximum Tsunami	Table 2.0-1
Ice Effects	Table 2.0-1
Cooling Water Canals and Reservoirs	Table 2.0-1
Channel Diversion	Table 2.0-1
Flooding Protection Requirements	Table 2.0-1
Cooling Water Supply	Table 2.0-1
Groundwater	Table 2.0-1
Accidental Releases of Liquid Effluents in Ground and Surface Waters	Table 2.0-1
Technical Specifications and Emergency Operation Requirements	Table 2.0-1
Basic Geologic and Seismic Information	Table 2.0-1
Vibratory Ground Motion	Table 2.0-1
Surface Faulting	Table 2.0-1
Stability of Subsurface Materials and Foundations	Table 2.0-1
Stability of Slopes	Table 2.0-1
Provide a Description of the Switchyard	3.2.4 and Table 3.2-1
Site-Specific Design Basis Wind and Tornado	3.3.3.1
Ensure Remainder of Plant Structures, Systems and Components that are not Designed for Tornado Loads are Analyzed for Site-Specific Loadings	3.3.3.2
Evaluate Exposure to Water Spray	3.4.1.3
Detailed Flooding Evaluation	3.4.3
Submit Turbine System Maintenance Program including Probability Calculations of Turbine Missile Generation or Volumetrically Inspect All Low Pressure Turbine Rotors Every Other Refueling Outage	3.5.1.1.1.2
Evaluation of Nonsafety-related Structures, Systems, and Components (not housed in a tornado structure)	3.5.1.4
Confirm Low Probability of Site Proximity Missiles (Except Aircraft)	3.5.1.5

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Missiles Generated by Natural Phenomena from Remainder of Plant Structures, Systems, and Components	3.5.4.1
Site Proximity Missiles and Aircraft Hazards	3.5.4.2
Impact of Failure of Nonsafety-Related Structures, Systems and Components	3.5.4.3
Turbine System Maintenance Program	3.5.4.4
Protection of Main Steamline Isolation Valves and Feedwater Isolation and Check Valves from Postulated Pipe Failures	3.6.1.3
Leak Before Break Evaluation Report	3.6.3
Details of Pipe Break Analysis Results and Protection Methods	3.6.5
Seismic Design Parameters	3.7.5.1
Seismic Analysis of EBAS Building	3.7.5.2
Structural Integrity Pressure Test of Containment Structure	3.8.1.7.1
Other Seismic Category I Structures	3.8.4
Foundation Waterproofing	3.8.6.1
Site-Specific Physical Properties and Foundation Settlement	3.8.6.2
Structural Integrity Pressure Result	3.8.6.3
Identification of Seismic Category I Structures	3.8.6.4
Risk-Informed In-Service Testing	3.9.7
Risk-Informed In-Service Inspection of Piping	3.9.8
Reactor Internals Vibration Analysis, Measurement and Inspection Program	3.9.9.1
ASME Class 2 or 3 or Quality Group D Components with 60-Year Design Life	3.9.9.2
Pump and Valve Inservice Testing Program	3.9.9.3
Audit of Design Specification and Design Reports	3.9.9.4
Valves for Process Radiation Monitoring System, Containment Monitoring System and HVAC Systems in Reactor, Control and Fuel Buildings	Table 3.9-8
Equipment Qualification Records	3.10.4
Dynamic Qualification Report	3.10.4
Verify Gamma and Beta Doses Assumed in Analysis are Bounding	3.11.4
Environmental Qualification Document (EQD)	3.11.5

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Environmental Qualification Records	3.11.5
Drywell Pressurization: Vent Filter Design	3B.3.1.1
Gravity-Driven Cooling System Drain Pipe Design	3B.7.2
Lower Drywell Spillover Pipes	3B.7.3
Leak Before Break Evaluation Report	3.E.1.1
Radiation Environment Conditions Inside Containment Vessel for Accident Conditions	Table 3H-11
Radiation Environment Inside Reactor Building for Accident Conditions	Table 3H-12
Radiation Environment Conditions Inside Control Room Zone for Accident	Table 3H-13
Alternate Evaluation of Postulated Ruptures in High Energy Pipes	3J.1
Provide Fuel Design for Specific Application	4.2 and 4.2.5
Control Rod Design and Model	4.2.5
Demonstrate Stability for Different Fuel Design with NRC-Approved Methodology	4.3.2.2 and 4.3.2.3.1
Power Distribution	4.3.5.1
Thermal Hydraulic Stability	4.3.5.2
Thermal Limits	4.4.7.1
Control Rod Drive (CRD) Inspection Program	4.5.1.2.1 and 4.5.3.1
CRD Maintenance	4.6.2.1.4
Fine-Motion Control Rod Drive Procedures During Maintenance	4.6.6.1
Establish ESBWR-Specific Pressure Conditions for CRD System	Figure 4.6-9
Different Fuel Design Characteristics	4A.3
Develop Details of Detect and Suppress Solution	4D
Verify Stability of Final Core Design	4D.3
Confirm that NRC-Approved Detect and Suppress Solution is Implemented	4D.3
Verify Startup Procedures for Limiting Core and Bundle Power to Analysis Values	4D.3
Analysis of Anticipated Operational Occurrences (AOOs) for Each Core Loading	5.2.2.3.2

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Designing Reactor Coolant Pressure Boundary Components (excluding RPV) for Preservice and Inservice Inspection and Testing	5.2.4
Specify Applicable Edition of ASME Code	5.2.4
Designing Components for Accessibility for Preservice and Inservice Inspection	5.2.4.2
List Examination Category in Preservice and Inservice Inspection Programs	5.2.4.3.1
Inservice Inspection Program for Reactor Pressure Vessel	5.2.4.3.2
Overpressure Protection Analysis	5.2.6
Fracture Toughness	5.3.1.5
Positioning of Surveillance Capsules and Methods of Attachment	5.3.1.6.4
Fracture Toughness Data	5.3.4
Materials and Surveillance Capsule	5.3.4
Protective Coatings	6.1.2.1
Other Organic Materials	6.1.2.2
Protective Coatings and Organic Materials	6.1.3.1
Containment Penetration Leakage Rate Test (Type B)	6.2.6.2
Administrative Control Maintaining Containment Isolation	6.2.8.1
Wetwell-to-Drywell Vacuum Breaker Protection	6.2.8.2
Containment Penetration Leakage Rate Test (Type B)	6.2.8.3
Containment Isolation Valve Information for the Process Radiation Monitoring System	Table 6.2-42
Containment Isolation Valve Information for the Post Accident Sampling System	Table 6.2-43
Isolation Valve Provisions in the Influent Lines to the Containment	Table 6.2-44
Isolation Valve Provisions in the Effluent Lines from the Containment	Table 6.2-45
Containment Penetrations Subject to Type B Testing	Table 6.2-47
Acceptance Criteria for Emergency Core Cooling System (ECCS) Performance	6.3.3.2
Break Spectrum Calculations	6.3.3.7.3
Summary of ECCS Loss-of-Coolant Accident (LOCA) Performance Analysis Results	6.3.3.7.8

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
ECCS Performance Results	6.3.5.1
ECCS Testing Requirements	6.3.5.2
Limiting Break Results	6.3.5.3
Potential Site-Specific Toxic or Hazardous Materials That May Affect Control Room Habitability	6.4.5
Site Adequacy in regard to Neighboring Toxic or Hazardous Materials Shipping, Handling, or Storage	6.4.9
Development of Preservice and Inservice Inspection Program Plans	6.6
Specify Applicable Edition of ASME Code	6.6
Designing Class 2 and 3 Components for Accessibility for Preservice and Inservice Inspection	6.6.2
Examination Categories for Preservice and Inservice Inspection Programs	6.6.3.1
Nondestructive Testing Program to Verify Structural Integrity of Systems Susceptible to Single-Phase Erosion-Corrosion	6.6.7
Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping	6.6.10
Offsite Power System Description	8.1.5.1
Utility Power Grid Description	8.1.6.1
Offsite Power System Description	8.1.6.2
Compliance to Regulatory Requirements and Guidelines	8.1.6.3
On-Site Power System SRP Criteria Applicability Matrix	Table 8.1-1
Transmission System Description	8.2.4.1
Switchyard Description	8.2.4.2
Normal Preferred Power	8.2.4.3
Alternate Preferred Power	8.2.4.4
Unit Synchronization	8.2.4.5
Protective Relaying	8.2.4.6
Switchyard DC Power	8.2.4.7
Switchyard AC Power	8.2.4.8
Transformer Protection	8.2.4.9

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Stability of Off-Site Power Systems	8.2.4.10
Transmission System Reliability	8.2.4.11
Generator Circuit Breaker	8.2.4.12
Degraded Voltage	8.2.4.13
Interface Requirements	8.2.4.14
Load Shedding and Sequencing on Plant Investment Protection Buses	8.3.1.1.7
Standby On-site AC Power Supply System	8.3.1.1.8
Regulatory Requirements	8.3.2.2.2
Interrupting Capacity of Electrical Distribution Equipment	8.3.4.1
Defective Refurbished Circuit Breakers	8.3.4.2
Nonsafety-Related Standby Diesel Generator Load Table Changes	8.3.4.3
Minimum Starting Voltages for Class 1E Motors	8.3.4.4
Certified Proof Tests on Cable Samples	8.3.4.5
Associated Circuits	8.3.4.6
Electrical Penetration Assemblies	8.3.4.7
DC Voltage Analysis	8.3.4.8
Administrative Controls for Bus Grounding Circuit Breakers	8.3.4.9
Testing of Thermal Overload Bypass Contacts for Motor Operated Valves	8.3.4.10
Emergency Operating Procedures for Station Blackout	8.3.4.11
Periodic Testing of Power and Protection Systems	8.3.4.12
Common Industrial Standards Referenced in Purchase Specifications	8.3.4.13
Periodic Testing of Batteries	8.3.4.14
Regulatory Guide 1.160 – Maintenance Rule Development	8.3.4.15
Perform Ground Resistance Measurements	8A.1.3
Cathodic Protection	8A.2.3
New Fuel Storage Dynamic Analysis	9.1.1.1
Fuel Handling Procedures and Administrative Controls	9.1.1.3
Analysis of Natural Circulation Cooling in Spent Fuel Storage Racks	9.1.2.5

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Load Testing of Dryer/Separator and Magnetic Particle Testing of Welds after Load Tests	9.1.4.15
Fuel Racks Load Drop Analysis	9.1.4.18
Fuel Storage Racks Criticality Analysis	9.1.6
Fuel Racks Load Drop Analysis	9.1.6
Dynamic and Impact Analyses of New Fuel Storage Racks	9.1.6
Fuel Handling Procedural Control	9.1.6
Handling of Heavy Loads	9.1.6
Ultimate Heat Sink External Water Makeup Source	9.2.5
Cooling Water Systems	9.2.9.1
Station Water System	9.2.9.2
Ultimate Heat Sink Water Source	9.2.9.3
Potable and Sanitary Water System	9.2.9.4
Sanitary Waste Discharge Systems	9.2.9.5
Determine Need for Additional Sampling Points in Process Sampling System	9.3.2.2
Determine Final Size of Drywell Sump	9.3.3.2
Hydrogen and Oxygen Supply Systems	9.3.9.2
Oxygen Supply System	9.3.10.2
Determine Need for Zinc Injection System	9.3.11.2
Required Capacity of Auxiliary Boiler System	9.3.12.2
Process Sampling System	9.3.13.1
Equipment and Floor Drain System	9.3.13.2
Oxygen Injection System	9.3.13.3
Zinc Injection System	9.3.13.4
Auxiliary Boiler System	9.3.13.5
Process Sampling System Sampling Measurements	Table 9.3-1
Containment Inerting System	9.4.10.1
Major Equipment for CONAVS	Table 9.4-11
Fire Water Supply Piping, Yard Piping, and Yard Hydrants	9.5.1.5

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Compliance Review of As-Built Fire Protection System against Fire Hazards Analysis Assumptions	9.5.1.12
Connection between Plant Simulator, Emergency Operations Facility (EOF) and Technical Support Center (TSC) with Distributed Control and Information System (DCIS)	9.5.2.2
Security Power System	9.5.3.4
Diesel Generator (DG) Fuel Oil System Design	9.5.4.2
DG Jacket Waste Water System Design	9.5.5.2
DG Air Starting System Design	9.5.6.2
DG Lubrication System	9.5.7.2
DG Air Intake and Exhaust System	9.5.8.2
Fire Protection System	9.5.9.1
Communication Systems	9.5.9.2
Site Lighting	9.5.9.3
Diesel Generator Auxiliary Systems	9.5.9.4
Establish Fire Hazard Design Acceptance Criteria for Service Water Pump Building and Service Building	9A.1
Fire Area Separation and Fire Equipment Drawings	9A.2.2
Fire Zone Drawings for Yard Areas	9A.4.7
Design Service Water Pump Building Fire Protection Features	9A.4.8
Design Service Building Fire Protection Features	9A.4.9
Fire Hazards Analysis for Yard Areas	9A.5.7
Fire Protection Compliance for Service Water Pump House	9A.5.8
Fire Barrier and Piping Penetrations, Reactor Building	9A.6.1
Obtain Approvals for Underground Structures without Sprinkler Protection	9A.6.5
Obtain Approvals for Areas Lacking Exterior Access Openings for Fire Fighters, without Sprinkler Protection	9A.6.6
Fire Hazard Design Acceptance Criteria for the Service Water Pump Building and Service Building	9A.7.1
Drawings Showing the Fire Area Separation and Fire Protection Features for the Yard, Service Water Pump Building and Service Building	9A.7.2

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Fire Zone Drawings for Those Portions of the Yard Except for That Associated With Turbine and Electrical Building Equipment	9A.7.3
Service Water Pump Building Fire Protection Features	9A.7.4
Service Building Fire Protection Features	9A.7.5
Piping Penetration in the Reactor Building	9A.7.6
Obtain Approval for Alternative Method of Fire Protection for Underground Portions of the Reactor, Control and Fuel Buildings	9A.7.7
Obtain Approval for Alternative Method of Fire Protection for Nonsprinkled Reactor, Control and Fuel Buildings Involving Lack of Exterior Access Openings for Fire Department Personnel	9A.7.8
Design Features and Performance Characteristics of the Steam and Power Conversion System	10.1.2.1
Important Design Features and Performance Characteristics of the Steam and Power Conversion System	Table 10.1-1
Non-Safety Power Generation Design Bases	10.2.1.2
Extraction Non-return Valves	10.2.2.2
Fracture Toughness	10.2.3.2
Overspeed Design of Turbine Components	10.2.3.3
Turbine Inservice Inspection Program	10.2.3.5
Low Pressure Turbine Disk Fracture Toughness	10.2.5.1
Turbine Design Overspeed	10.2.5.2
Turbine Inservice Test and Inspection	10.2.5.3
Extraction Non-Return Values	10.2.5.4
Procedures to Avoid Steam Hammer and Discharge Loads	10.3.3
Procedures to Avoid Steam Hammer and Discharge Loads	10.3.7.1
Conformance with Regulatory Guide 1.71	10.3.7.2
Applicability of Regulatory Guide 1.33	10.4.2.2 & 10.4.3.2.1
Effluent Monitoring	10.4.3.5.1

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Alternate Configurations of the Turbine Bypass Valves	10.4.4.2.2
Instrumentation Applications – Analysis of Permanent Flow Meter Installation	10.4.5.5
Nonsafety-Related Power Generation Design Bases (Interface Requirements)	10.4.5.7.2
Radiological Analysis of the Turbine Gland Seal System Effluents	10.4.10.1
Turbine Bypass Valve Configuration	10.4.10.2
Applicability of Regulatory Guide 1.33	10.4.10.3
Circulating Water Flow	10.4.10.4
Main Condenser Data	Table 10.4-1
Alternative Design for Steam and Power Conversion System	10A.
Destructive Tests of Turbine Rotor Samples	10A.2.3.1 & 10A.2.5.1
Low Pressure Turbine Disk Fracture Toughness	10A.2.3.2
Turbine Design Overspeed	10A.2.3.4
Turbine In-Service Test and Inspection	10A.2.3.6
Generator Hydrogen and CO ₂ System Figure	Figure 10A.2-4
Turbine Bypass System Description Clarifications	10A.4.4.2
Radiological Analysis of the Turbine Gland Seal System Effluents	10A.4.10.1
Circulating Water System Data	Table 10A.4-3
Condensate and Feedwater System Data	Table 10A.4-5
Circulating Water Figure	Figure 10A.4-1
Signal Flow Chart for Turbine Bypass Control System	Figure 10A.4-6
Turbine Bypass System Figure	Figure 10A.4-11
Offgas System Data	11.3.8.1 and Table 11.3-2
Regulatory Guide 8.8	12.1.1.3.1

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Regulatory Guide 8.10	12.1.1.3.2
Regulatory Guide 1.8	12.1.1.3.3
Operational Considerations	12.1.3
Regulatory Guide 8.10	12.1.4.1
Regulatory Guide 1.8	12.1.4.2
Occupational Radiation Exposures	12.1.4.3
Regulatory Guide 8.8	12.1.4.4
Facility Design Features, including Materials Selection for Systems and Components Exposed to Reactor Coolant	12.3.1
Airborne Radionuclide Concentration Calculation	12.3.3.1
Detailed Information on Instrumentation Monitoring Airborne Radioactivity	12.3.4
Facility Design Features	12.3.7.1
Airborne Radionuclide Concentration Calculation	12.3.7.2
Operational Considerations	12.3.7.3
Radiation Protection Program	12.5.4.1
Equipment, Instrumentation, and Facilities	12.5.4.2
Compliance with Paragraph 50.34 (f) (xxvii) of 10 CFR 50 and NUREG-0737 Item III.D.3.3	12.5.4.3
Organizational Structure of Applicant	13.1
Reactor Operator Training	13.2.1
Training for Non-Licensed Plant Staff	13.2.2
Incorporation of Operating Experience into Training	13.2.3.1
Training Requirements for Preoperational and Low-Power Testing	13.2.3.2
Emergency Plan	13.3.2
Identification of Operational Support Center and Communication Interfaces with Control Room and Technical Support Center	13.3.3.1
Identification of Emergency Operations Facility and Communication Interfaces with Control Room and Technical Support Center	13.3.3.2
Decontamination Facilities	13.3.3.3
Conduct Reviews of Important Operating Phase Activities	13.4.1

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Administrative Procedures	13.5.1
Operating and Maintenance Procedures	13.5.2
Plant Operating Procedures Development Plan	13.5.3.1
Emergency Procedures Development	13.5.3.2
Implementation of the Plant Operating Procedures Development Plan	13.5.3.3
Procedures Included in Scope of Plan	13.5.3.4
Development of Comprehensive Site Security Plan	13.6.1
Security Organization Planning	13.6.1.1.1
Physical Barriers	13.6.1.1.2
Detection Aids	13.6.1.1.3
Communications	13.6.1.1.4
Access Controls	13.6.1.1.5
Security Lighting	13.6.1.1.6
Security Power Supply	13.6.1.1.7
Testing and Maintenance of Security System	13.6.1.1.8
Security Policies and Procedures	13.6.1.2
Physical Security Plan	13.6.1.3.1
Contingency Plan	13.6.1.3.2
Guard Force Training Plan	13.6.1.3.3
Physical Systems Security Design	13.6.1.3.4
Security System Testing and Maintenance	13.6.1.3.5
Organization and Staffing	14.2.1.4
Review and Approve Test Procedures	14.2.2
Request NRC Permission to Proceed with Fuel Loading	14.2.6
Test Program Schedule and Sequence	14.2.7
Initial Plant Test Program for Plant-Specific Systems	14.2.9
Startup Administration Manual	14.2.9
List of Tests Exempt from License Conditions	14.2.9

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
ITAACs for the Site-Specific Portions of the Plant	14.3
ITAACs for the Site-Specific Design Features that Implement the Interface Requirements	14.3
Programmatic Aspects of the Design and Construction Processes	14.3.2.1
Software Development Details	14.3.3.2
Interface Material	14.3.4
MCPR Operating Limit for As-built Initial and Reload Core Designs	15.0.4.3
Liquid-Containing Tank Failure	Table 15.0-2
Loss of Feedwater Heating Analysis	15.2.1.1.3
Closure of One Turbine Control Valve Analysis	15.2.2.1.3
Limiting Anticipated Operational Occurrences to Be Analyzed	15.2.7
Feedwater Controller Failure to Maximum Demand Analysis	15.3.2.3.2
Application of Generic Radiological Dose Assessment for Misloaded Fuel Bundles to Site Meteorological Characteristics	15.3.7
Rod Withdrawal Error (RWE) During Startup Confirmatory Analysis Result with the ESBWR Initial Core and Rod Group Assignments	15.3.8.3.1, 15.3.8.4.2 and 15.3.17
Fuel Handling Accident Assumptions	15.4.1.4.2
Loss-of-Coolant Accident Inside Containment Radiological Analysis Assumptions	15.4.4.5.7
Main Steamline Break Accident Outside Containment Assumptions	15.4.5.5.1
Feedwater Line Break Outside Containment Assumptions	15.4.7.5.4
RWCU/SDC System Line Failure Outside Containment Assumptions	15.4.9.5.4
Summary of Analysis Assumptions to Be Confirmed	15.4.11
Station Blackout	15.5.5
Replace Tech Spec Information in Brackets with Plant-Specific Information	16.0
Oscillation Range Power Monitor Trip Protection Algorithm (B 3.3.1.4)	16B
Application of Regulatory Guides 1.8 and 1.176	Table 17.0-1
Quality Assurance During the Operations Phase	17.2

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Quality Assurance Program Document	17.3
Specify Design Reliability Assurance Program (D-RAP) Policy and Implement D-RAP Procedures	17.4.1
Evaluate Reliability of Risk-Significant Structures, Systems and Components	17.4.7
Provide Operational Reliability Assurance Program (O-RAP) to NRC for Review	17.4.9
Policy and Implementation Procedures for Design Reliability Assessment Program	17.4.13.1
D-RAP Organization	17.4.13.2
Provision for Operational Reliability Assessment Program	17.4.13.3
Modify EPGs/SAGs in Appendices 18A through 18C as appropriate	18.1
Analysis of Information and Control Capability Needs of Main Control Room Operators	18.1.3.2
Validate Design of Each Main Control Room Standard Design Feature	18.1.4.1.1
Evaluate Effects of Automation Strategies on Operator Reliability and Consider Malfunctions of the Plant Automation System	18.1.4.1.6.1
Address Human Factors Aspects of Safety System Status Monitoring	18.1.4.1.8
Confirm Safety Parameter Display System Design Meets Applicable Criteria	18.1.4.1.11
Remote Shutdown System (evaluate alternate design approaches)	18.1.5
Plant Specific Reactor Building Operating Values for Emergency Procedure Guidelines and Severe Accident Guidelines (EPGs/SAGs)	18.1.8.1
EPG/SAG Appendix C: Calculation Input Data and Results	18.1.8.2
Human-System Interface Design Implementation Process	18.1.8.3
Number of Operators Needing Controls Access	18.1.8.3.1
Automation Strategies and Their Effect on Operator Reliability	18.1.8.3.2
Safety Parameter Display System Integration With Related Emergency Response Capabilities	18.1.8.3.3
Standard Design Features Design Validation	18.1.8.3.4
Remote Shutdown System Design Evaluation	18.1.8.3.5
Local Valve Position Indication	18.1.8.3.6
Operator Training	18.1.8.4

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Safety System Status Monitoring	18.1.8.5
Plant Automation System Malfunction	18.1.8.6
Local Control Stations	18.1.8.7
As-Built Evaluation of Main Control Room and Remote Shutdown System	18.1.8.8
Accident Monitoring Instrumentation	18.1.8.9
In-Core Cooling Instrumentation	18.1.8.10
Performance of Critical Tasks	18.1.8.11
Plant Status and Post-Accident Monitoring	18.1.8.12
Performance of HSI Verification and Validation on a Dynamic Simulator	18.1.8.13
Emergency Operation Information and Control	18.1.8.14
Supporting Analysis for Emergency Operation Information and Controls	18.1.8.15
Human Performance Monitoring	18.1.8.16
Full Scope Simulator	Figure 18.1-1
Training Program Development	18.10
Design Implementation	18.12
Human Performance Monitoring	18.13
Human Factors Engineering Design Team Composition	18.2.3
Reactor Building Temperature Operating Values for EPGs and SAGs	Table 18A-2
Reactor Building Radiation Level Operating Values for EPGs and SAGs	Table 18A-3
Reactor Building Water Level Operating Values for EPGs and SAGs	Table 18A-4
ESBWR EPG/SAG Input Data	18C
Emergency Operation Information and Controls	18F
Supporting Analysis for Emergency Operation Information and Controls	18H
Complete the COL Specific PRA	19
Further Design Details for BiMAC Cover Plate	19.3.5.2
Full Scale Testing of BiMAC	19.3.5.5
Maintenance and Testing of Components of Significance to Limiting Core Damage Frequency	19.5.2

Table 1.10-1
Summary of COL Items

Subject / Description of Item	Section
Procedures to Align Fire Protection System for Vessel Injection or IC/PCC Pool Makeup	19.5.10

Note: Table 1.10-1 has not yet been fully updated based on Revision 1 of all chapters.

1.11 TECHNICAL RESOLUTIONS OF TASK ACTION PLAN ITEMS, NEW GENERIC ISSUES, NEW GENERIC SAFETY ISSUES AND CHERNOBYL ISSUES

Consistent with 10 CFR 52.47, this section provides technical resolutions of Unresolved Safety Issues (USIs) and New Generic Issues, medium and high priority Generic Safety Issues (GSIs) that are identified in Table II of NUREG-0933 and its Supplements through Supplement 28, which are technically relevant to the ESBWR.

1.11.1 Approach

Each item and/or issue in Table II of NUREG-0933 is addressed in Table 1.11-1. 10 CFR 52.47(a)(1)(iv) requires the “Proposed technical resolutions of those Unresolved Safety Issues and medium- and high-priority Generic Safety Issues that are identified in the version of NUREG-0933 current on the date six months prior to application and that are technically relevant to the design,” be included in a DCD. In accordance with 10 CFR 52.47(a)(1)(iv), those issues that are not technically relevant to the ESBWR design are not necessarily addressed in detail.

Table 1.11-1 uses a series of notes, which are consistent with the 10 CFR 52.47(a)(1)(iv) requirement and the Legend and Notes of Table II of NUREG-0933, to disposition many of the items/issues.

- For issues that are not applicable to the 10 CFR 52.47(a)(1)(iv) requirement, Table 1.11-1 only provides notes explaining those conclusions.
- For issues specifically addressed elsewhere in Tier 2, Table 1.11-1 only provides cross-references to the applicable Tier 2 locations.
- For issues whose technical concerns are adequately addressed elsewhere in Tier 2, Table 1.11-1 only provides cross-references to the applicable Tier 2 locations.
- For issues whose technical concerns are only partially addressed elsewhere in Tier 2, Table 1.11-1 provides cross-references to the applicable Tier 2 locations and the additional information to provide their resolutions.

For issues whose technical concerns are not addressed elsewhere in Tier 2, Table 1.11-1 provides their technical resolutions.

Table 1.11-1**Resolutions To NUREG-0933 Table II Task Action Plan Items, New Generic Issues,
Human Factors Issues and Chernobyl Issues**

Notes:

- (1) Not applicable to the ESBWR design.
- (2) Combined Operating License applicant scope.
- (3) Issue Dropped as a generic issue.
- (4) Generically resolved with No New requirements, and thus, if required, would be addressed elsewhere in Tier 2. [Equivalent to NUREG-0933 Table II, Note 3b]
- (5) Issue is not a generic issue. [Equivalent to NUREG-0933 Table II, Note 5]
- (6) Adequately addressed by other (generic) issue(s)/item(s).
- (7) Environmental issue that is outside the scope of the DCD.
- (8) Resolution Resulted in the Establishment of New Regulatory Requirements (By Rule, SRP Change, or equivalent) and thus, if required, would be addressed elsewhere in Tier 2. [Equivalent to NUREG-0933 Table II, Note 3a]
- (9) LOW Safety Priority Ranking

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
TMI ACTION PLAN ITEMS		
All	See Appendix 1A	DCD Tier-2 Appendix 1A
TASK ACTION PLAN ITEMS		
A-1	Water Hammer	<p>This issue is considered resolved through compliance with appropriate revisions of Standard Review Plan (SRP) Subsections 3.9.3, 3.9.4, 5.4.6, 5.4.7, 6.3, 9.2.1, 9.2.2, 10.3 and 10.4.7, and with NUREG-0927, Rev. 1, consistent with the NRC resolution. As noted in Tables 1.9-3, 1.9-5, 1.9-6, 1.9-9, and 1.9-10, the ESBWR Standard Plant design complies with all of these SRP sections, and NUREG-0927, Rev. 1, respectively.</p> <p>The ESBWR design utilizes design features, such as keep-full system water lines, that preclude the occurrence of water hammer incidents.</p>
A-2	Asymmetric Blowdown Loads on Reactor Primary Coolant Systems	(1) PWR issue. Discussion of blowdown loads in ESBWR is addressed in Section 3.8, Appendices 3F and 3G.
A-3	Westinghouse Steam Generator Tube Integrity	(1) There are no steam generators in the ESBWR design.
A-4	CE Steam Generator Tube Integrity	(1) There are no steam generators in the ESBWR design.
A-5	B&W Steam Generator Tube Integrity	(1) There are no steam generators in the ESBWR design.
A-6	Mark I Short-Term Program	(1) The ESBWR containment design is not classified as a Mark I containment. All suppression pool hydrodynamic loads have been accounted for in the design of the ESBWR containment. See Section 3.8 and Appendix 3G.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-7	Mark I Long-Term Program	<p>(8)</p> <p>Although the ESBWR containment design is not classified as a Mark I containment, this issue is still valid and applicable to the ESBWR containment.</p> <p>This issue is considered resolved through compliance with SRP Subsection 6.2.1.1.C and NUREG-0661, Supp. 1, consistent with the NRC resolution, and compliance with Generic Letter (GL) 79-57. As noted in Table 1.9-6, the ESBWR Standard Plant design complies with SRP Section 6.2.1.1.C, which in turn references NUREG-0661, Supp. 1.</p> <p>During a postulated LOCA, drywell-to-wetwell flow of gas and steam/water mixture produces hydrodynamic loading conditions on the suppression pool (S/P) boundary. Also, SRV flow discharging into the S/P during SRV actuation produces hydrodynamic loading conditions on the pool boundary.</p> <p>The containment and its internal structures are designed to withstand all S/P dynamic loads, due to LOCA and SRV actuation events in combination with those from the postulated seismic events. The load combinations are described and specified in Section 3.8.</p> <p>A complete description of and diagrammatic representation of these loads is provided in Appendix 3B.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-8	Mark II Containment Pool Dynamic Loads Long-Term Program	<p>(8)</p> <p>Although the ESBWR containment design is not classified as a Mark II containment, this issue is still valid and applicable to the ESBWR containment.</p> <p>This issue is considered resolved through compliance with SRP Section 6.2.1.1.C and NUREG-0808, consistent with the NRC resolution. As noted in Table 1.9-6, the ESBWR Standard Plant design complies with SRP Section 6.2.1.1.C, which references NUREG-0808.</p> <p>During a postulated LOCA, drywell-to-wetwell flow of gas and steam/water mixture produces hydrodynamic loading conditions on the suppression pool (S/P) boundary. Also, SRV flow discharging into the S/P during SRV actuation produces hydrodynamic loading conditions on the pool boundary.</p> <p>The containment and its internal structures are designed to withstand all S/P dynamic loads, due to LOCA and SRV actuation events in combination with those from the postulated seismic events. The load combinations are described and specified in Section 3.8.</p> <p>A complete description of and diagrammatic representation of these loads is provided in Appendix 3B.</p>
A-9	ATWS	<p>(8) Subsections 9.3.5 and 15.5.4.</p> <p>This issue is considered resolved through compliance with 10 CFR 50.62. As noted within Subsection 15.5.4, the ESBWR Standard Plant design meets 10 CFR 50.62.</p> <p>Analyses of ATWS events and design features for ATWS prevention and mitigation incorporated in the ESBWR Standard Plant design can be found within Subsection 15.5.4.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-10	BWR Feedwater Nozzle Cracking	(8) Subsection 3.9.3.2. This issue is considered resolved through compliance with NUREG-0619, consistent with the NRC resolution, and compliance with Generic Letter (GL) 81-11.
A-11	Reactor Vessel Materials Toughness	(8) Subsections 5.3.1 through 5.3.3. This issue is considered resolved through compliance with NUREG-0744, Revision 1.
A-12	Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports	(1) There are no steam generators or reactor coolant pumps in the ESBWR design.
A-13	Snubber Operability Assurance	<p>(8) Subsections 3.9.3 and 3.9.3.7.1. This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 3.9.3, consistent with the NRC resolution. As noted in Table 1.9-3, the ESBWR Standard Plant design complies with SRP Section 3.9.3. The criteria for the structural and mechanical performance parameters used for snubbers and the installation and inspection consideration for the snubbers are as follows:</p> <p style="text-align: center;"><u>Snubber Design and Testing</u></p> <p>The snubbers are required by the pipe support design specification to be designed in accordance with ASME Code Section III, Subsection NF. The snubbers are tested to insure proper performance during seismic and other reactor building vibration events, and under anticipated operational transient loads or other mechanical loads associated with the design requirements of the plant.</p> <p style="text-align: center;"><u>Snubber Pre-service Examination</u></p> <p>The pre-service examination will verify the following:</p> <ul style="list-style-type: none"> • There are no visible signs of damage or impaired operability as a result of storage, handling, or installation.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<ul style="list-style-type: none"> The snubber location, orientation, position setting, and configuration are according to design drawings and specifications. Snubbers are not seized, frozen or jammed. Adequate swing clearance is provided to allow snubber movements. If applicable, fluid is to the recommended level and is not to be leaking from the snubber system. Structural components (e.g., pins, fasteners, etc.) are installed correctly. <p>If the period between the initial pre-service examination and initial system pre-operational tests exceeds 6 months, reexaminations of the first, fourth, and fifth items are performed. Snubbers that are installed incorrectly or otherwise fail to meet the above requirements will be prepared or replaced and re-examined in accordance with the above criteria.</p> <p>Refer to Subsection 3.9.3.7.1 for further details.</p>
A-14	Flaw Detection	(3)
A-15	Primary Coolant System Decontamination and Steam Generator Chemical Cleaning	(8) Issue resolved with publication of decontamination criteria in NUREG/CR-2963.
A-16	Steam Effects on BWR Core Spray Distribution	(1) There is no core spray in the ESBWR design.
A-17	Systems Interactions in Nuclear Power Plants	(4)
A-18	Pipe Rupture Design Criteria	(3)
A-19	Digital Computer Protection System	(5) See Chapter 7 for further details.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-20	Impacts of the Coal Fuel Cycle Description	(5)
A-21	Main Steam Line Break Inside Containment – Evaluation of Environmental Conditions for Equipment Qualification	(3)
A-22	PWR Main Steam Line Break – Core, Reactor Vessel, and Containment Building Response	(1) These are PWR issues that do not apply to the ESBWR design.
A-23	Containment Leak Testing	(5) Subsection 6.2.6
A-24	Qualification of Class 1E Safety-Related Equipment	<p>(8) Section 3.11.</p> <p>This issue is considered resolved through compliance with NUREG-0588, consistent with the NRC resolution, and compliance with 10 CFR 50.49. As noted in Subsection 3.11.2.2, the ESBWR Standard Plant design complies with NUREG-0588. The ESBWR Standard Plant design also meets the requirements of 10 CFR 50.49.</p> <p>Section 3.11 documents the qualification methods and procedures employed to demonstrate the capability of electrical equipment to perform their required functions when exposed to the environmental conditions in their respective locations. Limiting design conditions include normal operating, abnormal operating, test, accident, and post-accident conditions.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-25	Non-Safety Loads on Class 1E Power Sources	(8) Subsections 7.1.2.2, 8.1.5.2.4, 8.3.2.2.2. This issue is considered resolved through compliance with Regulatory Guide (RG) 1.75, consistent with the NRC resolution. As noted in Table 1.9-21a and Subsections 7.1.2.2, 8.1.5.2.4 and 8.3.2.2.2, the ESBWR Standard Plant design complies with RG 1.75. Refer to Subsections 7.1.2.2, 8.1.5.2.4 and 8.3.2.2.2 for further details.
A-26	Reactor Vessel Pressure Transient Protection	(1) This is a PWR issue that does not apply to the ESBWR design.
A-27	Reload Applications	(5)
A-28	Increase in Spent Fuel Pool Storage Capacity	ESBWR design incorporates high-density racks for storage of spent fuel. See Subsection 9.1.2 for further details.
A-29	Nuclear Power Plant Design for the Reduction of Vulnerability to Industrial Sabotage	(4)
A-30	Adequacy of Safety-Related DC Power Supplies	(6) Issue integrated into the resolution of Issue 128.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-31	RHR Shutdown Requirements	<p>(8) Subsections 5.4.6, 5.4.7, 5.4.8.</p> <p>This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 5.4.7, consistent with the NRC resolution. As noted in Table 1.9-5, the ESBWR Standard Plant design complies with SRP Section 5.4.7.</p> <p>The ESBWR does not have an historical RHR system. For normal shutdown and cooldown, residual and decay heat is removed via the main condenser and the RWCU/SDC System (refer to Subsection 5.4.8). The ICS provides cooling of the reactor when the RCPB becomes isolated following a scram during power operations. The ICS automatically removes residual and decay heat to limit reactor pressure within safety limits when the reactor isolation occurs (refer to Subsection 5.4.6).</p>
A-32	Missile Effects	(6) Addressed in Items A-37, A-38 and B-68.
A-33	NEPA Review of Accident Risks	(7)
A-34	Instruments for Monitoring Radiation and Process Variables During Accidents	(6) Resolution implemented via TMI Action Plan Item II.F.3. See Appendix 1A.
A-35	Adequacy of Offsite Power Systems	<p>(8) Subsections 8.1.2.2, 8.1.5.1, 8.1.6 and Section 8.2.</p> <p>This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 8.3.1, consistent with the NRC resolution. As noted in Table 1.9-8, the ESBWR Standard Plant design complies with SRP Section 8.3.1.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-36	Control of Heavy Loads Near Spent Fuel	<p>(2, 8)</p> <p>This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 9.1.5 and NUREG-0612, consistent with the NRC resolution. As noted in Table 1.9-9, the ESBWR Standard Plant design complies with SRP Section 9.1.5, which references NUREG-0612.</p> <p>The equipment utilized in the ESBWR Overhead Heavy Load Handling (OHLH) Systems, described in Subsection 9.1.5, are designed with consideration of radioactivity release, criticality accidents, inability to cool fuel within the reactor vessel or within the spent fuel pool, or prevention of safe shutdown of the reactor. Descriptions of the designs of the reactor building crane and other overhead load handling systems can be found in Subsection 9.1.5.2.</p> <p>In addition, a COL license information requirement is included (see Subsection 9.1.6) for NRC confirmatory spent fuel rack load drop analysis, which includes consideration of equipment maintenance procedures; equipment inspection; safe load paths and routing plans; heavy load handling operations controls; and operator qualification, training, and control.</p>
A-37	Turbine Missiles	(3)
A-38	Tornado Missiles	(3)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-39	Determination of Safety Relief Valve Pool Dynamic Loads and Temperature Limits	<p>(8) Appendix 3B.</p> <p>Although the ESBWR containment design is not classified as a Mark I, II or III containment, this issue is applicable to the ESBWR containment, because it is of the pressure-suppression type.</p> <p>This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 6.2.1.1.C. As noted in Table 1.9-6, the ESBWR Standard Plant design complies with SRP Section 6.2.1.1.C.</p> <p>During a postulated LOCA, drywell-to-wetwell flow of gas and steam/water mixture produces hydrodynamic loading conditions on the suppression pool (S/P) boundary. Also, SRV flow discharging into the S/P during SRV actuation produces hydrodynamic loading conditions on the pool boundary.</p> <p>The containment and its internal structures are designed to withstand all S/P dynamic loads, due to LOCA and SRV actuation events in combination with those from the postulated seismic events. The load combinations are described and specified in Section 3.8.</p> <p>A complete description of and diagrammatic representation of these loads is provided in Appendix 3B.</p>
A-40	Seismic Design Criteria	<p>(8) Sections/Subsection 3.2, 3.7, 3.8, 3.9.2.2, 3.10, and Appendices 3A, 3C and 3G.</p> <p>This issue is considered resolved through compliance with SRP Subsections 2.5.2, 3.7.1, 3.7.2 and 3.7.3, consistent with the NRC resolution. As noted in Tables 1.9-2 and 1.9-3 the ESBWR Standard Plant design complies with SRP Subsections 2.5.2, 3.7.1, 3.7.2 and 3.7.3.</p>
A-41	Long-Term Seismic Program	(4)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-42	Pipe Cracks in Boiling Water Reactors	<p>(8) Section 5.2.</p> <p>This issue is considered resolved through compliance with NUREG-0313, Rev. 2, consistent with the NRC resolution, and compliance with Generic Letter (GL) 88-01. As noted in Subsection 5.2.3.4.1, the ESBWR Standard Plant design complies with NUREG-0313.</p> <p>The ESBWR utilizes designs, materials and processes that will prevent IGSCC. This is accomplished with materials resistant to IGSCC (e.g., Type 316 Nuclear Grade stainless steel and stabilized nickel-base Alloy 600M and 182M), limits on sensitizing operations, heat treatment after sensitizing, and elimination of crevice conditions.</p>
A-43	Containment Emergency Sump Performance	(1) The ESBWR relies on passive methods rather than pumps for preventing core melt following a LOCA event.
A-44	Station Blackout	<p>(1) Subsection 15.5.5.</p> <p>The ESBWR does not require emergency AC power to achieve safe shutdown. Therefore, this issue is not applicable to the ESBWR Standard Plant design.</p>
A-45	Shutdown Decay Heat Removal Requirements	(4) The ESBWR capability in response to the NRC Policy Statement on Severe Accidents encompasses the NRC requirements for resolution of USI A-45. Therefore, this issue is considered resolved for the ESBWR Standard Plant design.
A-46	Seismic Qualification of Equipment in Operating Plants	(8) Seismic qualification of ESBWR equipment is described in Sections 3.7 and 3.10.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
A-47	Safety Implications of Control Systems	<p>(8) Addressed throughout Chapter 7.</p> <p>The automatic reactor vessel overfill protection is a feature of the Feedwater Control System (FWCS) described in Subsection 7.7.3. If the reactor water level rises to Level 8, then equipment protective action will trip the main turbine and reduce feedwater demand to zero. The feedwater pumps will be tripped if the water level continues to rise to Level 9. The trip logic for the FWCS overfill protection is part of the Reactor Protection System (RPS) Instrumentation. The ESBWR Standard Plant Technical Specifications (Chapter 16) provide surveillance requirements for the "reactor vessel water high-high, Level 8" function of the RPS Instrumentation.</p> <p>This issue is considered resolved for the ESBWR Standard Plant design.</p>
A-48	Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment	<p>(8) Subsection 6.2.5.</p> <p>The ESBWR containment is inerted and per 10 CFR 50.34(f)(2)(ix) can withstand the pressure and energy addition from 100% fuel cladding metal water reaction. Therefore, this issue is resolved for the ESBWR Standard Plant design.</p>
A-49	Pressurized Thermal Shock	(1) This is a PWR issue that is not applicable to the ESBWR design.
B-1	Environmental Technical Specifications	(7)
B-2	Forecasting Electricity Demand	(8)
B-3	Event Categorization	(3)
B-4	ECCS Reliability	(6) Covered under TMI Action Plan Item II.E.3.2
B-5	Ductility of Two-Way Slabs and Shells and Buckling Behavior of Steel Containments	(4)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-6	Loads, Load Combinations, Stress Limits	(4, 6, and 8), ESBWR loads and load combinations are addressed in Subsections 3.8.1.3, 3.8.2.3, 3.8.3.3, 3.8.4.3, 3.8.5.3, 3.9.2.2, 3.9.4.3, Appendices 3B and 3F. Resolution covered in Issue 119.1.
B-7	Secondary Accident Consequence Modeling	(3)
B-8	Locking out of ECCS Power-Operated Valves	(3)
B-9	Electrical Cable Penetrations of Containment	(4)
B-10	Behavior of BWR Mark III Containments	<p>(8) Although the ESBWR containment design is not classified as a Mark III containment, this issue is applicable to the ESBWR containment, because it is of the pressure-suppression type. However, the various core-cooling systems (e.g. ICS and GDCS) do not take suction from the suppression pool. These systems utilize dedicated pools.</p> <p>This issue is considered resolved through compliance with Standard Review Plan (SRP) Section 6.2.1.1.C, consistent with the NRC resolution. As noted in Table 1.9-6, the ESBWR Standard Plant design complies with SRP Section 6.2.1.1.C, Rev. 6.</p> <p>During a postulated LOCA, drywell-to-wetwell flow of gas and steam/water mixture produces hydrodynamic loading conditions on the suppression pool (S/P) boundary. Also, SRV flow discharging into the S/P during SRV actuation produces hydrodynamic loading conditions on the pool boundary.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<p>The containment and its internal structures are designed to withstand all S/P dynamic loads, due to LOCA and SRV actuation events in combination with those from the postulated seismic events. The load combinations are described and specified in Section 3.8.</p> <p>A complete description of and diagrammatic representation of these loads is provided in Appendix 3B.</p>
B-11	Subcompartment Standard Problems	(5)
B-12	Containment Cooling Requirements (Non-LOCA)	(4) Subsections 6.2.2, 7.3.2, 9.2.7 and 9.4.8.
B-13	Marviken Test Data Evaluation	(5)
B-14	Study of Hydrogen Mixing Capability in Containment Post-LOCA	(6) Covered under Item A-48.
B-15	Contempt Computer Code Maintenance	(3)
B-16	Protection Against Postulated Piping Failures in Fluid Systems Outside Containment	(6) Issue incorporated into Item A-18.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-17	Criteria for Safety-Related Operator Actions	(4) The ESBWR design satisfies the NRC requirements concerning automation of safety-related operator actions and operator response times. The ESBWR resolution is consistent with the ALWR resolution. For example, the ESBWR design requires no operator action earlier than 72 hours for any design basis accidents. The ESBWR design has eliminated the need for operator actions for several accidents/transients. In addition, advanced displays are utilized in the control room for monitoring and alarm functions for safety-related and nonsafety-related systems. Therefore, this issue is resolved for the ESBWR Standard Plant design.
B-18	Vortex Suppression Requirements for Containment Sumps	(1, 6) Issue is covered by Item A-43. ESBWR does not obtain ECCS water from containment sumps.
B-19	Thermal-Hydraulic Stability	(4)
B-20	Standard Problem Analysis	(5)
B-21	Core Physics	(3)
B-22	LWR Fuel	(3)
B-23	LMFBR Fuel	(1, 3) The ESBWR is not an LMFBR.
B-24	Seismic Qualification of Electrical and Mechanical Equipment	(6) Issue is covered by Item A-46.
B-25	Piping Benchmark Problems	(5)
B-26	Structural Integrity of Containment Penetrations	(4)
B-27	Implementation and Use of Subsection NF	(5)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-28	Radionuclide/ Sediment Transport Program	(7)
B-29	Effectiveness of Ultimate Heat Sinks	(5)
B-30	Design Basis Floods and Probability	(5)
B-31	Dam Failure Model	(3, 5)
B-32	Ice Effects on Safety- Related Water Supplies	(6) Addressed in the evaluation of Issue 153.
B-33	Dose Assessment Methodology	(5)
B-34	Occupational Radiation Exposure Reduction	(6) This item is covered under TMI Action Plan Item III.D.3.1, which was resolved with no new requirements being established.
B-35	Confirmation of Appendix I Models for Calculations of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light Water-Cooled Power Reactors	(5)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-36	Develop Design, Testing, and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Features Systems and for Normal Ventilation Systems	<p>(8) The ESBWR engineered safety features (ESFs) do not require a separate ventilation system. The ESBWR has no filter systems that perform safety-related functions following a design basis accident (DBA). The control room is provided with self-contained bottled air to maintain a safe control room atmosphere following a DBA as discussed in Section 6.4. Therefore, this issue, as it applies to ESF ventilation system air filtration and adsorption units, is not applicable to the ESBWR Standard Plant design.</p> <p>However, this issue, as it applies to normal ventilation system air filtration and adsorption units, is applicable to ESBWR and is considered resolved through compliance with Regulatory Guides 1.52 and 1.140, consistent with the NRC resolution. As noted in Table 1.9-21 and Subsection 14.2.3, the ESBWR Standard Plant design complies with RG 1.140. As noted in Tables 1.9-21 and 1.9-21a for RG 1.52, use of a passive plant-specific physically-based source term eliminates the need for additional systems.</p> <p>Design details of the normal ventilation system air filtration and adsorption units for the control room area, spent fuel pool area, radwaste area, turbine building, and reactor building can be found in Subsections 9.4.1, 9.4.2, 9.4.3, 9.4.4, and 9.4.6, respectively.</p>
B-37	Chemical Discharges to Receiving Waters	(5, 7)
B-38	Reconnaissance Level Investigations	(2, 3) Issue to be addressed in site-specific environmental impact statement.
B-39	Transmission Lines	(2, 3) Issue to be addressed in site-specific environmental impact statement.
B-40	Effects of Power Plant Entrainment on Plankton	(2, 3) Issue to be addressed in site-specific environmental impact statement.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-41	Impacts on Fisheries	(2, 3) Impact of power plant operation on fishery resources to be addressed in site-specific environmental impact statement.
B-42	Socioeconomic Environmental Impacts	(7)
B-43	Value of Aerial Photographs for Site Evaluation	(2, 7) Work completed to date on this issue is published in NUREG/CR-2861. COL applicant may make use of this methodology in preparing their site-specific environmental impact statement.
B-44	Forecasts of Generating Costs of Coal and Nuclear Plants	(4)
B-45	Need for Power-Energy Conservation	(6) This issue is covered in Item B-2
B-46	Costs of Alternatives in Environmental Design	(3)
B-47	Inservice Inspection of Supports – Classes 1, 2, 3, and MC Components	(3)
B-48	BWR Control Rod Drive Mechanical Failures	(8) The control rod drives used in the ESBWR design take into account the resolution of this item. See Subsection 4.5.1.
B-49	Inservice Inspection Criteria and Corrosion Prevention Criteria for Containments	(5)
B-50	Post-Operating Basis Earthquake Inspection	(1, 9) An Operating Basis Earthquake is no longer required to be considered in the licensing process.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-51	Assessment of Inelastic Analysis Techniques for Equipment and Components	(6) This item is covered by Item A-40.
B-52	Fuel Assembly Seismic and LOCA Responses	(6) This item is covered by Item A-2.
B-53	Load Break Switch	(5, 8)
B-54	Ice Condenser Containments	(1) The ESBWR does not have an ice condenser containment.
B-55	Improved Reliability of Target Rock Safety Relief Valves	<p>(4) ESBWR SRV reliability is assured through proper design, inspection, and testing.</p> <p>The ESBWR overpressure protection system (i.e., SRVs) is designed to satisfy the requirements of Section III of the ASME Code. The SRV malfunctions are addressed in Chapter 15, and the results show that in the case of an inadvertent SRV opening, the resulting transient is a mild depressurization and produces no significant challenge to the RCPB, containment, or integrity of the fuel.</p> <p>The inspection and testing of applicable SRVs utilizes a quality assurance program, which complies with Appendix B of 10 CFR 50. The SRVs are tested in accordance with quality control procedures to detect defects and to provide operability prior to installation. The valve manufacturer certifies that the design and performance requirements have been met.</p> <p>After installation at the plant, valve operability is verified during the preoperational test program as discussed in Chapter 14. The external and flange seating surfaces of the SRVs are 100% visually inspected whenever any valve is removed for maintenance or bench testing during normal plant shutdowns.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
B-56	Diesel Reliability	(1) The ESBWR uses passive safety-related systems that do not rely on availability of diesel generators.
B-57	Station Blackout	(1) This issue is covered in Item A-44.
B-58	Passive Mechanical Failures	(4)
B-59	(N-1) Loop Operation in BWRs and PWRs	(1) The ESBWR does not contain loops for reactor coolant flow.
B-60	Loose Parts Monitoring Systems	(4) Subsections 1.2.2.5.11, and 4.4.4
B-61	Allowable ECCS Equipment Outage Periods	(4)
B-62	Reexamination of Technical Bases for Establishing SLs, LSSSs, and Reactor Protection System Trip Functions	(3, 5)
B-63	Isolation of Low Pressure Systems Connected to the Reactor Coolant Pressure Boundary	(8) This issue is considered resolved through compliance with the latest revision of Standard Review Plan (SRP) Section 3.9.6. As noted in Table 1.9-3, the ESBWR Standard Plant design complies with SRP Section 3.9.6, Rev. 2. Subsection 7.6.1 describes high pressure/low pressure interlocks to prevent overpressurization of low pressure systems which are connected to high pressure systems.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<p>Portions of the GDSCS piping are considered part of the reactor coolant boundary and portions of the piping connect to the low pressure GDSCS pools. Positive means are provided in the system design to prevent reactor pressure from being transmitted to the low pressure portion of the GDSCS. Both mechanical means of isolation and system interlocks ensure that high pressure is not transmitted to the low pressure portions of the system.</p> <p>The only other high pressure/low pressure interface is the LPCI mode of the nonsafety-related Fuel and Auxiliary Pools Cooling System (FAPCS), which is described in Subsection 9.1.3.4.</p>
B-64	Decommissioning of Reactors	(2, 8) Decommissioning is not part of the design certification process and will be addressed by each ESBWR licensee as their unit approaches the end of its lifetime.
B-65	Iodine Spiking	(3)
B-66	Control Room Infiltration Measurements	<p>(8) This issue is considered resolved through compliance with Standard Review Plan (SRP) Sections 6.4 and 9.4.1. As noted in Table 1.9-6 and 1.9-9, the ESBWR Standard Plant design complies with SRP Sections 6.4 and SRP 9.4.1. Safe occupancy of the control room during abnormal conditions is provided for in the design. Adequate shielding is provided to maintain tolerable radiation levels in the control room in the event of a design basis accident for the duration of the accident.</p> <p>The control room ventilation system has redundant equipment and includes radiation, toxic and smoke detectors with appropriate alarms and interlocks. If any hazards exist at the normal control room ventilation intake, habitability is assured by the Emergency Breathing Air System (EBAS), which upon isolation of the control room habitability area provides a positive air purge.</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		In the unlikely event that the control room must be vacated and access is restricted, instrumentation and controls are provided outside the control room, which can be utilized to initiate reactor shutdown, maintain a safe shutdown condition and achieve subsequent cold shutdown of the reactor.
B-67	Effluent and Process Monitoring Instrumentation	(6, 8) One subtask covered under TMI Action Plan Item III.D.2.1. The remaining subtasks for this issue are considered resolved through compliance with Standard Review Plan (SRP) Sections 11.3, 11.4 and 15.7.3. As noted in Table 1.9-11 and 1.9-15, the ESBWR Standard Plant design complies with SRP Sections 11.3, 11.4 and 15.7.3.
B-68	Pump Overspeed During LOCA	(1) There are no recirculation pumps in the ESBWR design.
B-69	ECCS Leakage Ex-Containment	(6) This issue is covered by TMI Action Plan Item III.D.1.1. See Appendix 1A.
B-70	Power Grid Frequency Degradation and Effect on Primary Coolant Pumps	(1) There are no primary coolant pumps in the ESBWR design.
B-71	Incident Response	(6) Covered in TMI Action Plan Item III.A.3.1
B-72	Health Effects and Life-Shortening from Uranium and Coal Fuel Cycles	(5)
B-73	Monitoring for Excessive Vibration Inside the Reactor Pressure Vessel	(6) This issue is covered in Item C-12.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
C-1	Assurance of Continuous Long-Term Capability of Hermetic Seals on Instrumentation and Electrical Equipment	(8) This issue is considered resolved through compliance with NRC Memorandum and Order CLI-80-21 (dated May 27, 1980) and NUREG-0588, consistent with the NRC resolution. As noted in Table 7.5-1 and in Section 3.11, the ESBWR Standard Plant design complies with NUREG-0588. Refer to Section 3.11 for further details on qualification of safety-related electrical equipment.
C-2	Study of Containment Depressurization by Inadvertent Spray Operation to Determine Adequacy of Containment External Design Pressure	(1) The ESBWR design does not require/have a wetwell containment spray. Drywell spray requires manual initiation for ESBWR and is not credited in any analysis.
C-3	Insulation Usage within Containment	(6) Addressed in the resolution of Issue A-43.
C-4	Statistical Methods for ECCS Analysis	(8) The ESBWR analyses in Subsection 6.3.3 make use of statistical methodology.
C-5	Decay Heat Update	(8) The ESBWR analysis in Subsection 6.3.3 makes use of the improved decay heat model.
C-6	LOCA Heat Sources	(8)
C-7	PWR System Piping	(1) This is a PWR issue that is not applicable to ESBWR.
C-8	Main Steam Line Leakage Control Systems	(4)
C-9	RHR Heat Exchanger Tube Failures	(3)
C-10	Effective Operation of Containment Sprays in a LOCA	(1) The ESBWR design does not require/have a wetwell containment spray. Drywell spray requires manual initiation for ESBWR and is not credited in any analysis.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
C-11	Assessment of Failure and Reliability of Pumps and Valves	(4)
C-12	Primary System Vibration Assessment	(4)
C-13	Non-Random Failures	(6) This issue is addressed in issues A-9, A-17, A-30, A-35, B-56 and B-57.
C-14	Storm Surge Model for Coastal Sites	(3)
C-15	NUREG Report for Liquid Tank Failure Analysis	(3)
C-16	Assessment of Agricultural Land in Relation to Power Plant Siting and Cooling System Selection	(2, 3) Issue to be addressed in site-specific environmental impact statement.
C-17	Interim Acceptance Criteria for Solidification Agents for Radioactive Solid Wastes	(8) This issue is considered resolved through compliance with 10 CFR 61.56, consistent with the NRC resolution. As noted in Subsection 11.4.1, the ESBWR Standard Plant design meets the requirements of 10 CFR 61.
D-1	Advisability of a Seismic Scram	(3) The ESBWR design does not include a seismic scram.
D-2	Emergency Core Cooling System Capability for Future Plants	(3)
D-3	Control Rod Drop Accident	(4) See Subsection 15.4.6 for discussion of this event.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
NEW GENERIC ISSUES		
Issue 1	Failures in Air-Monitoring, Air-Cleaning, and Ventilating Systems	(3)
Issue 2	Failure of Protective Devices on Essential Equipment	(3)
Issue 3	Set Point Drift in Instrumentation	(4)
Issue 4	End-of-Life and Maintenance Criteria	(4)
Issue 5	Design Check and Audit of Balance-of-Plant Equipment	(6) Issue addressed under TMI Action Plan Item I.F.1. See Appendix 1A.
Issue 6	Separation of Control Rod from its Drive and BWR High Rod Worth Events	(4) See Section 15.4.6
Issue 7	Failures Due to Flow-Induced Vibrations	(3)
Issue 8	Inadvertent Actuation of Safety Injection in PWRs	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 9	Reevaluation of Reactor Coolant Pump Trip Criteria	(1) There are no reactor coolant pumps in the ESBWR design.
Issue 10	Surveillance and Maintenance of TIP Isolation Valves and Squib Charges	(1) There is no Traversing In-Core Probe (TIP) system in ESBWR. The Fixed In-Core Calibration System is applied as described in Appendix 7A.
Issue 11	Turbine Disc Cracking	(6) This issue is covered by Item A-37.
Issue 12	BWR Jet Pump Integrity	(1) There are no jet pumps in the ESBWR design.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 13	Small-Break LOCA from Extended Overheating of Pressurizer Heaters	(1) There is no pressurizer in the ESBWR design.
Issue 14	PWR Pipe Cracks	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 15	Radiation Effects on Reactor Vessel Supports	(4) Section 5.3
Issue 16	BWR Main Steam Isolation Valve Leakage Control Systems	(6) Issue has been combined with Item C-8
Issue 17	Loss of Offsite Power Subsequent to a LOCA	(3)
Issue 18	Steam-Line Break with Consequential Small LOCA	(1) PWR issue resolved in accordance with TMI Action Plan Item I.C.1.
Issue 19	Safety Implications of Non-safety Instrument and Control Power Supply Bus	(6) Issue included in the scope of broader efforts for Item A-47.
Issue 20	Effects of Electromagnetic Pulse on Nuclear Power Plants	(4)
Issue 21	Vibration Qualification of Equipment	(3)
Issue 22	Inadvertent Boron Dilution Events	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 23	Reactor Coolant Pump Seal Failures	(1) The ESBWR is a passive plant utilizing natural circulation and does not have a Reactor Coolant Pump.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 24	Automatic ECCS Switchover to Recirculation	(1) This is a PWR issue. The ESBWR design includes a passive ECCS that has no automatic switchover functions.
Issue 25	Automatic Air Header Dump on BWR Scram System	(1) In the ESBWR Fine Motion Control Rod Drive (FMCRD) design, described in Section 4.6, the water which scrams the control rod discharges into the reactor vessel and does not require a scram discharge volume, thus eliminating a potential source for common mode scram failure. Therefore, this issue is not applicable to the ESBWR Standard Plant design.
Issue 26	Diesel Generator Loading Problems Related to SIS Reset on Loss of Offsite Power	(6) This issue is covered under Issue 17.
Issue 27	Manual vs. Automated Actions	(6) This issue is covered under Item B-17
Issue 28	Pressurized Thermal Shock	(1, 6) PWR issue covered under Item A-49.
Issue 29	Bolting Degradation or Failure in Nuclear Power Plants	(4) Refer to Subsection 3.9.3, ASME Code Class 1, 2 and 3 Components, Component Supports and Core Support Structures for further details.
Issue 30	Potential Generator Missiles – Generator Rotor Retaining Rings	(3)
Issue 31	Natural Circulation Cooldown	(1, 6) This PWR issue is considered part of TMI Action Plan Item I.C.1.
Issue 32	Flow Blockage in Essential Equipment Caused by Corbicula	(6) This issue has been combined and evaluated with Issue 51.
Issue 33	Correcting Atmospheric Dump Valve Opening upon Loss of Integrated Control System Power	(1, 6) This PWR issue is covered in Item A-47.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 34	RCS Leak	(3)
Issue 35	Degradation of Internal Appurtenances in LWRs	(9)
Issue 36	Loss of Service Water	(4)
Issue 37	Steam Generator Overfill and Combined Primary and Secondary Blowdown	(1) There are no steam generators in the ESBWR design.
Issue 38	Potential Recirculation System Failure as a Consequence of Ingestion of Containment Paint Flakes or Other Fine Debris	(3)
Issue 39	Potential for Unacceptable Interaction between the CRD System and Non-Essential Control Air System	(1, 6) This issue is addressed in Issue 25.
Issue 40	Safety Concerns Associated with Pipe Breaks in the BWR Scram System	(1) In the ESBWR Fine Motion Control Rod Drive (FMCRD) design, described in Section 4.6, the water which scrams the control rod discharges into the reactor vessel and does not require a scram discharge volume, thus eliminating a potential source for common mode scram failure. Therefore, this issue is not applicable to the ESBWR Standard Plant design.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 41	BWR Scram Discharge Volume Systems	(1) In the ESBWR Fine Motion Control Rod Drive (FMCRD) design, described in Section 4.6, the water which scrams the control rod discharges into the reactor vessel and does not require a scram discharge volume, thus eliminating a potential source for common mode scram failure. Therefore, this issue is not applicable to the ESBWR Standard Plant design.
Issue 42	Combination Primary/Secondary System LOCA	(1) This PWR issue is covered by TMI Action Plan Item I.C.1. The ESBWR is a direct cycle plant.
Issue 43	Reliability of Air Systems	(8)
Issue 44	Failure of Saltwater Cooling System	(4, 6) Remaining generic issue covered by Issue 43. No new requirements for other parts of this issue.
Issue 45	Inoperability of Instrumentation Due to Extreme Cold Weather	(8) This issue is considered resolved through compliance with SRP Sections 7.1, 7.5 and 7.7 and Regulatory Guide (RG) 1.151. As noted in Table 1.9-7, the ESBWR Standard Plant design complies with SRP Sections 7.1, 7.5 and 7.7. Also, as noted in Table 1.9-21 and Section 7.1, the ESBWR Standard Plant design complies with RG 1.151.
Issue 46	Loss of 125 Volt DC Bus	(6) This issue is covered by Issue 76.
Issue 47	The Loss of Offsite Power	(4)
Issue 48	LCO for Class 1E Vital Instrument Buses in Operating Reactors	(6) Integrated into the resolution of Issue 128.
Issue 49	Interlocks and LCOs for Class 1E Tie-Breakers	(6) Integrated into the resolution of Issue 128.
Issue 50	Reactor Vessel Level Instrumentation in BWRs	(4)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 51	Proposed Requirements for Improving the Reliability of Open Cycle Service Water System	(1, 2) The water systems described in Section 9.2 (e.g., Plant Service Water System, Reactor Component Cooling Water System, Make-up Water System, Chilled Water System, Turbine Component Cooling Water System) are nonsafety-related and are not designed to cool any safety-related heat loads. The ESBWR post-accident heat removal is through passive means. Overall reliability of the design of these systems will be addressed as a COL item.
Issue 52	SSW Flow Blockage by Blue Mussels	(1) This issue has been combined with Issue 51.
Issue 53	Consequences of a Postulated Flow Blockage Incident in a BWR	(3)
Issue 54	Survey of Valve Operator-Related Events Occurring During 1978, 1979, and 1980	(6) Objectives of issue are met by TMI Action Plan Item II.E.6.1.
Issue 55	Failure of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand	(3)
Issue 56	Abnormal Transient Operating Guidelines as Applied to a Steam Generator Overfill Event	(1) There are no steam generators in the ESBWR design.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 57	Effects of Fire Protection System Actuation on Safety-Related Equipment	(4) The ESBWR Fire Protection System (FPS) described in Subsection 9.5.1 is designed in compliance with NUREG-0800, SRP 9.5.1 Branch Technical Position (BTP) SPLB 9.5-1. Therefore, this issue is resolved for the ESBWR Standard Plant design. Refer to Subsection 9.5.1 for further details.
Issue 58	Containment Flooding	(3)
Issue 59	Technical Specification Requirements for Plant Shutdown When Equipment for Safe Shutdown Is Degraded or Inoperable	(5)
Issue 60	Lamellar Tearing of Reactor Systems Structural Supports	(6) This issue is addressed as a subtask of Item A-12.
Issue 61	SRV Line Break Inside the BWR Wetwell Airspace of Mark I and II Containments	(4)
Issue 62	Reactor Systems Bolting Applications	(6) This issue was integrated into the resolution of Issue 29.
Issue 63	Use of Equipment Not Classified as Essential to Safety in BWR Transient Analysis	(3)
Issue 64	Identification of Protection System Instrument Sensing Lines	(4)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 65	Probability of Core-Melt Due to Component Cooling Water System Failures	(1, 6) Incorporated into the resolution of Issue 23. The ESBWR does not rely on component cooling water systems to prevent core melt.
Issue 66	Steam Generator Requirements	(1) There are no steam generators in the ESBWR design.
Issue 67	<u>Steam Generator Staff Actions</u>	(1) There are no steam generators in the ESBWR design, so in general this issue is not applicable. See rows below for discussion of various subtasks.
Issue 67.2.1	Integrity of Steam Generator Tube Sleeves	(1, 6) This PWR issue was addressed in the resolution of Issue 135.
Issue 67.3.1	Steam Generator Overfill	(1, 6) This PWR issue is covered by Item A-47 and TMI Action Plan Item I.C.1.
Issue 67.3.2	Pressurized Thermal Shock	(1, 6) This PWR issue is addressed in Item A-49.
Issue 67.3.3	Improved Accident Monitoring	<p>(8) This issue is considered resolved through compliance with Generic Letter (GL) 82-33, consistent with the NRC resolution. As noted in Table 1.9-4, the ESBWR Standard Plant design complies with GL 82-33.</p> <p>The ESBWR Standard Plant is designed in accordance with Regulatory Guide 1.97, Revision 3 (Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident). A detailed assessment of the Regulatory Guide, including the list of instruments, is found in Section 7.5.</p>
Issue 67.3.4	Reactor Vessel Inventory Measurement	(6) Addressed by implementation of TMI Action Plan Item II.F.2. See Appendix 1A for discussion of application of that item to ESBWR.
Issue 67.4.1	RCP Trip	(1, 6) The ESBWR has no reactor coolant pumps. Issue covered by TMI Action Plan Item II.K.3(5).

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 67.4.2	Control Room Design Review	(6) This issue is covered by TMI Action Plan Item I.D.1. See Appendix 1A and Chapter 18.
Issue 67.4.3	Emergency Operating Procedures	(6) This issue is covered by TMI Action Plan Item I.C.1. See Appendix 18A.
Issue 67.5.1	Reassessment of Radiological Consequences	(1) The ESBWR design does not include steam generators so the event discussed in this issue cannot occur for ESBWR.
Issue 67.5.2	Reevaluation of SGTR Design Basis	(1) A steam generator tube rupture event is not possible in an ESBWR.
Issue 67.5.3	Secondary System Isolation	(1, 3) The ESBWR is a direct cycle plant with no secondary system to isolate.
Issue 67.6.0	Organizational Responses	(6) This issue is covered by TMI Action Plan Item III.A.3.
Issue 67.7.0	Improved Eddy Current Tests	(6) This issue was integrated into the resolution of Issue 135.
Issue 67.8.0	Denting Criteria	(1, 6) The ESBWR has no steam generator tubes that could become dented. This issue was addressed in the resolution of Issue 135.
Issue 67.9.0	Reactor Coolant System Pressure Control	(1, 6) Specific issue deals with reducing pressure after a steam generator tube rupture and thus is not directly applicable to ESBWR. The issue was considered resolved under TMI Action Plan Items I.C.1(2,3) and Issue A-45. The ESBWR capability in response to the NRC Policy Statement on Severe Accidents encompasses the NRC requirements for resolution of USI A-45 (and Issue 67.9.0). Therefore, this issue is considered resolved for the ESBWR Standard Plant design.
Issue 67.10.0	Supplemental Tube Inspections	(1) The ESBWR has no steam generator tubes to inspect.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 68	Postulated Loss of Auxiliary Feedwater System Resulting from Turbine-Driven Auxiliary Feedwater Pump Steam Supply Line Rupture	(1, 6) This PWR issue was integrated into the resolution of Issue 124.
Issue 69	Make-Up Nozzle Cracking in B&W Plants	(1, 4) This issue only applies to B&W PWRs.
Issue 70	PORV and Block Valve Reliability	(8)
Issue 71	Failure of Resin Demineralizer Systems and their Effects on Nuclear Power Plant Safety	(3)
Issue 72	Control Rod Drive Guide Tube Support Pin Failures	(3)
Issue 73	Detached Thermal Sleeves	(8)
Issue 74	Reactor Coolant Activity Limits for Operating Reactors	(3)
Issue 75	Generic Implications of ATWS Events at the Salem Nuclear Plant	<p>(8) The reactor protection (trip) system (RPS) design for the ESBWR, described in detail in Subsection 7.2.1 of this DCD Tier-2, fully satisfies all NRC requirements indicated in Generic Letter 83-28 and in NUREG-1000.</p> <p>The RPS designs for BWRs are substantially different from the reactor trip system design used in Salem Unit 1. These differences were outlined in the NRC Staff Meeting on Generic Implications of Salem Events with General Electric Company on March 10, 1983. The basic differences between BWR designs, used at the time of the Salem events,</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<p>and the reactor trip system designs then used by PWRs, are described in Section 3.1.2.5 (and preceding Sections 3.1.2.2 to 3.1.2.4) and Table 3.1 of NUREG-1000, Volume 1.</p> <p>The ESBWR further improves upon the BWR RPS designs used at the time of the Salem ATWS events. The RPS is designed to provide reliable single-failure-proof capability to automatically or manually initiate a reactor scram while maintaining protection against unnecessary scrams resulting from single failures. The RPS remains single-failure-proof even when one entire division of channel sensors is bypassed and/or when one of the four automatic RPS trip logic systems is out-of-service. This is accomplished through the combination of fail-safe equipment design, the redundant two-out-of-four sensor channel trip decision logic, and the redundant two-out-of-four trip systems output scram logic arrangement utilized in the RPS design.</p> <p>The RPS has built-in redundancy in its design to satisfy the reliability and availability requirements of the system. A separate and diverse manual trip method is provided in the form of two manual trip systems. Actuation of both manual trip systems is required for a full reactor scram. Physical separation and electrical isolation between redundant portions of the RPS are provided by separated process instrumentation, separated racks, and either separated or protected panels and cabling.</p> <p>The ESBWR design addresses the ATWS rule of 10 CFR 50.62 and thus satisfies the regulatory objectives of "defense in depth". 10 CFR 50.62 provides the "requirements for reduction of risk from anticipated transients without scram (ATWS) events for light-water cooled nuclear power plants". The ESBWR design employs separate sensors and logic, which are independent and/or diverse from the RPS design, to monitor selected reactor parameters for</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<p>conditions that could be indicative of an ATWS event.</p> <p>The ESBWR design also includes an automatic Standby Liquid Control (SLC) system, which has a combined minimum flow capacity and boron content that exceeds the requirements as indicated in 10 CFR 50.62. The SLC system injection locations are designed to permit its function in a reliable manner.</p> <p>Based on the above statements, this issue is considered resolved for the ESBWR Standard Plant design.</p>
Issue 76	Instrumentation and Control Power Interactions	(3)
Issue 77	Flooding of Safety Equipment Compartments by Backflow through Floor Drains	(6) This issue was integrated into the resolution of Issue A-17.
Issue 78	Monitoring of Fatigue Transient Limits for Reactor Coolant System	<p>(4)</p> <p>The Technical Specifications for ESBWR follow the pattern of Standard Tech Spec such as NUREG-1433 and 1434. The ESBWR RCPB design includes the fatigue consideration from thermal cycles established for the operating design life of the reactor pressure vessel.</p> <p>Therefore, this issue is resolved for the ESBWR Standard Plant design.</p>
Issue 79	Unanalyzed Reactor Vessel Thermal Stress During Natural Convection Cooldown	(1, 4) This issue applies specifically to B&W PWRs. The thermal cycles discussed above in response to Issue 78 already consider the maximum RPV cooldown rate for ESBWR.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 80	Pipe Break Effects on Control Rod Drive Hydraulic Lines in the Drywells of BWR Mark I and II Containments	(1) The ESBWR Containment and layout of CRD hydraulic lines are markedly different from Mark I and II Containments. The concerns associated with this issue have been addressed in the design of the ESBWR Containment and CRD hydraulic lines.
Issue 81	Impact of Locked Doors and Barriers on Plant and Personnel Safety	(9)
Issue 82	Beyond Design Basis Accidents in Spent Fuel Pools	(4)
Issue 83	Control Room Habitability	<p>(4) ESBWR control room habitability is addressed and described in detail in Section 6.4. The ESBWR Control Room Habitability Area (CRHA) includes instrumentation and controls necessary for safe shutdown of the plant and is limited to those areas requiring operator access during and after a Design Basis Accident (DBA). The CRHA constitutes the operation control area, which can be isolated for an extended period if such is required by the existence of a LOCA or high radiation condition.</p> <p>The control room shielding design is based upon protecting personnel from radiation resulting from a design basis LOCA.</p> <p>The Control Room Habitability Area Heating, Ventilation, and Air Conditioning System (CRHAHVS) instrumentation is designed to detect, and automatically isolate the CRHA upon detection of, high airborne radioactivity, toxic gases, or smoke. The CRHAHVS is designed to remove smoke or other airborne hazardous materials from the control room or other areas of the control room habitability area (purge mode), provided that the outside air is free of airborne hazardous materials. The CRHAHVS can also filter recirculating air without outside air make-up (recirculation mode).</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		These design features resolve this issue for the ESBWR Standard Plant design.
Issue 84	CE PORVs	(1, 4) This is specifically an issue for CE PWRs. ESBWR design features for providing overpressure protection are discussed in Subsections 5.2.2 and 5.4.13.
Issue 85	Reliability of Vacuum Breakers Connected to Steam Discharge Lines Inside BWR Containments	(3)
Issue 86	Long Range Plan for Dealing with Stress Corrosion Cracking in BWR Piping	(8) This issue is considered resolved through compliance with NUREG-0313, Rev. 2 and Generic Letter (GL) 88-01, consistent with the NRC resolution. As noted in Subsection 5.2.3.4.1, the ESBWR Standard Plant design complies with NUREG-0313, Rev. 2.
Issue 87	Failure of HPCI Steam Line without Isolation	(1) There is no HPCI system in the ESBWR design.
Issue 88	Earthquakes and Emergency Planning	(4)
Issue 89	Stiff Pipe Clamps	(9 for existing plants only) This issue will be considered during detailed design of Class 1 piping for ESBWR.
Issue 90	Technical Specifications for Anticipatory Trips	(3)
Issue 91	Main Crankshaft Failures in Transamerica Delaval Emergency Diesel Generators	(4) The ESBWR design includes nonsafety-related Standby Diesel Generators instead of safety-related Emergency Diesel Generators.
Issue 92	Fuel Crumbling During LOCA	(3)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 93	Steam Binding of Auxiliary Feedwater Pumps	(1) The ESBWR does not include Auxiliary Feedwater Pumps or any other pumps that might experience steam binding.
Issue 94	Additional Temperature Overpressure Protection for Light Water Reactors	(1, 8) PWR issue. ESBWR design features for providing overpressure protection are discussed in Subsections 5.2.2 and 5.4.13.
Issue 95	Loss of Effective Volume for Containment Recirculation Spray	(4)
Issue 96	RHR Suction Valve Testing	(1, 6) PWR issue that has been integrated into resolution of Issue 105.
Issue 97	PWR Reactor Cavity Uncontrolled Exposures	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 98	CRD Accumulator Check Valve Leakage	(3)
Issue 99	RCS/RHR Suction Line Valve Interlock on PWRs	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 100	Once-Through Steam Generator Level	(1) This is a PWR issue that is not applicable to ESBWR.
Issue 101	BWR Water Level Redundancy	(4)
Issue 102	Human Error in Events Involving Wrong Unit or Wrong Train	(4)
Issue 103	Design for Probable Maximum Precipitation	(8) The maximum flood level for the ESBWR design is 0.3 m (1 foot) below grade, which is consistent with the NRC recommendation. The developed NOAA/NWS procedures from Generic Letter 89-22 will be used for determining PMP for a specific site. Therefore, this issue is resolved for the ESBWR Standard Plant design.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 104	Reduction of Boron Dilution Requirements	(1) This is a PWR issue that is not applicable to the ESBWR design.
Issue 105	Interfacing Systems LOCA at LWRs	<p>(4)</p> <p>Subsection 7.6.1 describes high pressure/low pressure interlocks to prevent overpressurization of low pressure systems which are connected to high pressure systems.</p> <p>Portions of the GDCS piping are considered part of the reactor coolant boundary and portions of the piping connect to the low pressure GDCS pools. A positive means is provided in the system design to prevent reactor pressure from being transmitted to the low pressure portion of the GDCS. Both mechanical means of isolation and system interlocks ensure that high pressure is not transmitted to the low pressure portions of the system.</p> <p>The only other high pressure/low pressure interface is the LPCI mode of the nonsafety-related Fuel and Auxiliary Pools Cooling System (FAPCS), which is described in Subsection 9.1.3.4.</p> <p>Based on system design and testing procedure evaluations from the point of view of interfacing system LOCA and overpressurization of low pressure systems, the following conclusions are reached:</p> <ul style="list-style-type: none"> • The low pressure portions of the system are adequately protected from high pressure during normal plant operation. • Interlocks on the valves are provided that allow operability testing of valves during normal plant operation or under cold shutdown conditions. • Isolation of the high/low pressure systems is maintained during valve testing.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<ul style="list-style-type: none"> Isolation of the high/low pressure systems is maintained under the condition of an inadvertent opening of a valve due to an electrical failure. ALWR requirements imposed on ESBWR for high/low pressure interface design for systems are met. The system design pressures requirements imposed by ALWR are met. <p>The overall conclusion is that the concerns identified in GSI 105, "Interfacing Systems LOCA at LWRs," are resolved for ESBWR.</p>
Issue 106	Piping and the Use of Highly Combustible Gases in Vital Areas	(4) This issue is considered resolved through compliance with SRP Section 9.5.1, consistent with the NRC resolution. Table 1.9-9 summarizes ESBWR Standard Plant design compliance with SRP Section 9.5.1, and notes some differences to acceptance criteria along with references to Subsections where the differences are discussed. Refer to Subsection 9.5.1 for further details.
Issue 107	Main Transformer Failures	(9 for existing plants only) This issue will be considered during detailed design of the ESBWR electrical systems. See Chapter 8.
Issue 108	BWR Suppression Pool Temperature Limits	(9)
Issue 109	Reactor Vessel Closure Failure	(3)
Issue 110	Equipment Protective Devices on Engineered Safety Features	(3)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 111	Stress Corrosion Cracking of Pressure Boundary Ferritic Steels in Selected Environments	(5)
Issue 112	Westinghouse RPS Surveillance Frequencies and Out-of-Service Times	(1) This is a Westinghouse PWR issue that is not applicable to ESBWR.
Issue 113	Dynamic Qualification Testing of Large Bore Hydraulic Snubbers	(4) Regulatory Guide may eventually be developed addressing this issue for new plants.
Issue 114	Seismic-Induced Relay Chatter	(6) This issue is addressed in the resolution of Issue A-46.
Issue 115	Enhancement of the Reliability of Westinghouse Solid State Protection System	(1, 4) Issue is specific to Westinghouse PWRs.
Issue 116	Accident Management	(5)
Issue 117	Allowable Time for Diverse Simultaneous Equipment Outages	(3)
Issue 118	Tendon Anchor Head Failure	<p>(1) Inspection of a PWR prestressed concrete containment structure revealed that three lower vertical tendon anchor heads were broken. The failures appeared to have been caused by hydrogen stress cracking. Hydrogen is liberated by zinc in the presence of water. Quantities of water ranging from a few ounces to about 1.5 gallons have been found in the grease caps.</p> <p>The ESBWR primary containment structure is a reinforced concrete design. Therefore, this GSI is not applicable to the ESBWR Standard Plant design.</p>
Issue 119	<u>Piping Review Committee Recommendations</u>	(Covered below)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 119.1	Piping Rupture Requirements and Decoupling of Seismic and LOCA Loads.	(8) This issue is considered resolved through compliance with SRP Sections 3.6.1 and 3.6.2, consistent with the NRC resolution. As noted in Table 1.9-3, the ESBWR Standard Plant design complies with SRP Sections 3.6.1 and 3.6.2.
Issue 119.2	Piping Damping Values	(3)
Issue 119.3	Decoupling the OBE from the SSE	(1) The OBE is not part of the licensing basis for ESBWR.
Issue 119.4	BWR Piping Materials	(1, 8) This issue primarily addresses materials for use in recirculation piping in BWRs. The ESBWR design does not include recirculation lines.
Issue 119.5	Leak Detection Requirements	(5)
Issue 120	On-Line Testability of Protection Systems	<p>(4) The main concern of this issue is the on-line testability of the actuation subgroup (slave) relays in the engineered safety features actuation system (ESFAS).</p> <p>The requirements for at-power testability of components are included in GDC 21 of Appendix A of 10 CFR 50. RG 1.22, "Periodic Testing of Protection System Actuation Functions," RG 1.118, "Periodic Testing of Electric Power and Protection Systems," and IEEE 338-1987, "Criteria for the Periodic Testing of Nuclear Power Generating Station Safety Systems," provide supplementary guidance. This guidance is intended to ensure that protection (including logic, actuation devices, and associated actuated equipment) will be designed to permit testing while a plant is operating at power without adversely affecting the plant's operation.</p> <p>The ESBWR design utilizes microprocessors and final actuation contacts instead of slave relays in the protection systems. The protection system design permits on-line (at-power) surveillance testing without adversely affecting the plant's operation.</p> <p>The ESBWR Technical Specifications in Chapter 16</p>

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		provide surveillance requirements for several RPS instrumentation functions while in Mode 1 (Power Operation). Surveillance of ECCS instrumentation is also specified in the ESBWR Technical Specifications, and is applicable while in Mode 1.
Issue 121	Hydrogen Control for Large, Dry PWR Containments	(1) This GSI is applicable to PWR-type designs only. This GSI is not applicable to the ESBWR Standard Plant design.
Issue 122	<u>Davis-Besse Loss of All Feedwater Event of June 9, 1985 – Short-Term Actions</u>	
Issue 122.1	Potential Inability to Remove Reactor Decay Heat.	See subissues below
Issue 122.1.a	Failure of Isolation Valves in Closed Position.	(1, 6) Integrated into the resolution of Issue 124. The ESBWR design does not rely on the reopening of isolation valves to remove decay heat.
Issue 122.1.b	Recovery of Auxiliary Feedwater.	(1, 6) Addressed initially by Issue 122.2, but later integrated into resolution of Issue 124. ESBWR uses Isolation Condensers for this function, which run continuously once they have been initiated.
Issue 122.1.c	Interruption of Auxiliary Feedwater Flow.	(1, 6) Integrated into the resolution of Issue 124, which only applies to PWRs.
Issue 122.2	Initiating Feed-and-Bleed	(1, 4) The ESBWR design does not rely upon feed-and-bleed cooling.
Issue 122.3	Physical Security System Constraints.	(3)
Issue 123	Deficiencies in the Regulations Governing DBA and Failure Criterion Suggested by the Davis-Besse Incident of June 9, 1985	(3, 6) Safety concerns associated with this issue are addressed in the resolution of Issues A-17, A-44, A-45 and A-47.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 124	Auxiliary Feedwater System Reliability	(1, 8) This GSI is applicable to PWR-type designs only. Therefore, this GSI is not applicable to the ESBWR Standard Plant design.
Issue 125	<u>Davis-Besse Loss of All Feedwater Event of June 9, 1985 – Long-Term Actions</u>	
Issue 125.I.1	Availability of the Shift Technical Advisor	(3)
Issue 125.I.2	PORV Reliability	See rows below.
Issue 125.I.2.a	Need for a Test Program to Establish Reliability of the PORV.	(1, 6) This issue is covered in Issue 70. The ESBWR does not have PORVs.
Issue 125.I.2.b	Need for PORV Surveillance Tests to Confirm Operational Readiness.	(1, 6) This issue is covered in Issue 70. The ESBWR does not have PORVs.
Issue 125.I.2.c	Need for Additional Protection Against PORV Failure.	(1, 3) The ESBWR does not have PORVs.
Issue 125.I.2.d	Capability of the PORV to Support Feed-and-Bleed.	(1, 6) This issue is covered in Issue A-45. The ESBWR does not have PORVs.
Issue 125.I.3	SPDS Availability	(4, 6) This issue is addressed in the resolution of TMI Action Plan Item I.D.2. See Appendix 1A.
Issue 125.I.4	Plant-Specific Simulator.	(3, 6) This issue is addressed in the resolution of TMI Action Plan Item I.A.4.2(4). See Appendix 1A.
Issue 125.I.5	Safety Systems Tested in All Conditions Required by DBA.	(3, 6) An alternative approach to address this issue is assessed as part of Issue 145.
Issue 125.I.6	Valve Torque, Limit, and Bypass Switch Settings.	(3, 6) This issue is addressed by IE Bulletin 85-03 and in the resolution of TMI Action Plan Item II.E.6.1.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 125.I.7	Operator Training Adequacy.	See rows below.
Issue 125.I.7.a	Recover Failed Equipment.	(3, 6) This issue is addressed by Issue HF2.1.
Issue 125.I.7.b	Realistic Hands-On Training.	(3, 6) This issue is addressed by Issue HF3.1.
Issue 125.I.8	Procedures and Staffing for Reporting to NRC Emergency Response Center.	(3, 6) This issue is a duplication of the concern addressed in TMI Action Plan Item III.A.3.4.
Issue 125.II.1	Need for Additional Actions on AFW Systems.	(1) See rows below. The ESBWR has no Auxiliary Feedwater System so this group of items is generally not applicable.
Issue 125.II.1.a	Two-Train AFW Unavailability.	(1, 3, 6) This issue is the same as Issue 124.
Issue 125.II.1.b	Review Existing AFW Systems for Single Failure.	(1, 6) This issue is covered by Issue 124.
Issue 125.II.1.c	NUREG-0737 Reliability Improvements.	(3)
Issue 125.II.1.d	AFW/Steam and Feedwater Rupture Control System/ICS Interactions in B&W Plants.	(1, 3, 6) This issue is covered in Issue 124 and applies specifically to auxiliary feedwater systems in PWRs designed by B&W. The ESBWR design does not contain an auxiliary feedwater system.
Issue 125.II.2	Adequacy of Existing Maintenance Requirements for Safety-Related Systems.	(3)
Issue 125.II.3	Review Steam/Feedline Break Mitigation Systems for Single Failure	(3, 6) This issue is covered by Issues 125.II.1.b and 125.II.7.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 125.II.4	Thermal Stress of OTSG Components	(1, 3) The ESBWR design does not contain a once-through steam generator.
Issue 125.II.5	Thermal-Hydraulic Effects of Loss and Restoration of Feedwater on Primary System Components.	(3)
Issue 125.II.6	Reexamine PRA Estimates of Core Damage Risk from Loss of All Feedwater.	(3)
Issue 125.II.7	Reevaluate Provision to Automatically Isolate Feedwater from Steam Generator During a Line Break.	(1, 4) The ESBWR design does not include a steam generator.
Issue 125.II.8	Reassess Criteria for Feed-and-Bleed Initiation.	(3, 6) This issue is covered under Issue 122.2.
Issue 125.II.9	Enhanced Feed-and-Bleed Capability.	(3)
Issue 125.II.10	Hierarchy of Impromptu Operator Actions.	(3, 6) This issue is addressed in Issue HF4.4.
Issue 125.II.11	Recovery of Main Feedwater as Alternative to Auxiliary Feedwater.	(3, 6) This issue is addressed in Issue 124 and in revisions to PWR Emergency Procedure Guidelines.
Issue 125.II.12	Adequacy of Training Regarding PORV Operation.	(3, 6) This issue is addressed in Issue HF3.1.
Issue 125.II.13	Operator Job Aids.	(3, 6) This issue is partially addressed by the resolution of Issue HF5.1.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 125.II.14	Remote Operation of Equipment Which Must Now Be Operated Locally.	(3)
Issue 126	Reliability of PWR Main Steam Safety Valves	(1) This issue is specific to Main Steam Safety Valves in PWRs.
Issue 127	Maintenance and Testing of Manual Valves in Safety-Related Systems	(9)
Issue 128	Electrical Power Reliability	<p>(8) The ESBWR design incorporates specific design features that assure that the problems described in this issue are avoided. These design features include:</p> <ul style="list-style-type: none"> • Two independent and physically separate off-site sources supply reliable power to the plant auxiliary and service loads, such that any single active failure can affect only one power source and cannot propagate to the alternate power source. • In the event of total loss of off-site power sources, two on-site independent nonsafety-related standby diesel generators are provided to power the Plant's Investment Protection (PIP) nonsafety-related loads (and safety-related loads through battery chargers). • Four independent and redundant on-site Class 1E DC systems supply power for operation of safety-related DC loads. • Each division of the safety-related power distribution system is provided with physically separated and electrically independent batteries sized to supply emergency power to the safety-

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
		<p>related systems in the event of loss of all other power sources.</p> <ul style="list-style-type: none"> Any two of four on-site electrical safety-related divisions can safely shut down the unit and maintain it in a safe shutdown condition. Separation criteria are established for preserving the independence of redundant Class 1E systems and providing isolation between Class 1E and non-Class 1E equipment. Specified functions of engineered safety systems are met by use of redundant divisions. <p>This issue is considered resolved for the ESBWR Standard Plant design because of these ESBWR design features.</p>
Issue 129	Valve Interlocks to Prevent Vessel Drainage During Shutdown Cooling.	(3)
Issue 130	Essential Service Water Pump Failures at Multiplant Sites.	(1) The ESBWR Standard Plant contains only one unit. The ESBWR design also does not contain Essential Service Water pumps.
Issue 131	Potential Seismic Interaction Involving the Movable In-Core Flux Mapping System Used in Westinghouse-Designed Plants.	(1) This is a Westinghouse PWR issue that is not applicable to ESBWR.
Issue 132	RHR System Inside Containment.	(3)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 133	Update Policy Statement on Nuclear Plant Staff Working Hours.	(5)
Issue 134	Rule on Degree and Experience Requirement.	(4)
Issue 135	Steam Generator and Steam Line Overfill.	(1) The ESBWR is a direct cycle plant and does not have a Steam Generator.
Issue 136	Storage and Use of Large Quantities of Cryogenic Combustibles on site.	(5)
Issue 137	Refueling Cavity Seal Failure.	(3)
Issue 138	Deinerting of BWR Mark I and Mark II Containments During Power Operations upon Discovery of RCS Leakage or a Train of a Safety System Inoperable	(3)
Issue 139	Thinning of Carbon Steel Piping in LWRs.	(8)
Issue 140	Fission Product Removal Systems.	(3)
Issue 141	Large Break LOCA with Consequential SGTR.	(1, 3) The ESBWR has no steam generator tubes that could rupture during a LOCA.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 142	Leakage through Electrical Isolators in Instrumentation Circuits	<p>(4) The ESBWR design has interfaces between electrical divisions for logic voting, and between divisional and non-divisional circuits for annunciators, etc. However, these interfaces are accomplished through a fiber-optic medium that is non-conductive and thus providing full Class-1E isolation. No interlocking is provided, nor required, for these interfaces.</p> <p>The ESBWR electrical hardware is not affected significantly by noise because of the combination of digital transmission and fiber optics incorporated in the design. See Chapter 7 for further details.</p>
Issue 143	Availability of Chilled Water Systems and Room Cooling	(4) The ESBWR Chilled Water System (CWS), described in Subsection 9.2.7, provides chilled water to the cooling coils of air conditioning units and other coolers in the reactor building portion of the plant, and has no safety-related function. Failure of the CWS does not compromise any safety-related system or component, nor does it prevent a safe shutdown of the plant.
Issue 144	Scram without a Turbine/Generator Trip	(3)
Issue 145	Actions to Reduce Common Cause Failures	(4)
Issue 146	Support Flexibility of Equipment and Components.	(4) Resolution of this issue recommends actions for new plants that could lead to updates to some SRP Sections.
Issue 147	Fire-Induced Alternate Shutdown/Control Room Panel Interactions.	(5)
Issue 148	Smoke Control and Manual Fire-Fighting Effectiveness.	(5)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 149	Adequacy of Fire Barriers.	(3)
Issue 150	Overpressurization of Containment Penetrations.	(3)
Issue 151	Reliability of Anticipated Transient Without Scram Recirculation Pump Trip in BWRs.	(1) The ESBWR is a passive design and does not have Recirculation Pumps. The ESBWR response to ATWS events is discussed in Chapter 15.
Issue 152	Design Basis for Valves that Might be Subjected to Significant Blowdown Loads.	(3)
Issue 153	Loss of Essential Service Water in LWRs	(4) The traditional essential (or Emergency) Service Water (ESW) system found in most plants provides cooling water to the safety-related equipment required to safely shut down the reactor and to mitigate the consequences of postulated accidents. The ESBWR does not need/have a safety-related ESW system. The water systems described in Section 9.2 (e.g., Plant Service Water System, Reactor Component Cooling Water System, Make-up Water System, Chilled Water System, Turbine Component Cooling Water System) are nonsafety-related and are not designed to cool any safety-related heat loads. The ESBWR post-accident heat removal is through passive means.
Issue 154	Adequacy of Emergency and Essential Lighting.	(3)
Issue 155	<u>Generic Concerns Arising from TMI-2 Cleanup.</u>	

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 155.1	More Realistic Source Term Assumptions	(8) The use of alternate source terms is addressed in Chapter 15. Regulatory Guide 1.183 has been applied to ESBWR.
Issue 155.2	Establish Licensing Requirements for Non-Operating Facilities	(5)
Issue 155.3	Improve Design Requirements for Nuclear Facilities	(3)
Issue 155.4	Improve Criticality Calculations	(3)
Issue 155.5	More Realistic Severe Accident Scenario	(3)
Issue 155.6	Improve Decontamination Regulations	(3)
Issue 155.7	Improve Decommissioning Regulations	(3)
Issue 156	<u>Systematic Evaluation Program</u>	
Issue 156.1.1	Settlement of Foundations and Buried Equipment.	(3)
Issue 156.1.2	Dam Integrity and Site Flooding.	(3)
Issue 156.1.3	Site Hydrology and Ability to Withstand Floods.	(3)
Issue 156.1.4	Industrial Hazards.	(3)
Issue 156.1.5	Tornado Missiles.	(3)
Issue 156.1.6	Turbine Missiles.	(3)
Issue 156.2.1	Severe Weather Effects on Structures.	(3)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 156.2.2	Design Codes, Criteria, and Load Combinations.	(3)
Issue 156.2.3	Containment Design and Inspection.	(3)
Issue 156.2.4	Seismic Design of Structures, Systems, and Components.	(3)
Issue 156.3.1.1	Shutdown Systems.	(3, 6) Safety concerns addressed in resolution of Issue A-45.
Issue 156.3.1.2	Electrical Instrumentation and Controls.	(3, 6) Safety concerns addressed in resolution of Issue A-45.
Issue 156.3.2	Service and Cooling Water Systems.	(3)
Issue 156.3.3	Ventilation Systems.	(3, 6) Covered by Issues 83, 106, 136, 143 and 148.
Issue 156.3.4	Isolation of High and Low Pressure Systems.	(3, 6) Safety concern addressed in resolution of Issue 105.
Issue 156.3.5	Automatic ECCS Switchover.	(1, 6) Covered in the resolution of Issue 24. There is no ECCS switchover function in the ESBWR.
Issue 156.3.6.1	Emergency AC Power.	(3, 6) Safety concern addressed in resolution of Issues A-44, 128 and B-56.
Issue 156.3.6.2	Emergency DC Power.	(3)
Issue 156.3.8	Shared Systems.	(1, 3, 6) Systems of potential concern already addressed by Issues 43, 130, 153 and A-44. ESBWR is a single unit plant with no shared systems.
Issue 156.4.1	RPS and ESFS Isolation.	(4) Addressed through satisfying the provisions of IEEE 279-1971, which is achieved through compliance with Regulatory Guide 1.153. As indicated in Table 1.9-21, the ESBWR complies with Regulatory Guide 1.153. See Subsection 7.1.2.2 for further details.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 156.4.2	Testing of the RPS and ESFS.	(4, 6) Covered by ASME Code requirements in accordance with 10 CFR 50.55(a) and the resolution of Issue 120.
Issue 156.6.1	Pipe Break Effects on Systems and Components.	Covered by Sections 3.5, 3.6, 3.8, 3.9
Issue 157	Containment Performance.	(4) Resolution is specific to the type of containment design. Supplement 3 of Generic Letter 88-20 requested individual licensees of Mark II and Mark III containments to consider insights and improvements identified in the Containment Improvement Program, but did not identify any generic improvements. The ESBWR containment design, as described in Section 6.2, differs from those considered as part of this issue.
Issue 158	Performance of Safety-Related Power-Operated Valves under Design Basis Conditions.	(4)
Issue 159	Qualification of Safety-Related Pumps While Running on Minimum Flow.	(3)
Issue 160	Spurious Actuations of Instrumentation upon Restoration of Power.	(3)
Issue 161	Use of Non-Safety-Related Power Supplies in Safety-Related Circuits.	(3)
Issue 162	Inadequate Technical Specifications for Shared Systems at Multiplant Sites When One Unit Is Shutdown.	(1, 3) The ESBWR is a single unit plant design with no shared systems.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 163	Multiple Steam Generator Tube Leakage.	(1) The ESBWR is a direct cycle plant and does not have Steam Generators.
Issue 164	Neutron Fluence in Reactor Vessel.	(3) Safety concern addressed in Draft Regulatory Guide DG-1025, which has since been issued as Regulatory Guide 1.190. As indicated in Table 1.9-21, the ESBWR complies with Regulatory Guide 1.190.
Issue 165	Spring-Actuated Safety and Relief Valve Reliability.	(4)
Issue 166	Adequacy of Fatigue Life of Metal Components.	(4) See also related Issue 190.
Issue 167	Hydrogen Storage Facility Separation.	(9)
Issue 168	Environmental Qualification of Electrical Equipment.	(4)
Issue 169	BWR MSIV Common Mode Failure Due to Loss of Accumulator Pressure.	(3)
Issue 170	Fuel Damage Criteria for High Burnup Fuel.	(4)
Issue 171	ESF Failure from LOOP Subsequent to a LOCA.	(4)
Issue 172	Multiple System Responses Program.	(6) This issue is addressed through resolution of Issue 106.
Issue 173	<u>Spent Fuel Storage Pool.</u>	
Issue 173.A	Operating Facilities.	(4)
Issue 173.B	Permanently Shutdown Facilities.	(1) Not applicable to the ESBWR Design Certification Process.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 174	<u>Fastener Gaging Practices</u>	
Issue 174.A	SONGS Employees' Concern.	(4)
Issue 174.B	Johnson Gage Company Concern.	(4)
Issue 175	Nuclear Power Plant Shift Staffing.	(4)
Issue 176	Loss of Fill-Oil in Rosemount Transmitters.	(4)
Issue 177	Vehicle Intrusion at TMI	(8)
Issue 178	Effect of Hurricane Andrew on Turkey Point	(5)
Issue 179	Core Performance.	(5)
Issue 180	Notice of Enforcement Discretion.	(5)
Issue 181	Fire Protection	(5)
Issue 182	General Electric Extended Power Uprate	(5)
Issue 183	Cycle-Specific Parameter Limits in Technical Specifications.	(5)
Issue 184	Endangered Species.	(7)
Issue 185	Control of Recriticality Following Small-Break LOCAs in PWRs.	(1) This is a PWR issue that is not applicable to ESBWR.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 186	Potential Risk and Consequences of Heavy Load Drops in Nuclear Power Plants.	See Section 9.1 and Subsections 15.4.1, "Fuel Handling Accident," and 15.4.10, "Spent Fuel Cask Drop Accident."
Issue 187	The Potential Impact of Postulated Cesium Concentration on Equipment Qualification.	(3)
Issue 188	Steam Generator Tube Leaks or Ruptures, Concurrent with Containment Bypass from Main Steam Line or Feedwater Line Breaches.	(1) The ESBWR is a direct cycle plant and does not have a Steam Generator.
Issue 189	Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident.	(1) The ESBWR Containment is considerably different from Ice Condenser Containment. The ESBWR Containment differs from the Mark III Containment in that it is inerted to prevent hydrogen combustion.
Issue 190	Fatigue Evaluation of Metal Components for 60-Year Plant Life.	(4)
Issue 191	Assessment of Debris Accumulation on PWR Sump Performance	(1) The ESBWR does not have an ECCS pump, and no sump provides ECCS water.
Issue 192	Secondary Containment Drawdown Time.	(3)
Issue 193	BWR ECCS Suction Concerns.	(1) The ESBWR does not have an ECCS pump, and does not take ECCS water from the suppression pool.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
Issue 194	Implications of Updated Probabilistic Seismic Hazard Estimates.	(3)
Issue 195	Hydrogen Combustion in BWR Piping.	(3) This issue has been addressed in GE Service Information Letter SIL No. 643, "Potential for Radiolytic Gas Detonation," dated June 14, 2002.
	HUMAN FACTORS ISSUES	Human Factors Issues are addressed in Chapter 18
HF1.1	Shift Staffing	(8) This issue is considered resolved through compliance with 10 CFR 50.54; the latest revision to SRP Section 13.1.2; and Regulatory Guide (RG) 1.114, Rev. 2, consistent with the NRC resolution. Compliance with 10 CFR 50.54 is the responsibility of the COL applicant. Compliance with SRP Section 13.1.2 and RG 1.114, Rev. 2, is also a COL applicant responsibility.
HF1.2	Engineering Expertise on Shift	(4)
HF1.3	Guidance on Limits and Conditions of Shift Work	(4)
HF2.1	Evaluate Industry Training	(5)
HF2.2	Evaluate INPO Accreditation	(5)
HF2.3	Revise SRP Section 13.2	(5)
HF3.1	Develop Job Knowledge Catalog	(5)
HF3.2	Develop License Examination Handbook	(5)
HF3.3	Develop Criteria for Nuclear Power Plant Simulators	(6) This issue is covered in TMI Action Plan Item I.A.4.2(4). See Appendix 1A.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
HF3.4	Examination Requirements	(6) This issue is covered in TMI Action Plan Item I.A.2.6(1).
HF3.5	Develop Computerized Exam System	(5)
HF4.1	Inspection Procedure for Upgraded Emergency Operating Procedures	(4)
HF4.2	Procedures Generation Package Effectiveness Evaluation	(5)
HF4.3	Criteria for Safety-Related Operator Actions	(6) This item is covered in Issue B-17.
HF4.4	Guidelines for Upgrading Other Procedures	(4)
HF4.5	Application of Automation and Artificial Intelligence	(6) This item is covered in Item HF5.2.
HF5.1	Local Control Systems	(4) The ESBWR on-going program for the design of instrumentation and control systems and man-machine interface systems incorporates all the applicable ALWR human factors engineering requirements. The design bases, approach, and acceptance criteria are given in Chapter 18. In addition, the COL Applicant is required to ensure the establishment of an interdisciplinary design review group and reviews for site-specific design and construction work. This issue is considered resolved for the ESBWR Standard Plant design.

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
HF5.2	Review Criteria for Human Factors Aspects of Advanced Controls and Instrumentation	(4) The ESBWR on-going program for the design of instrumentation and control systems and man-machine interface systems incorporates all the applicable ALWR human factors engineering requirements. The design bases, approach, and acceptance criteria are given in Chapter 18 of this DCD Tier-2. In addition, the COL Applicant is required to ensure the establishment of an interdisciplinary design review group and reviews for site-specific design and construction work. This issue is considered resolved for the ESBWR Standard Plant design.
HF5.3	Evaluation of Operational Aid Systems	(6) This issue is covered in Item HF5.2.
HF5.4	Computers and Computer Displays	(6) This issue is covered in Item HF5.2.
HF6.1	Develop Regulatory Position on Management and Organization	(6) This item is covered in TMI Action Plan Items I.B.1.1(1, 2, 3 and 4).
HF6.2	Regulatory Position on Management and Organization at Operating Reactors	(6) This item is covered in TMI Action Plan Items I.B.1.1(1, 2, 3 and 4).
HF7.1	Human Error Data Acquisition	(5)
HF7.2	Human Error Data Storage and Retrieval	(5)
HF7.3	Reliability Evaluation Specialist Aids	(5)
HF7.4	Safety Event Analysis Results Application	(5)
HF8	Maintenance and Surveillance Program	(4)

Table 1.11-1 (continued)

Action Plan Item/Issue Number	Description	Associated Tier 2 Location(s) and/or Technical Resolution
	CHERNOBYL ISSUES	The Chernobyl issues listed in NUREG-0933 Table II are all not Generic Issues (5) or are not applicable to the ESBWR design (1).