

Changes From Revision 00 to Revision 01

DCD Tier 2, Chapter 13

Item	Location (e.g., subsection with paragraph/sentence/item, table with column/row, or figure)	Description of Change
1	Cover Sheet	Conditional Release Statement Removed Change from Rev. 0 to Rev. 1 Issue Date Changed from August 2005 to January 2006
2	Header	Change from Rev. 0 to Rev. 1
3	Acronyms pg 13-xi	Corrected definition for NS to delete (non-seismic Category I)
4	13.1	The organizational structure must be consistent with the human system interface design assumptions used in the design of the ESBWR.
5	13.1.1	COL applicant referencing the ESBWR will submit documentation that demonstrates that their organizational structure is consistent with the Human Factors Engineering ESBWR design requirements.
6	13.3 2 nd para 1 st sentence	Spelled out Technical Support Center (TSC)
7	13.3 2 nd para 3rd sentence	Revised text to more generically reflect the informational display capabilities that will be available in the TSC.
8	13.3 4 th para	"5 rem whole body, or its equivalent, to any part of the body" has been replaced with "0.05 Sv (5 rem) total effective dose equivalent (TEDE) as defined in 10 CFR 50.2 for the duration of the accident." per 10 CFR 52
9	13.3 4 th para	Revised text to a more generic statement stating that the TSC function would be relocated to a safe location.
10	13.3 5 th para	Spelled out Emergency Operations Facility (EOF) and Operational Support Center (OSC)
11	13.3 5 th para	Control room data communication of emergency response data system (ERDS) data with the NRC Operations Centers will also be provided as appropriate.

Changes From Revision 00 to Revision 01

DCD Tier 2, Chapter 13

Item	Location (e.g., subsection with paragraph/sentence/item, table with column/row, or figure)	Description of Change
12	13.3.3.3 2 nd para	The COL applicant will provide decontamination facilities and supplies at the site for decontamination of on-site individuals in the service building adjacent to the main change rooms.
13	13.4.1 and 13.5.3.3	Changed ANSI 18.7/ANS 3.2 to ANSI/ANS 3.2 and deleted the option to adopt a later version since it is no longer necessary.

Note: The Page Turn comments were addressed as part of Rev.0. The Red Team review comments were reviewed and none were identified as applicable to DCD Chapter 13. None of the 14 NRC acceptance review issues are applicable to DCD Chapter 13.