



LEGEND:
KEY: FAN POWERED EXHAUST → 8-5

- NOTES**
- 1. FOR GENERAL NOTES AND LEGEND AND REFERENCE DWG'S SEE G-191238 FOR EQUIPMENT SCHEDULES AND CONTROL DIAGRAMS SEE G-191235
 - 2. NEW WAREHOUSE HVAC SEE GROUND FLOOR 5920-5740 SECOND FLOOR 5920-5741
 - 3. UNLESS OTHERWISE NOTED ALL INSTRUMENTS AND CONTROL VALVE NUMBERS SHALL BE PREFIXED BY SYSTEM NUMBER 113
 - 4. TBAC-1 TO BE OPERATED ONLY WHEN PLANT IS SHUT DOWN THIS EQUIPMENT UTILIZES 20% - 50% FRESH AIR MAKE-UP INLET & OUTLET ISOLATION DAMPERS ARE MANUALLY CLOSED FOR PLANT OPERATION
 - 5. TORNADO PRESSURE RELIEF DAMPERS AAD-42 ROOM A AND-43 ROOM B
 - 6. SERVICE BUILDING ROOM USAGE DESCRIPTION IS NOT BEING MAINTAINED
 - 7. AIRFLOWS SHOWN ARE NOMINAL BASED ON THE ORIGINAL DESIGN

15	REVISED PER CU 2002-034	5-11-04	5-18-04	5-16-04
46	REVISED PER WOSE 2003-089	1-18-05		
NO.	DESCRIPTION	BY	CHKD.	APPD.
ENTERGY	ENTERGY NUCLEAR VERMONT YANKEE			
	VERMONT, VERMONT			
DRAWING TITLE	HVAC-FLOW DIAGRAM TURBINE, SERVICE & CONTROL ROOM BUILDINGS			
DRAWING NO.	G-191237 SH.1			

COMPONENTS SUBJECT TO AMR

HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS AMR-19

0	3-29-05								
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP			
REVISIONS									
LRA-G-191237-SH-01-0									
CNO FILE LRA-G-191237-SH-01-46.DGN									
NOTED FILE G191237-SH-01-CALS-46.CAL									

THIS IS AN FSAR DRAWING

D-40