

March 07, 2006

Mr. R. T. Ridenoure  
Vice President - Chief Nuclear Officer  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT  
REQUEST (TAC NO. MC9298)

Dear Mr. Ridenoure:

By letter dated December 19, 2005, Omaha Public Power District (OPPD) applied for an amendment to the Fort Calhoun Station, Unit No. 1 (FCS), Facility Operating License No. DPR-40. The proposed change would have revised the FCS's Technical Specifications (TS) pertaining to TS 3.7(1)c.i, "Emergency Power System Periodic Tests." Specifically, this proposed change would have revised the diesel generator surveillance test to reflect the removal of the anticipatory (idle speed) diesel generator start signals.

The Nuclear Regulatory Commission staff determined that additional information is needed to complete the review. As a result of a teleconference, OPPD has decided to reevaluate the modification to remove the anticipatory diesel generator start signals. As such, the amendment is no longer needed at this time. Subsequently, by letter dated February 17, 2006, OPPD withdrew the amendment request.

The purpose of this letter is to advise that the above cited application is being treated as withdrawn. The Notice of Consideration of Issuance of the proposed amendment had not been published in the *Federal Register*.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: See next page

March 07, 2006

Mr. R. T. Ridenoure  
Vice President - Chief Nuclear Officer  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT  
REQUEST (TAC NO. MC9298)

Dear Mr. Ridenoure:

By letter dated December 19, 2005, Omaha Public Power District (OPPD) applied for an amendment to the Fort Calhoun Station, Unit No. 1 (FCS), Facility Operating License No. DPR-40. The proposed change would have revised the FCS's Technical Specifications (TS) pertaining to TS 3.7(1)c.i, "Emergency Power System Periodic Tests." Specifically, this proposed change would have revised the diesel generator surveillance test to reflect the removal of the anticipatory (idle speed) diesel generator start signals.

The Nuclear Regulatory Commission staff determined that additional information is needed to complete the review. As a result of a teleconference, OPPD has decided to reevaluate the modification to remove the anticipatory diesel generator start signals. As such, the amendment is no longer needed at this time. Subsequently, by letter dated February 17, 2006, OPPD withdrew the amendment request.

The purpose of this letter is to advise that the above cited application is being treated as withdrawn. The Notice of Consideration of Issuance of the proposed amendment had not been published in the *Federal Register*.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: See next page

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsNrrDorLplg (DTerao)

RidsNrrLALFeizollahi

RidsNrrDorLDpr

RidsOgcRp

RidsRgn4MailCenter (DGraves)

RidsNrrPMAWang

RidsAcrcAcnwMailCenter

ADAMS ACCESSION NUMBER: **ML060580529**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	AWang	LFeizollahi	DTerao
DATE	3/3/06	3/2/06	3/7/06

**OFFICIAL RECORD COPY**

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn  
ATTN: James R. Curtiss, Esq.  
1400 L Street, N.W.  
Washington, DC 20005-3502

Chairman  
Washington County Board of Supervisors  
P.O. Box 466  
Blair, NE 68008

Mr. John Hanna, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 310  
Fort Calhoun, NE 68023

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager  
Radiation Control Program  
Nebraska Health & Human Services R & L  
Public Health Assurance  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager  
Fort Calhoun Station  
Omaha Public Power District  
Fort Calhoun Station FC-1-1 Plant  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis  
Manager - Nuclear Licensing  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee  
Bureau of Radiological Health  
Iowa Department of Public Health  
Lucas State Office Building, 5th Floor  
321 East 12th Street  
Des Moines, IA 50319

January 2006