

## **ATTACHMENT 4**

**Calculation QDC-0000-N-1266, Revision 2, "Re-analysis of  
Main Steam Line Break (MSLB) Accident Using Alternative Source Terms"**

**ATTACHMENT I**  
**Design Analysis Cover Sheet**

## CALCULATION TABLE OF CONTENTS

1.0	PURPOSE/OBJECTIVE.....	3
2.0	METHODOLOGY AND ACCEPTANCE CRITERIA .....	4
2.1	General Description .....	4
2.2	Source Term Model .....	4
2.3	Release Model.....	4
2.4	Dispersion Model.....	4
2.4.1	EAB and LPZ.....	4
2.4.2	Control Room.....	5
2.5	Dose Model.....	5
2.5.1	EAB and LPZ.....	5
2.5.2	Control Room.....	6
2.6	Acceptance Criteria.....	6
3.0	ASSUMPTIONS .....	9
3.1	Activity Release and Transport.....	9
3.2	Control Room.....	9
4.0	DESIGN INPUT .....	10
4.1	Mass Release Data .....	10
4.2	Iodine and Noble Gas Activity Release .....	10
4.3	Control Room Data .....	11
4.4	EAB and LPZ Data (from the Dresden Technical Specifications) .....	11
5.0	REFERENCES .....	12
6.0	CALCULATIONS .....	13
6.1	Cloud Volumes, Masses, and Control Room Intake Transit Times.....	13
6.2	Dispersion for Offsite Dose Assessment.....	14
6.3	Release Isotopics and Quantification.....	15
6.4	Dose Assessment .....	16
7.0	SUMMARY AND CONCLUSIONS .....	17
8.0	OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL DESIGN ANALYSIS.....	18

## Attachments:

- A. Spreadsheet Performing Cesium Molar Fraction and Total MSLB Dose Assessment, With Formula Sheets [pages A1-A10]
- B. Computer Disclosure Sheet [pages B1-B1]

## 1.0 PURPOSE/OBJECTIVE

The purpose of this calculation is to determine the Control Room (CR), Exclusion Area Boundary (EAB), and Low Population Zone (LPZ) doses following a Main Steam Line Break (MSLB) Accident. This calculation is performed in accordance with Regulatory Guide (RG) 1.183 [Reference 6] as described herein.

The principal attributes of this analysis compared to those performed previously for this event under Standard Review Plan 15.6.4 guidance and 10CFR100 and 10CFR50, General Design Criterion 19 requirements are:

1. Doses are evaluated in terms of Total Effective Dose Equivalent (TEDE) and evaluated against 10CFR50.67 limits as modified by RG 1.183.
2. Noble gas releases are as previously analyzed and are not impacted by AST application.
3. Historically determined liquid reactor coolant and steam release continue to be the basis for the determination that no fuel damage results from an MSLB.
4. A simplified and more conservative basis is used for the determination of radionuclide releases based on a bounding reactor coolant blowdown value.
5. Iodine releases are based on reactor coolant I-131 equivalent limitations in Technical Specifications for "Case 1" and a 20 times higher iodine spike limit for "Case 2".
6. Cesium releases, as cesium iodide, and noble gas release are now considered in addition to iodine that has been historically assumed.

As per Quad Cities - UFSAR [Ref. 8] Section 15.6.4, this event involves the postulation that the largest steam line instantaneously and circumferentially breaks outside the primary containment at a location downstream of the outermost isolation valve, with this event representing the envelope evaluation of steam line failures outside primary containment. Closure of the Main Steam Isolation Valves (MSIVs) terminates the reactor coolant mass loss when the full closure is reached. No operator actions are assumed to be taken during the accident, and the radioactivity concentration inside the Control Room is considered the same as that just outside the intake (with a geometry factor applied) to address any degree of postulated unfiltered inleakage during the duration of the event.

The mass of coolant released during the MSLB is taken for this dose calculation as a bounding maximized value for all current Boiling Water Reactor (BWR) plants of 140,000 pounds of water, as provided in Standard Review Plan 15.6.4, Paragraph III.2.a for a GESSAR-251 plant. This value bounds for dose calculation purposes the historic UFSAR values such as 55,000 pounds of steam and 45,000 pounds of water in UFSAR Section 15.6.4.5. This ensures that the discharge quantity and dose consequences are maximized, and that the releases should bound any other credible pipe break. Considering the release as all water maximizes the iodine (the primary dose contributor) release quantity compared to any actual release of steam, which would contain iodine quantities limited by the carryover fraction (typically 2%, as per Reference 10).

## **2.0 METHODOLOGY AND ACCEPTANCE CRITERIA**

### **2.1 General Description**

The radiological consequences resulting from a design basis MSLB accident to a person at the EAB; to a person at the LPZ; and to an operator in the Control Room following an MSLB accident were performed using a Microsoft EXCEL spreadsheet, provided as Attachment A.

### **2.2 Source Term Model**

No fuel damage is expected to result from a MSLB. Therefore, the activity available for release from the break is that present in the reactor coolant and steam lines prior to the break, with two cases analyzed. Case 1 is for continued full power operation with a maximum equilibrium coolant concentration of 0.2 uCi/gm dose equivalent I-131 [Ref. 8]. Case 2 is for a maximum coolant concentration of 4.0 uCi/gm dose equivalent I-131, based on a pre-accident iodine spike caused by power changes. This accident source term basis is consistent with the pre-AST MSLB analyses per Regulatory Guide 1.5 [Ref. 5], and meets the guidance in RG 1.183 for analysis of this event as well.

Inhalation Committed Effective Dose Equivalent (CEDE) Dose Conversion Factors (DCFs) from Federal Guidance Report (FGR) No. 11 [Ref. 3] and External Dose Equivalent (EDE) DCFs from FGR No. 12 [Ref. 4] are used.

### **2.3 Release Model**

Noble gas releases are those historically determined from the release fractions in Reference 2 and its Curie release formulation, corresponding to 100,000 uCi/sec off-gas emission after 30 minutes decay, per UFSAR Section 15.6.4.5, and for the Quad Cities Technical Specification value of 5.5 seconds MSIV closure time.

Iodine releases are determined based on a release of 140,000 lbs of reactor coolant with either 0.2 uCi/gm or 4.0 uCi/gm of I-131 dose equivalent activity.

The iodine species released from the main steam line are assumed to be 95% CsI as an aerosol, 4.85% elemental, and 0.15% organic. Therefore, 95% of iodine releases have an atom equivalent cesium release. Cesium isotopic abundance is determined based on source terms developed for pH control for longer lived or stable isotope [Ref. 13], and from ANSI/ANS-18.1-1999 [Ref. 10] for shorter lived isotopes.

Releases are assumed to be instantaneous and no credit is taken for dilution in turbine building air.

### **2.4 Dispersion Model**

#### **2.4.1 EAB and LPZ**

EAB and LPZ X/Q's are determined using the methodology in R.G. 1.5 [Ref. 5], that is also cited as a basis for evaluation in the Quad Cities – UFSAR (e.g., Section 15.6.4.5). Specifically:

$$\frac{\chi}{Q} = \frac{0.0133}{\sigma_y u}$$

where

$\sigma_y$  = horizontal standard deviation of the plume (meters)

$u$  = wind velocity (meters/second)

Horizontal standard deviations are taken from the PAVAN outputs for the EAB and LPZ included in Ref. 9. Per R.G. 1.5, F stability and a 1 meter/sec wind speed are used.

#### 2.4.2 Control Room

For control room dose calculations, the plume was modeled as a hemispherical volume, the dimensions of which are determined based on the portion of the liquid reactor coolant release that flashed to steam. The activity of the cloud is based on the total mass of water released from the break. This assumption is conservative because it considers the maximum release of fission products.

Activity release is conservatively assumed to effectively occur at the Control Room intake elevation and, again conservatively, no credit is taken for plume buoyancy.

### 2.5 Dose Model

Dose models for both onsite and offsite are simplified and meet R.G. 1.183 [Ref. 6] requirements, providing results in units of Total Effective Dose Equivalent (TEDE). Dose conversion factors are based on Federal Guidance Reports 11 and 12 [Refs 1 & 0].

#### 2.5.1 EAB and LPZ

Doses at the EAB and LPZ for the MSLB are based on the following formulas:

$$\text{Dose}_{\text{CEDE}} (\text{rem}) = \text{Release (Curies)} * \frac{\chi}{Q} (\text{sec/m}^3) * \text{Breathing Rate (m}^3/\text{sec)} * \text{Inhalation DCF (rem}_{\text{CEDE}}/\text{Ci inhaled)}$$

and

$$\text{Dose}_{\text{EDE}} (\text{rem}) = \text{Release (Curies)} * \frac{\chi}{Q} (\text{sec/m}^3) * \text{Submersion DCF (rem}_{\text{EDE}} - \text{m}^3/\text{Ci - sec)}$$

and finally,

$$\text{Dose}_{\text{TEDE}} (\text{rem}) = \text{Dose}_{\text{CEDE}} (\text{rem}) + \text{Dose}_{\text{EDE}} (\text{rem})$$

### 2.5.2 Control Room

CR operator doses are determined somewhat differently. Steam cloud concentrations are used, rather than X/Q times a curie release rate. No CR filter credit is taken and, therefore, for inhalation, a dose for a location outside of the CR is used. For cloud submersion, a geometry factor is used to credit the reduced plume size seen in the CR. This is a conservative implementation of RG 1.183 guidance. The formulas used are:

$$\text{Dose}_{\text{CEDE}} (\text{rem}) = \text{Plume Concentration (Ci/m}^3) * \text{Transit Duration (sec)} *$$

$$\text{Breathing Rate (m}^3/\text{sec)} * \text{Inhalation DCF (rem}_{\text{CEDE}}/\text{Ci inhaled)}$$

and

$$\text{Dose}_{\text{EDE}} (\text{rem}) = \text{Plume Concentration (Ci/m}^3) * \text{Transit Duration (sec)} * \text{Submersion DCF (rem}_{\text{EDE}} - \text{m}^3/\text{Ci} - \text{sec)}$$

and finally,

$$\text{Dose}_{\text{TEDE}} (\text{rem}) = \text{Dose}_{\text{CEDE}} (\text{rem}) + \text{Dose}_{\text{EDE}} (\text{rem})$$

## 2.6 Acceptance Criteria

Dose acceptance criteria are per 10CFR50.67 [Ref. 7] and R.G. 1.183 [Ref. 6] guidance.

The Table below lists the regulatory limits for accidental dose to 1) a control room operator, 2) a person at the EAB, and 3) a person at the LPZ boundary.

Regulatory Dose Limits (Rem TEDE) per Refs. 7 and 6.

I-131 Dose Equivalent	CR (30 days)	EAB (2 hours)	LPZ (30 days)
Normal Equilibrium	5	2.5	2.5
Iodine Spike	5	25	25

Direct conformance with the relevant guidance in Regulatory Guide 1.183 (e.g., the TEDE concept and the above limits) and in particular its assumptions provided in Appendix D "Assumptions for Evaluating the Radiological Consequences of a BWR Main Steam Line Break Accident" is provided by this analysis, as shown in the Conformance Matrix Table 2.1

Table 2.1: Conformance with RG 1.183 Appendix D (Main Steam Line Break)

RG Section	RG Position	Dresden/Quad Cities Analysis	Comments
1	Assumptions acceptable to the NRC staff regarding core inventory and the release of radionuclides from the fuel are provided in Regulatory Position 3 of this guide. The release from the breached fuel is based on Regulatory Position 3.2 of this guide and the estimate of the number of fuel rods breached.	Not Applicable	No fuel damage, release estimate based on coolant activity.
2	If no or minimal fuel damage is postulated for the limiting event, the released activity should be the maximum coolant activity allowed by technical specification. The iodine concentration in the primary coolant is assumed to correspond to the following two cases in the nuclear steam supply system vendor's standard technical specifications.	Conforms	See below
2.1	The concentration that is the maximum value (typically 4.0 $\mu\text{Ci/gm DE I-131}$ ) permitted and corresponds to the conditions of an assumed pre-accident spike, and	Conforms	4.0 $\mu\text{Ci/gm DE I-131}$ is used in this analysis.
2.2	The concentration that is the maximum equilibrium value (typically 0.2 $\mu\text{Ci/gm DE I-131}$ ) permitted for continued full power operation.	Conforms	0.2 $\mu\text{Ci/gm DE I-131}$ is a Technical Specification limit and is used in this analysis.
3	The activity released from the fuel should be assumed to mix instantaneously and homogeneously in the reactor coolant. Noble gases should be assumed to enter the steam phase instantaneously.	Not Applicable	No fuel damage.
4.1	The main steam line isolation valves (MSIV) should be assumed to close in the maximum time allowed by technical specifications.	Conforms	An MSIV closure time of 5.5 seconds was assumed in the analysis. This is the Technical Specification maximum allowed MSIV closure time of 5 seconds plus 0.5 seconds for instrument response.
4.2	The total mass of coolant released should be assumed to be that amount in the steam line and connecting lines at the time of the break	Conforms	A bounding value of 140,000 lbs or reactor coolant is used



**Table 2.1: Conformance with RG 1.183 Appendix D (Main Steam Line Break)**

<b>RG Section</b>	<b>RG Position</b>	<b>Dresden/Quad Cities Analysis</b>	<b>Comments</b>
	plus the amount that passes through the valves prior to closure.		for dose assessment.
4.3	All the radioactivity in the released coolant should be assumed to be released to the atmosphere instantaneously as a ground-level release. No credit should be assumed for plateout, holdup, or dilution within facility buildings.	Conforms	Release is assumed at ground level, with no credit taken for plateout, holdup or dilution within facility buildings.
4.4	The iodine species released from the main steam line should be assumed to be 95% Csl as an aerosol, 4.85% elemental, and 0.15% organic.	Conforms	The subject values are used.

### 3.0 ASSUMPTIONS

#### 3.1 *Activity Release and Transport*

- Iodine coolant activity isotopic distributions and Noble Gas activity releases are taken from the Quad Cities UFSAR [Ref. 8] Section 15.6.4.5.
- Noble Gas activity releases are taken from Reference 2.
- Release from the break to the environment is assumed instantaneous. No holdup in the Turbine Building or dilution by mixing with Turbine Building air volume is credited.
- The steam cloud is assumed to consist of the portion of the liquid reactor coolant release that flashed to steam.
- The activity of the cloud is based on the total mass of water released from the break. This assumption is conservative because it considers the maximum release of fission products.
- Buoyancy effect of the cloud was conservatively ignored.
- For the control room dose calculations,
  - The plume was modeled as a hemispherical volume. This is consistent with the assumption of no Turbine Building credit. It is also reasonable for the more likely release paths through multiple large blowout panels situated around the Turbine Building Main Floor.
  - Dispersion of the activity of the plume was conservatively ignored.
  - The cloud was assumed to be carried away by a wind of speed 1 m/s. Credit is not taken for decay.

#### 3.2 *Control Room*

- No credit was taken for the operation of the control room emergency filtration systems during the MSLB.
- Inhalation doses are determined based on concentrations at the intake, and exposures for the duration of plume traverse.
- External exposure doses are determined based on concentrations at the intake, exposures for the duration of plume traverse, and a geometry factor credit (Equation 1 of Ref. 6) based on the maximum control room volume of 184,000 cubic feet [Ref. 11].

## 4.0 DESIGN INPUT

### 4.1 Mass Release Data

- As stated in UFSAR Section 15.6.4.3, there is no core uncover and therefore no fuel damage as a consequence of this accident for the assumed releases. For this dose analysis, a conservative 140,000 pounds of primary coolant liquid is assumed to be released to maximize the iodine release, with a conservative fraction of this liquid flashing to steam.

### 4.2 Iodine and Noble Gas Activity Release

The MSLB noble gas release fractions listed in the second column below are provided in Table 3-1 of Reference 2. Using the formula below in this Reference for a 100,000 uCi /sec off-gas emission after 30 minutes decay, per UFSAR Section 15.6.4.5, and the Quad Cities Technical Specification value of 5.5 seconds MSIV closure time, the Curie releases in the third column below are obtained:  $\text{Curies Released} = \text{Release fraction} \times 5.5 \times 3 \times 0.45$ , where 0.45 is the offgas rate at the break, in Curies/second, corresponding to a 100,000 uCi /sec off-gas emission after 30 minutes decay, and 3 is nominally the ratio of NRC-assumed to design basis noble release rate.

<u>Noble Gas</u> <u>Isotope</u>	<u>Release Fraction</u>	<u>Curies</u> <u>Release</u>
Kr-83M	0.00936	6.95E-02
Kr-85M	0.0164	1.22E-01
Kr-85	0.000064	4.75E-04
Kr-87	0.0511	3.79E-01
Kr-88	0.0524	3.89E-01
Kr-89	0.218	1.62E+00
Xe-131M	0.0000523	3.88E-04
Xe-133M	0.000782	5.81E-03
Xe-133	0.0219	1.63E-01
Xe-135M	0.0641	4.76E-01
Xe-135	0.0592	4.40E-01
Xe-137	0.288	2.14E+00
Xe-138	0.218	1.62E+00

The relative mix of iodine isotopes in the reactor coolant at the onset of the accident, based on the Quad Cities UFSAR [Ref. 8] Section 15.6.4, is given below.

Iodine Isotope	Activity ( $\mu\text{Ci/cc}$ )
I-131	0.067
I-132	0.38
I-133	0.40
I-134	0.53
I-135	0.49

Release activities are calculated in Attachment A.

#### 4.3 *Control Room Data*

- Control Room Emergency Zone Volume = 184,000 cubic feet [Ref. 11]  
(the maximum volume above rather than the volume of the Control Room proper is utilized to maximize the calculated doses, which are proportional to geometry factor)
- No Emergency Filtration Credit taken.

#### 4.4 *EAB and LPZ Data*

- EAB Distance from Release: 380 m [Quad Cities Tech Specs]
- LPZ Distance from Release,: 4,828 m [Quad Cities Tech Specs]

## 5.0 REFERENCES

1. Deleted.
2. NEDO-21143-1, "Radiological Accident Evaluation - The CONAC03 Code", General Electric Company, December, 1981.
3. Federal Guidance Report No. 11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion", 1988.
4. Federal Guidance Report No. 12, "External Exposure to Radionuclides in Air, Water, and Soil", 1993.
5. Regulatory Guides 1.5, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Steam Line Break Accidents for Boiling Water Reactors," 3/10/71.
6. Regulatory Guide 1.183, "Alternative Radiological Source Terms For Evaluating Design Basis Accidents At Nuclear Power Reactors", July 2000.
7. 10 CFR Part 50.67, "Accident source term", January 1, 2001.
8. Quad Cities Nuclear Power Station UFSAR Rev. 7, Section 15.6.4.
9. Calculation QDC-0000-M-1408, Rev. 1 "Atmospheric Dispersion Factors (X/Qs) for Accident Release".
10. American Nuclear Society Standard (ANS) 18.1-1999 "Radioactive Source Terms For Normal Operation of Light Water Reactors", Table 5.
11. QDC-0000-N-1020, "Impact of Extended Power Uprate on Site Boundary and Control room Doses for LOCA and Non-LOCA Events", Revision 1.
12. Deleted.
13. PBAPS Calculation PM-1056, Rev. 1, "Suppression Pool pH Calculation for Alternative Source Terms".

## 6.0 CALCULATIONS

No fuel damage is expected for the limiting MSLB. As discussed in Section 2, two iodine concentrations are used (0.2  $\mu\text{Ci/g}$  and 4.0  $\mu\text{Ci/g}$ ) [per Ref. 6] when determining the consequences of the main steam line break. All of the radioactivity in the released coolant is assumed to be released to the atmosphere instantaneously as a ground-level release. No credit is taken for plateout, holdup, or dilution within facility buildings.

The spreadsheets in Attachment A perform this analysis using data and formulations discussed above and shown in Attachment A. The following summarizes parameters and their treatment in the spreadsheet.

### 6.1 *Cloud Volumes, Masses, and Control Room Intake Transit Times*

The cloud is assumed to consist of portion of the conservatively bounding liquid reactor coolant release that flashes to steam. The flashing fraction (FF) is derived as follows:

$$\text{FF} \times (\text{steam enthalpy at 212 F}) + (1 - \text{FF}) \times (\text{liquid enthalpy at 212 F}) = (\text{liquid enthalpy at temperature of steam at reactor vessel outlet})$$

A 548 F vessel outlet temperature is used, with liquid enthalpy of 546.9 BTU/lb.

At 212 F, a steam enthalpy of 1150.5 BTU/lb and a liquid enthalpy of 180.17 BTU/lb are used (these enthalpies are taken from the ASME Steam Tables).

Substituting,

$$\text{FF} = (546.9 - 180.17) / [(1150.5 - 180.17)] = 0.378$$

For conservatism, a value of .40 or 40% is used.

As stated in Section 3.1, the cloud is assumed to consist of the initial steam blowdown and that portion of the liquid reactor coolant release that flashed to steam.

The mass liquid water released	= 140,000 lb
Flashing fraction for calculating cloud volume	= 40%
The mass of water carrying activity into the cloud	= 140,000 lb
	= (140,000 lb)(453.59 g/lb)
	= 6.350E76 g
The mass of steam in the cloud	= 40% * 140,000 lb
	= 56,000 lb

The release is assumed to be a hemisphere with a uniform concentration. The cloud dimensions (based on 56,000 lb of steam at 14.7 psi and 212 °F,  $v_g = 26.799 \text{ ft}^3/\text{lb}$ ) were calculated as follows:

$$\begin{aligned}\text{Volume} &= (56,000 \text{ lb})(26.799 \text{ ft}^3/\text{lb}) \\ &= 1,500,744 \text{ ft}^3 \\ &= (1,500,744 \text{ ft}^3)/(35.3 \text{ ft}^3/\text{m}^3) \\ &= 42,514 \text{ m}^3\end{aligned}$$

The volume of a hemisphere is  $\pi d^3 / 12$ . Thus, the diameter of the hemispherical cloud is 54.6 meters.

The period of time required for the cloud to pass over the control room intake, assuming a wind speed of 1 m/s is 54.6 s  $(= (54.6 \text{ m}) / (1 \text{ m/s}))$ . Therefore, at a wind speed of 1 m/s, the base of the hemispherical cloud will pass over the control room intake in 54.6 seconds.

## 6.2 Dispersion for Offsite Dose Assessment

As discussed in Section 2.4.1 the following formulation was used for Offsite Dose X/Q assessment, with F Pasquill Stability and a 1 m/sec wind speed.

$$\frac{\chi}{Q} = \frac{0.0133}{\sigma_y u}$$

where

$\sigma_y$  = horizontal standard deviation of the plume (meters)

$u$  = wind velocity (meters/second)

As calculated in the PAVAN run in Reference [9], at the 380 meter EAB distance  $\sigma_y$  is 15.4, and at the 4828 meter LPZ distance  $\sigma_y$  is 153. The resulting EAB and LPZ X/Qs are 8.64E-04 and 8.69E-05 sec/m<sup>3</sup>, respectively.

### 6.3 *Release Isotopics and Quantification*

The iodine, noble gas and cesium activity releases are given in Attachment A, which also determines resulting doses.

Noble gas releases are taken from the input in Section 4.2.

Iodine releases are based on reactor coolant isotopic distributions from Section 4.2, which are normalized based on FGR-11 CEDE dose conversion factors to obtain coolant concentrations corresponding to Case 1: 0.2 uCi/gm, and Case 2 4.0 uCi/gm. The resulting concentrations were multiplied by the 140,000 lbs of release converted to grams.

Cesium releases are based on the fact that a single cesium atom will accompany 95% of the released iodine atoms. For Cs-133, Cs-134, Cs-135, and Cs-137, isotopic data (in Curies per Megawatt, and therefore generally applicable to similar BWRs such as Quad Cities +) for end of cycle conditions from Reference 13 were used. For shorter lived isotopes such as Cs-136 and Cs-138, the ratio of their concentration values in Reactor Water to that of Cs-137 in Reference 10 is used to predict their relative concentrations. Releases reflect this distribution, with the molar fractions converted to curie quantities based on the isotope's decay constant. Cs-133, representing about 38% of the cesium, is stable.



#### 6.4 *Dose Assessment*

Doses at the EAB and LPZ distances, and in the Control Room are calculated in Attachment A using the formulas in Section 2.5. Concentrations at the receptor locations are that in the steam plume for the Control Room or based on the release times the applicable X/Q for the EAB and LPZ.

Doses are calculated for inhalation (rem CEDE) and plume submersion (rem EDE) and totaled to yield rem TEDE. The breathing rate of  $3.47\text{E-}04 \text{ m}^3/\text{sec}$  is per RG 1.183 guidance without the round-off.

The resulting calculated doses are in the spreadsheet and in the Summary and Conclusions Section below.

## 7.0 SUMMARY AND CONCLUSIONS

Accident doses from a design basis MSLB were calculated for the control room operator, a person at the EAB, and a person at the LPZ. The results are summarized in the Table below. The doses at the Control Room, EAB, and LPZ resulting from a postulated design basis MSLB do not exceed the regulatory limits.

Location	Case 1 (normal equilibrium limit of 0.2 $\mu$ Ci) Dose (rem TEDE)	Case 2 (iodine spike limit of 4.0 $\mu$ Ci) Dose (rem TEDE)
LIMITS	CR: 5.0; EAB&LPZ: 2.5	CR: 5.0; EAB&LPZ: 25
EAB	0.167	3.32
LPZ	0.0168	0.335
CR	0.189	3.79

## 8.0 OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL DESIGN ANALYSIS

### DESIGN ANALYSIS NO. QDC-0000-N-1266 REV: 4

		Yes	No	N/A
1.	Do assumptions have sufficient rationale?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.	Are assumptions compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.	Do the design inputs have sufficient rationale?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.	Are design inputs correct and reasonable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.	Are design inputs compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.	Are Engineering Judgments clearly documented and justified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.	Are Engineering Judgments compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.	Do the results and conclusions satisfy the purpose and objective of the Design Analysis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.	Are the results and conclusions compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.	Does the Design Analysis include the applicable design basis documentation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11.	Have any limitations on the use of the results been identified and transmitted to the appropriate organizations?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12.	Are there any unverified assumptions?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13.	Do all unverified assumptions have a tracking and closure mechanism in place?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14.	Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated Configuration Change?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15.	Do the sources of inputs and analysis methodology used meet current technical requirements and regulatory commitments? (If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16.	Have vendor supporting technical documents and references (including GE DRFs) been reviewed when necessary?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EXELON REVIEWER:

T.J. Mscisz  
Print / Sign

DATE:

1/20/06

	A	B	C	D	E	F	G	H	I	J	K	L	M
1	Quad Cities 1&2 MSLB Dose Spreadsheet					Case 1:	Reactor Coolant at maximum value (DE I-131 of 0.2 uCi/g) permitted for continued full power operation						
2						Case 2:	Reactor Coolant at maximum value permitted (DE I-131 of 4.0 uCi/g) corresponding to an assumed pre-accident spike						
3	42514	Volume of cloud (cubic meters)											
4	6.35E+07	Mass of water in reactor coolant release (grams)											
5	54.6	seconds for cloud to pass over CR intake for wind speed of 1 m/second											
6	184000	Volume of Control Room Envelope (cubic feet) - maximum used for conservatism											
7	140,000	Mass of Liquid Water Released (lb)											
8	40%	Flashing Fraction											
9	56000	Mass of Steam in the Cloud (lb)											
10	26.799	Vg (ft³/lb) (based on 14.7 psi and 212F)											
11	Reactor coolant iodine distribution is assumed to be a 1 gm/cc specific gravity												
12									Case 1	Case 2			
13									Release	Release			
14				Normalized	Case 1	Case 2	Case 1	Case 2	Cloud	Cloud		Case 1	Case 2
15	Isotope	Activity	FGR 11	I-131 DE	Normalized	Normalized	Activity	Activity	Concentration	Concentration	Decay	Activity	Activity
16		Distribution	DCF¹	Activity	Activity	Activity	Release	Release			Constant	Release	Release
17		uCi/gm	Rem <sub>CEDE</sub> /Ci	uCi/gm	uCi/gm	uCi/gm	Ci	Ci	Ci/m3	Ci/m3	1/seconds	moles	moles
18	I-131	0.067	3.29E+04	6.70E-02	8.23E-02	1.65E+00	5.22E+00	1.04E+02	1.23E-04	2.46E-03	9.98E-07	3.22E-07	6.43E-06
19	I-132	0.38	3.81E+02	4.40E-03	5.40E-03	1.08E-01	2.96E+01	5.93E+02	6.97E-04	1.39E-02	8.37E-05	2.17E-08	4.35E-07
20	I-133	0.4	5.85E+03	7.11E-02	8.73E-02	1.75E+00	3.12E+01	6.24E+02	7.34E-04	1.47E-02	9.26E-06	2.07E-07	4.14E-06
21	I-134	0.53	1.31E+02	2.11E-03	2.59E-03	5.18E-02	4.13E+01	8.26E+02	9.72E-04	1.94E-02	2.20E-04	1.16E-08	2.31E-07
22	I-135	0.49	1.23E+03	1.83E-02	2.25E-02	4.50E-01	3.82E+01	7.64E+02	8.99E-04	1.80E-02	2.91E-05	8.06E-08	1.61E-06
23			Totals	1.63E-01	2.00E-01	4.00E+00					Totals	6.42E-07	1.28E-05
24					"non-spiked"	"spiked"							
25		NEDO-	NEDO-	NEDO-									
26		21143-1³	21143-1³	21143-1³	Case 1	Case 2							
27		MSLB	Case 1	Case 2	Release	Release							
28		Noble Gas	Activity	Activity	Cloud	Cloud							
29		Release	Release	Release	Concentration	Concentration							
30		Fractions	Ci	Ci	Ci/m3	Ci/m3							
31	Kr-83M	0.00936	6.95E-02	6.95E-02	1.63E-06	1.63E-06			Case 1	Case 2		Case 1	Case 2
32	Kr-85M	0.0164	1.22E-01	1.22E-01	2.86E-06	2.86E-06			Activity	Activity	Decay	Activity	Activity
33	Kr-85	0.000064	4.75E-04	4.75E-04	1.12E-08	1.12E-08			Release	Release	Constant	Release	Release
34	Kr-87	0.0511	3.79E-01	3.79E-01	8.92E-06	8.92E-06		Molar Frac.	moles	moles	1/seconds	curies	curies
35	Kr-88	0.0524	3.89E-01	3.89E-01	9.15E-06	9.15E-06	Cs-134	4.4317%	2.70E-08	5.41E-07	1.07E-08	4.69E-03	9.38E-02
36	Kr-89	0.218	1.62E+00	1.62E+00	3.81E-05	3.81E-05	Cs-135	17.4506%	1.06E-07	2.13E-06	9.55E-15	1.66E-08	3.31E-07
37	Xe-131M	0.0000523	3.66E-04	3.66E-04	9.13E-09	9.13E-09	Cs-136	0.0120%	7.32E-11	1.46E-09	6.10E-07	7.26E-04	1.45E-02
38	Xe-133M	0.000782	5.81E-03	5.81E-03	1.37E-07	1.37E-07	CS-137	40.17%	2.45E-07	4.90E-06	7.28E-10	2.91E-03	5.81E-02
39	Xe-133	0.0219	1.63E-01	1.63E-01	3.82E-06	3.82E-06	Cs-138	0.0102%	6.22E-11	1.24E-09	3.59E-04	3.63E-01	7.26E+00
40	Xe-135M	0.0641	4.76E-01	4.76E-01	1.12E-05	1.12E-05	Totals	62.08%	3.79E-07	7.58E-06			
41	Xe-135	0.0592	4.40E-01	4.40E-01	1.03E-05	1.03E-05	Balance is stable Cs-133						
42	Xe-137	0.288	2.14E+00	2.14E+00	5.03E-05	5.03E-05							
43	Xe-138	0.218	1.62E+00	1.62E+00	3.81E-05	3.81E-05							
44													

	A	B	C	D	E	F	G	H	I	J	K	L	M
45			Curies Released			Case 1 Dose (rem CEDE)			Case 2 Dose (rem CEDE)				
46			to the Environment				(Inhalation)			(Inhalation)			
47	Isotope		Case 1	Case 2	DCF <sup>1</sup>	CR	EAB	LPZ	CR	EAB	LPZ		
48	I-131		5.22E+00	1.04E+02	3.29E+04	7.65E-02	5.15E-02	5.18E-03	1.53E+00	1.03E+00	1.04E-01		
49	I-132		2.96E+01	5.93E+02	3.81E+02	5.03E-03	3.38E-03	3.40E-04	1.01E-01	6.77E-02	6.81E-03		
50	I-133		3.12E+01	6.24E+02	5.85E+03	8.12E-02	5.46E-02	5.50E-03	1.62E+00	1.09E+00	1.10E-01		
51	I-134		4.13E+01	8.26E+02	1.31E+02	2.41E-03	1.62E-03	1.63E-04	4.82E-02	3.24E-02	3.27E-03		
52	I-135		3.82E+01	7.64E+02	1.23E+03	2.09E-02	1.41E-02	1.42E-03	4.18E-01	2.82E-01	2.83E-02		
53													
54	Cs-134		4.69E-03	9.38E-02	4.63E+04	9.66E-05	6.50E-05	6.54E-06	1.93E-03	1.30E-03	1.31E-04		
55	Cs-135		1.66E-08	3.31E-07	4.55E+03	3.36E-11	2.26E-11	2.27E-12	6.71E-10	4.52E-10	4.55E-11		
56	Cs-136		7.26E-04	1.45E-02	7.33E+03	2.37E-06	1.59E-06	1.61E-07	4.74E-05	3.19E-05	3.21E-06		
57	Cs-137		2.91E-03	5.81E-02	3.19E+04	4.13E-05	2.78E-05	2.80E-06	8.26E-04	5.56E-04	5.60E-05		
58	Cs-138		3.63E-01	7.26E+00	1.01E+02	1.64E-05	1.10E-05	1.11E-06	3.28E-04	2.21E-04	2.22E-05		
59	Sub-total (rem CEDE)					1.86E-01	1.25E-01	1.26E-02	3.72E+00	2.51E+00	2.52E-01		
60													
61			Curies Released			Case 1 Dose (rem EDE)			Case 2 Dose (rem EDE)				
62			to the Environment				(External)			(External)			
63	isotope		Case 1	Case 2	DCF <sup>2</sup>	CR	EAB	LPZ	CR	EAB	LPZ		
64	I-131		5.22E+00	1.04E+02	6.73E-02	2.32E-05	3.04E-04	3.06E-05	4.63E-04	6.08E-03	6.12E-04		
65	I-132		2.96E+01	5.93E+02	4.14E-01	8.08E-04	1.06E-02	1.07E-03	1.62E-02	2.12E-01	2.13E-02		
66	I-133		3.12E+01	6.24E+02	1.09E-01	2.23E-04	2.93E-03	2.95E-04	4.47E-03	5.86E-02	5.90E-03		
67	I-134		4.13E+01	8.26E+02	4.81E-01	1.31E-03	1.72E-02	1.73E-03	2.62E-02	3.43E-01	3.46E-02		
68	I-135		3.82E+01	7.64E+02	2.95E-01	7.43E-04	9.74E-03	9.80E-04	1.49E-02	1.95E-01	1.96E-02		
69													
70	Cs-134		4.69E-03	9.38E-02	2.80E-01	8.65E-08	1.13E-06	1.14E-07	1.73E-06	2.27E-05	2.28E-06		
71	Cs-135		1.66E-08	3.31E-07	2.09E-06	2.28E-18	2.99E-17	3.01E-18	4.56E-17	5.98E-16	6.02E-17		
72	Cs-136		7.26E-04	1.45E-02	3.92E-01	1.88E-08	2.46E-07	2.48E-08	3.75E-07	4.92E-06	4.95E-07		
73	Cs-137		2.91E-03	5.81E-02	2.86E-05	5.48E-12	7.19E-11	7.23E-12	1.10E-10	1.44E-09	1.45E-10		
74	Cs-138		3.63E-01	7.26E+00	4.48E-01	1.07E-05	1.40E-04	1.41E-05	2.14E-04	2.81E-03	2.83E-04		
75													

	A	B	C	D	E	F	G	H	I	J	K	L	M
76	Sub-total (rem EDE)					3.12E-03	4.09E-02	4.12E-03	6.23E-02	8.18E-01	8.23E-02		
77	Iodine and Cesium Total (rem TEDE)					1.89E-01	1.66E-01	1.67E-02	3.79E+00	3.32E+00	3.35E-01		
78			Curies Released			Case 1 Dose (rem EDE)			Case 2 Dose (rem EDE)				
79			to the Environment				(External)			(External)			
80			Case 1	Case 2	DCF <sup>2</sup>	CR	EAB	LPZ	CR	EAB	LPZ		
81	Kr-83M		6.95E-02	6.95E-02	5.55E-06	2.54E-11	3.33E-10	3.35E-11	2.54E-11	3.33E-10	3.35E-11		
82	Kr-85M		1.22E-01	1.22E-01	2.77E-02	2.22E-07	2.91E-06	2.93E-07	2.22E-07	2.91E-06	2.93E-07		
83	Kr-85		4.75E-04	4.75E-04	4.40E-04	1.38E-11	1.81E-10	1.82E-11	1.38E-11	1.81E-10	1.82E-11		
84	Kr-87		3.79E-01	3.79E-01	1.52E-01	3.81E-06	5.00E-05	5.03E-06	3.81E-06	5.00E-05	5.03E-06		
85	Kr-88		3.89E-01	3.89E-01	3.77E-01	9.67E-06	1.27E-04	1.28E-05	9.67E-06	1.27E-04	1.28E-05		
86	Kr-89		1.62E+00	1.62E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
87	Xe-131M		3.88E-04	3.88E-04	1.44E-03	3.68E-11	4.83E-10	4.86E-11	3.68E-11	4.83E-10	4.86E-11		
88	Xe-133M		5.81E-03	5.81E-03	5.07E-03	1.94E-09	2.54E-08	2.56E-09	1.94E-09	2.54E-08	2.56E-09		
89	Xe-133		1.63E-01	1.63E-01	5.77E-03	6.18E-08	8.11E-07	8.16E-08	6.18E-08	8.11E-07	8.16E-08		
90	Xe-135M		4.76E-01	4.76E-01	7.55E-02	2.37E-06	3.10E-05	3.12E-06	2.37E-06	3.10E-05	3.12E-06		
91	Xe-135		4.40E-01	4.40E-01	4.40E-02	1.27E-06	1.67E-05	1.68E-06	1.27E-06	1.67E-05	1.68E-06		
92	Xe-137		2.14E+00	2.14E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
93	Xe-138		1.62E+00	1.62E+00	2.13E-01	2.28E-05	2.98E-04	3.00E-05	2.28E-05	2.98E-04	3.00E-05		
94	Noble Gas Sub-total (rem EDE)					4.02E-05	5.27E-04	5.30E-05	4.02E-05	5.27E-04	5.30E-05		
95													
96	Overall Total (rem TEDE)					1.89E-01	1.67E-01	1.68E-02	3.79E+00	3.32E+00	3.35E-01		
97													
98		<sup>1</sup> Dose Conversion Factor (rem/Curie) from Federal Guidance Report (FGR) 11 per Reg. Guide 1.183											
99		<sup>2</sup> Dose Conversion Factor (rem-m <sup>3</sup> /Curie-second) from FGR 12 per Reg. Guide 1.183											
100		<sup>3</sup> From NEDO-21143-1, "Radiological Accident Evaluation - The CONAC03 Code", General Electric Company, December, 1981,											
101		with its Table 3-1 ("SLBA Source Activities") Release Fractions and page 3-3 Ci conversion formula for a 0.1 Ci/sec design basis											
102		offgas release rate and 5.5 second MSIV closure time, both of which apply											
103	3.47E-04	Breathing rate (m <sup>3</sup> /second) per Regulatory Guide 1.183 (without round-off)											
104	5.13E-02	Control Room Geometry Factor per Reg. Guide 1.183, Regulatory Position 4.2.7											
105	1.54E+01	EAB $\sigma_y$ (meters) for F stability, (taken from PAVAN runs in Calc. QDC-0000-M-1408, Rev. 1)											
106	1.530E+02	LPZ $\sigma_y$ (meters) for F stability, (taken from PAVAN runs in Calc. QDC-0000-M-1408, Rev. 1)											
107	1.00E+00	Wind Speed (m/s)											
108	8.64E-04	X/Q (seconds/m <sup>3</sup> ) at EA Boundary - 0-2 hours based on RG 1.5 methodology											
109	8.69E-05	X/Q (seconds/m <sup>3</sup> ) at Low Population Zone - 0-2 based on RG 1.5 methodology											
110													

	A	B	C	D	E	F	G
1	Quad Cities 1&2 MSL					Case 1:	Reactor Coolant at maximum value (D
2						Case 2:	Reactor Coolant at maximum value pe
3	=A9*A10/35.3	Volume of cloud (cubic meters)					
4	=A7*453.59	Mass of water in reactor coolant r					
5	=(A3*12/PI())^(1/3)	seconds for cloud to pass over CR					
6	184000	Volume of Control Room Envelop					
7	140000	Mass of Liquid Water Released (lb					
8	0.4	Flashing Fraction					
9	=A7*A8	Mass of Steam in the Cloud (lb)					
10	26.799	Vg (ft <sup>3</sup> /lb) (based on 14.7 psi and					
11	Reactor coolant iodine dist						
12							
13							
14				Normalized	Case 1	Case 2	Case 1
15	Isotope	Activity	FGR 11	I-131 DE	Normalized	Normalized	Activity
16		Distribution	DCF <sup>1</sup>	Activity	Activity	Activity	Release
17		uCi/gm	Rem/CEDE/Ci	uCi/gm	uCi/gm	uCi/gm	Ci
18	I-131	0.067	32900	=C18*B18/C\$18	=D18*0.2/D\$23	=E18*20	=E18*\$A\$4*\$C\$18/C18/1000000
19	I-132	0.38	381	=C19*B19/C\$18	=D19*0.2/D\$23	=E19*20	=E19*\$A\$4*\$C\$18/C19/1000000
20	I-133	0.4	5846	=C20*B20/C\$18	=D20*0.2/D\$23	=E20*20	=E20*\$A\$4*\$C\$18/C20/1000000
21	I-134	0.53	131	=C21*B21/C\$18	=D21*0.2/D\$23	=E21*20	=E21*\$A\$4*\$C\$18/C21/1000000
22	I-135	0.49	1230	=C22*B22/C\$18	=D22*0.2/D\$23	=E22*20	=E22*\$A\$4*\$C\$18/C22/1000000
23			Totals	=SUM(D18:D22)	=SUM(E18:E22)	=SUM(F18:F22)	
24					"non-spiked"	"spiked"	
25		NEDO-	NEDO-	NEDO-			
26		21143-1 <sup>3</sup>	21143-1 <sup>3</sup>	21143-1 <sup>3</sup>	Case 1	Case 2	
27		MSLB	Case 1	Case 2	Release	Release	
28		Noble Gas	Activity	Activity	Cloud	Cloud	
29		Release	Release	Release	Concentration	Concentration	
30		Fractions	Ci	Ci	Ci/m3	Ci/m3	
31	Kr-83M	0.00936	=B31*5.5*3*0.45	=B31*5.5*3*0.45	=C31/\$A\$3	=D31/\$A\$3	
32	Kr-85M	0.0164	=B32*5.5*3*0.45	=B32*5.5*3*0.45	=C32/\$A\$3	=D32/\$A\$3	
33	Kr-85	0.000064	=B33*5.5*3*0.45	=B33*5.5*3*0.45	=C33/\$A\$3	=D33/\$A\$3	
34	Kr-87	0.0511	=B34*5.5*3*0.45	=B34*5.5*3*0.45	=C34/\$A\$3	=D34/\$A\$3	
35	Kr-88	0.0524	=B35*5.5*3*0.45	=B35*5.5*3*0.45	=C35/\$A\$3	=D35/\$A\$3	Cs-134
36	Kr-89	0.218	=B36*5.5*3*0.45	=B36*5.5*3*0.45	=C36/\$A\$3	=D36/\$A\$3	Cs-135
37	Xe-131M	0.0000523	=B37*5.5*3*0.45	=B37*5.5*3*0.45	=C37/\$A\$3	=D37/\$A\$3	Cs-136
38	Xe-133M	0.000782	=B38*5.5*3*0.45	=B38*5.5*3*0.45	=C38/\$A\$3	=D38/\$A\$3	Cs-137
39	Xe-133	0.0219	=B39*5.5*3*0.45	=B39*5.5*3*0.45	=C39/\$A\$3	=D39/\$A\$3	Cs-138
40	Xe-135M	0.0641	=B40*5.5*3*0.45	=B40*5.5*3*0.45	=C40/\$A\$3	=D40/\$A\$3	Totals
41	Xe-135	0.0592	=B41*5.5*3*0.45	=B41*5.5*3*0.45	=C41/\$A\$3	=D41/\$A\$3	
42	Xe-137	0.288	=B42*5.5*3*0.45	=B42*5.5*3*0.45	=C42/\$A\$3	=D42/\$A\$3	
43	Xe-138	0.218	=B43*5.5*3*0.45	=B43*5.5*3*0.45	=C43/\$A\$3	=D43/\$A\$3	
44							
45			Curies Released				Case 1 Dose (rem CEDE)
46			to the Environment				(Inhalation)
47	Isotope		Case 1	Case 2	DCF <sup>1</sup>	CR	EAB
48	I-131		=G18	=H18	32900	=I18*\$E48*\$A\$103*\$A\$5	=C48*\$E48*\$A\$103*\$A\$108
49	I-132		=G19	=H19	381	=I19*\$E49*\$A\$103*\$A\$5	=C49*\$E49*\$A\$103*\$A\$108
50	I-133		=G20	=H20	5846	=I20*\$E50*\$A\$103*\$A\$5	=C50*\$E50*\$A\$103*\$A\$108
51	I-134		=G21	=H21	131	=I21*\$E51*\$A\$103*\$A\$5	=C51*\$E51*\$A\$103*\$A\$108
52	I-135		=G22	=H22	1230	=I22*\$E52*\$A\$103*\$A\$5	=C52*\$E52*\$A\$103*\$A\$108
53							
54	Cs-134		=L35	=M35	=(3700000000000)*0.0000000125	=(\$C54/\$A\$3)*\$E54*\$A\$103*\$A\$5	=C54*\$E54*\$A\$103*\$A\$108
55	Cs-135		=L36	=M36	=(3700000000000)*0.0000000123	=(\$C55/\$A\$3)*\$E55*\$A\$103*\$A\$5	=C55*\$E55*\$A\$103*\$A\$108
56	Cs-136		=L37	=M37	=(3700000000000)*0.0000000198	=(\$C56/\$A\$3)*\$E56*\$A\$103*\$A\$5	=C56*\$E56*\$A\$103*\$A\$108
57	Cs-137		=L38	=M38	=(3700000000000)*0.0000000863	=(\$C57/\$A\$3)*\$E57*\$A\$103*\$A\$5	=C57*\$E57*\$A\$103*\$A\$108
58	Cs-138		=L39	=M39	=(3700000000000)*0.000000000274	=(\$C58/\$A\$3)*\$E58*\$A\$103*\$A\$5	=C58*\$E58*\$A\$103*\$A\$108

A	B	C	D	E	F	G
59	Sub-total (rem CEDE)				=SUM(F48:F58)	=SUM(G48:G58)
60						
61		Curies Released to the Environment				Case 1 Dose (rem EDE)
62						(External)
63	Isotope	Case 1	Case 2	DCF <sup>2</sup>	CR	EAB
64	I-131	=C48	=D48	0.06734	=I18*\$E64*\$A\$104*\$A\$5	=C64*\$E64*\$A\$108
65	I-132	=C49	=D49	0.4144	=I19*\$E65*\$A\$104*\$A\$5	=C65*\$E65*\$A\$108
66	I-133	=C50	=D50	0.10878	=I20*\$E66*\$A\$104*\$A\$5	=C66*\$E66*\$A\$108
67	I-134	=C51	=D51	0.481	=I21*\$E67*\$A\$104*\$A\$5	=C67*\$E67*\$A\$108
68	I-135	=C52	=D52	0.29526	=I22*\$E68*\$A\$104*\$A\$5	=C68*\$E68*\$A\$108
69						
70	Cs-134	=L35	=M35	=(3700000000000)*0.0000000000000757	=(C70/\$A\$3)*\$E70*\$A\$104*\$A\$5	=C70*\$E70*\$A\$108
71	Cs-135	=L36	=M36	=(3700000000000)*5.65E-19	=(C71/\$A\$3)*\$E71*\$A\$104*\$A\$5	=C71*\$E71*\$A\$108
72	Cs-136	=L37	=M37	=(3700000000000)*0.000000000000106	=(C72/\$A\$3)*\$E72*\$A\$104*\$A\$5	=C72*\$E72*\$A\$108
73	Cs-137	=L38	=M38	=(3700000000000)*7.74E-18	=(C73/\$A\$3)*\$E73*\$A\$104*\$A\$5	=C73*\$E73*\$A\$108
74	Cs-138	=L39	=M39	=(3700000000000)*0.000000000000121	=(C74/\$A\$3)*\$E74*\$A\$104*\$A\$5	=C74*\$E74*\$A\$108
75						
76	Sub-total (rem EDE)				=SUM(F64:F74)	=SUM(G64:G74)
77	Iodine and Cesium Total				=SUM(F59:F76)	=SUM(G59:G76)
78		Curies Released to the Environment				Case 1 Dose (rem EDE)
79						(External)
80		Case 1	Case 2	DCF <sup>2</sup>	CR	EAB
81	Kr-83M	=C31	=D31	0.00000555	=E31*\$E81*\$A\$104*\$A\$5	=C81*\$E81*\$A\$108
82	Kr-85M	=C32	=D32	0.027676	=E32*\$E82*\$A\$104*\$A\$5	=C82*\$E82*\$A\$108
83	Kr-85	=C33	=D33	0.0004403	=E33*\$E83*\$A\$104*\$A\$5	=C83*\$E83*\$A\$108
84	Kr-87	=C34	=D34	0.15244	=E34*\$E84*\$A\$104*\$A\$5	=C84*\$E84*\$A\$108
85	Kr-88	=C35	=D35	0.3774	=E35*\$E85*\$A\$104*\$A\$5	=C85*\$E85*\$A\$108
86	Kr-89	=C36	=D36	0	=E36*\$E86*\$A\$104*\$A\$5	=C86*\$E86*\$A\$108
87	Xe-131M	=C37	=D37	0.0014393	=E37*\$E87*\$A\$104*\$A\$5	=C87*\$E87*\$A\$108
88	Xe-133M	=C38	=D38	0.005069	=E38*\$E88*\$A\$104*\$A\$5	=C88*\$E88*\$A\$108
89	Xe-133	=C39	=D39	0.005772	=E39*\$E89*\$A\$104*\$A\$5	=C89*\$E89*\$A\$108
90	Xe-135M	=C40	=D40	0.07548	=E40*\$E90*\$A\$104*\$A\$5	=C90*\$E90*\$A\$108
91	Xe-135	=C41	=D41	0.04403	=E41*\$E91*\$A\$104*\$A\$5	=C91*\$E91*\$A\$108
92	Xe-137	=C42	=D42	0	=E42*\$E92*\$A\$104*\$A\$5	=C92*\$E92*\$A\$108
93	Xe-138	=C43	=D43	0.21349	=E43*\$E93*\$A\$104*\$A\$5	=C93*\$E93*\$A\$108
94	Noble Gas Sub-total (rem EDE)				=SUM(F81:F93)	=SUM(G81:G93)
95						
96	Overall Total (rem TEDE)				=SUM(F77:F94)	=SUM(G77:G94)
97						
98	<sup>1</sup> Dose Conversion Factor (rem/Curie) f					
99	<sup>2</sup> Dose Conversion Factor (rem-m <sup>3</sup> /Cur					
100	<sup>3</sup> From NEDO-21143-1, "Radiological A					
101	with its Table 3-1 ("SLBA Source Acti					
102	offgas release rate and 5.5 second M					
103	0.000347 Breathing rate (m <sup>3</sup> /second) per Regul					
104	=(A\$6*0.338)/1173 Control Room Geometry Factor per R					
105	15.4 EAB α <sub>o</sub> (meters) for F stability, (taken					
106	153 LPZ α <sub>o</sub> (meters) for F stability, (taken					
107	1 Wind Speed (m/s)					
108	=0.0133/A\$105/A\$107 X/Q (seconds/m <sup>3</sup> ) at EA Boundary - 0					
109	=0.0133/A\$106/A\$107 X/Q (seconds/m <sup>3</sup> ) at Low Population					



	H	I	J	K	L	M
1	E I-131 of 0.2 uCi/g) permitted for continued full power operation					
2						
3	mitted (DE I-131 of 4.0 uCi/g) corresponding to an assumed pre-accident spike					
4						
5						
6						
7						
8						
9						
10						
11						
12		Case 1	Case 2			
13		Release	Release			
14	Case 2	Cloud	Cloud		Case 1	Case 2
15	Activity	Concentration	Concentration	Decay	Activity	Activity
16	Release			Constant	Release	Release
17	Cl	Cl/m3	Cl/m3	1/seconds	moles	moles
18	=G18*20	=G18/\$A\$3	=H18/\$A\$3	=LN(2)/(8.04*86400)	=G18*37000000000/\$K18/6.023E+23	=H18*37000000000/\$K18/6.023E+23
19	=G19*20	=G19/\$A\$3	=H19/\$A\$3	=LN(2)/(2.3*3600)	=G19*37000000000/\$K19/6.023E+23	=H19*37000000000/\$K19/6.023E+23
20	=G20*20	=G20/\$A\$3	=H20/\$A\$3	=LN(2)/(20.8*3600)	=G20*37000000000/\$K20/6.023E+23	=H20*37000000000/\$K20/6.023E+23
21	=G21*20	=G21/\$A\$3	=H21/\$A\$3	=LN(2)/(52.6*60)	=G21*37000000000/\$K21/6.023E+23	=H21*37000000000/\$K21/6.023E+23
22	=G22*20	=G22/\$A\$3	=H22/\$A\$3	=LN(2)/(6.61*3600)	=G22*37000000000/\$K22/6.023E+23	=H22*37000000000/\$K22/6.023E+23
23				Totals	=SUM(L18:L22)	=SUM(M18:M22)
24						
25						
26						
27						
28						
29						
30						
31		Case 1	Case 2		Case 1	Case 2
32		Activity	Activity	Decay	Activity	Activity
33		Release	Release	Constant	Release	Release
34	Molar Frac.	moles	moles	1/seconds	curies	curies
35	0.044317152955112	=0.95*\$H35*\$L\$23	=0.95*\$H35*\$M\$23	=LN(2)/(2.062*86400*365.25)	=I35*6.023E+23*\$K35/37000000000	=J35*6.023E+23*\$K35/37000000000
36	0.174506296053598	=0.95*\$H36*\$L\$23	=0.95*\$H36*\$M\$23	=LN(2)/(2300000*86400*365.25)	=I36*6.023E+23*\$K36/37000000000	=J36*6.023E+23*\$K36/37000000000
37	0.000119942189253291	=0.95*\$H37*\$L\$23	=0.95*\$H37*\$M\$23	=LN(2)/(13.16*86400)	=I37*6.023E+23*\$K37/37000000000	=J37*6.023E+23*\$K37/37000000000
38	0.401736793048373	=0.95*\$H38*\$L\$23	=0.95*\$H38*\$M\$23	=LN(2)/(30.17*86400*365.25)	=I38*6.023E+23*\$K38/37000000000	=J38*6.023E+23*\$K38/37000000000
39	0.000101901239392202	=0.95*\$H39*\$L\$23	=0.95*\$H39*\$M\$23	=LN(2)/(32.2*60)	=I39*6.023E+23*\$K39/37000000000	=J39*6.023E+23*\$K39/37000000000
40	=SUM(H35:H39)	=SUM(I35:I39)	=SUM(J35:J39)			
41	Balance is stable Cs-133					
42						
43						
44						
45			Case 2 Dose (rem CEDE)			
46			(Inhalation)			
47	LPZ	CR	EAB	LPZ		
48	=C40*\$E40*\$A\$103*\$A\$109	=J16*\$E46*\$A\$103*\$A\$5	=D46*\$E48*\$A\$103*\$A\$108	=D48*\$E48*\$A\$103*\$A\$109		
49	=C49*\$E49*\$A\$103*\$A\$109	=J19*\$E49*\$A\$103*\$A\$5	=D49*\$E49*\$A\$103*\$A\$108	=D49*\$E49*\$A\$103*\$A\$109		
50	=C50*\$E50*\$A\$103*\$A\$109	=J20*\$E50*\$A\$103*\$A\$5	=D50*\$E50*\$A\$103*\$A\$108	=D50*\$E50*\$A\$103*\$A\$109		
51	=C51*\$E51*\$A\$103*\$A\$109	=J21*\$E51*\$A\$103*\$A\$5	=D51*\$E51*\$A\$103*\$A\$108	=D51*\$E51*\$A\$103*\$A\$109		
52	=C52*\$E52*\$A\$103*\$A\$109	=J22*\$E52*\$A\$103*\$A\$5	=D52*\$E52*\$A\$103*\$A\$108	=D52*\$E52*\$A\$103*\$A\$109		
53						
54	=C54*\$E54*\$A\$103*\$A\$109	=(D54/\$A\$3)*\$E54*\$A\$103*\$A\$5	=D54*\$E54*\$A\$103*\$A\$108	=D54*\$E54*\$A\$103*\$A\$109		
55	=C55*\$E55*\$A\$103*\$A\$109	=(D55/\$A\$3)*\$E55*\$A\$103*\$A\$5	=D55*\$E55*\$A\$103*\$A\$108	=D55*\$E55*\$A\$103*\$A\$109		
56	=C56*\$E56*\$A\$103*\$A\$109	=(D56/\$A\$3)*\$E56*\$A\$103*\$A\$5	=D56*\$E56*\$A\$103*\$A\$108	=D56*\$E56*\$A\$103*\$A\$109		
57	=C57*\$E57*\$A\$103*\$A\$109	=(D57/\$A\$3)*\$E57*\$A\$103*\$A\$5	=D57*\$E57*\$A\$103*\$A\$108	=D57*\$E57*\$A\$103*\$A\$109		
58	=C58*\$E58*\$A\$103*\$A\$109	=(D58/\$A\$3)*\$E58*\$A\$103*\$A\$5	=D58*\$E58*\$A\$103*\$A\$108	=D58*\$E58*\$A\$103*\$A\$109		

	H	I	J	K	L	M
59	=SUM(H48:H58)	=SUM(I48:I58)	=SUM(J48:J58)	=SUM(K48:K58)		
60						
61			Case 2 Dose (rem EDE)			
62			(External)			
63	LPZ	CR	EAB	LPZ		
64	=C64*\$E64*\$A\$109	=J18*\$E64*\$A\$104*\$A\$5	=D64*\$E64*\$A\$108	=D64*\$E64*\$A\$109		
65	=C65*\$E65*\$A\$109	=J19*\$E65*\$A\$104*\$A\$5	=D65*\$E65*\$A\$108	=D65*\$E65*\$A\$109		
66	=C66*\$E66*\$A\$109	=J20*\$E66*\$A\$104*\$A\$5	=D66*\$E66*\$A\$108	=D66*\$E66*\$A\$109		
67	=C67*\$E67*\$A\$109	=J21*\$E67*\$A\$104*\$A\$5	=D67*\$E67*\$A\$108	=D67*\$E67*\$A\$109		
68	=C68*\$E68*\$A\$109	=J22*\$E68*\$A\$104*\$A\$5	=D68*\$E68*\$A\$108	=D68*\$E68*\$A\$109		
69						
70	=C70*\$E70*\$A\$109	=(D70/\$A\$3)*\$E70*\$A\$104*\$A\$5	=D70*\$E70*\$A\$108	=D70*\$E70*\$A\$109		
71	=C71*\$E71*\$A\$109	=(D71/\$A\$3)*\$E71*\$A\$104*\$A\$5	=D71*\$E71*\$A\$108	=D71*\$E71*\$A\$109		
72	=C72*\$E72*\$A\$109	=(D72/\$A\$3)*\$E72*\$A\$104*\$A\$5	=D72*\$E72*\$A\$108	=D72*\$E72*\$A\$109		
73	=C73*\$E73*\$A\$109	=(D73/\$A\$3)*\$E73*\$A\$104*\$A\$5	=D73*\$E73*\$A\$108	=D73*\$E73*\$A\$109		
74	=C74*\$E74*\$A\$109	=(D74/\$A\$3)*\$E74*\$A\$104*\$A\$5	=D74*\$E74*\$A\$108	=D74*\$E74*\$A\$109		
75						
76	=SUM(H64:H74)	=SUM(I64:I74)	=SUM(J64:J74)	=SUM(K64:K74)		
77	=SUM(H59+H76)	=SUM(I59+I76)	=SUM(J59+J76)	=SUM(K59+K76)		
78			Case 2 Dose (rem EDE)			
79			(External)			
80	LPZ	CR	EAB	LPZ		
81	=C81*\$E81*\$A\$109	=F31*\$E81*\$A\$104*\$A\$5	=D81*\$E81*\$A\$108	=D81*\$E81*\$A\$109		
82	=C82*\$E82*\$A\$109	=F32*\$E82*\$A\$104*\$A\$5	=D82*\$E82*\$A\$108	=D82*\$E82*\$A\$109		
83	=C83*\$E83*\$A\$109	=F33*\$E83*\$A\$104*\$A\$5	=D83*\$E83*\$A\$108	=D83*\$E83*\$A\$109		
84	=C84*\$E84*\$A\$109	=F34*\$E84*\$A\$104*\$A\$5	=D84*\$E84*\$A\$108	=D84*\$E84*\$A\$109		
85	=C85*\$E85*\$A\$109	=F35*\$E85*\$A\$104*\$A\$5	=D85*\$E85*\$A\$108	=D85*\$E85*\$A\$109		
86	=C86*\$E86*\$A\$109	=F36*\$E86*\$A\$104*\$A\$5	=D86*\$E86*\$A\$108	=D86*\$E86*\$A\$109		
87	=C87*\$E87*\$A\$109	=F37*\$E87*\$A\$104*\$A\$5	=D87*\$E87*\$A\$108	=D87*\$E87*\$A\$109		
88	=C88*\$E88*\$A\$109	=F38*\$E88*\$A\$104*\$A\$5	=D88*\$E88*\$A\$108	=D88*\$E88*\$A\$109		
89	=C89*\$E89*\$A\$109	=F39*\$E89*\$A\$104*\$A\$5	=D89*\$E89*\$A\$108	=D89*\$E89*\$A\$109		
90	=C90*\$E90*\$A\$109	=F40*\$E90*\$A\$104*\$A\$5	=D90*\$E90*\$A\$108	=D90*\$E90*\$A\$109		
91	=C91*\$E91*\$A\$109	=F41*\$E91*\$A\$104*\$A\$5	=D91*\$E91*\$A\$108	=D91*\$E91*\$A\$109		
92	=C92*\$E92*\$A\$109	=F42*\$E92*\$A\$104*\$A\$5	=D92*\$E92*\$A\$108	=D92*\$E92*\$A\$109		
93	=C93*\$E93*\$A\$109	=F43*\$E93*\$A\$104*\$A\$5	=D93*\$E93*\$A\$108	=D93*\$E93*\$A\$109		
94	=SUM(H81:H93)	=SUM(I81:I93)	=SUM(J81:J93)	=SUM(K81:K93)		
95						
96	=SUM(H77+H94)	=SUM(I77+I94)	=SUM(J77+J94)	=SUM(K77+K94)		
97						
98						
99						
100						
101						
102						
103						
104						
105						
106						
107						
108						
109						

	A	B	C	D	E	F	G	H	I	J	K	L
1	<b>Peach Bottom Beginning of Core Life (100 Effective Full Power Days) and End of Cycle (EOC) Cesium Isotope Quantities</b>											
2	<b>(Used for General Cs Molar Fraction Determination for AST)</b>											
3										<b>Decay</b>		
4		<b>100 EFPD</b>	<b>EOC</b>					<b>100 EFPD</b>	<b>EOC</b>	<b>Constant</b>	<b>100 EFPD</b>	<b>EOC</b>
5		<b>(grams)</b>	<b>(grams)</b>				<b>At. Mass</b>	<b>(gm-moles)</b>	<b>(gm-moles)</b>	<b>1/seconds</b>	<b>Ci</b>	<b>Ci</b>
6	Cs-133	1.025E+05	1.678E+05			Cs-133	132.91	7.712E+02	1.263E+03	0.000E+00	0.000E+00	0.000E+00
7	Cs-134	1.031E+04	1.977E+04			Cs-134	133.91	7.699E+01	1.476E+02	1.07E-08	1.335E+07	2.559E+07
8	Cs-135	4.502E+04	7.841E+04			Cs-135	134.91	3.337E+02	5.812E+02	9.55E-15	5.188E+01	9.035E+01
9	Cs-137	1.087E+05	1.832E+05			Cs-137	136.91	7.940E+02	1.338E+03	7.28E-10	9.410E+06	1.586E+07
10						Cs-136		2.37E-01	3.99E-01	6.10E-07	2.352E+06	3.964E+06
11						Cs-138		2.01E-01	3.39E-01	3.59E-04	1.176E+09	1.982E+09
12	<b>Total</b>	<b>2.665E+05</b>	<b>4.492E+05</b>					<b>1.976E+03</b>	<b>3.331E+03</b>			
13												
14	<b>ANSI/ANS-18.1-1999 Relative Abundances in Reactor Water</b>											<b>Molar Fraction</b>
15		<b>uCi/gram of</b>	<b>moles/gram of</b>	<b>ratio to</b>						Cs-133	39.0219%	37.9218%
16		<b>Reactor Coolant</b>	<b>Reactor Coolant</b>	<b>Cs-137</b>						Cs-134	3.8956%	4.4317%
17	Cs-134	3.00E-05	1.04E+08	2.56E-02						Cs-135	16.8848%	17.4506%
18	Cs-136	2.00E-05	1.21E+06	2.99E-04						Cs-137	40.1755%	40.1737%
19	Cs-137	8.00E-05	4.07E+09	1.00E+00						Cs-136	0.0120%	0.0120%
20	Cs-138	1.00E-02	1.03E+06	2.54E-04						Cs-138	0.0102%	0.0102%

	A	B	C	D	E	F	G	H
1	Peach Bot							
2	(Used for C							
3								
4		100 EFPD	EOC					100 EFPD
5		(grams)	(grams)				At. Mass	(gm-moles)
6	Cs-133	102500	167800			Cs-133	132.9054	771.2
7	Cs-134	10310	19770			Cs-134	133.9067	76.99
8	Cs-135	45020	78410			Cs-135	134.9059	333.7
9	Cs-137	108700	183200			Cs-137	136.9071	794
10						Cs-136		=K10*37000000000/\$J10/6.023E+23
11						Cs-138		=K11*37000000000/\$J11/6.023E+23
12	Total	=SUM(B6:B9)	=SUM(C6:C9)					=SUM(H6:H11)
13								
14	ANSI/ANS-							
15		uCi/gram of	moles/gram of	ratio to				
16		Reactor Coolant	Reactor Coolant	Cs-137				
17	Cs-134	0.00003	=B17*37000/J7	=C17/C\$19				
18	Cs-136	0.00002	=B18*37000/J10	=C18/C\$19				
19	Cs-137	0.00008	=B19*37000/J9	=C19/C\$19				
20	Cs-138	0.01	=B20*37000/J11	=C20/C\$19				

	I	J	K	L
1				
2				
3				
4	<b>EOC</b>	<b>Decay</b>	<b>100 EFPD</b>	<b>EOC</b>
5	<b>(gm-moles)</b>	<b>Constant</b>	<b>CI</b>	<b>CI</b>
6	1263	0	=H6*\$J6*6.023E+23/37000000000	=I6*\$J6*6.023E+23/37000000000
7	147.6	=LN(2)/(2.062*86400*365.25)	=H7*\$J7*6.023E+23/37000000000	=I7*\$J7*6.023E+23/37000000000
8	581.2	=LN(2)/(2300000*86400*365.25)	=H8*\$J8*6.023E+23/37000000000	=I8*\$J8*6.023E+23/37000000000
9	1338	=LN(2)/(30.17*86400*365.25)	=H9*\$J9*6.023E+23/37000000000	=I9*\$J9*6.023E+23/37000000000
10	=L10*370000000000/\$J10/6.023E+23	=LN(2)/(13.16*86400)	=K\$9*\$B\$18/\$B\$19	=L\$9*\$B\$18/\$B\$19
11	=L11*370000000000/\$J11/6.023E+23	=LN(2)/(32.2*60)	=K\$9*\$B\$20/\$B\$19	=L\$9*\$B\$20/\$B\$19
12	=SUM(I6:I11)			
13				
14				
15			<b>Molar Fraction</b>	
15		Cs-133	=H6/H\$12	=I6/I\$12
16		Cs-134	=H7/H\$12	=I7/I\$12
17		Cs-135	=H8/H\$12	=I8/I\$12
18		Cs-137	=H9/H\$12	=I9/I\$12
19		Cs-136	=H10/H\$12	=I10/I\$12
20		Cs-138	=H11/H\$12	=I11/I\$12

**Computer Disclosure Sheet**Discipline Nuclear

Client:: Exelon Corporation  
Project: Quad Cities Units 1&2 MSLB AST

Date: January 2006  
Job No.

Program(s) used  
Attachment A spreadsheet

Rev No.  
N/A

Rev Date  
N/A

Calculation Set No.: QDC-0000-N-1266, Rev. 4

Status ☐ Prelim.  
☒ Final  
☐ Void

WGI Prequalification ☐ Yes  
☒ No

Run No.

Description:

Analysis Description: Spreadsheet used to perform dose assessment for MSLB, as described in calculation.

The attached computer output has been reviewed, the input data checked,  
And the results approved for release. Input criteria for this analysis were established.

By:

On: January 2006


Run by: H. Rothstein



Checked by: P. Reichert



Separate cell-by-cell independent check by: A. Boatright



Approved by: H. Rothstein



Remarks: WGI Form for Computer Software Control

This spreadsheet is relatively straight-forward and was hand checked. Attachment includes the spreadsheet in both normal and formula display mode and so is completely documented. A separate cell-by-cell independent check was also performed.