

March 2, 2006

Mr. James H. Lash  
Vice President  
FirstEnergy Nuclear Operating Company  
Beaver Valley Power Station  
P. O. Box 4  
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNIT NO. 2 (BVPS-2) - REQUEST FOR  
ADDITIONAL INFORMATION (RAI) - STATION BATTERY CHARGER  
UPGRADE (TAC NO. MC8735)

Dear Mr. Lash:

By letter dated October 14, 2005, FirstEnergy Nuclear Operating Company requested an Amendment to the BVPS-2, Technical Specifications (TSs). The proposed changes would revise TSs 3/4.8.2.3 and 3/4.8.2.4 to permit implementation of station battery charger upgrades, including installation of new battery chargers. The Nuclear Regulatory Commission (NRC) staff has determined that the information contained in the enclosed RAI will be needed for the NRC staff to complete its review.

As discussed with your staff, we request your response within 30 days of receipt of this letter in order to maintain our review schedule. If you have any questions, please contact me at 301-415-1402.

Sincerely,

*/RA/*

Timothy G. Colburn, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-412

Enclosure:  
RAI

cc w/encl: See next page

March 2, 2006

Mr. James H. Lash  
Vice President  
FirstEnergy Nuclear Operating Company  
Beaver Valley Power Station  
P. O. Box 4  
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNIT NO. 2 (BVPS-2) - REQUEST FOR  
ADDITIONAL INFORMATION (RAI) - STATION BATTERY CHARGER  
UPGRADE (TAC NO. MC8735)

Dear Mr. Lash:

By letter dated October 14, 2005, FirstEnergy Nuclear Operating Company requested an Amendment to the BVPS-2, Technical Specifications (TSs). The proposed changes would revise TSs 3/4.8.2.3 and 3/4.8.2.4 to permit implementation of station battery charger upgrades, including installation of new battery chargers. The Nuclear Regulatory Commission (NRC) staff has determined that the information contained in the enclosed RAI will be needed for the NRC staff to complete its review.

As discussed with your staff, we request your response within 30 days of receipt of this letter in order to maintain our review schedule. If you have any questions, please contact me at 301-415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-412

Enclosure:  
RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	LPLI-1 R/F	RidsNrrLASLittle	RidsACRS	RidsNrrPMTColburn
MMcConnell	RidsNrrDorlLpla	RidsNrrDeEeeb	RidsOGC	RBellamy, RGN-I

ADAMS Accession No.: ML060580625

\*Input received. No substantive changes made.

OFFICE	LPLI-1/LA	LPLI-1/PM	EEEEB/BC(A)	LPLI-1/BC
NAME	SLittle	TColburn	EBrown*	RLaufer
DATE	3/01/06	3/01/06	02/17/06	3/02/06

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION (RAI)  
BEAVER VALLEY POWER STATION, UNIT NO. 2 (BVPS-2)  
STATION BATTERY CHARGER UPGRADE  
DOCKET NO. 50-412

By letter dated October 14, 2005 (Agencywide Documents Access and Management System Accession No. ML052920419), FirstEnergy Nuclear Operating Company requested an amendment to the BVPS-2 Technical Specifications (TSs). The proposed changes would revise TSs 3/4.8.2.3 and 3/4.8.2.4 to permit implementation of station battery charger upgrades, including installation of new battery chargers. The Nuclear Regulatory Commission (NRC) staff has determined that the information contained below is needed for the NRC staff to complete its review.

1. Provide assurance that any spare charger that could be credited by removing '2-7' from TS 3.8.2.3 ACTION b and the note in TS 3.8.2.4 would be equivalent to what is detailed in the BVPS-2 Updated Final Safety Analysis Report (UFSAR).
2. The Institute of Electrical and Electronics Engineers (IEEE) Standard - 450 (1987-2002), "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications," states that degradation is indicated when the battery capacity drops more than 10% from its capacity on the previous performance test, or is below 90% of manufacturer's rating.

Provide assurance that the current definition for battery degradation being used at BVPS-2 provides an accurate indication of each battery's condition.

3. Provide assurance that the BVPS-2 UFSAR will reflect the proposed design change.
4. Provide an updated electrical one-line diagram that shows the proposed design configuration.
5. How will you prevent the rectifier assemblies from providing direct current input to the respective 125-volt direct current bus?

cc:

Gary R. Leidich  
President and Chief Nuclear Officer  
FirstEnergy Nuclear Operating Company  
Mail Stop A-GO-19  
76 South Main Street  
Akron, OH 44308

Joseph J. Hagan  
Senior Vice President of Operations  
and Chief Operating Officer  
FirstEnergy Nuclear Operating Company  
Mail Stop A-GO-14  
76 South Main Street  
Akron, OH 44308

Danny L. Pace  
Senior Vice President, Fleet Engineering  
FirstEnergy Nuclear Operating Company  
Mail Stop A-GO-14  
76 South Main Street  
Akron, OH 44308

Jeannie M. Rinckel  
Vice President, Fleet Oversight  
FirstEnergy Nuclear Operating Company  
Mail Stop A-GO-14  
76 South Main Street  
Akron, OH 44308

David W. Jenkins, Attorney  
FirstEnergy Corporation  
Mail Stop A-GO-18  
76 South Main Street  
Akron, OH 44308

Manager, Fleet Licensing  
FirstEnergy Nuclear Operating Company  
Mail Stop A-GHE-107  
395 Ghent Road  
Akron, OH 44333

Executive Vice President, Special Projects  
FirstEnergy Nuclear Operating Company  
Beaver Valley Power Station  
Mail Stop A-BV-SGRP  
P.O. Box 4, Route 168  
Shippingport, PA 15077

Manager, Site Regulatory Compliance  
FirstEnergy Nuclear Operating Company  
Beaver Valley Power Station  
Mail Stop A-BV-A  
P.O. Box 4, Route 168  
Shippingport, PA 15077

Commissioner James R. Lewis  
West Virginia Division of Labor  
749-B, Building No. 6  
Capitol Complex  
Charleston, WV 25305

Director, Utilities Department  
Public Utilities Commission  
180 East Broad Street  
Columbus, OH 43266-0573

Director, Pennsylvania Emergency  
Management Agency  
2605 Interstate Dr.  
Harrisburg, PA 17110-9364

Ohio EPA-DERR  
ATTN: Zack A. Clayton  
P.O. Box 1049  
Columbus, OH 43266-0149

Dr. Judith Johnsrud  
Environmental Coalition on Nuclear Power  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Lew W. Myers

Beaver Valley Power Station, Unit Nos. 1 and 2 (continued)

cc:

Director  
Bureau of Radiation Protection  
Pennsylvania Department of  
Environmental Protection  
Rachel Carson State Office Building  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Mayor of the Borough of Shippingport  
P.O. Box 3  
Shippingport, PA 15077

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 298  
Shippingport, PA 15077