

From: "BENNETT, STEVE A" <SBENNE2@entergy.com>
To: "Drew Holland" <DGH1@nrc.gov>
Date: 1/30/06 3:36PM
Subject: RE: Re: ANO-1 Reactor Containment and Tendon Surv....MC5849

Drew,

Based on the call that we had in December, we took the action to look into performing regression analysis for ANO-1 in accordance with IN 99-10. We have decided that going forward that both ANO-1 and ANO-2 will use the regression analysis approach for trending tendon degradation for consistency. This should resolve Hans' concern and should be sufficient for closure of the ANO-1 Tendon report.

Steve

-----Original Message-----

From: Drew Holland [mailto:DGH1@nrc.gov]
Sent: Monday, January 30, 2006 12:56 PM
To: BENNETT, STEVE A
Subject: Fwd: Re: ANO-1 Reactor Containment and Tendon Surv....MC5849

Steve: Please factor Hans Asher's concerns attached into the reactor building surveillance and inspection program.

CC: "BROWN, STEVEN G" <SBROWN7@entergy.com>

DOCKET No. 50-313
TAC No 5 MC5849

Mail Envelope Properties (43DE78AE.274 : 1 : 62068)

Subject: RE: Re: ANO-1 Reactor Containment and Tendon Surv....MC5849
Creation Date: 1/30/06 3:35PM
From: "BENNETT, STEVE A" <SBENNE2@entergy.com>

Created By: SBENNE2@entergy.com

Recipients

nrc.gov
owf4_po.OWFN_DO
DGH1 (Drew Holland)

entergy.com
SBROWN7 CC (STEVEN G BROWN)

Post Office
owf4_po.OWFN_DO

Route
nrc.gov
entergy.com

Files	Size	Date & Time
MESSAGE	734	01/30/06 03:35PM
Mime.822	2120	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

DOCKET No 50-313
TAC No. MC5849