

February 24, 2006

Director, Spent Fuel Project Office  
Office of Nuclear Material Safety and Safeguards  
U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**Subject: Docket Nos. 50-206, 50-361, 50-362, 72-41  
Annual Radioactive Effluent Release Report for  
Independent Spent Fuel Storage Installation – 2005  
San Onofre Nuclear Generation Station Units 1, 2 and 3**

Gentlemen:

In accordance with 10 CFR 72.44(d)(3) and Certificate of Compliance No. 72-1029, Technical Specification Section 5.2.3(c), Southern California Edison (SCE) is providing the Annual Radioactive Effluent Release Report for the Independent Spent Fuel Storage Installation (ISFSI) at San Onofre Nuclear Generating Station (SONGS). The period of the report is January 1, 2005 through December 31, 2005.

The dry shielded canisters are double seal welded and designed to meet the criteria of Interim Staff Guidance-18 and thus prevent effluent releases. In addition, we have completed in-process inspections and tests during the fabrication and sealing of the canisters in compliance with Certificate of Compliance No. 72-1029. On that basis, SCE is reporting there were no releases of principal radionuclides in liquid or gaseous effluents from the SONGS ISFSI to the environment in 2005.

If you require additional information, please contact Mr. Clay E. Williams at (949) 368-6707.

Sincerely,



cc: B. S. Mallett, NRC Regional Administrator, Region IV  
J. C. Shepherd, NRC Project Manager, SONGS Unit 1  
C. C. Osterholtz, NRC Senior Resident Inspector, SONGS Units 2 and 3  
NRC Project Manager, SONGS ISFSI

P.O. Box 128  
San Clemente, CA 92672  
949-368-7501  
Fax 949-368-7575

IE48  
IE17  
NMSSDI