

DOCKET NUMBER
PROPOSED RULE PR 50
(70FR 67598)

DOCKETED
USNRC

9

March 9, 2006 (10:37am)

OFFICE OF SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Comment on Proposed 50.46a

During Session W4D of the Regulatory Information Conference (RIC 2006) on March 8, 2006, it was stated that 50.46a would not address LOCA/LOOP. (Reference M. Tschiltz presentation, slide No. 2)

However it was also stated that one assumption permitted would be the availability of offsite power. A second statement would remove the requirement for a fast start diesel generator. Both of these statements would imply that a LOCA/LOOP was addressed as not creditable during a LBLOCA. These statements seem incompatible with a position to not address LOCA/LOOP through 50.46a. Please clarify the intent of 50.46a.

Template = SECY-067

SECY-02

From: Carol Gallagher
To: Evangeline Ngbea
Date: Thu, Mar 9, 2006 10:26 AM
Subject: Comment letter on Proposed Rule - Risk-Informed Changes to LOCA Technical Requirements

Attached for docketing is a comment letter on the above noted proposed rule that I received via the rulemaking website on 3/8/06.

Carol

Mail Envelope Properties (44104930.6B3 : 3 : 886)

Subject: Comment letter on Proposed Rule - Risk-Informed Changes to LOCA
Technical Requirements
Creation Date: 3/9/06 10:26AM
From: Carol Gallagher
Created By: CAG@nrc.gov

Recipients

nrc.gov
owf5_po.OWFN_DO
ESN (Evangeline Ngbea)

Post Office

owf5_po.OWFN_DO

Route

nrc.gov

Files	Size	Date & Time
MESSAGE	568	03/09/06 10:26AM
1434-0004.wpd	2863	03/09/06 10:24AM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard