



March 13, 2006

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir or Madam:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR) 2006-002

South Carolina Electric & Gas Company (SCE&G) is submitting this report pursuant to the requirements of Technical Specification 3.3.3.1.b. This report addresses the inoperability of the Main Steam Line radiation monitors (RMG-19A(B)(C)) for greater than 72 hours. During the inoperable period of 91 hours and 15 minutes, V. C. Summer Nuclear Station (VCSNS) implemented a preplanned alternate monitoring in accordance with the requirements of Action 30 of the Technical Specification.

The radiation monitors were removed from service on February 25, 2006 at 1700 hours in order to replace the Victoreen Model 845 series monitor with a new Victoreen Model 945A series to improve equipment reliability. The modifications were completed and the equipment returned to operability on March 1, 2006 at 1215 hours.

Should you have any questions, please call Mr. Robert Sweet at (803) 345-4080 at your convenience.

Very truly yours,

Jeffrey B. Archie

CJM/JBA/cm

c: N. O. Lorick
S. A. Byrne
N. S. Cams
J. H. Hamilton
R. J. White
W. D. Travers
R. E. Martin
K. M. Sutton
NRC Resident Inspector
INPO Records Center
NSRC
CER (C-06-0757)
File (818.08)
DMS (RC-06-0051)

IE22