

**From:** Emmett Murphy  
**To:** Drew Holland  
**Date:** 3/9/06 9:49AM  
**Subject:** Re: Plugging report.

Then it's OK to close it out.

>>> Drew Holland 03/09/06 9:48 AM >>>

Emmett: This TS is: "Following each inservice inspection of steam generator tubes the number of tubes plugged in each steam generator shall be reported to the commission within 15 days."

>>> Emmett Murphy 03/09/06 9:16 AM >>>

Drew, what does TS 6.6.7.a say? I just want to be clear on what requirement there April 11 report is responsive to.

DOCKET 50-368

PERTAINS TO SUCCESSFUL NRC REVIEW OF  
AND-2 2005 STEAM GENERATOR  
TUBE INSPECTION DURING OUTAGE.  
NRR REVIEWED THE LICENSEE'S  
INSPECTION REPORT AND FOUND IT  
TO BE ADEQUATE.

**Mail Envelope Properties** (44104075.288 : 22 : 35304)

**Subject:** Re: Plugging report.  
**Creation Date:** 3/9/06 9:49AM  
**From:** Emmett Murphy

**Created By:** ELM@nrc.gov

**Recipients**

nrc.gov  
owf4\_po.OWFN\_DO  
DGH1 (Drew Holland)

**Post Office**

owf4\_po.OWFN\_DO

**Route**

nrc.gov

**Files**

MESSAGE

**Size**

966

**Date & Time**

03/09/06 09:49AM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard