

From: Ed Miller
To: david.distel@exeloncorp.com
Date: 3/28/06 1:04PM
Subject: Oyster Creek EAL LAR RAI

Dave,

The following are two draft questions from the reviewer of your January 24, 2006, Oyster Creek LAR to revise the Emergency Action Levels HA5 and HU5:

<1> HU5 and HA5 do not specifically state how the MSL value is read or how to respond when the MSL value cannot be read (canal iced over, etc.). The EAL or EAL basis needs to state how the MSL value is obtained and any restrictions there may be on using this level indication.

<2> HU5 and HA5 do not address the PI-533-1172/73 instruments in the EAL basis. The EAL basis should discuss these instruments, any restrictions, and a brief explanation of the need for both indicators to be used for EAL declaration.

Please note that these do not represent an official NRC staff position. If you need any clarification on the questions, please let me know and I can set up a conference call to discuss.

G. Edward Miller
Project Manager
Division of Operating Reactor Licensing
U.S. Nuclear Regulatory Commission
(301) 415-2481

Mail Envelope Properties

(44297AB8.3E9 : 9 : 35080)

Subject: Oyster Creek EAL LAR RAI
Creation Date: 3/28/06 1:04PM
From: Ed Miller

Created By: GXM@nrc.gov

Recipients

exeloncorp.com
david.distel (david.distel@exeloncorp.com)

Action

Transferred

Date & Time

03/28/06 1:05 PM

Post Office**Delivered****Route**

exeloncorp.com

Files

MESSAGE

Size

1841

Date & Time

03/28/06 01:04PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened