

March 29, 2006

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-06-005

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date.

**Facility**

Columbia Generating Station  
Energy Northwest  
Richland, WA  
Docket: 50-397  
License No. NPF-21

**Licensee Emergency Classification**

☒ Notification of Unusual Event  
☐ Alert  
☐ Site Area Emergency  
☐ General Emergency  
☐ Not Applicable

SUBJECT: NOTICE OF UNUSUAL EVENT DUE TO RANGE FIRE IN PROXIMITY OF THE COLUMBIA NUCLEAR PLANT

DESCRIPTION: At 1:57 p.m. (PST) on March 28, 2006, an unusual event was declared at the Columbia Generating Station due to a range fire near the facility. The range fire was located on owner controlled property approximately 150 yards southeast of the protected area boundary. The fire was extinguished by the Hanford fire department. The unusual event was terminated at 4:40 p.m. (PST).

The basis for the event declaration was the potential for the fire to impact plant safety equipment. During this event, the fire did not cause an actual threat to any plant safety equipment. No personnel were injured during the event.

The licensee is investigating the cause of the fire.

The state of Washington has been informed.

The resident inspectors monitored the licensee's response to this event.

This information has been discussed with the licensee and is current as of 12:05 p.m. (PST) on March 29, 2006.

ADAMS ACCESSION NUMBER: ML 060880454

CONTACTS: Claude E. Johnson, Chief  
Project Branch A  
Division of Reactor Projects  
817-860-8148  
CEJ1@NRC.GOV

Zach Dunham  
Senior Resident Inspector  
Columbia Generating Station  
509-377-2627  
ZKD@NRC.GOV