

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

- 2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow < 10% rated core flow:

THERMAL POWER shall be \leq 25% RTP.

- 2.1.1.2 With the reactor steam dome pressure \geq 785 psig and core flow \geq 10% rated core flow:

For Unit 1, MCPR shall be \geq 1.10 for two recirculation loop operation or \geq 1.11 for single recirculation loop operation.

For Unit 2, MCPR for GNF fuel shall be \geq 1.09 for two recirculation loop operation, or \geq 1.10 for single recirculation loop operation. MCPR for Westinghouse fuel shall be \geq 1.11 for two recirculation loop operation, or \geq 1.13 for single recirculation loop operation.

- 2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be \leq 1345 psig.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

- 2.2.1 Restore compliance with all SLs; and

- 2.2.2 Insert all insertable control rods.
-