

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION (Continued)</u>				
h. HPCI Torus Compartment Temperature - High	NA	Q	R	1, 2, 3
i. Drywell Pressure - High	NA	Q	R	1, 2, 3
j. Manual Initiation	NA	R	NA	1, 2, 3
7. <u>RHR SYSTEM SHUTDOWN COOLING MODE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Level 3	S	Q	R	1, 2, 3
b. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	NA	Q	R	1, 2, 3
c. Manual Initiation	NA	Q(a)	NA	1, 2, 3

* When handling recently irradiated fuel in the secondary containment and during operations with a potential for draining the reactor vessel.

** When any turbine stop valve is greater than 90% open and/or when the key-locked bypass switch is in the Norm position.

Refer to Specification 3.1.5 for applicability.

(a) Manual initiation switches shall be tested at least once per 18 months. All other circuitry associated with manual initiation shall receive a CHANNEL FUNCTIONAL TEST at least once per 92 days as part of circuitry required to be tested for automatic system isolation.

(b) Each train or logic channel shall be tested at least every other 92 days.