

July 12, 2006

Mr. Louis Quintana
Manager, Licensing
GE Nuclear Energy
P. O. Box 780, M/C A-30
Wilmington, NC 28401

SUBJECT: DRAFT SAFETY EVALUATION (SE) FOR GENERAL ELECTRIC NUCLEAR ENERGY (GENE) TOPICAL REPORT (TR) NEDE-32906P, REVISION 2, "TRACG APPLICATION FOR ANTICIPATED OPERATIONAL OCCURRENCES (AOO) TRANSIENT ANALYSES" (TAC NO. MD0249)

Dear Mr. Quintana:

By letter dated February 14, 2006, GENE submitted TR NEDE-32906P, Revision 2, "TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses," to the U.S. Nuclear Regulatory Commission (NRC) staff for review. Enclosed for GENE review and comment is a copy of the NRC staff's draft SE for the TR.

Pursuant to Section 2.390 of Title 10 of the *Code of Federal Regulations* (10 CFR), we have determined that the enclosed draft SE does not contain proprietary information. However, we will delay placing the draft SE in the public document room for a period of 10 working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects. If you believe that any information in the enclosure is proprietary, please identify such information line-by-line and define the basis pursuant to the criteria of 10 CFR 2.390. After 10 working days, the draft SE will be made publicly available, and an additional 10 working days are provided to you to comment on any factual errors or clarity concerns contained in the draft SE. The final SE will be issued after making any necessary changes and will be made publicly available. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes. If you have any questions, please contact Michelle Honcharik at 301-415-1774.

Sincerely,

/RA/

Stacey L. Rosenberg, Chief
Special Projects Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Project No. 710

Enclosure: Draft SE

cc w/encl: See next page

July 12, 2006

Mr. Louis Quintana
Manager, Licensing
GE Nuclear Energy
P. O. Box 780, M/C A-30
Wilmington, NC 28401

SUBJECT: DRAFT SAFETY EVALUATION (SE) FOR GENERAL ELECTRIC NUCLEAR ENERGY (GENE) TOPICAL REPORT (TR) NEDE-32906P, REVISION 2, "TRACG APPLICATION FOR ANTICIPATED OPERATIONAL OCCURRENCES (AOO) TRANSIENT ANALYSES" (TAC NO. MD0249)

Dear Mr. Quintana:

By letter dated February 14, 2006, GENE submitted TR NEDE-32906P, Revision 2, "TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses," to the U.S. Nuclear Regulatory Commission (NRC) staff for review. Enclosed for GENE review and comment is a copy of the NRC staff's draft SE for the TR.

Pursuant to Section 2.390 of Title 10 of the *Code of Federal Regulations* (10 CFR), we have determined that the enclosed draft SE does not contain proprietary information. However, we will delay placing the draft SE in the public document room for a period of 10 working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects. If you believe that any information in the enclosure is proprietary, please identify such information line-by-line and define the basis pursuant to the criteria of 10 CFR 2.390. After 10 working days, the draft SE will be made publicly available, and an additional 10 working days are provided to you to comment on any factual errors or clarity concerns contained in the draft SE. The final SE will be issued after making any necessary changes and will be made publicly available. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes. If you have any questions, please contact Michelle Honcharik at 301-415-1774.

Sincerely,

/RA/

Stacey L. Rosenberg, Chief
Special Projects Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Project No. 710
Enclosure: Draft SE
cc w/encl: See next page

DISTRIBUTION:

PUBLIC (No DPC for 10 working days)

PSPB Reading File	RidsNrrDpr	RidsNrrDprPspb
RidsNrrPMMHoncharik	RidsNrrLADBaxley	RidsOgcMailCenter
RidsAcrsAcnwMailCenter	RidsNrrDssSnpb	ETHrom

ADAMS ACCESSION NO.: ML061800330

*No major changes to SE input.

NRR-106

OFFICE	PSPB/PM	PSPB/LA	SNPB/BC*	PSPB/BC	DPR/DD
NAME	MHoncharik	DBaxley	FAkstulewicz	SRosenberg	HNieh
DATE	7/10/06	7/10/06	6/23/06	7/11/06	7/12/06

OFFICIAL RECORD COPY

GENE

Project No. 710

cc:

Mr. George B. Stramback
Regulatory Services Project Manager
GE Nuclear Energy
175 Curtner Avenue
San Jose, CA 95125

Mr. Charles M. Vaughan, Manager
Facility Licensing
Global Nuclear Fuel
P.O. Box 780
Wilmington, NC 28402

Mr. Glen A. Watford, Manager
Technical Services
GE Nuclear Energy
175 Curtner Avenue
San Jose, CA 95125

Andrew A. Lingenfelter, Manager
GNF Engineering
Global Nuclear Fuels - Americas, LLC
P.O. Box 780, M/C F12
Wilmington, NC 28402

04/18/06

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

TOPICAL REPORT NEDE-32906P, REVISION 2

"TRACG APPLICATION FOR ANTICIPATED OPERATIONAL

OCCURRENCES (AOO) TRANSIENT ANALYSES"

GENERAL ELECTRIC NUCLEAR ENERGY (GENE)

PROJECT NO. 710

1.0 INTRODUCTION AND BACKGROUND

GENE and its subsidiary Global Nuclear Fuel (GNF) submitted TRACG02A (referred to hereafter as TRACG) for U.S. Nuclear Regulatory Commission (NRC) review for application to anticipated operational occurrence (AOO) transient events on January 25, 2000 (Reference 1). The submittal included the code model documents related to the TRACG code (References 2(a), 2(b), and 2(c)). The TRACG code is a thermal-hydraulic analysis code intended to be used as a realistic analysis model. The NRC staff approved TRACG for AOO transient events on October 22, 2001 (Reference 3). The approved topical report, NEDE-32906P-A, Revision 1, was provided by GENE on February 6, 2006 (Reference 4).

The TRAC family of codes began as a pressurized water reactor analysis code developed for the NRC at Los Alamos National Laboratory. A boiling water reactor (BWR) version of the code was developed jointly by the NRC and GENE at the Idaho National Engineering Laboratory as TRAC-BD1/MOD1 (Reference 5). GENE developed a proprietary version of the code designated as TRACG. The objective of the proprietary code development was to have a code capable of realistic analyses of transients, stability, and anticipated transients without scram events. The code was modified to include a three-dimensional kinetic model in addition to the multi-dimensional, two-fluid thermal-hydraulics models.

The plant types for which the TRACG code is to be applied include the BWR/2, BWR/3, BWR/4, BWR/5, and BWR/6 designs. This code has not been submitted for review for application to any other plant design.

GENE submitted a proposed revision to TRACG, in a letter dated February 14, 2006 (Reference 6). GENE has corrected a small error in the quantification of the accuracy of the void coefficient, an element of the NRC-approved methodology used in TRACG licensing basis AOO analyses. GENE revised the discussion of item "C1AX Void Coefficient, H" in Subsection 5.1, "Model Parameters and Uncertainties" of NEDE-32906P-A, Revision 1. The responses to related NRC staff requests for additional information (RAIs) during the initial review, particularly RAI 13, were also revised to document the void coefficient correction. In addition, other non-technical changes were made to address typographical errors and provide additional clarifications. Because the error did not involve the model description or qualification

1 studies, there were no changes to the TRACG model and qualification reports (References 2(a)
2 and 2(b)).

3
4 GENE supplemented the submittal in response to the May 31, 2006, NRC staff RAI
5 (Reference 7) on June 7, 2006 (Reference 8).

6 7 2.0 REGULATORY AND TECHNICAL EVALUATION 8

9 TRACG uses a 3-dimensional neutron kinetics model to compute the needed neutronics
10 parameters. The contribution of the change in the water density to the reactivity in a node is
11 computed in terms of the infinite multiplication factor as a function of the void fraction and fuel
12 exposure in the node (modeled volume).

13
14 The overall analysis approach to AOOs in NEDE-32906P followed the Code Scaling
15 Applicability and Uncertainty (CSAU) analysis methodology (Reference 9). In the CSAU
16 process, model uncertainty is derived from the propagation of individual model uncertainties
17 through code calculations and experimental comparisons. The total uncertainty for a figure of
18 merit is characterized by a bias and a standard error which allows for the computation of a
19 "best-estimate" value with its uncertainty. This permits a more realistic comparison to
20 regulatory acceptance criteria as opposed to the use of computed conservative values. One
21 such individual model uncertainty of high significance is the void coefficient. The biases and
22 uncertainties in the estimate of the void coefficient are predominantly due to biases and
23 uncertainties in the infinite lattice eigenvalues (k_4) calculated with the TGBLA lattice physics
24 code (Reference 10).

25
26 The TGBLA code is used to generate the cross section fits that are evaluated in TRACG. The
27 biases and uncertainties associated with the TGBLA computed infinite multiplication factors
28 were estimated by comparing the TGBLA results to those computed with the continuous energy
29 Monte Carlo code MCNP (Reference 11). The accuracy of MCNP in predicting k_4 has been
30 well established through numerous comparisons to critical experiments. While it is reasonable
31 to assume that the MCNP computed void coefficient is the "true" value, the TRACG transient
32 calculation uses TGBLA generated cross sections. Therefore, the approach used in TRACG
33 required a correction factor based on the comparison of the TGBLA and the MCNP calculations
34 of k_4 .

35
36 The revised approach to the computation of the correction factor removes an artificially
37 introduced void-fraction dependent variation in the bias and the variance of the correction factor
38 to the TGBLA computed value. The NRC staff reviewed the revised void coefficient description
39 in "C1AX Void Coefficient, H" of Subsection 5.1, "Model Parameters and Uncertainties" in TR
40 NEDE-32906P, Revision 2, and the revised development of the bias and variance correction to
41 the TGBLA computer void coefficient presented in the responses to RAI 13. The NRC staff
42 finds the revised approach consistent with the standard methodology used for incorporating
43 data from critical experiments (the "true" value) into core design calculations where the Monte
44 Carlo computed values of k_4 are used to replace measured data from critical experiments.

45
46 GENE has revised Table 5-1, "Normality Test P-Values for the Void Coefficient Residual
47 Errors," of NEDE-32906P, Revision 2, in response to the NRC staff's RAI. Table 5-1 was
48 updated using the revised void coefficient correction factor to confirm the NRC staff's previous

conclusion in Reference 3 that the "p-values for the Andersen-Darling statistic demonstrates the normality at the 5 percent level at each exposure-in-channel void fraction point."

GENE has revised Section 7.5.1, "Conformance with Design Limits," of TR NEDE-32906P, Revision 2, in response to the NRC staff's RAI. The revision clarifies the process by which the statistical results are used to compare key output values to design limits. Cases are defined where (1) the key output should be greater than the design limit and (2) where the key output should be less than the design limit.

GENE updated Section 7.6, "Statistical Analysis for Qualification Events," and Section 8.4.1, "Uncertainty Screening," of TR NEDE-32906P, Revision 2, as appropriate to evaluate the proposed revision to the calculation of the void coefficient correction factor. The comparisons of the TRACG results to typical licensing analysis data and the deviation from nominal at a ± 1 sigma uncertainty were updated using the revised void coefficient correction factor. The correction in the void coefficient accuracy typically results in more conservative responses in the licensing analyses, and the TRACG results fall within the 2 sigma band. The NRC staff finds these results acceptable for licensing analyses.

3.0 CONCLUSION

GENE has documented the quantification of uncertainties as applied to realistic nominal results from TRACG analyses such that less than 0.1 percent of the fuel rods are expected to experience a boiling transition for the most severe AOO. The approach follows the accepted CSAU analysis methodology. GENE has quantified the uncertainties and biases in models associated with those identified and highly ranked phenomena based on experimental data and computation with validated codes. GENE's proposal to revise the computation of the void coefficient, a high ranked phenomenon, correction factor is acceptable. The revised approach to the computation of the correction factor removes an artificially introduced void-fraction dependent variation in the bias and the variance of the correction factor to the TGBLA computed value. The NRC staff finds the revised approach consistent with the standard methodology used for incorporating data from critical experiments (the "true" value) into core design calculations where the Monte Carlo computed values of k_4 are used to replace measured data from critical experiments. The process is acceptable and the quantities are reasonable. These together with the computed sensitivity estimates of the change in the critical power ratio with respect to variation in the model parameters indicate smoothness and stability in the solution to TRACG transient computations within the uncertainties in the models.

The conditions and limitations identified in Section 6.0 of the NRC staff's previous safety evaluation (Reference 3) are unchanged as a result of the proposed revision to the calculation of the void coefficient correction factor.

4.0 REFERENCES

1. Letter MFN 00-001 from J. F. Klapproth, Manager, Engineering and Technology, GE Nuclear Energy, to USNRC, "TRANSMITTAL OF GE PROPRIETARY LICENSING TOPICAL REPORT NEDE-32906P, 'TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses,' Revision 0, dated January 2000," January 25, 2000 (ADAMS Package Accession No. ML003681270).

2. (a) Letter MFN 99-40 from J. F. Klapproth, Manager, Engineering and Technology, GE Nuclear Energy, to USNRC, "TRANSMITTAL OF GE PROPRIETARY LICENSING TOPICAL REPORT NEDE-32176P, 'TRACG Model Description,' Revision 2, dated December 1999," December 15, 1999 (ADAMS Package Accession No. ML993630286).
- (b) Letter MFN 00-002 from J. F. Klapproth, Manager, Engineering and Technology, GE Nuclear Energy, to USNRC, "TRANSMITTAL OF GE PROPRIETARY LICENSING TOPICAL REPORT NEDE-32177P/R2, 'TRACG Qualification,' Revision 2, dated January 2000," January 31, 2000 (ADAMS Accession Package No. ML003682927).
- (c) Letter MFN 00-007 from J. F. Klapproth, Manager, Engineering and Technology, GE Nuclear Energy, to USNRC, "TRANSMITTAL OF GE PROPRIETARY REPORT NEDC-32956P, 'TRACG02A User's Manual,' Revision 0, dated February 2000," February 28, 2000 (ADAMS Package Accession No. ML003688295).
3. Letter from S.A. Richards, USNRC, to J.F. Klapproth, Manager, Engineering & Technology, GE Nuclear Energy, "Safety Evaluation Report on General Electric Nuclear Energy Topical Report NEDE-32906P, Revision 0, 'TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses' (TAC NO. MA7779)," October 22, 2001 (ADAMS Accession No. ML012740161).
4. Letter MFN 06-042 from L.M. Quintana, Manager, Licensing, GE Nuclear Energy, to USNRC, "GE Licensing Topical Report NEDE-32906P-A, Revision 1, 'TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses'," February 6, 2006 (ADAMS Package Accession No. ML060390557).
5. NUREG/CR-3633, "TRAC-BD1/MOD1: An Advanced Best Estimate Program for Boiling Water Reactor Transient Analysis, Volumes 1-4," Idaho National Engineering Laboratory, April 1984.
6. Letter MFN 06-046 from L.M. Quintana, Manager, Licensing, GE Nuclear Energy, to USNRC, "GE Licensing Topical Report NEDE-32906P, Revision 2, 'TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses'," February 14, 2006 (ADAMS Package Accession No. ML060530560).
7. Letter from M.C. Honcharik, Project Manager, USNRC, to L.M. Quintana, Manager, Licensing, GE Nuclear Energy, "Request for Additional Information (RAI) Regarding General Electric Nuclear Energy (GENE) Topical Report (TR) NEDE-32906P, Revision 2, 'TRACG Application for Anticipated Operational Occurrences (AOO) Transient Analyses' (TAC NO. MD0249)," May 31, 2006 (ADAMS Accession No. ML061450405).

- 1 8. Letter MFN 06-169 from L.M. Quintana, Manager, Licensing, GE Nuclear Energy, to
2 USNRC, "Response to Request For Additional Information (RAI) Regarding General
3 Electric Nuclear Energy (GENE) Topical Report (TR) NEDE-32906P, Revision 2,
4 'TRACG Application For Anticipated Operational Occurrences (AOO) Transient
5 Analyses' (TAC No. MD0249)," June 7, 2006 (ADAMS Package Accession
6 No. ML061600297).
7
- 8 9. NUREG/CR-5249, "Quantifying Reactor Safety Margins: Application of Code Scaling,
9 Applicability, and Uncertainty Evaluation Methodology to a Large-Break, Loss-of-Coolant
10 Accident," December 1989 (ADAMS Package Accession No. ML030380503).
11
- 12 10. General Electric Company, "TGBLA06A: General Electric Lattice Physics Method,"
13 DRF A00-05526, October 1994.
14
- 15 11. Briemeister, J. G., Ed., "MCNP - A General Monte Carlo Code for Neutron, Photon and
16 Electron Transport, Version 3A/3B/4," LA-7396-M, Los Alamos National Laboratory,
17 1986/Revisions 1988 and 1991.
18

19 Principle Contributor: E. Throm

20
21 Date: July 12, 2006