

July 12, 2006

LICENSEE: Wolf Creek Nuclear Operating Corporation (WCNOC, the licensee)

FACILITIES: Wolf Creek Generating Station

SUBJECT: MEETING WITH REPRESENTATIVES OF WOLF CREEK NUCLEAR
OPERATING CORPORATION FOR WOLF CREEK GENERATING
STATION

A meeting was held on Wednesday, June 28, 2006, between the Nuclear Regulatory Commission (NRC) staff and representatives of WCNOC for Wolf Creek Generating Station (WCGS). The meeting was held at the request of the licensee for WCNOC to present its Main Steam and Feedwater Isolation System (MSFIS) Controls Replacement Project. This presentation is not part of any license amendment request submitted by the licensee to the NRC. The notice for the meeting was issued on June 14, 2006.

The licensee is intending to replace the existing (1) hydraulically-operated actuators for the main steam isolation valves (MSIVs) and main feedwater isolation valves (MFIVs), (2) MSIV and MFIV bodies, and (3) MSFIS controls in the refueling outage scheduled for the spring of 2008. The purpose of the meeting was to explain the project to the NRC, and when the license application requests (LARs) were likely to be submitted for NRC review and approval. This would include upgrading the existing MSFIS controls.

Enclosure 1 is the list of attendees. Enclosure 2 is the material handed out by the licensee. There was no handout from the NRC staff.

The agenda for the meeting is the following, which is the second page of Enclosure 2 (Agencywide Documents Access and Management System Accession No. ML061800029):

- MSFIS Replacement Project (page 3 of Enclosure 2)
- Current MSFIS Controls (pages 4 through 6)
- Replacement MSFIS Controls (pages 7 and 8)
- Advanced Logic System (pages 9 through 13)
- Development Team and Development Process (pages 14 through 17)
- Regulatory Process (pages 18 and 19)
- Questions (page 20)

The slides for the licensee's presentation are given in Enclosure 2. The page numbers for the slides are given in the above agenda and Enclosure 2. An important part of the meeting was the presentation of the project milestones on page 17 of Enclosure 2, which shows the current schedule for submitting the MSFIS LAR in March 2007. This is about a year before the schedule to install the new MSFIS at WCGS. The licensee stated that it is currently in the early part of the Requirements Phase of the project, as shown on page 16 of Enclosure 2.

In the discussion on the MSFIS Controls Project Team, which is page 15 of Enclosure 2, the licensee stated that the lines on the page, between the Validation and Verification (V&V) and the Qualification functions and the project manager, represent information flow paths to the project manager and not that the people performing these functions in the MSFIS Replacement Project report to the project manager. The people would report to management separate from the project manager to prevent any conflicts of interests and provide independence between the project functions, and the V&V and quality assurance functions. The licensee stated that the slide of the organization chart on page 15 of Enclosure 2 was both misleading and incorrect in terms of who reports to the project manager for the MSFIS Controls Replacement Project. The lines on the slide were only to show how the project information from different technical areas flowed up to the project manager and was not to show who reported to whom. The licensee agreed to provide an updated slide of page 15's chart at the next meeting with the NRC staff.

The NRC staff completed its discussion of the licensee's presentation. There were no members of the public in attendance.

Please direct any inquiries to me at 301-415-1307, or jnd@nrc.gov.

/RA/

Jack Donohew, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures: 1. List of Meeting Attendees
2. Licensee's Handout

cc w/encls: See next page

In the discussion on the MSFIS Controls Project Team, which is page 15 of Enclosure 2, the licensee stated that the lines on the page, between the Validation and Verification (V&V) and the Qualification functions and the project manager, represent information flow paths to the project manager and not that the people performing these functions in the MSFIS Replacement Project report to the project manager. The people would report to management separate from the project manager to prevent any conflicts of interests and provide independence between the project functions, and the V&V and quality assurance functions. The licensee stated that the slide of the organization chart on page 15 of Enclosure 2 was both misleading and incorrect in terms of who reports to the project manager for the MSFIS Controls Replacement Project. The lines on the slide were only to show how the project information from different technical areas flowed up to the project manager and was not to show who reported to whom. The licensee agreed to provide an updated slide of page 15's chart at the next meeting with the NRC staff.

The NRC staff completed its discussion of the licensee's presentation. There were no members of the public in attendance.

Please direct any inquires to me at 301-415-1307, or jnd@nrc.gov.

/RA/

Jack Donohew, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures: 1. List of Meeting Attendees
2. Licensee's Handout

cc w/encls: See next page

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsNrrDorl (CHaney/CHolden)

RidsNrrDorlLpl4 (DTerao)

RidsNrrPMJDonohew

RidsNrrLALFeizollahi

RidsOgcRp

RidsAcrsAcnwMailCenter

RJasinski, NRR

SO'Connor, EDO RIV

RidsRgn4MailCenter

RidsNrrDeEicb (AHowe)

PLoeser, EICB

PREbstock, EICB

NCarte, EICB

WKemper, IEEB

MWaterman, IEEB

ADAMS ACCESSION NO. **ML061810456**

OFFICE	LPL4/PM	LPL4/LA	EICB/BC	LPL4/BC
NAME	JDonohew	LFeizollahi	AHowe	DTerao
DATE	07/12/06	07/12/06	7/11/06	07/12/06

OFFICIAL RECORD COPY

LIST OF ATTENDEES AT MEETING OF JUNE 28, 2006

WITH WOLF CREEK NUCLEAR OPERATING CORPORATION

NAME	AFFILIATION
J. Donohew	NRC/NRR/LPLIV
A. Howe	NRC/NRR/EICB
P. Rebstock	NRC/NRR/EICB
P. Loeser	NRC/NRR/EICB
N. Carte	NRC/NRR/EICB
W. Kemper	NRC/RES/IEEB
M. Waterman	NRC/RES/IEEB
D. Hooper	WCNOC
S. Wideman	WCNOC
P. Guevel	WCNOC
G. Clarkson	WCNOC
S. Sorensen	CS Innovations (WCNOC contractor)
T. Harris	STARS

Where:

EICB	= Instrumentation and Controls Branch
IEEB	= Instrumentation and Electrical Engineering Branch
LPLIV	= Plant Licensing Branch IV
NRC	= Nuclear Regulatory Commission
NRR	= Office of Nuclear Reactor Regulation
RES	= Office of Nuclear Regulatory Research
STARS	= Strategic Teaming and Resource Sharing
WCNOC	= Wolf Creek Nuclear Operating Corporation

LICENSEE'S HANDOUT FOR JUNE 28, 2006, MEETING

ADAMS* ACCESSION NO. ML061800029

The licensee's handout (20 pages) contained the following:

1. Title (page 1)
2. Agenda (page 2)
3. Project Overview (page 3)
4. Current MSFIS** Controls (pages 4 through 6)
5. Replacement MSFIS Controls (pages 7 through 13)
6. Development Process (pages 14 through 17)
7. Regulatory Process (pages 18 and 19)
8. Questions (page 20)

* = Agencywide Documents Access and Management System

** = Main Steam and Feedwater Isolation System (MSFIS)

ENCLOSURE 2

Wolf Creek Generating Station

cc:

Jay Silberg, Esq.
Pillsbury Winthrop Shaw Pittman LLP
2300 N Street, NW
Washington, D.C. 20037

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 311
Burlington, KS 66839

Chief Engineer, Utilities Division
Kansas Corporation Commission
1500 SW Arrowhead Road
Topeka, KS 66604-4027

Office of the Governor
State of Kansas
Topeka, KS 66612

Attorney General
120 S.W. 10th Avenue, 2nd Floor
Topeka, KS 66612-1597

County Clerk
Coffey County Courthouse
110 South 6th Street
Burlington, KS 66839

Chief, Radiation and
Asbestos Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson, Suite 310
Topeka, KS 66612-1366

Vice President Operations/Plant Manager
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, KS 66839

Supervisor Licensing
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, KS 66839

U.S. Nuclear Regulatory Commission
Resident Inspectors Office/Callaway Plant
8201 NRC Road
Steelman, MO 65077-1032

Mr. Rick A. Muench
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KS 66839

February 2006