

**Britt T. McKinney**  
Sr. Vice President & Chief Nuclear Officer

**PPL Susquehanna, LLC**  
769 Salem Boulevard  
Berwick, PA 18603  
Tel. 570.542.3149 Fax 570.542.1504  
btmckinney@pplweb.com



**JUN 27 2006**

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station OP1-17  
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
REVISION TO PROPOSED AMENDMENT NO. 276  
TO LICENSE NPF-14 AND PROPOSED AMENDMENT  
NO. 245 TO LICENSE NPF-22: APPLICATION FOR  
TECHNICAL SPECIFICATION IMPROVEMENT  
TO REVISE TECHNICAL SPECIFICATIONS TO  
ADD A LIMITING CONDITION FOR  
OPERATION 3.0.8 ON INOPERABILITY OF  
SNUBBERS USING THE CONSOLIDATED LINE  
ITEM IMPROVEMENT PROCESS  
PLA-6081**

**Docket Nos. 50-387  
and 50-388**


*Reference: 1) PLA 5901, B. T. McKinney (PPL) to Document Control Desk (NRC),  
"Proposed Amendment No. 276 to License NPF-14 and Proposed Amendment  
No. 245 to License NPF-22: Application for Technical Specification Improvement  
to Revise Technical Specifications to Add a Limiting Condition for Operation 3.0.8  
on Inoperability of Snubbers Using the Consolidated Line Item Improvement Process,"  
dated February 1, 2006.*

The purpose of this letter is to request that the implementation period for the amendments proposed in Reference 1 be revised from 60 days to 90 days. The 90 day period will allow sufficient time for the appropriate procedures and programs to be revised and issued prior to implementation of the proposed amendments.

The proposed amendments modify the SSES Unit 1 and Unit 2 Technical Specification requirements by adding Limiting Condition for Operation (LCO) 3.0.8 addressing requirements for inoperable snubbers. The proposed changes are consistent with Nuclear Regulatory Commission (NRC) approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification change TSTF-372, Revision 4.

A001

If you have any questions regarding this submittal, please contact  
Mr. Cornelius T. Coddington at (610) 774-4019.

A handwritten signature in black ink, appearing to read "B. T. McKinney". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

B. T. McKinney

cc: NRC Region I  
Mr. A. J. Blamey, NRC Sr. Resident Inspector  
Mr. R. V. Guzman, NRC Project Manager  
Mr. R. Janati, DEP/BRP