

July 5, 2006

Mr. Christopher M. Crane
President and Chief Nuclear Officer
Exelon Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LA SALLE COUNTY STATION - NOTIFICATION OF AN NRC BIENNIAL
HEAT SINK PERFORMANCE INSPECTION AND INFORMATION REQUEST

Dear Mr. Crane:

On August 28, 2006, the NRC will begin the Biennial Heat Sink Performance Inspection at your LaSalle County Station. This inspection will be performed in accordance with NRC baseline inspection procedure (IP) 71111.07. The systems selected for detailed review during this baseline inspection are the high pressure coolant injection pump room cooler, the reactor core isolation cooling pump room cooler and the unit 1 core spray pump motor cooler.

We have enclosed a request for documents needed for the inspection. This information can be sent to the following e-mail address cea4@nrc.gov, no later than August 21, 2006, so that we may start the review of these documents. A hard-copy with the required information is also an acceptable option.

The lead inspector for this inspection is Ms. Caroline Acosta Acevedo. If there are questions about the material requested, or the inspection, please call Ms. Acosta Acevedo at (630) 829-9718.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any), will be available electronically for public inspection in License Nos. NPF-11; NPF-18

the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ann Marie Stone, Chief
Engineering Branch 2
Division of Reactor Safety

Docket Nos. 50-373; 50-374
License Nos. NPF-11; NPF-18

Enclosure: BIENNIAL HEAT SINK INSPECTION
DOCUMENT REQUEST

cc w/encl: Site Vice President - LaSalle County Station
LaSalle County Station Plant Manager
Regulatory Assurance Manager - LaSalle County Station
Chief Operating Officer
Senior Vice President - Nuclear Services
Senior Vice President - Mid-West Regional
Operating Group
Vice President - Mid-West Operations Support
Vice President - Licensing and Regulatory Affairs
Director Licensing - Mid-West Regional
Operating Group
Manager Licensing - Clinton and LaSalle
Senior Counsel, Nuclear, Mid-West Regional
Operating Group
Document Control Desk - Licensing
Assistant Attorney General
Illinois Emergency Management Agency
State Liaison Officer
Chairman, Illinois Commerce Commission

the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

Ann Marie Stone, Chief
Engineering Branch 2
Division of Reactor Safety

Docket Nos. 50-373; 50-374

Enclosure: BIENNIAL HEAT SINK INSPECTION
DOCUMENT REQUEST

cc w/encl: Site Vice President - LaSalle County Station
LaSalle County Station Plant Manager
Regulatory Assurance Manager - LaSalle County Station
Chief Operating Officer
Senior Vice President - Nuclear Services
Senior Vice President - Mid-West Regional
Operating Group
Vice President - Mid-West Operations Support
Vice President - Licensing and Regulatory Affairs
Director Licensing - Mid-West Regional
Operating Group
Manager Licensing - Clinton and LaSalle
Senior Counsel, Nuclear, Mid-West Regional
Operating Group
Document Control Desk - Licensing
Assistant Attorney General
Illinois Emergency Management Agency
State Liaison Officer
Chairman, Illinois Commerce Commission

ADAMS Distribution:

DXC1
DMS6
RidsNrrDirslrib
GEG
KGO
DEK
CAA1
DRPIII
DRSIII
PLB1
JRK1
ROPreports@nrc.gov

DOCUMENT NAME: ML061920581.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII	RIII	RIII	
NAME	CAcostaAcevedo: ls	BBurgess	AMStone	
DATE	07/05/06	07/05/06	07/05/06	

OFFICIAL RECORD COPY

BIENNIAL HEAT SINK INSPECTION DOCUMENT REQUEST

Inspection Date: August 28, 2006

Inspection Procedures: Heat Sink Performance

Inspector: Caroline Acosta Acevedo, Reactor Engineer
(630) 829-9718
CEA4@nrc.gov

Initial Document Request

The systems selected for detailed review during this baseline inspection are the high pressure coolant injection pump room cooler, the reactor core isolation cooling pump room cooler, and the unit 1 core spray pump motor cooler.

1. Copy of the two most recently completed tests confirming thermal performance of each HX. Include documentation and procedures that identify the types, accuracy, and location of any special instrumentation used for these tests (e.g., high accuracy ultrasonic flow instruments or temperature instruments). Include calibration records for the instruments used during these tests.
2. Copy of the evaluations of data for the two most recent completed tests confirming the thermal performance of each HX.
3. Copy of the calculation which establishes the limiting (maximum) design basis heat load which is required to be removed by each of these HXs.
4. Copy of the calculation which correlates surveillance testing results from these HXs with design basis heat removal capability (e.g., basis for surveillance test acceptance criteria).
5. The clean and inspection maintenance schedule for each HX, including justifications for the schedule if it has been increased since the Generic Letter (GL) 89-13 program was implemented.
6. For the last two clean and inspection activities completed on each HX, provide a copy of the document describing the inspection results.
7. Provide a copy of the document which identifies the current number of tubes in service for each heat exchanger and the supporting calculation which establishes the maximum number of tubes which can be plugged in each HX.
8. Copies of the procedures used to monitor or inspect heat exchanger performance.
9. Copy of the design specification and heat exchanger data sheets for each HX.

10. Copy of the vendor/component drawing for each HX.
11. Provide a list of issues with a summary of your corrective action system associated with these HXs in the past three years.
12. Provide a list of calculations with a description which currently apply to each HX.
13. Provide HX performance trending data tracked for each HX.
14. Provide the Design Basis Documents for the above listed HXs.
15. System health report(s) and maintenance rule system notebooks for these HX(s).
16. Copies of procedures developed to implement the recommendations of GL 89-13, "Service Water System Problems Affecting Safety-Related Equipment."
17. List of operability evaluations currently relied upon and those that were previously (past two years) relied upon for operability.
18. List of engineering-related Operator Workarounds/Temporary Modifications for these HX(s).
19. Copy of HX self-assessments and audits for HX(s).
20. Updated Final Safety Analysis Report pages for these HX(s)
21. Information regarding any alarms which monitor on-line performance of these HXs.
22. Copy of calculations which evaluate the potential for water hammer or excessive tube vibration in these HXs.
23. Copy of the procedures which describe the methods taken to control water chemistry in the service water systems, including any provisions for controlling biotic fouling.
24. Copy of the last completed surveillance procedure which verifies that the service water systems are free from clogging due to macrofouling (i.e., silt, dead mussel shells, debris, etc.).
25. Copy of the procedure and last test results which show that the overall functionality of service water systems in relation to minimum wall thickness corrosion or erosion, especially in low flow areas.
26. Copies of procedures which address ultimate heat sink functionality during adverse weather conditions, such as extreme cold or hot temperatures, or during incursion of seasonal aquatic material.
27. List of the GL 89-13 heat exchangers in order of risk significance.