



FPLEnergy.

Duane Arnold Energy Center

June 29, 2006

FPL Energy Duane Arnold, LLC
3277 DAEC Road
Palo, Iowa 52324

NG-06-00459
10 CFR 2.201

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station O-P1-17
Washington, DC 20555-0001

Duane Arnold Energy Center
Docket 50-331
License No. DPR-49

Supplement to a Reply to a Notice of Violation; EA-04-053

References:

1. G. Van Middlesworth (FPL Energy Duane Arnold, LLC) to USNRC, "Reply to a Notice of Violation; EA-04-053," Dated May 31, 2006.
2. G. Van Middlesworth (FPL Energy Duane Arnold, LLC) to USNRC, "Response to Apparent Violation in Office of Investigations Report No. 3-2004-033; EA-06-047," Dated April 7, 2006.

In Reference 1, FPL Energy Duane Arnold, LLC provided a reply to a notice of violation associated with a 2003 refuel floor event. Prior to that, in Reference 2, FPL Energy Duane Arnold, LLC provided a response to an apparent violation associated with a similar refuel floor event which occurred in 2004. The purpose of this letter is to supplement the corrective actions listed in Reference 1. Specifically, corrective actions taken in response to the event documented in Reference 2 were also applicable to the event discussed in Reference 1. The corrective actions include, but are not limited to the following:

- Designated the Operations Department as responsible for all fuel moving activities. In addition, the Fuel Handling Supervisor is required to hold a Senior Reactor Operator license.
- Established guidance for management observations of High Consequence Activities. This included designating a management sponsor and detailing the responsibilities of the sponsor.

IE14

NG-06-0459
June 29, 2006
Page 2 of 2

- Delivered a Case Study to the Duane Arnold leadership team regarding refuel floor events, focusing on the decision making that occurred. This presentation also discussed the organizational failures from the 2003 event that allowed the 2004 event to occur.

If you have any questions, please call Steve Catron, Licensing Manager, at (319) 851-7234.

This letter contains no new commitments and no revisions to existing commitments.



Gary D. Van Middlesworth
Site Vice President, Duane Arnold Energy Center
FPL Energy Duane Arnold, LLC

cc: Administrator, Region III, USNRC
Project Manager, DAEC, USNRC
Resident Inspector, DAEC, USNRC
Enforcement Officer, Region III, USNRC