

July 14, 2006

MEMORANDUM TO: Brooke D. Poole, Acting Chief
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Senior Project Manager **/RAI/**
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 - FACSIMILE
TRANSMISSION, DRAFT REQUEST FOR ADDITIONAL INFORMATION
REGARDING POST MAINTENANCE/MODIFICATION SURVEILLANCE
REQUIREMENTS (TAC NO. MD0693)

The attached draft request for additional information (RAI) was transmitted on July 14, 2006, to Mr. Paul Willoughby, at Dominion Nuclear Connecticut, Inc. (DNC) by facsimile. This was done to support a telephone conversation to facilitate the review being conducted by the Nuclear Regulatory Commission (NRC) staff in order to clarify certain items in the licensee's submittal. The draft RAI is related to DNC's submittal dated March 28, 2006, regarding a request for deleting redundant surveillance requirements pertaining to post-maintenance/post-modification testing. Review of the draft RAI will allow DNC to determine and agree upon a schedule for response to the RAI. This memorandum and the attachment do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Enclosure:
As stated

July 14, 2006

MEMORANDUM TO: Brooke D. Poole, Acting Chief
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Senior Project Manager **/RA/**
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 - FACSIMILE
TRANSMISSION, DRAFT REQUEST FOR ADDITIONAL INFORMATION
REGARDING POST MAINTENANCE/MODIFICATION SURVEILLANCE
REQUIREMENTS (TAC NO. MD0693)

The attached draft request for additional information (RAI) was transmitted on July 14, 2006, to Mr. Paul Willoughby, at Dominion Nuclear Connecticut, Inc. (DNC) by facsimile. This was done to support a telephone conversation to facilitate the review being conducted by the Nuclear Regulatory Commission (NRC) staff in order to clarify certain items in the licensee's submittal. The draft RAI is related to DNC's submittal dated March 28, 2006, regarding a request for deleting redundant surveillance requirements pertaining to post-maintenance/post-modification testing. Review of the draft RAI will allow DNC to determine and agree upon a schedule for response to the RAI. This memorandum and the attachment do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Enclosure:
As stated

DISTRIBUTION:

PUBLIC LPL1-2 R/F RidsNrrLACRaynor RidsNrrPMGMiller
RidsNrrDorLP11-2

ADAMS Accession Number: **ML061950004**

OFFICE	LPL1-2/PM	LPL1-2/LA	SPWR/BC
NAME	VNerses:rsa	CRaynor	JNakoski
DATE	7/14/06	7/14/06	7/14/06

OFFICIAL RECORD COPY

DRAFT REQUEST FOR ADDITIONAL INFORMATION

MILLSTONE POWER STATION, UNIT 3

POST MAINTENANCE/MODIFICATION SURVEILLANCE REQUIREMENTS

DOCKET NO. 50-423

By letter dated March 28, 2006, Dominion Nuclear Connecticut, Inc. (DNC, the licensee) submitted a request for deleting redundant surveillance requirements (SRs) pertaining to post-maintenance/post-modification testing. The Nuclear Regulatory Commission (NRC) staff requests the following additional information to complete its review.

The licensee proposed to delete from the Technical Specifications the following post-maintenance SRs: SR 4.1.3.4.b, a portion of SR 4.5.2.g.1, and SR 4.5.2.h. The licensee claimed that the removal of these portions of the SRs is adequate by citing SR 4.0.1, which states in the associated Bases section, in part, that "upon completion of maintenance, appropriate post-maintenance testing is required to declare the equipment operable." However, neither SR 4.0.1 nor the associated Bases section specify what post-maintenance testing must be completed to fulfill the deleted SRs. For example, SR 4.1.3.4 requires that the rod drop time is demonstrated. SR 4.5.2.g requires verification of the correct position of each electrical and/or mechanical stop for emergency core cooling system throttle valves. SR 4.5.2.h requires that flow balance testing is performed on the charging pump lines, safety injection pump lines, and residual heat removal pump lines.

Identify specific post-maintenance testing requirements in the relevant maintenance procedure or documentation, and justify that the test requirements equivalent to the deleted SRs discussed above will be completed in accordance with SR 4.0.1.

Enclosure