

RSSI

6312 West Oakton Street
Morton Grove, IL 60053-2723
847-965-1999
Fax 847-965-1991

July 13, 2006 J-6

Dennis Lawyer via fax: 610-337-5393
Division of Nuclear Materials Safety
U.S. Nuclear Regulatory Commission, Region I
475 Allendale Road
King of Prussia, PA 19406

RE: LICENSE NUMBER 45-25330-01 03033825


Dear Mr. Lawyer:

This letter is in response to your June 29, 2006, telephone request for additional information regarding Radiocat's June 19, 2006, amendment request. The following information is being submitted in response to your questions.

- Licensed material was never possessed or used at the Manchester Missouri address.
- The 9937 Big Bend Boulevard, St Louis, Missouri location has a dedicated HVAC system and an exhaust extraction system. The HVAC system supplies and returns 1200 cfm. This system is not shared with the other areas and does not effect pressure balance. The separate exhaust system removes 350 cfm. This maintains the room at a relative negative pressure. The airflow differential is made up by infiltration.

If you have any questions or require additional information, please call me at 847-965-1999.

Sincerely,



Eli A. Port, CHP, CIH, P.E.

Attachments

pc: Rand Wachstock, DVM

G:\HOME\400001 Health Physics\RADIOCAT\NRC\NRC20.doc

139032
NMSS/RGNI MATERIALS-002