

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 142 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) Southern Nuclear Operating Company shall be capable of establishing containment hydrogen monitoring within 90 minutes of initiating safety injection following a loss of coolant accident.

(4) DELETED

(5) DELETED

(6) DELETED

(7) DELETED

(8) DELETED

(9) DELETED

(10) Additional Conditions

The Additional Conditions contained in Appendix D, as revised through Amendment No. 102, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Additional Conditions.

- D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70. These include (a) an exemption from the requirements of 10 CFR 70.24 for two criticality monitors around the fuel storage area, and (b) an exemption from the requirements of Paragraph III.D.2(b)(ii) of Appendix J of 10 CFR 50, the testing of containment air locks at times when containment integrity is not required. The special circumstances regarding exemption b are identified in Section 6.2.6 of SSER 5.

An exemption was previously granted pursuant to 10 CFR 70.24. The exemption was granted with NRC materials license No. SNM-1967, issued August 21, 1986, and relieved GPC from the requirement of having a criticality alarm system. GPC and Southern Nuclear are hereby exempted from the criticality alarm system provision of 10 CFR 70.24 so far as this section applies to the storage of fuel assemblies held under this license.

These exemptions are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. The exemptions in items b and c above are granted pursuant to 10CFR 50.12. With

- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified or incorporated below.

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at reactor core power levels not in excess of 3565 megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 122 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

The Surveillance Requirements (SRs) contained in the Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment No. 74. The SRs listed below shall be successfully demonstrated prior to the time and condition specified below for each:

- a) DELETED
  - b) DELETED
  - c) SR 3.8.1.20 shall be successfully demonstrated at the first regularly scheduled performance after implementation of this license amendment.
- (3) Southern Nuclear Operating Company shall be capable of establishing containment hydrogen monitoring within 90 minutes of initiating safety injection following a loss of coolant accident.

(4) Additional Conditions

The Additional Conditions contained in Appendix D, as revised through Amendment No. 80, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Additional Conditions.

- D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70. These include (a) an exemption from the requirements of 10 CFR 70.24 for two criticality monitors around the fuel storage area, and (b) an exemption from the requirements of Paragraph III.D.2(b)(ii) of Appendix J of 10 CFR 50, the testing of containment air locks at times when containment integrity is not required. The special circumstances regarding exemption b are identified in Section 6.2.6 of SSER 8.

### 3.7 PLANT SYSTEMS

#### 3.7.5 Auxiliary Feedwater (AFW) System

LCO 3.7.5 Three AFW trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTIONS

#### NOTE

LCO 3.0.4b is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One steam supply to turbine driven AFW pump inoperable.	A.1 Restore steam supply to OPERABLE status.	7 days <u>AND</u> 10 days from discovery of failure to meet the LCO
B. One AFW train inoperable for reasons other than Condition A.	B.1 Restore AFW train to OPERABLE status.	72 hours <u>AND</u> 10 days from discovery of failure to meet the LCO

(continued)