

From: "Croulet, Donald" <dcroule@entergy.com>
To: "Conroy, Pat" <PConroy@entergy.com>, "Cox, Mark R" <mcox90@entergy.com>, "Bowman, Greg" <GBowm90@cc--exs03.prod.entergy.com>, "James Noggle" <JDN@nrc.gov>, "Janicki, John" <JJanick@entergy.com>, "Timothy Rice" <tbrice@gw.dec.state.ny.us>, "PRICE, ERNEST JR" <EPRICE2@entergy.com>, "Robert Oliveira (boliveira@amnucins.com)" <boliveira@amnucins.com>
Date: 3/20/06 6:59AM
Subject: FW: MONITORING WELL STATUS

From: Sachatello, Ronald
Sent: Monday, March 20, 2006 6:56 AM
To: Mayer, Don; Axelson, William L; Hinrichs, Gary
Cc: Croulet, Donald; Sachatello, Ronald
Subject: MONITORING WELL STATUS

Latest Monitoring Well Results -March 20, 2006-0600 hours

Three wells remain to be drilled. <<MONITORING WELL STATUS-MARCH 13.doc>>

Ex. 4

* MW-52	(North side of U-2 Turbine Bldg)	80' of 200' completed
* MW-45	[]	To be started this week
* MW- 51	(South Hill, North of MW-40)	To be started this week

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 4
FOIA- 2006-0195

C-2

PHASE II WELL STATUS

<u>Well #</u>	<u>Location</u>	<u>Status</u>	<u>Notes</u>	<u>Most Recent IPEC Results</u>	
MW-39	[]	In Service	N/A	798 pCi/L	(3/2/06)
MW-40	Parking Lot above Sewerage Plant	In Service	N/A	ND	(2/9/06)
MW-41	[]	Developed	To be sampled		
MW-42	[]	Drilling complete	Develop well next		
MW-43	[]	Developed	To be sampled		
MW-44	[]	Drilling complete	To be sampled		
MW-45	[]	To be drilled	Need to complete drilling		
MW-46	U3 Transformer Yard	In Service	N/A	1430 pCi/L	(3/1/06)
MW-47	[]	Drilling completed	To be sampled		
MW-48	Far South Property Boundary	In Service	N/A	ND	(2/10/06)
MW-49	West side of Discharge Canal	Drilling complete	Develop well		
MW-50	East side of Discharge Canal	Drilling complete	To be sampled		
MW-51	South Hill North of MW-40	To be drilled	Need to complete drilling		
MW-52	North end of U2 Turbine Bldg	Drilled 80' of 200'	Complete drilling		

Ex. 4