

July 27, 2006

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - REQUEST FOR
ADDITIONAL INFORMATION REGARDING RELIEF REQUEST INSERVICE
INSPECTION (ISI)-013, FOURTH 10-YEAR ISI INTERVAL (TAC NO. MD0287)

Dear Mr. Kansler:

By letter dated February 16, 2006, as supplemented by letter on March 27, 2006, Entergy Nuclear Operations, Inc. (the licensee) requested relief from requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, for Vermont Yankee Nuclear Power Station. Specifically, you requested an alternative for the examination of Category B-F, Item 5.10, nozzle-to-safe end welds.

The Nuclear Regulatory Commission staff has been reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). A response to these RAIs is requested to be provided within 30 days.

Sincerely,

/RA/

James J. Shea, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosure: As stated

cc w/encl: See next page

July 27, 2006

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - REQUEST FOR
ADDITIONAL INFORMATION REGARDING RELIEF REQUEST INSERVICE
INSPECTION (ISI)-013, FOURTH 10-YEAR ISI INTERVAL (TAC NO. MD0287)

Dear Mr. Kansler:

By letter dated February 16, 2006, as supplemented by letter on March 27, 2006, Entergy Nuclear Operations, Inc. (the licensee) requested relief from requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, for Vermont Yankee Nuclear Power Station. Specifically, you requested an alternative for the examination of Category B-F, Item 5.10, nozzle-to-safe end welds.

The Nuclear Regulatory Commission staff has been reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). A response to these RAIs is requested to be provided within 30 days.

Sincerely,

/RA/

James J. Shea, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-271
Enclosure: As stated
cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDORLLp11-1	RidsOgcRP	TMcLellan
LPLI-1 R/F	RidsNrrLASLlittle	RidsAcrcAcnwMailCenter	
RidsNrrPMJShea	RidsNrrDORLDpr	RidsRgn1MailCenter	

Accession Number: ML062050222

OFFICE	LPL1-1/PM	LPL1-1/LA	DCI/CVIB	LPL1-1/BC
NAME	JShea	SLittle	MMitchell	RLaufer
DATE	7/27/06	7/26/06	7/27/06	7/27/06

Official Record Copy

REQUEST FOR ADDITIONAL INFORMATION
FOURTH 10-YEAR INSERVICE INSPECTION (ISI) INTERVAL
REQUEST FOR RELIEF NO. ISI-013
VERMONT YANKEE NUCLEAR POWER STATION
ENTERGY NUCLEAR NORTHEAST
DOCKET NUMBER 50-271

By letter dated February 16, 2006, as supplemented by letter on March 27, 2006, Entergy Nuclear Operations, Inc. (the licensee) requested relief from requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, for Vermont Yankee Nuclear Power Station.

The Nuclear Regulatory Commission staff reviewed the information submitted by the licensee and, based on this review, determined the following information is required to complete the evaluation.

1. Please provide drawings or sketches of the ASME Code, Section XI, Category B-F components listed in the *List of Affected B-F Welds* attached to the licensee's letter dated February 16, 2006. Drawings or sketches of every component is not required. An example of each type of similar component will satisfy this request.
2. In the *List of Affected B-F Welds*, under materials, please clarify the materials for the components listed in the table and provide weld rod material.
3. In accordance with BWRVIP-75-A, "BWR Vessel and Internals Project Technical Basis for Revisions to Generic Letter 88-01 Inspection Schedules," Chapter 3, page 3-1 second paragraph, please provide a discussion as to how the conditions contained in BWRVIP-75-A are applicable to Vermont Yankee. Include a discussion as to why your material is resistant to intergranular stress-corrosion cracking (IGSCC). (For example, hydrogen water chemistry treatment program, material of subject components, and/or other measures such as control of conductivity to prevent IGSCC).
4. Please clarify that the personnel and procedures used for the examinations of Category A piping at Vermont Yankee are in accordance with the Electric Power Research Institute demonstration initiative program, under ASME Code, Section XI, Appendix VII and Appendix VIII.

Enclosure

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. David R. Lewis
Pillsbury, Winthrop, Shaw, Pittman, LLP
2300 N Street, N.W.
Washington, DC 20037-1128

Mr. David O'Brien, Commissioner
Vermont Department of Public Service
112 State Street
Montpelier, VT 05620-2601

Mr. James Volz, Chairman
Public Service Board
State of Vermont
112 State Street
Montpelier, VT 05620-2701

Chairman, Board of Selectmen
Town of Vernon
P.O. Box 116
Vernon, VT 05354-0116

Operating Experience Coordinator
Vermont Yankee Nuclear Power Station
320 Governor Hunt Road
Vernon, VT 05354

G. Dana Bisbee, Esq.
Deputy Attorney General
33 Capitol Street
Concord, NH 03301-6937

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Carla A. White, RRPT, CHP
Radiological Health
Vermont Department of Health
P.O. Box 70, Drawer #43
108 Cherry Street
Burlington, VT 05402-0070

Mr. James M. DeVincentis
Manager, Licensing
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Resident Inspector
Vermont Yankee Nuclear Power Station
U. S. Nuclear Regulatory Commission
P.O. Box 176
Vernon, VT 05354

Director, Massachusetts Emergency
Management Agency
ATTN: James Muckerheide
400 Worcester Rd.
Framingham, MA 01702-5399

Jonathan M. Block, Esq.
Main Street
P.O. Box 566
Putney, VT 05346-0566

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

Vermont Yankee Nuclear Power Station

cc:

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpas
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwarz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Theodore Sullivan
Site Vice President
Entergy Nuclear Operations, Inc.
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Mr. James H. Snizek
5486 Nithsdale Drive
Salisbury, MD 21801

Mr. Garrett D. Edwards
814 Waverly Road
Kennett Square, PA 19348

Ms. Stacey M. Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. Norman L. Rademacher
Director, NSA
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Mr. Raymond Shadis
New England Coalition
Post Office Box 98
Edgecomb, ME 04556

Mr. James P. Matteau
Executive Director
Windham Regional Commission
139 Main Street, Suite 505
Brattleboro, VT 05301

Mr. William K. Sherman
Vermont Department of Public Service
112 State Street
Drawer 20
Montpelier, VT 05620-2601

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Ms. Charlene D. Faison
Manager, Licensing
440 Hamilton Avenue
White Plains, NY 10601