

<b>U.S. NUCLEAR REGULATORY COMMISSION</b>  <b>TELEPHONE CONVERSATION RECORD</b>		Date: 7/25/2006  Time: 2:30 PM
Mail Control	139066	License No(s). 37-30089-01
or Report No(s).		Docket No(s). 03033342
Name of Licensee: Scrubgrass Generating Company, L.P.		
Name of Participant(s): Bradley Knight, proposed RSO Kathy Modes, NRC		
Telephone No. 814-385-6661 x15		
Subject: Non-routine maintenance on fixed gauges <small>(NOTE: This will be used as the Documents Title in ADAMS)</small>		
Summary: Left a message:  Please provide Mr. Knight's phone, fax and email address for our records.  Please provide a copy of Mr. Knight's fixed gauge training courses.  Review License Condition 18 and inform us as to which of these non-routine maintenance activities you would like to be authorized to perform.  Please provide a sample calculation of a prospective evaluation using the highest activity source.  Monthly surveys are not acceptable. Surveys should be performed prior to, during and after any non-routine maintenance activity. Please revise this in your procedure.  Your letter dated June 27, 2006 did not include specific procedures. Please provide specific detailed procedures.		
Action Required: Wait for response from licensee		
Document Availability: <input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available <input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Non-Sensitive Copyright <input type="checkbox"/> Sensitive <input type="checkbox"/> Sensitive Copyright <input type="checkbox"/> Immediate Release <input checked="" type="checkbox"/> Normal Release <input type="checkbox"/> Delay Release Date		
Prepared & SUNSI Review Completed By: K Modes                      / RA /                      Date: 7/25/2006		