



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

JUL 28 2006

10 CFR 50.90

U. S. Nuclear Regulatory Commission
Mail Stop: OFWN P1-35 [TS ONLY]
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of) Docket No. 50-390
Tennessee Valley authority)

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - TECHNICAL SPECIFICATION
(TS) CHANGE NO. 04-013 - WITHDRAWAL OF PROPOSED LICENSE
AMENDMENT REQUEST (TAC MC4586)

Reference: TVA Letter to NRC, "WBN Unit 1 - TS Change No. 04-13 - Auxiliary Feedwater (AFW) Start Upon Trip of Turbine Driven Main Feedwater (TDMFW) Pumps," September 23, 2004

The referenced letter submitted a proposed license amendment request to change the TS for WBN Unit 1. The amendment would have revised Limiting Condition for Operation (LCO) 3.3.2 (6)(e) to allow the AFW Start upon Trip of TDMFW Pump function to be required only when the one or more of TDMFW Pump are operating. However, based upon further review, TVA has decided to withdraw this request.

There are no regulatory commitments associated with this submittal. If you have any questions concerning this matter, please call me at (423) 365-1824.

Sincerely,

Sam

P. L. Pace
Manager, Site Licensing
and Industry Affairs

cc: See Page 2

P030

U.S. Nuclear Regulatory Commission
Page 2

JUL 28 2006

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. D. V. Pickett, Senior Project Manager
U.S. Nuclear Regulatory Commission
MS 08G9a
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission, Region II
Sam Nunn Atlanta Federal Center
Suite 23T85, 61 Forsyth Street, SW
Atlanta, Georgia 30303-8931

Mr. Lawrence E. Nanny, Director
Division of Radiological Health
3rd Floor
L & C Annex
401 Church Street
Nashville, Tennessee 37243