



- NOTES
1. ALL COMPONENT MARK NUMBERS PREFIXED 67 FOR SYSTEM 67 UNLESS OTHERWISE NOTED.
  2. (N) ROOM DESIGNATION NUMBER INDICATED OTHERWISE.
  3. ALL AUTOMATIC AIR DAMPERS ARE FAIL CLOSE UNLESS INDICATED OTHERWISE.
  4. SOLENOID VALVES ARE SHOWN AT FAILURE POSITION.
  5. FOR MODEL AND DUCT SIZE SEE DWG. 10.00-721.
  6. VALVES ARE SHOWN IN THE FAILED OPEN POSITION.
  7. 17RM-461 RETIRED IN PLACE.

UNIT/UC/TCV LIST 1-5

UNIT/UC/TCV NO.	11/13/15/17/19	COOLING COIL NO.	11/13/15/17/19
UC-7A	101/101/101	F-11	143 X
UC-7B	102/102/102	E-14	142 X
UC-7C	103/103/103	C-4	145/144
UC-7D	104/104/104	E-3	145/149
UC-8A	105/105/105		
UC-8B	106/106/106		
UC-9A	107/107/107		
UC-9B	108/108/108		
UC-9C	109/109/109		
UC-9D	110/110/110		
UC-9E	111/111/111		
UC-9F	112/112/112		
UC-9G	113/113/113		
UC-9H	114/114/114		
UC-9I	115/115/115		
UC-9J	116/116/116		
UC-9K	117/117/117		
UC-9L	118/118/118		
UC-9M	119/119/119		
UC-9N	120/120/120		
UC-9O	121/121/121		
UC-9P	122/122/122		
UC-9Q	123/123/123		
UC-9R	124/124/124		
UC-9S	125/125/125		
UC-9T	126/126/126		
UC-9U	127/127/127		
UC-9V	128/128/128		
UC-9W	129/129/129		
UC-9X	130/130/130		
UC-9Y	131/131/131		
UC-9Z	132/132/132		
UC-9AA	133/133/133		
UC-9AB	134/134/134		
UC-9AC	135/135/135		
UC-9AD	136/136/136		
UC-9AE	137/137/137		
UC-9AF	138/138/138		
UC-9AG	139/139/139		
UC-9AH	140/140/140		
UC-9AI	141/141/141		
UC-9AJ	142/142/142		
UC-9AK	143/143/143		
UC-9AL	144/144/144		
UC-9AM	145/145/145		
UC-9AN	146/146/146		
UC-9AO	147/147/147		
UC-9AP	148/148/148		
UC-9AQ	149/149/149		
UC-9AR	150/150/150		

REFERENCE:  
1. FLOW DIAGRAM SYMBOLS ----- FM-14A

SYSTEM INTENDED FUNCTION BOUNDARY

COMPONENTS SUBJECT TO AMR

HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS  
AMR-16

James A. Fitzpatrick  
NUCLEAR POWER PLANT

FLOW DIAGRAM  
TURBINE AREA  
HEATING, VENT & COOLING  
SYSTEM 67

SCALE: NONE  
DWG NO: FB-16A  
REV: 28

REVISIONS

NO.	DATE	DESCRIPTION	BY	CHK	APP
28	8/4/05	AS BUILT PER MOD NO JD-02-093	PJL/JB	-	KM/TES
27	6/9/00	AS BUILT PER MOD NO M1 B6 049	DMCKMB	-	KJ/SKK
26	3/6/99	AS BUILT PER DCR-98-039	PJL/KMB	-	KF/SKK
25	3/2/97	AS BUILT PER DCR-94-149	DMCKPJL	-	KF/SKK

0 8-4-05

NO. DATE DESCRIPTION BY ENK CHG APP

REVISIONS

LRA-FB-16A-0

FILE LRA-FB-16A-28.DGN

WATER FB-16A-28.CAL