


- NOTE
1. FOR NOTES, LEGENDS & FIRE HOSE STATIONS NUMERICAL DESIGNATION CODES, SEE DWG. NO. FB-499.
 2. ISOLATION VALVE FOR HYDRANT 18 IS WEST OF THE TRANSFORMER, NORTH OF THE WAREHOUSE.
 3. ISOLATION VALVE FOR HYDRANT 22 IS NORTH OF THE HYDRANT.
 4. FIRE DEPT. CONNECTION IS 4" STORTZ.

SYSTEM INTENDED FUNCTION BOUNDARY

COMPONENTS SUBJECT TO AMR

FIRE PROTECTION WATER SYSTEM AMM-14



THIS IS A COMPUTER AIDED DESIGN DRAWING. A RECORD OF THE REVISIONS OF THIS DOCUMENT WITH APPROVED INITIALS AND SIGNATURES, IS MAINTAINED IN THE FILES OF THE NEW YORK POWER AUTHORITY.

REV NO	DATE	DESCRIPTION	DWN	CHK	RE	VFY	APP
9	6/11/97	AS BUILT PER DCR-97-159	RVB	KMB	--	KF	SKK

QA CAT M, II/III

JAMES A. FITZPATRICK
NUCLEAR POWER PLANT

DESIGN: JAF
DISCIPLINE: ENG
DISCIPLINE: MRC
PROJECT: FB-499
DATE: 6/11/97

SCALE: NONE
DWG NO: FB-499B
SHEET: 1 OF 1

REV: 9

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
0	10-11-05					
REVISIONS						
LRA-FB-498-0						
CAB FILE LRA-FB-498_09.DGN						
PLOTTER FILE FB-498_09.CAL						