

rcy
From: Samuel Collins
To: Ellis Merschoff
Date: 11/18/04 7:22AM
Subject: Re: Hope Creek Outage Update-Internal and Allegation Information

Got it, pictures of the condenser pipe on the way.....

>>> Ellis Merschoff 11/18/04 07:07AM >>>
Thanks. Please keep me posted on the Op Eval issue

>>> Samuel Collins 11/17/04 05:25PM >>>

Received a call from Chris Bakken, the preliminary root cause of the low pressure steam line break could call into question engineering evaluation to support operation of the facility...he is evaluating the need to review a population of past engineering evaluation and this could impact the outage schedule. Other news: a pipe inside the condenser was found failed (looking at root cause and past inspection criteria), he's releasing the recirc. pump independent study and the decision not to rebuild the pump this outage, and [REDACTED] the outage schedule and allegation are internal info. only. Sam

70

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 7C
FOIA- 2005-194

T-236