

Lamar W. Pearce  
Vice President, Nuclear

440-280-5382

July 11, 2006  
PY-CEI/OEPA-0456L

Ohio Environmental Protection Agency  
Division of Water Pollution Control  
Enforcement Section, ES/MOR  
P.O. Box 1049  
Columbus, Ohio 43216-1049

Ladies and Gentlemen:

Enclosed is the corrected May 2006 NPDES monthly report for the Perry Power Plant,, Station Code 004, "Point Representative of Discharge." The flow rate for 7/31/06 was not on the report (64.3 MDG). No violations occurred during this period.

If you have questions or require additional information, please contact Mrs. Liz Ryan at (440) 280-5536.

Sincerely,



Enclosures

cc: NRC Region III  
NRC Resident Inspector  
NRC Project Manager  
NRC Document Control Desk (Docket No. 50-440)

IE25

Name, Address City, County, ZIP :

Station Code :

Reported Date (Month Year) :

Application :

7/10/2006

Perry Nuclear Power Plant  
 Perry Nuclear Power Plant  
 10 Center Rd.  
 PerryOH44081

004

May 2006

3IB00016\*GD

Sampling Station Description :

Point Representative of Discharge

in(1) - Enter 1 for Continuous, 2 for Composite, 3 for Grab Sample  
 in(2) - Enter frequency of sampling

Reporting Lab :  
 CCB125

Analyst :  
 Liz Ryan

(1)	3	3	3	1	3	1	3
(2)	1	1	1	999	1	999	1
Day	(50060) Chlorine, Total Residual mg/l	(00400) pH S.U.	(01119) Copper, Total Recoverable ug/l	(00011) Water Temperature F	(34044) Oxidants, Total Residual mg/l	(50050) Flow Rate MGD	(78739) Chlorination/Brominat Duration Minutes
01	AA			68.9	AH	90.4	51
02	AA	8.74		69	AH	92.8	95
03	AA			68	AH	86.4	90
04	AA			71.6	AH	93.2	90
05	AA	8.68	5.3	69	AH	98.2	98
06	AA			68	AH	98.1	85
07	AA			69	AH	89.2	90
08	AA			68	AH	76.2	90
09	AA	8.58		57	AH	83.4	90
10	AA			61	AH	79.9	67
11	AA			63	AH	85.3	77
12	AA	8.51		62	AH	80	92
13	AA			68	AH	62.6	67
14	AA			68	AH	69.2	65
15	AA			70	AH	68.6	65
16	AA	8.77		69	AH	70.2	81
17	AA			71	AH	66.2	75
18	AA			72	AH	65.7	85
19	AA	8.6		70	AH	65.7	95
20	AA			72	AH	69.5	90
21	AA			73	AH	67.6	105
22	AA			72	AH	68	105
23	AA	8.49		72	AH	53.8	105
24	AA			73	AH	62.2	110
25	AA			75	AH	63.5	60
26	AA	8.73		77	AH	60.2	55
27	AA			75	AH	66	110
28	AA			79	AH	62.8	110
29	AA			80.6	AH	58.1	110
30	AA	8.67		78	AH	40.4	105
31	AA			84	AH	64.3	110
TOTAL	0	77.77	5.3	2193.1	0	2257.7	2723
AVG	0	N/A	5.3	70.7452	0	72.829	87.8387
MAX	0	8.77	5.3	84	0	98.2	110
MIN	0	8.49	5.3	57	0	40.4	51

I certify under the penalty of law that I have personally examined and am familiar with the information submitted and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Date Report Completed:  
 07/10/2006

Signature of Reporter:

Title of Reporter:

Vice President, Nuclear

## MONTHLY REPORT FORM

4500

Name, Address City, County, ZIP :

Perry Nuclear Power Plant  
 Perry Nuclear Power Plant  
 10 Center Rd.  
 Perry OH 44081

Station Code :

004

Reported Date (Month Year) :

May 2006

Application :

3IB00016\*GD

7/10/2006

Sampling Station Description :

Point Representative of Discharge

Reporting Code	Result Date	Additional Remarks	Mdl
34044	05/01/2006	No bromination events this date	.
34044	05/02/2006	No bromination events this date	.
34044	05/03/2006	No bromination events this date	.
34044	05/04/2006	No bromination events this date	.
34044	05/05/2006	No bromination events this date	.
34044	05/06/2006	No bromination events this date	.
34044	05/07/2006	No bromination events this date	.
34044	05/08/2006	No bromination events this date	.
34044	05/09/2006	No bromination events this date	.
34044	05/10/2006	No bromination events this date	.
34044	05/11/2006	No bromination events this date	.
34044	05/12/2006	No bromination events this date	.
34044	05/13/2006	No bromination events this date	.
34044	05/14/2006	No bromination events this date	.
34044	05/15/2006	No bromination events this date	.
34044	05/16/2006	No bromination events this date	.
34044	05/17/2006	No bromination events this date	.
34044	05/18/2006	No bromination events this date	.
34044	05/19/2006	No bromination events this date	.
34044	05/20/2006	No bromination events this date	.
34044	05/21/2006	No bromination events this date	.
34044	05/22/2006	No bromination events this date	.
34044	05/23/2006	No bromination events this date	.
34044	05/24/2006	No bromination events this date	.
34044	05/25/2006	No bromination events this date	.
34044	05/26/2006	No bromination events this date	.
34044	05/27/2006	No bromination events this date	.
34044	05/28/2006	No bromination events this date	.
34044	05/29/2006	No bromination events this date	.
34044	05/30/2006	No bromination events this date	.
34044	05/31/2006	No bromination events this date	.
50060	05/01/2006	Less than MDL	.05
50060	05/02/2006	Less than MDL	.05
50060	05/03/2006	Less than MDL	.05
50060	05/04/2006	Less than MDL	.05
50060	05/05/2006	Less than MDL	.05
50060	05/06/2006	Less than MDL	.05
50060	05/07/2006	Less than MDL	.05
50060	05/08/2006	Less than MDL	.05

Reporting Code	Result Date	Additional Remarks	mul
50060	05/09/2006	Less than MDL	.05
50060	05/10/2006	Less than MDL	.05
50060	05/11/2006	Less than MDL	.05
50060	05/12/2006	Less than MDL	.05
50060	05/13/2006	Less than MDL	.05
50060	05/14/2006	Less than MDL	.05
50060	05/15/2006	Less than MDL	.05
50060	05/16/2006	Less than MDL	.05
50060	05/17/2006	Less than MDL	.05
50060	05/18/2006	Less than MDL	.05
50060	05/19/2006	Less than MDL	.05
50060	05/20/2006	Less than MDL	.05
50060	05/21/2006	Less than MDL	.05
50060	05/22/2006	Less than MDL	.05
50060	05/23/2006	Less than MDL	.05
50060	05/24/2006	Less than MDL	.05
50060	05/25/2006	Less than MDL	.05
50060	05/26/2006	Less than MDL	.05
50060	05/27/2006	Less than MDL	.05
50060	05/28/2006	Less than MDL	.05
50060	05/29/2006	Less than MDL	.05
50060	05/30/2006	Less than MDL	.05
50060	05/31/2006	Less than MDL	.05