



August 14, 2006

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No.	06-670
NSS&L/DF	R0
Docket No.	50-423
License No.	NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 3
IMPLEMENTATION PERIOD FOR PROPOSED TECHNICAL
SPECIFICATION CHANGE FOR RECIRCULATION SPRAY SYSTEM

In a letter dated September 13, 2005, as supplemented by letter dated June 13, 2006, Dominion Nuclear Connecticut, Inc. (DNC) requested an amendment to Operating License NPF-49 for Millstone Power Station Unit 3 (MPS3). The proposed amendment revises surveillance requirements for the recirculation spray system (RSS) to verify proper initiation of the RSS through actuation of the refueling water storage tank low-low level signal instead of actuation by a timer. The design change to install the necessary circuitry to support the license amendment request is currently planned for implementation during the upcoming spring 2007 refueling outage (3R11). For this reason, the implementation of the proposed license amendment is tied to startup from 3R11. Therefore DNC respectfully requests the license amendment for the RSS be made effective as of the date of issuance with completion of implementation no later than startup from 3R11.

If you should have any questions regarding this submittal, please contact Mr. Paul R. Willoughby at (804) 273-3572.

Very truly yours,

A handwritten signature in black ink, appearing to read "G. T. Bischof", written in a cursive style.

G. T. Bischof
Vice President - Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. V. Nerses
Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8C2
Rockville, MD 20852-2738

Mr. S. M. Schneider
NRC Senior Resident Inspector
Millstone Power Station

Director
Bureau of Air Management
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127