

R2/E42

**DAVID AYRES BI-WEEKLY OPERATIONS STATUS REPORT**

Don Goldbach, Manager  
Environment, Health & Safety

Thursday August 10, 2000

**OPERATIONS SUMMARY****LAST WEEK (7/31-8/4)**

Conversion = 4 UF<sub>6</sub> lines + Line 1 on nitrate

Pelleting = 4 lines + Line 5 on annulars

**LAST WEEKEND (8/5-6)**

Conversion = Down

Pelleting = 2 lines + Line 5 on annulars (Saturday & Sunday)

**THIS WEEK (8/7-11)**

Conversion = 4 UF<sub>6</sub> lines + Line 5 on nitrate for 1 day, scrap Defluorination/Oxidation for 1 day

Pelleting = 4 lines + Line 5 on annulars

**THIS WEEKEND (8/12-13)**

Conversion = 4 UF<sub>6</sub> lines (Saturday & Sunday)

Pelleting = 1 line + Line 5 down (Saturday & Sunday)

**UNUSUAL INCIDENTS**

Dropped bulk container = Root Cause Analysis (RCA) complete and reviewed by Incident Review Committee (IRC) this past Tuesday. Corrective Action team kickoff tomorrow.

URRS "Absolute Filter Disassembly" procedure SSC violation = RCA complete. Review by IRC next Thursday.

Pressurized ADU elevator on Conversion Line 2 released ADU into area (August 6<sup>th</sup>) when opened for maintenance. Nobody put on restriction. Investigation continuing.

**MISCELLANEOUS**

PHA for Hematite operations being moved to Columbia as-is was completed last week at Hematite.

SSC training (operators and maintenance) for Conversion vaporizers and URRS SOLX / C4 Dissolver systems completed last week.

This week, made about 4 MTU of UO<sub>2</sub> powder for Japan Nuclear Corp (JNC) and packaged up for shipment.

A-13